Programmable Controllers

C200HX/C200HG/C200HE

OPERATION MANUAL

OMRON

C200HX/C200HG/C200HE Programmable Controllers

Operation Manual

Revised February 2003

Notice:

OMRON products are manufactured for use according to proper procedures by a qualified operator and only for the purposes described in this manual.

The following conventions are used to indicate and classify precautions in this manual. Always heed the information provided with them. Failure to heed precautions can result in injury to people or damage to property.

/!\ DANGER

Indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury.

/!\WARNING

Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.

(!) Caution

Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury, or property damage.

OMRON Product References

All OMRON products are capitalized in this manual. The word "Unit" is also capitalized when it refers to an OMRON product, regardless of whether or not it appears in the proper name of the product.

The abbreviation "Ch," which appears in some displays and on some OMRON products, often means "word" and is abbreviated "Wd" in documentation in this sense.

The abbreviation "PC" means Programmable Controller and is not used as an abbreviation for anything else.

Visual Aids

The following headings appear in the left column of the manual to help you locate different types of information.

Note Indicates information of particular interest for efficient and convenient operation of the product.

1, 2, 3... 1. Indicates lists of one sort or another, such as procedures, checklists, etc.

© OMRON, 1996

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form, or by any means, mechanical, electronic, photocopying, recording, or otherwise, without the prior written permission of OMRON.

No patent liability is assumed with respect to the use of the information contained herein. Moreover, because OMRON is constantly striving to improve its high-quality products, the information contained in this manual is subject to change without notice. Every precaution has been taken in the preparation of this manual. Nevertheless, OMRON assumes no responsibility for errors or omissions. Neither is any liability assumed for damages resulting from the use of the information contained in this publication.

TABLE OF CONTENTS

PRE	CAUTIONS					
	ended Audience					
	2 General Precautions					
	3 Safety Precautions					
	erating Environment Precautions					
	5 Application Precautions					
6 Co	6 Conformance to EC Directives					
SEC	TION 1					
mtr	oduction					
1-1	Overview					
1-2	The Origins of PC Logic					
1-3	PC Terminology					
1-4	OMRON Product Terminology					
1-5	Overview of PC Operation					
1-6	Peripheral Devices					
1-7	Available Manuals					
1-8	C200HX/HG/HE Features					
SEC	TION 2					
Hard	dware Considerations					
2-1	CPU Unit Components					
2-2	PC Configuration					
2-3	CPU Unit Capabilities					
2-4	Memory Cassettes					
2-5	CPU Unit DIP Switch					
2-6	Operating without a Backup Battery					
SEC						
	TION 3					
Men	nory Areas					
3-1	Introduction					
3-2	Data Area Structure					
3-3	IR (Internal Relay) Area					
3-4	SR (Special Relay) Area					
3-5	AR (Auxiliary Relay) Area					
3-6	DM (Data Memory) Area					
3-7	HR (Holding Relay) Area					
3-8	TC (Timer/Counter) Area					
3-9	LR (Link Relay) Area					
	UM Area					
3-11	TR (Temporary Relay) Area					
3-12	EM (Extended Data Memory) Area					
SEC	TION 4					
	ing and Inputting the Program					
4-1	Basic Procedure					
4-2 4-3	Instruction Terminology					
4-3 4-4	Program Capacity					
4-4 4-5	Basic Ladder Diagrams The Programming Console					
4-3 4-6	Preparation for Operation					
4-0 4-7	Inputting, Modifying, and Checking the Program					
-r-/	inputting, mountying, and checking the rivgian					

TABLE OF CONTENTS

4-8	Controlling Bit Status
4-9	Work Bits (Internal Relays)
4-10	Programming Precautions
4-11	Program Execution
4-12	Special I/O Unit Interface Programs
4-13	Analog Timer Unit Programming
SEC	TION 5
Instr	ruction Set
5-1	Notation
5-2	Instruction Format
5-3	Data Areas, Definer Values, and Flags
5-4	Differentiated Instructions
5-5	Expansion Instructions
5-6	Coding Right-hand Instructions
5-7	Instruction Set Lists
5-8	Ladder Diagram Instructions
5-9	Bit Control Instructions
5-10	INTERLOCK and INTERLOCK CLEAR – IL(02) and ILC(03)
5-11	JUMP and JUMP END – JMP(04) and JME(05)
5-12	END – END(01)
5-13	NO OPERATION – NOP(00)
5-14	Timer and Counter Instructions
5-15	Data Shifting
5-16	Data Movement
5-17	Data Comparison
5-18	Data Conversion
5-19	BCD Calculations
5-20	Binary Calculations
5-21	Special Math Instructions
5-22	Logic Instructions
5-23	Subroutines and Interrupt Control
5-24	Step Instructions
5-25	Special Instructions
5-26	Network Instructions
5-27	Serial Communications Instructions
5-28	Advanced I/O Instructions
5-29	Special I/O Unit Instructions
CEC	TION 6
-	
rrog	ram Execution Timing
6-1	Cycle Time
6-2	Calculating Cycle Time
6-3	Instruction Execution Times
6-4	I/O Response Time
CE/	TION 7
rrog	ram Monitoring and Execution
7-1	Monitoring Operation and Modifying Data
7-2	Programming Console Operations

TABLE OF CONTENTS

SEC	TION 8
Seria	al Communications
8-1	Introduction
8-2	Host Link Communications
8-3	RS-232C Communications
8-4 8-5	One-to-one PC Links
8-5 8-6	NT Links
SEC	TION 9
	ibleshooting
9-1	Alarm Indicators
9-2	Programmed Alarms and Error Messages
9-3	Reading and Clearing Errors and Messages
9-4	Error Messages
9-5	Error Flags
9-6	Host Link Errors
SEC	TION 10
Host	Link Commands
	Host Link Command Summary
	Host Link End Codes
	Host Link Commands
App	endices
	andard Models
B Pr	ogramming Instructions
	rror and Arithmetic Flag Operation
D W	ford Assignment Recording Sheets
E Pr	ogram Coding Sheet
	ata Conversion Tables
G Ex	xtended ASCII
Glos	sary
Inde	X
Revi	sion History

About this Manual:

This manual describes the operation of the C200HX/HG/HE Programmable Controllers, and it includes the sections described below. Installation information is provided in the C200HX/HG/HE Programmable Controller Installation Guide. A table of other manuals that can be used in conjunction with this manual is provided in Section 1 Introduction. Provided in Section 2 Hardware Considerations is a description of the differences between the C200HS CPU Units and the new CPU Units described in this manual.

Please read this manual completely and be sure you understand the information provided before attempting to operate the C200HX/HG/HE. Be sure to read the precautions in the following section.

Section 1 Introduction explains the background and some of the basic terms used in ladder-diagram programming. It also provides an overview of the process of programming and operating a PC and explains basic terminology used with OMRON PCs. Descriptions of Peripheral Devices used with the C200HX/HG/HE PCs and a table of other manuals available to use with this manual for special PC applications are also provided.

Section 2 Hardware Considerations explains basic aspects of the overall PC configuration, describes the indicators that are referred to in other sections of this manual, and explains how to use the Memory Cassette to manage UM and IOM data.

Section 3 Memory Areas takes a look at the way memory is divided and allocated and explains the information provided there to aid in programming. It explains how I/O is managed in memory and how bits in memory correspond to specific I/O points. It also provides information on System DM, a special area in C200HX/HG/HE PCs that provides the user with flexible control of PC operating parameters.

Section 4 Writing and Entering Programs explains the basics of ladder-diagram programming, looking at the elements that make up the parts of a ladder-diagram program and explaining how execution of this program is controlled. It also explains how to convert ladder diagrams into mnemonic code so that the programs can be entered using a Programming Console.

Section 5 Instruction Set describes all of the instructions used in programming.

Section 6 Program Execution Timing explains the cycling process used to execute the program and tells how to coordinate inputs and outputs so that they occur at the proper times.

Section 7 Program Debugging and Execution explains the Programming Console procedures used to input and debug the program and to monitor and control operation.

Section 8 Communications provides an overview of the communications features provided by the C200HS.

Section 9 Troubleshooting provides information on error indications and other means of reducing down-time. Information in this section is also useful when debugging programs.

Section 10 Host Link Commands explains the host link commands that can be used for host link communications via the C200HX/HG/HE ports.

The *Appendices* provide tables of standard OMRON products available for the C200HX/HG/HE PCs, reference tables of instructions, a coding sheet to help in programming and parameter input, and other information helpful in PC operation.

/! WARNING Failure to read and understand the information provided in this manual may result in personal injury or death, damage to the product, or product failure. Please read each section in its entirety and be sure you understand the information provided in the section and related sections before attempting any of the procedures or operations given.

PRECAUTIONS

This section provides general precautions for using the Programmable Controller (PC) and related devices.

The information contained in this section is important for the safe and reliable application of the PC. You must read this section and understand the information contained before attempting to set up or operate a PC system.

1 Intended Audience	xiv
2 General Precautions	xiv
3 Safety Precautions	xiv
4 Operating Environment Precautions	X
5 Application Precautions	X
6 Conformance to EC Directives	

Safety Precautions 3

Intended Audience 1

This manual is intended for the following personnel, who must also have knowledge of electrical systems (an electrical engineer or the equivalent).

- Personnel in charge of installing FA systems.
- Personnel in charge of designing FA systems.
- Personnel in charge of managing FA systems and facilities.

2 General Precautions

The user must operate the product according to the performance specifications described in the operation manuals.

Before using the product under conditions which are not described in the manual or applying the product to nuclear control systems, railroad systems, aviation systems, vehicles, combustion systems, medical equipment, amusement machines, safety equipment, and other systems, machines, and equipment that may have a serious influence on lives and property if used improperly, consult your OMRON representative.

Make sure that the ratings and performance characteristics of the product are sufficient for the systems, machines, and equipment, and be sure to provide the systems, machines, and equipment with double safety mechanisms.

This manual provides information for programming and operating OMRON PCs. Be sure to read this manual before attempting to use the software and keep this manual close at hand for reference during operation.



/!\ WARNING It is extremely important that a PC and all PC Units be used for the specified purpose and under the specified conditions, especially in applications that can directly or indirectly affect human life. You must consult with your OMRON representative before applying a PC System to the above mentioned applications.

3 **Safety Precautions**



/!\WARNING Do not attempt to take any Unit apart while the power is being supplied. Doing so may result in electric shock.



/!\WARNING Do not touch any of the terminals or terminal blocks while the power is being supplied. Doing so may result in electric shock.

/! WARNING Provide safety measures in external circuits (i.e., not in the Programmable Controller), including the following items, to ensure safety in the system if an abnormality occurs due to malfunction of the PC or another external factor affecting the PC operation. Not doing so may result in serious accidents.

- Emergency stop circuits, interlock circuits, limit circuits, and similar safety measures must be provided in external control circuits.
- The PC will turn OFF all outputs when its self-diagnosis function detects any error or when a severe failure alarm (FALS) instruction is executed. As a countermeasure for such errors, external safety measures must be provided to ensure safety in the system.
- The PC outputs may remain ON or OFF due to deposition or burning of the output relays or destruction of the output transistors. As a countermeasure for

such problems, external safety measures must be provided to ensure safety in the system.

 When the 24-VDC output (service power supply to the PC) is overloaded or short-circuited, the voltage may drop and result in the outputs being turned OFF. As a countermeasure for such problems, external safety measures must be provided to ensure safety in the system.

∕!∖ Caution

Execute online edit only after confirming that no adverse effects will be caused by extending the cycle time. Otherwise, the input signals may not be readable.

∕!∖ Caution

Confirm safety at the destination node before transferring a program to another node or changing contents of the I/O memory area. Doing either of these without confirming safety may result in injury.



Tighten the screws on the terminal block of the AC Power Supply Unit to the torque specified in the operation manual. The loose screws may result in burning or malfunction.

Operating Environment Precautions 4

Do not operate the control system in the following places.

- Where the PC is exposed to direct sunlight.
- Where the ambient temperature is below 0°C or over 55°C.
- Where the PC may be affected by condensation due to radical temperature changes.
- Where the ambient humidity is below 10% or over 90%.
- Where there is any corrosive or inflammable gas.
- Where there is excessive dust, saline air, or metal powder.
- Where the PC is affected by vibration or shock.
- Where any water, oil, or chemical may splash on the PC.



The operating environment of the PC System can have a large effect on the longevity and reliability of the system. Improper operating environments can lead to malfunction, failure, and other unforeseeable problems with the PC System. Be sure that the operating environment is within the specified conditions at installation and remains within the specified conditions during the life of the system.

5 **Application Precautions**

Observe the following precautions when using the PC.



/! WARNING Failure to abide by the following precautions could lead to serious or possibly fatal injury. Always heed these precautions.

- Always ground the system to 100 Ω or less when installing the system to protect against electrical shock.
- Always turn OFF the power supply to the PC before attempting any of the following. Performing any of the following with the power supply turned ON may lead to electrical shock:
 - Mounting or removing any Units (e.g., I/O Units, CPU Unit, etc.) or memory cassettes.
 - Assembling any devices or racks.

Connecting or disconnecting any cables or wiring.

Failure to abide by the following precautions could lead to faulty operation of the PC or the system or could damage the PC or PC Units. Always heed these precautions.

- Use the Units only with the power supplies and voltages specified in the operation manuals. Other power supplies and voltages may damage the Units.
- Take measures to stabilize the power supply to conform to the rated supply if it is not stable.
- Provide circuit breakers and other safety measures to provide protection against shorts in external wiring.
- Do not apply voltages exceeding the rated input voltage to Input Units.
- Do not apply voltages exceeding the maximum switching capacity to Output Units.
- Always disconnect the functional ground terminal when performing withstand voltage tests.
- Carefully follow all of the installation instructions provided in the manuals, including the *Installation Guide*.
- Provide proper shielding when installing in the following locations:
 - Locations subject to static electricity or other sources of noise.
 - · Locations subject to strong electromagnetic fields.
 - Locations subject to possible exposure to radiation.
 - Locations near to power supply lines.
- Be sure to tighten Backplane screws, terminal screws, and cable connector screws securely.
- Do not attempt to take any Units apart, to repair any Units, or to modify any Units in any way.



The following precautions are necessary to ensure the general safety of the system. Always heed these precautions.

- Provide double safety mechanisms to handle incorrect signals that can be generated by broken signal lines or momentary power interruptions.
- Provide external interlock circuits, limit circuits, and other safety circuits in addition to any provided within the PC to ensure safety.
- Always test the operation of the user program sufficiently before starting actual system operation.
- Always confirm that there will be no adverse affects on the system before changing the PC's operating mode.
- Always confirm that there will be no adverse affects on the system before force-setting/resetting any bits in PC memory.
- Always confirm that there will be no adverse affects on the system before changing any set values or present values in PC memory.
- Whenever the CPU Unit has been replaced, be sure that all required memory data, such as that in the HR and DM areas, has been transferred to the new CPU Unit before starting operation.
- Never pull on or place objects on cables or cords, or wires may be broken.

6 Conformance to EC Directives

Observe the following precautions when installing the C200HX/HG/HE PCs that conform to the EC Directives.

Provide reinforced insulation or double insulation for the DC power source connected to the DC I/O Unit and for the Power Supply Unit.

Use a separate power source for the DC I/O Unit from the external power supply for the Relay Output Unit.

SECTION 1 Introduction

This section gives a brief overview of the history of Programmable Controllers and explains terms commonly used in ladder-diagram programming. It also provides an overview of the process of programming and operating a PC and explains basic terminology used with OMRON PCs. Descriptions of peripheral devices used with the C200HX/HG/HE PCs, a table of other manuals available to use with this manual for special PC applications, and a description of the new features of the C200HX/HG/HE PCs are also provided.

	Overview	
1-2	The Origins of PC Logic	2
1-3	PC Terminology	3
1-4	OMRON Product Terminology	4
1-5	Overview of PC Operation	4
1-6	Peripheral Devices	5
	Available Manuals	
1-8	C200HX/HG/HE Features	
	1-8-1 C200HS and C200HX/HG/HE Capabilities	7
	1-8-2 Program Compatibility	8

1-1 Overview

A PC (Programmable Controller) is basically a CPU (Central Processing Unit) containing a program and connected to input and output (I/O) devices. The program controls the PC so that when an input signal from an input device turns ON, the appropriate response is made. The response normally involves turning ON an output signal to some sort of output device. The input devices could be photoelectric sensors, pushbuttons on control panels, limit switches, or any other device that can produce a signal that can be input into the PC. The output devices could be solenoids, switches activating indicator lamps, relays turning on motors, or any other devices that can be activated by signals output from the PC.

For example, a sensor detecting a passing product turns ON an input to the PC. The PC responds by turning ON an output that activates a pusher that pushes the product onto another conveyor for further processing. Another sensor, positioned higher than the first, turns ON a different input to indicate that the product is too tall. The PC responds by turning on another pusher positioned before the pusher mentioned above to push the too-tall product into a rejection box.

Although this example involves only two inputs and two outputs, it is typical of the type of control operation that PCs can achieve. Actually even this example is much more complex than it may at first appear because of the timing that would be required, i.e., "How does the PC know when to activate each pusher?" Much more complicated operations, however, are also possible. The problem is how to get the desired control signals from available inputs at appropriate times.

To achieve proper control, the C200HX/HG/HE PCs use a form of PC logic called ladder-diagram programming. This manual is written to explain ladder-diagram programming and to prepare the reader to program and operate the PC.

1-2 The Origins of PC Logic

PCs historically originate in relay-based control systems. And although the integrated circuits and internal logic of the PC have taken the place of the discrete relays, timers, counters, and other such devices, actual PC operation proceeds as if those discrete devices were still in place. PC control, however, also provides computer capabilities and accuracy to achieve a great deal more flexibility and reliability than is possible with relays.

The symbols and other control concepts used to describe PC operation also come from relay-based control and form the basis of the ladder-diagram programming method. Most of the terms used to describe these symbols and concepts, however, have come in from computer terminology.

Relay vs. PC Terminology

The terminology used throughout this manual is somewhat different from relay terminology, but the concepts are the same.

The following table shows the relationship between relay terms and the PC terms used for OMRON PCs.

Relay term	PC equivalent
contact	input or condition
coil	output or work bit
NO relay	normally open condition
NC relay	normally closed condition

PC Terminology Section 1-3

Actually there is not a total equivalence between these terms. The term condition is only used to describe ladder diagram programs in general and is specifically equivalent to one of a certain set of basic instructions. The terms input and output are not used in programming per se, except in reference to I/O bits that are assigned to input and output signals coming into and leaving the PC. Normally open conditions and normally closed conditions are explained in *4-4 Basic Ladder Diagrams*.

1-3 PC Terminology

Although also provided in the *Glossary* at the back of this manual, the following terms are crucial to understanding PC operation and are thus explained here.

PC

Because the C200HX/HG/HE PCs are Rack PCs, there is no one product that is a C200HX/HG/HE PC. That is why we talk about the configuration of the PC, because a PC is a configuration of smaller Units.

To have a functional PC, you would need to have a CPU Rack with at least one Unit mounted to it that provides I/O points. When we refer to the PC, however, we are generally talking about the CPU Unit and all of the Units directly controlled by it through the program. This does not include the I/O devices connected to PC inputs and outputs.

If you are not familiar with the terms used above to describe a PC, refer to Section 2 Hardware Considerations for explanations.

Inputs and Outputs

A device connected to the PC that sends a signal to the PC is called an **input device**; the signal it sends is called an **input signal**. A signal enters the PC through terminals or through pins on a connector on a Unit. The place where a signal enters the PC is called an **input point**. This input point is allocated a location in memory that reflects its status, i.e., either ON or OFF. This memory location is called an **input bit**. The CPU Unit, in its normal processing cycle, monitors the status of all input points and turns ON or OFF corresponding input bits accordingly.

There are also **output bits** in memory that are allocated to **output points** on Units through which **output signals** are sent to **output devices**, i.e., an output bit is turned ON to send a signal to an output device through an output point. The CPU Unit periodically turns output points ON or OFF according to the status of the output bits.

These terms are used when describing different aspects of PC operation. When programming, one is concerned with what information is held in memory, and so I/O bits are referred to. When talking about the Units that connect the PC to the controlled system and the places on these Units where signals enter and leave the PC, I/O points are referred to. When wiring these I/O points, the physical counterparts of the I/O points, either terminals or connector pins, are referred to. When talking about the signals that enter or leave the PC, one refers to input signals and output signals, or sometimes just inputs and outputs. It all depends on what aspect of PC operation is being talked about.

Controlled System and Control System

The Control System includes the PC and all I/O devices it uses to control an external system. A sensor that provides information to achieve control is an input device that is clearly part of the Control System. The controlled system is the external system that is being controlled by the PC program through these I/O devices. I/O devices can sometimes be considered part of the controlled system, e.g., a motor used to drive a conveyor belt.

3

1-4 OMRON Product Terminology

OMRON products are divided into several functional groups that have generic names. *Appendix A Standard Models* list products according to these groups. The term **Unit** is used to refer to all of the OMRON PC products. Although a Unit is any one of the building blocks that goes together to form a C200HX/HG/HE PC, its meaning is generally, but not always, limited in context to refer to the Units that are mounted to a Rack. Most, but not all, of these products have names that end with the word Unit.

The largest group of OMRON products is the **I/O Units**. These include all of the Rack-mounting Units that provide non-dedicated input or output points for general use. I/O Units come with a variety of point connections and specifications.

High-density I/O Units are designed to provide high-density I/O capability and include Group 2 High-density I/O Units and Special I/O High-density I/O Units.

Special I/O Units are dedicated Units that are designed to meet specific needs. These include some of the High-density I/O Units, Position Control Units, High-speed Counter Units, and Analog I/O Units.

Link Units are used to create Link Systems that link more than one PC or link a single PC to remote I/O points. Link Units include Remote I/O Units, PC Link Units, Host Link Units, SYSMAC NET Link Units, and SYSMAC LINK Units. SYSMAC NET Link and SYSMAC LINK Units can be used with the CPU11-E only.

Other product groups include **Programming Devices**, **Peripheral Devices**, and **DIN Rail Products**.

1-5 Overview of PC Operation

The following are the basic steps involved in programming and operating a C200HX/HG/HE PC. Assuming you have already purchased one or more of these PCs, you must have a reasonable idea of the required information for steps one and two, which are discussed briefly below. This manual is written to explain steps three through six, eight, and nine. The relevant sections of this manual that provide more information are listed with each of these steps.

- **1, 2, 3...** 1. Determine what the controlled system must do, in what order, and at what times.
 - 2. Determine what Racks and what Units will be required. Refer to the C200HX/HG/HE PC Installation Guide. If a Link System is required, refer to the appropriate System Manual.
 - 3. On paper, assign all input and output devices to I/O points on Units and determine which I/O bits will be allocated to each. If the PC includes Special I/O Units or Link Systems, refer to the individual *Operation Manuals* or *System Manuals* for details on I/O bit allocation. (*Section 3 Memory Areas*)
 - 4. Using relay ladder symbols, write a program that represents the sequence of required operations and their inter-relationships. Be sure to also program appropriate responses for all possible emergency situations. (Section 4 Writing and Inputting the Program, Section 5 Instruction Set, Section 6 Program Execution Timing)
 - 5. Input the program and all required operating parameters into the PC. (Section 4-7 Inputting, Modifying, and Checking the Program.)
 - Debug the program, first to eliminate any syntax errors, and then to find execution errors. (Section 4-7 Inputting, Modifying, and Checking the Program, Section 7 Program Monitoring and Execution, and Section 9 Troubleshooting)

Peripheral Devices Section 1-6

7. Wire the PC to the controlled system. This step can actually be started as soon as step 3 has been completed. Refer to the C200HX/HG/HE PC Installation Guide and to Operation Manuals and System Manuals for details on individual Units.

- 8. Test the program in an actual control situation and carry out fine tuning as required. (Section 7 Program Monitoring and Execution and Section 9 Troubleshooting)
- 9. Record two copies of the finished program on masters and store them safely in different locations. (Section 4-7 Inputting, Modifying, and Checking the Program)

Control System Design

Designing the Control System is the first step in automating any process. A PC can be programmed and operated only after the overall Control System is fully understood. Designing the Control System requires, first of all, a thorough understanding of the system that is to be controlled. The first step in designing a Control System is thus determining the requirements of the controlled system.

Input/Output Requirements

The first thing that must be assessed is the number of input and output points that the controlled system will require. This is done by identifying each device that is to send an input signal to the PC or which is to receive an output signal from the PC. Keep in mind that the number of I/O points available depends on the configuration of the PC. Refer to 3-3 IR Area for details on I/O capacity and the allocation of I/O bits to I/O points.

Sequence, Timing, and Relationships

Next, determine the sequence in which control operations are to occur and the relative timing of the operations. Identify the physical relationships between the I/O devices as well as the kinds of responses that should occur between them.

For instance, a photoelectric switch might be functionally tied to a motor by way of a counter within the PC. When the PC receives an input from a start switch, it could start the motor. The PC could then stop the motor when the counter has received a specified number of input signals from the photoelectric switch.

Each of the related tasks must be similarly determined, from the beginning of the control operation to the end.

Unit Requirements

The actual Units that will be mounted or connected to PC Racks must be determined according to the requirements of the I/O devices. Actual hardware specifications, such as voltage and current levels, as well as functional considerations, such as those that require Special I/O Units or Link Systems will need to be considered. In many cases, Special I/O Units, Intelligent I/O Units, or Link Systems can greatly reduce the programming burden. Details on these Units and Link Systems are available in appropriate *Operation Manuals* and *System Manuals*. Once the entire Control System has been designed, the task of programming, debugging, and operation as described in the remaining sections of this manual can begin.

1-6 Peripheral Devices

The following peripheral devices can be used in programming, either to input/debug/monitor the PC program or to interface the PC to external devices to output the program or memory area data. Model numbers for all devices listed below are provided in *Appendix A Standard Models*. OMRON product names have been placed in bold when introduced in the following descriptions.

Programming Console

A Programming Console is the simplest form of programming device for OM-RON PCs. All Programming Consoles are connected directly to the CPU Unit without requiring a separate interface.

SYSMAC Support Software: SSS

SSS is designed to run on IBM PC/AT or compatibles and allows you to perform all the operations of the Programming Console as well as many additional ones.

Available Manuals Section 1-7

PC programs can be written on-screen in ladder-diagram form as well as in mnemonic form. As the program is written, it is displayed on a display, making confirmation and modification quick and easy. Syntax checks may also be performed on the programs before they are downloaded to the PC.

The SSS comes on 3.5" disks.

A computer running the SSS is connected to the C200HX/HG/HE PC via the Peripheral Port on the CPU Unit using the CQM1-CIF02 or CV500-CIF01 cable.

1-7 Available Manuals

The following table lists other manuals that may be required to program and/or operate the C200HX/HG/HE PCs. *Operation Manuals* and/or *Operation Guides* are also provided with individual Units and are required for wiring and other specifications.

Name	Cat. No.	Contents
GPC Operation Manual	W84	Programming procedures for the GPC (Graphics Programming Console)
FIT Operation Manual	W150	Programming procedures for using the FIT (Factory Intelligent Terminal)
SYSMAC Support Software Operation Manuals	W247/W248	Programming procedures for using the SSS
Data Access Console Operation Guide	W173	Data area monitoring and data modification procedures for the Data Access Console
Printer Interface Unit Operation Guide	W107	Procedures for interfacing a PC to a printer
PROM Writer Operation Guide	W155	Procedures for writing programs to EPROM chips
Floppy Disk Interface Unit Operation Guide	W119	Procedures for interfacing PCs to floppy disk drives
Wired Remote I/O System Manual (SYSMAC BUS)	W120	Information on building a Wired Remote I/O System to enable remote I/O capability
Optical Remote I/O System Manual (SYSMAC BUS)	W136	Information on building an Optical Remote I/O System to enable remote I/O capability
PC Link System Manual	W135	Information on building a PC Link System to automatically transfer data between PCs
Host Link System Manual (SYSMAC WAY)	W143	Information on building a Host Link System to manage PCs from a 'host' computer
SYSMAC NET Link Unit Operation Manual	W114	Information on building a SYSMAC NET Link System and thus create an optical LAN integrating PCs with computers and other peripheral devices
SYSMAC LINK System Manual	W174	Information on building a SYSMAC LINK System to enable automatic data transfer, programming, and programmed data transfer between the PCs in the System
High-speed Counter Unit Operation Manual	W141	Information on High-speed Counter Unit
Position Control Unit Operation Manuals	NC111: W137 NC112: W128 NC211: W166	Information on Position Control Unit
Analog I/O Units Operation Guide	W127	Information on the C200H-AD001, C200H-DA001 Analog I/O Units
Analog Input Unit Operation Manual	W229	Information on the C200H-AD002 Analog Input Unit
Temperature Sensor Unit Operation Guide	W124	Information on Temperature Sensor Unit
ASCII Unit Operation Manual	W165	Information on ASCII Unit
ID Sensor Unit Operation Guide	W153	Information on ID Sensor Unit
Voice Unit Operation Manual	W172	Information on Voice Unit
Fuzzy Logic Unit Operation Manual	W208	Information on Fuzzy Logic Unit
Fuzzy Support Software Operation Manual	W210	Information on the Fuzzy Support Software which supports the Fuzzy Logic Units
Temperature Control Unit Operation Manual	W225	Information on Temperature Control Unit
Heat/Cool Temperature Control Unit Operation Manual	W240	Information on Heating and Cooling Temperature Control Unit

Name	Cat. No.	Contents
PID Control Unit Operation Manual	W241	Information on PID Control Unit
Cam Positioner Unit Operation Manual	W224	Information on Cam Positioner Unit

1-8 C200HX/HG/HE Features

The C200HX/HG/HE CPU Units have a number of new features, but C200H and C200HS programs can be used in the new CPU Units.

1-8-1 C200HS and C200HX/HG/HE Capabilities

The following table shows the new capabilities of the C200HX/HG/HE PCs and compares them with those of the C200HS.

Function		Capability		
		C200HX/HG/HE	C200HS	
Memory	User memory (UM)	C200HE-CPU11-E: 3.2K words C200HE-CPU□2-E: 7.2K words C200HG-CPU□3-E: 15.2K words C200HX-CPU□4-E: 31.2K words	15.2K words	
	Normal DM	6,144 words (DM 0000 to DM 6143) (The C200HE-CPU11-E doesn't have DM 4096 to DM 5999.)	6,144 words (DM 0000 to DM 6143)	
	Fixed DM	512 words (DM 6144 to DM 6655)	512 words (DM 6144 to DM 6655)	
	Expansion DM	0 to 3,000 words (DM 7000 to DM 9999)	0 to 3,000 words (DM 7000 to DM 9999)	
	Extended Data Memory (EM)	6,144 words (EM 0000 to EM 6143) C200HE: None C200HG: 6,144 words × 1 bank C200HX: 6,144 words × 3 banks	None	
I/O allocation	Expansion Racks	3 Racks (2 Racks in the C200HE-CPU□□-E or C200HX/HG-CPU3□-E/4□-E)	2 Racks	
	Group-2 Multipoint I/O Units	Unit numbers 0 to 9, A to F (Incompatible with the C200HE-CPU11-E.) (Unit numbers 0 to 9 with the C200HE-CPU□2-E, C200HX/HG-CPU3□-E/4□-E.)	Unit numbers 0 to 9	
	Special I/O Units	Unit numbers 0 to 9, A to F (Unit numbers 0 to 9 with the C200HE-CPU□□-E or C200HX/HG-CPU3□-E/4□-E.)	Unit numbers 0 to 9	
Execution time	Basic instructions (LD)	0.104 μs (C200HX) 0.156 μs (C200HG) 0.313 μs (C200HE)	0.375 μs	
	MOV(21)	0.417 μs (C200HX) 0.625 μs (C200HG) 1.250 μs (C200HE)	19.00 μs	
	ADD(30)	16.65 μs (C200HX/HG) 31.45 μs (C200HE)	40.10 μs	
	Other instructions	C200HX/HG: 1/3 to 2/3 of C200HS time C200HE: 3/4 to 4/5 of C200HS time		
	Common processes (END(01) processing)	0.7 ms (C200HX/HG) 2.1 ms (C200HE)	0.7 ms	
	I/O refresh time	Same as the C200HS, although part of Special I/O refreshing takes 1/2 to 2/3 the C200HS time.		

	Function	Capability		
		C200HX/HG/HE	C200HS	
CPU Unit functions	RS-232C port	Available in the C200HX/HG/HE-CPU4□-E/6□-E	Available in the C200HS-CPU2□-E /3□-E	
	Clock function	Available in all except the C200HE-CPU11-E	Available in all models	
	SYSMAC NET Link and SYSMAC LINK functions	Communications Boards can be installed in all PCs except the C200HE-CPU11-E. (Board model numbers: C200HW-COM01/04-E)	Available in the C200HS-CPU3□-E	
Communications Boards		Communications Boards can be installed in all PCs except the C200HE-CPU11-E. These Boards can provide the following functions:		
		SYSMAC NET Link and SYSMAC LINK, Communications Ports (Ports 1 and 2), and Protocol Macro functions		
Special I/O Units		The IORD(—) and IOWR(—) instructions allow data to be transferred to and from Special I/O Units.		
Interrupts	Interrupt Input Units	2 Units (16 inputs)	1 Unit (8 inputs)	
	Communications Board interrupts	Can be set.		
	Response characteristics	Same as the C200HS, although a 1-ms response is possible in the C200HW-SLK	Normal mode: 10 ms High-speed mode: 1 ms	
			(Always 10 ms when a SYSMAC NET Link or SYSMAC LINK is used.)	
PTs		NT Link (1:1) or NT Link (1:N)	NT Link (1:1)	
		(Up to 8 PTs can be connected from the RS-232C port through an RS-422/485 Link Adapter. When the C200HE-CPU□□-E with a Communications Board is used, only 3 PTs can be connected)		
SYSMAC LINK	Service time	3.5 ms max. (1 operating level)	10.8 ms max. (1 operating level)	
	Remote programming	Possible from the Peripheral Port or RS-232C Ports (including Communications Boards).	Possible from the Peripheral Port.	
	Effect on response time	None	10 ms in any mode	

1-8-2 Program Compatibility

C200HS programs and Memory Cassettes can be used as is in the C200HX/HG/HE and programs developed for the C200H can be transferred for use in the C200HX/HG/HE very easily.

Detailed procedures for the individual steps involved in transferring programs can be found in the SSS Operation Manuals. You will also require a CQM1-CIF02 Connecting Cable to connect the computer running SSS to the C200HS.

Precautions

Observe the following precautions when transferring C200H programs to the C200HX/HG/HE.

If a C200H program including the SET SYSTEM instruction (SYS(49)) is transferred to the C200HX/HG/HE, the operating parameters set by this instruction will be transferred to the C200HX/HG/HE's PC Setup area (DM 6600, DM 6601, and DM 6655) and overwrite any current settings. Be sure to confirm that the settings in these words are correct before using the PC after program transfer.

- If the C200H program accesses the C200H's error log in DM 0969 to DM 0999, the addresses of the words being accessed must be changed to DM 6000 to DM 6030, which is the error log area for the C200HX/HG/HE.
- Any programs that rely on the execution cycle time (i.e., on the time required to execute any one part of all of the program) must be adjusted when used on the C200HX/HG/HE, which provides a much faster cycle time.

Using Internal Memory

The following procedure outlines the steps to transfer C200H programs to the user memory inside the C200HX/HG/HE.

- Transfer the program and any other required data to the SSS work area.
 This data can be transferred from a C200H CPU Unit, from floppy disk, or from a C200HS Memory Unit.
 - To transfer from a C200H CPU Unit, set the PC for the SSS to the C200H, connect the SSS to the C200H, go online, and transfer the program and any other required data to the SSS work area. You will probably want to transfer DM data and the I/O table, if you have created an I/O table for the C200H.
 - or To transfer from floppy disk, set the PC for the SSS to the C200H in the offline mode and load the program and any other require data to the SSS work area. You will probably want to load DM data and the I/O table, if you have created an I/O table for the C200H.
 - or To transfer from a C200H-MP831, set the PC for the SSS to the C200H in the offline mode and read data from the Memory Unit into the SSS work area.
 - 2. Go offline if the SSS is not already offline.
 - 3. Change the PC setting for the SSS to the C200HX/HG/HE.
 - 4. If you want to transfer I/O comments together with the program to the C200HX/HG/HE, allocate UM area for I/O comments.
 - 5. Connect the SSS to the C200HX/HG/HE and go online.
 - 6. Make sure that pin 1 on the C200HX/HG/HE's CPU Unit is OFF to enable writing to the UM area.
 - 7. Transfer the program and and any other required data to the C200HX/HG/HE. You will probably want to transfer DM data and the I/O table, if you have created an I/O table for the C200H.
 - 8. Turn OFF the C200HX/HG/HE and then back ON to reset it.
 - 9. Test program execution before attempting actual operation.

Using Memory Cassettes

The following procedure outlines the steps to transfer C200H programs to the C200HX/HG/HE via EEPROM or EPROM Memory Cassettes. This will allow you to read the program data from the Memory Cassette automatically at C200HX/HG/HE startup. The first four steps of this procedure is the same as those used for transferring directly to the C200HX/HG/HE's internal memory (UM area).

- Transfer the program and any other required data to the SSS work area.
 This data can be transferred from a C200H CPU Unit, from floppy disk, or from a Memory Unit.
 - To transfer from a C200H CPU Unit, set the PC for the SSS to the C200H, connect the SSS to the C200H, go online, and transfer the program and any other required data to the SSS work area. You will probably want to transfer DM data and the I/O table, if you have created an I/O table for the C200H.
 - or To transfer from floppy disk, set the PC for the SSS to the C200H in the offline mode and load the program and any other required data to the SSS work area. You will probably want to load DM data and the I/O table, if you have created an I/O table for the C200H.
 - or To transfer from a C200H-MP831, set the PC for the SSS to the C200H in the offline mode and read data from the Memory Unit into the SSS work area.

- 2. Go offline if the SSS is not already offline.
- 3. Change the PC setting for the SSS to the C200HX/HG/HE.
- 4. If you want to transfer I/O comments together with the program to the C200HX/HG/HE, allocate UM area for I/O comments.
- 5. Allocate expansion DM words DM 7000 to DM 7999 in the UM area using the UM allocation operation from the SSS.
- 6. Copy DM 1000 through DM 1999 to DM 7000 through DM 7999.
- 7. Write "0100" to DM 6602 to automatically transfer the contents of DM 7000 through DM 7999 to DM 1000 through DM 1999 at startup.
- 8. To transfer to an EEPROM Memory Cassette, use the following procedure.
 - a) Connect the SSS to the C200HX/HG/HE and go online.
 - b) Make sure that pin 1 on the C200HX/HG/HE's CPU Unit is OFF to enable writing to the UM area.
 - c) Transfer the program and any other require data to the C200HX/HG/HE. You will probably want to transfer DM data and the I/O table, if you have created an I/O table for the C200H. Make sure you specify transfer of the Expansion DM Area and, if desired, the I/O Comment Area.
 - d) Turn ON SR 27000 from the SSS to transfer UM data to the Memory Cassette and continue from step 9.
- **or** To transfer to an EPROM Memory Cassette, use the following procedure.
 - a) Connect a PROM Writer to the SSS and write the data to the EPROM chip using the SSS EPROM writing operation.
 - b) Set the ROM type selector on the Memory Cassette to the correct capacity.
 - c) Mount the ROM chip to the Memory Cassette.
 - d) Mount a EPROM Memory Cassette to the C200HX/HG/HE.
- 9. Turn ON pin 2 on the C200HX/HG/HE's DIP switch to enable automatic transfer of Memory Cassette data to the CPU Unit at startup.
- 10. Turn OFF the C200HX/HG/HE and then back ON to reset it and transfer data from the Memory Cassette to the CPU Unit.
- 11. Test program execution before attempting actual operation.


SECTION 2 Hardware Considerations

This section provides information on hardware aspects of the C200HX/HG/HE that are relevant to programming and software operation. These include CPU Unit Components, the basic PC configuration, CPU Unit capabilities, and Memory Cassettes. This information is covered in detail in the C200HX/HG/HE Installation Guide.

2-1	-1 CPU Unit Components					
	2-1-1 CPU Unit Indicators	13				
	2-1-2 Peripheral Device Connection	13				
2-2	PC Configuration	15				
2-3	CPU Unit Capabilities	15				
2-4	Memory Cassettes	16				
	2-4-1 Hardware and Software Settings	17				
	2-4-2 Writing/Reading UM Data	17				
	2-4-3 Writing/Reading IOM Data	18				
2-5	CPU Unit DIP Switch	20				
2-6	Operating without a Backup Battery					

2-1 CPU Unit Components

The following diagram shows the main CPU Unit components.



Memory Cassette

The CPU Unit has a compartment to connect the Memory Cassette to the CPU Unit. The Memory Cassette works as a RAM together with the built-in RAM of the CPU Unit.

Peripheral Port RS-232C Port A peripheral device can be connected to the peripheral port.

Communications Board

The CPU Unit has a built-in RS-232C port.

The CPU Unit has a compartment to connect the Communications Board to the CPU Unit.

DIP Switch

The PC operates according to the DIP switch settings of the CPU Unit. The DIP switch of the CPU Unit for the C200HX/HG/HE has six pins. For the function of each of the pins, refer to the following table. (All six pins are OFF when the PC is shipped.)



Pin	Setting	Function		
1	ON	Data cannot be written to the UM area.		
	OFF	Data can be written to the UM area.		
2	ON	Memory Cassette data is read automatically at startup.		
	OFF	Memory Cassette data is not read automatically at startup.		
3	ON	Programming Console displays messages in English.		
	OFF	Programming Console displays messages in Japanese.		
4	ON	The expansion instructions can be set.		
	OFF	The expansion instructions cannot be set (default setting).		
5	ON	Sets the following conditions for the communications port (including when a CQM1-CIF02 is connected to the Peripheral Port):		
		1 start bit, 7 data bits, even parity, 2 stop bit, 9,600 bps baud rate		
	OFF	Cancels the above settings.		
6	ON	Programming Console is in expansion terminal mode (AR 0712 is turned ON).		
	OFF	Programming Console is in normal mode (AR 0712 is turned OFF).		

2-1-1 CPU Unit Indicators

CPU Unit indicators provide visual information on the general operation of the PC. Although not substitutes for proper error programming using the flags and other error indicators provided in the data areas of memory, these indicators provide ready confirmation of proper operation.

Indicator	Meaning
RUN (green)	Lit when the PC is operating normally.
ERR (red)	Flashes if the PC detects any non-fatal error in operation. The PC will continue operating.
	Lit if the PC detects any fatal error in operation. The PC will stop operating. After the PC stops operating, the RUN indicator will be OFF and all output signals of the Output Units will be interrupted (turned OFF).
INH (orange)	Lit when the Load OFF flag (AR bit) is ON, in which case all output signals of the Output Units will be interrupted (turned OFF).
COMM (orange)	Flashes when the CPU Unit is communicating with the device connected to the peripheral port or RS-232C port.

2-1-2 Peripheral Device Connection

A Programming Console or IBM PC/AT running SSS can be used to program and monitor the C200HX/HG/HE PCs.

Programming Console

A C200H-PR027-E or CQM1-PR001-E Programming Console can be connected as shown in the diagram. The C200H-PR027-E is connected via the C200H-CN222 or C200H-CN422 Programming Console Connecting Cable, which must be purchased separately. A Connecting Cable is provided with the CQM1-PR001-E.


Data Access Console

A C200H-DAC01 Data Access Console can be connected via the C200H-CN222 or C200H-CN422 Programming Console Connecting Cable, which must be purchased separately. The following operations are not available when the C200H-DAC01 is used with the C200HX/HG/HE:

Set value read and change Error message display

IBM PC/AT with SSS

An IBM PC/AT or compatible computer with SYSMAC Support Software can be connected as shown in the diagram.



Note The connector of the XW2Z-200S/500S Connecting Cable is a male 25-pin terminal. An adapter is required for the 9-pin male D-sub terminal on the IBM PC/AT or compatible side.

2-2 PC Configuration

The basic PC configuration consists of two types of Rack: a CPU Rack and Expansion I/O Racks. The Expansion I/O Racks are not a required part of the basic system. They are used to increase the number of I/O points. An illustration of these Racks is provided in 3-3 IR Area. A third type of Rack, called a Slave Rack, can be used when the PC is provided with a Remote I/O System.

CPU Racks

A C200HX/HG/HE CPU Rack consists of three components: (1) The CPU Backplane, to which the CPU Unit and other Units are mounted. (2) The CPU Unit, which executes the program and controls the PC. (3) Other Units, such as I/O Units, Special I/O Units, and Link Units, which provide the physical I/O terminals corresponding to I/O points.

A C200HX/HG/HE CPU Rack can be used alone or it can be connected to other Racks to provide additional I/O points. The CPU Rack provides three, five, eight, or ten slots to which these other Units can be mounted depending on the backplane used.

Expansion I/O Racks

An Expansion I/O Rack can be thought of as an extension of the PC because it provides additional slots to which other Units can be mounted. It is built onto an Expansion I/O Backplane to which a Power Supply and up to ten other Units are mounted.

An Expansion I/O Rack is always connected to the CPU Unit via the connectors on the Backplanes, allowing communication between the two Racks. Up to three Expansion I/O Racks (two with the C200HE PCs) can be connected in series to the CPU Rack.

Unit Mounting Position

Only I/O Units and Special I/O Units can be mounted to Slave Racks. All I/O Units, Special I/O Units, Group-2 High-density I/O Units, Remote I/O Master Units, PC and Host Link Units, can be mounted to any slot on all other Racks. Interrupt Input Units must be mounted to Backplanes with the "-V2" suffix on the model number.

Refer to the C200HX/HG/HE Installation Guide for details about which slots can be used for which Units and other details about PC configuration. The way in which I/O points on Units are allocated in memory is described in 3-3 IR Area.

2-3 CPU Unit Capabilities

The following table shows the capabilities of the C200HX/HG/HE CPU Units. The CPU4—E and CPU6—E CPU Units are equipped with RS-232C ports.

Item	C20	OHE-	C200HG- C200H		DHX-	
	CPU11-E	CPU32-E/ 42-E	CPU33-E/ 43-E	CPU53-E/ 63-E	CPU34-E/ 44-E	CPU54-E/ 64-E
Program capacity	3.2K words	7.2K words	15.2K word	S	31.2K word	S
DM capacity	4K words	6K words	6K words	6K words 6K words		
EM capacity	None		6K words × 1 bank 6K words × 3 bank		3 banks	
Basic instruction execution time	0.3 μs min.		0.15 μs min. 0.1 μs min.			
Max. number of Expansion I/O Racks	2 Racks		2 Racks	3 Racks	2 Racks	3 Racks
Max. number of Group-2 High-density I/O Units	None 10 Units		10 Units	16 Units	10 Units	16 Units
Max. number of Special I/O Units	10 Units		10 Units	16 Units	10 Units	16 Units
Clock function	No	Yes	Yes	•	Yes	•
Communications Board Slot	No	Yes	Yes		Yes	

2-4 Memory Cassettes

The C200HX/HG/HE comes equipped with a built-in RAM for the user's program, so a normal program be created even without installing a Memory Cassette. An optional Memory Cassette can be used to store the program, PC Setup, I/O comments, DM area and other data area contents. Refer to the C200HX/HG/HE Installation Guide for details on installing Memory Cassettes.

Memory Cassette Functions

The Memory Cassette can be used to store and retrieve UM and IOM data; UM stored in the Memory Cassette can also be compared to the UM in the PC.

1, 2, 3...
 The contents of UM (user memory) can be stored in the Memory Cassette for later retrieval or verification. If pin 2 of the CPU Unit DIP switch is set to ON, the contents of the Memory Cassette are automatically retrieved when the PC is turned ON.

The UM area contains the ladder program, fixed DM (such as the PC Setup), expansion DM, I/O comments, the I/O table, and the UM area allocation information.

2. The contents of the PC's I/O memory (IOM) can be stored in the Memory Cassette for later retrieval.

IOM includes the IR area, SR area, LR area, HR area, AR area, timer and counter PVs, DM 0000 through DM 6143, and EM 0000 through EM 6143.

UM and IOM data is completely compatible between the C200HX/HG/HE and the C200HS data, except the portion of the C200HX/HG/HE data areas that exceed the capacity of the C200HS and the new instructions (BXF2(—), IEMS(—), IORD(—), IOWR(—), PMCR(—), STUP(—), and XFR2(—)) that aren't supported by the C200HS CPU Unit. Data area addresses and instructions that aren't supported by the C200HS can't be used in the C200HS. IOM data can't be retrieved to the PC's RAM unless the size of the IOM in the Memory Cassette matches the size of the IOM in the PC.

Compatible Memory Cassettes

There are two types of Memory Cassette available: EEPROM and EPROM. The following table shows the Memory Cassettes which can be used with the C200HX/HG/HE PCs.

Memory	Capacity	Model number	Comments
EEPROM	4K words	C200HW-ME04K	The EEPROM Memory Cassette can be used to write and read UM
	8K words	C200HW-ME08K	and I/O data to the CPU Unit. It does
	16K words	C200HW-ME16K	not require any backup power sup- ply and will retain its data even after
	32K words	C200HW-ME32K	it is removed from the CPU Unit.
EPROM	16K or 32K words	C200HS-MP16K	The EPROM chip is not included with the Memory Cassette; it must be purchased separately.
			27256 equivalent (ROM-JD-B): 16K 27512 equivalent (ROM-KD-B): 32K

Note

- 1. Data stored in EEPROM won't be reliable after the contents have been overwritten 50,000 times.
- Use a standard PROM writer to write a program to the EPROM Memory Cassette. Connect an EPROM to the EPROM Memory Cassette before installing the EPROM Memory Cassette to the CPU Unit. The EPROM Memory Cassette will lose its data if it is removed from the CPU Unit.

2-4-1 Hardware and Software Settings

The hardware and software settings related to Memory Cassette operations are described below.

Switch Settings

Switch 1 on the Memory Cassette is turned OFF when the Memory Cassette is shipped. Check the setting on switch 1 before installation.

Memory Cassette	Switch 1 setting	Function
EEPROM	ON	The data in the Memory Cassette is write-protected.
	OFF	The data in the Memory Cassette can be overwritten.
EPROM	ON	27512-equivalent ROM-KD-B EPROM (32K words, 150 ns access time)
	OFF	27256-equivalent ROM-JD-B EPROM (16K words, 150 ns access time)

SR Area Flags and Control Bits

SR 269 through SR 273 contain flags and control bits related to Memory Cassette contents and operation. Refer to 3-4 SR (Special Relay) Area for details.

2-4-2 Writing/Reading UM Data

1, 2, 3...

Use the following procedures to transfer UM data to or from a Memory Cassette. (A PROM writer is required to write data to an EPROM Memory Cassette. Refer to the SYSMAC Support Software Operation Manual for details.)

Note UM contains the ladder program, fixed DM (such as the PC Setup), expansion DM, I/O comments, the I/O table, and the UM area allocation information.

Writing UM Data to a Memory Cassette

Use the following procedure to write UM data to an EEPROM Memory Cassette.

- 1. Before turning ON the C200HX/HG/HE's power supply, make sure that switch 1 on the Memory Cassette is set to OFF.
- 2. Turn ON the C200HX/HG/HE and write the ladder program or read an existing program from a data disk.
- 3. Switch the C200HX/HG/HE to PROGRAM mode.
- 4. Use a host computer running SSS or a Programming Console to turn ON SR 27000 (the Save UM to Cassette Bit). The data will be written from the PC to the Memory Cassette. SR 27000 will be turned OFF automatically after the data transfer has been completed.
- 5. If you want to write-protect the data on the Memory Cassette, turn OFF the PC and set switch 1 of the Memory Cassette to ON. If this switch is ON, data in the Memory Cassette will be retained even if SR 27000 is turned ON.

Reading UM Data from a Memory Cassette

There are two ways to read UM data from a Memory Cassette: automatic transfer at startup or a one-time transfer using a Peripheral Device.

(There is no function that automatically writes data to the Memory Cassette.)

Automatic Transfer at Startup:

- 1, 2, 3... 1. Turn ON pin 2 of the CPU Unit's DIP switch.
 - 2. Install the Memory Cassette containing the data into the C200HX/HG/HE.
 - Turn ON the C200HX/HG/HE's power supply. The contents of the Memory Cassette will be transferred to the CPU Unit automatically. A memory error will occur if the data couldn't be transferred.

One-time Transfer using a Peripheral Device:

- 1, 2, 3... 1. Install the Memory Cassette containing the data into the C200HX/HG/HE.
 - 2. Turn ON the C200HX/HG/HE and switch it to PROGRAM mode.
 - 3. Use a host computer running SSS or a Programming Console to turn ON SR 27001 (the Load UM from Cassette Bit). The data will be read from the Memory Cassette to the PC. SR 27001 will be turned OFF automatically after the data transfer has been completed.

Comparing UM Data on a Memory Cassette

Use the following procedure to the UM data on an Memory Cassette to the UM data in the PC.

1, 2, 3... 1. Switch the C200HX/HG/HE to PROGRAM mode.

- Use a host computer running SSS or a Programming Console to turn ON SR 27002 (the Compare UM to Cassette Bit). The data will be compared between the PC and the Memory Cassette. SR 27002 will be turned OFF automatically after the data comparison has been completed.
- 3. Use a host computer running SSS or a Programming Console to check the status of SR 27003 (the Comparison Results Flag).

Note If data verification is executed in a mode other than the PROGRAM mode, an operation continuance error (FAL90) will occur and 27002 will turn ON (1). Although 27003 will also turn ON, comparison will not be performed. If data comparison is executed without mounting the Memory Cassette, 27003 will turn ON (1).

2-4-3 Writing/Reading IOM Data

Use the following procedures to transfer IOM data to or from a Memory Cassette. (A PROM writer is required to write data to an EPROM Memory Cassette. Refer to the SYSMAC Support Software Operation Manual for details.)

IOM includes the IR area, SR area, LR area, HR area, AR area, timer and counter PVs, DM 0000 through DM 6143, and EM 0000 through EM 6143.

The capacity of the Memory Cassette must match the memory capacity of the CPU Unit when IOM data is transferred to or from a Memory Cassette. The memory requirements are as follows:

Writing IOM: CPU Unit's capacity ≤ Memory Cassette's capacity Reading IOM: CPU Unit's capacity = Amount of IOM data in Memory Cassette

Note In C200HS PCs, the data transfer will be performed even if the memory capacities don't match, an error which can easily go unnoticed.

The following table shows the Memory Cassette capacity required to store 1 or more banks of EM.

Memory Cassette capacity	Number of EM banks		
4K words	None (A 4K-word Memory Cassette can't be used to store other IOM data, either.)		
8K words	None		
16K words	1 bank (Only EM bank 0 can be stored.)		
32K words	3 banks (EM banks 0 through 2 can be stored.)		

Bits 08 through 15 of SR 273 indicate the EM bank number of the IOM data stored in the Memory Cassette.

Content of SR 27308 to SR 27315	Meaning
00	There is no Memory Cassette installed, no IOM data in the Memory Cassette, or no EM data in the Memory Cassette.
01	The Memory Cassette contains IOM data that includes EM bank 0 only.
04	The Memory Cassette contains IOM data that includes EM banks 0 through 2.

Writing IOM Data to a Memory Cassette

Use the following procedure to write IOM data to an EEPROM Memory Cassette.

1, 2, 3... 1. Before turning ON the C200HX/HG/HE's power supply, make sure that switch 1 on the Memory Cassette is set to OFF.

- 2. Turn ON the C200HX/HG/HE and switch it to PROGRAM mode.
- 3. Use a host computer running SSS or a Programming Console to turn ON SR 27300 (the Save IOM to Cassette Bit). The data will be written from the PC to the Memory Cassette. SR 27300 will be turned OFF automatically after the data transfer has been completed.
- 4. If you want to write-protect the data on the Memory Cassette, turn OFF the PC and set switch 1 of the Memory Cassette to ON. If this switch is ON, data in the Memory Cassette will be retained even if SR 27300 is turned ON.

Reading IOM Data from a Memory Cassette

Use the following procedure to read IOM data from a Memory Cassette. The contents of the error history (DM 6000 through DM 6030) can't be read from the Memory Cassette.

Note There is no function that automatically reads IOM data from the Memory Cassette.

- 1. Install the Memory Cassette containing the data into the C200HX/HG/HE.
 - 2. Turn ON the C200HX/HG/HE and switch it to PROGRAM mode.
 - 3. Use a host computer running SSS or a Programming Console to turn ON SR 27301 (the Load IOM from Cassette Bit). The data will be read from the Memory Cassette to the PC. SR 27301 will be turned OFF automatically after the data transfer has been completed.

CPU Unit DIP Switch Section 2-5

2-5 CPU Unit DIP Switch

The 6 pins on the DIP switch control 6 of the CPU Unit's operating parameters.

Pin	Item	Setting	Function		
1	Memory protect	ON	The UM area ¹ cannot be overwritten from a Peripheral Device.		
		OFF	The UM area ¹ can be overwritten from a Peripheral Device.		
2	2 Automatic transfer of Memory Cassette contents		The contents of the Memory Cassette will be automatically transferred to the internal RAM at start-up.		
		OFF	The contents will not be automatically transferred.		
3	Message language	ON	Programming Console messages will be displayed in English. (see note 1)		
		OFF	Programming Console messages will be displayed in Japanese.		
4	Expansion instruction setting	ON	Expansion instructions will be set by user. Normally ON when using a host computer for programming/monitoring.		
		OFF	Expansion instructions will be set to defaults.		
5	Communications parameters	ON	Standard communications parameters (see note 2) will be set for the following serial communications ports.		
			Built-in RS-232C port		
			Peripheral port (only when a CQM1-CIF01/-CIF02 Cable is connected. Does not apply to Programming Console.)		
			Note 1. Standard communications parameters are as follows: Serial communications mode: Host Link or peripheral bus; start bits: 1; data length: 7 bits; parity: even; stop bits: 2; baud rate: 9,600 bps		
			The CX-Programmer running on a personal computer can be connected to the peripheral port via the peripheral bus using the above standard communications parameters.		
			The communications parameters for the following serial communications ports will be set in PC Setup as follows:		
			Built-in RS-232C port: DM 6645 and DM 6646		
			Peripheral port: DM 6650 and DM 6651		
			Note When the CX-Programmer is connected to the peripheral port with the peripheral bus, either set bits 00 to 03 of DM 6650 in the Fixed DM Area to 0 Hex (for standard parameters), or set bits 12 to 15 of DM 6650 to 0 Hex and bits 00 to 03 of DM 6650 to 1 Hex (for Host Link or peripheral bus) separately.		
6	Expansion TERMINAL mode	ON	Expansion TERMINAL mode (Programming Console); AR 0712 ON.		
	setting when AR 0712 is ON	OFF	Normal mode (Programming Console); AR 0712: OFF		

Note

- 1. Pin 3 is set to ON when the PC is shipped.
- 2. The UM area contains the ladder program, fixed DM (including the PC Setup), expansion DM, I/O comments, the I/O table, and the UM area allocation information.
- 3. All pins except pin 3 are set to OFF when the PC is shipped.

2-6 Operating without a Backup Battery

An EEPROM or EPROM Memory Cassette can be used together with various memory settings to enable operation without a backup battery. The following conditions must be met.

- **1, 2, 3...** 1. The user program must be written to an EPROM or EEPROM Memory Cassette.
 - 2. The clock cannot be used. (A battery is required to run the internal clock.)
 - 3. The PC Setup must be set to not detect low battery voltage.
 - 4. The system must be designed to run properly even if DM area data is lost.
 - 5. The Output OFF Bit (SR 25215) must be programmed to remain OFF. (The status of this bit will be unstable without a battery.)



- 6. The Forced Status Hold Bit (SR 25211) and Data Retention Control Bit (SR 25212) must be set to be cleared in the PC Setup. (The status of these bits will be unstable without a battery.)
- 7. The DIP switch on the CPU Unit must be set so that pin 1 is OFF and pin 2 is ON.

If these conditions can be met, use the following procedures to operate without a backup battery.

EEPROM Memory Cassette

- 1, 2, 3...
- 1. Allocate UM area using the SYSMAC Support Software (SSS) if you want to use Expansion DM for Special I/O Units or if you want to store I/O comments in the PC.
- 2. Write and transfer the user program, including a line using the Always OFF Flag (SR 25314) to ensure that the Output OFF Bit (SR 25215) remains OFF.



3. Set the following in the PC Setup


DM 6601 = 0000 (To reset Forced Status Hold Bit (SR 25211) and I/O Status Hold Bit (SR 25212) at startup)

DM 6655 bits 12 to 15 = 1, bits 4 to 7 = 0 (To not detect low battery voltage) DM 6600 and DM 6602 to DM 6654 = As required by the application.

- 4. Set Fixed DM (including the Communications Board settings in DM 6144 to DM 6599) and Expansion DM as required by the application.
- 5. Check operation.
- 6. Mount the Memory Cassette in the CPU Unit.
- 7. Switch to PROGRAM mode.
- 8. Turn ON SR 27000 to transfer the program, Fixed DM, and the PC Setup to the Memory Cassette. (This bit will automatically reset itself if turned ON from a Programming Console. It will need to be turned OFF by clearing forced status if it is set from the SSS.)
- 9. Turn ON the write protect switch on the Memory Cassette.
- Turn OFF pin 1 and turn ON pin 2 on the DIP switch on the CPU Unit to automatically transfer the program, Fixed DM, and the PC Setup from the Memory Cassette when power is turned ON.

EPROM Memory Cassette

- Allocate UM area using the SYSMAC Support Software (SSS) if you want to use Expansion DM for Special I/O Units or if you want to store I/O comments in the PC.
 - 2. Write and transfer the user program, including a line using the Always OFF Flag (SR 25314) to ensure that the Output OFF Bit (SR 25215) remains OFF.



- 3. Set the following in the PC Setup
 - DM 6601 = 0000 (To reset Forced Status Hold Bit (SR 25211) and I/O Status Hold Bit (SR 25212) at startup)
 - DM 6655 bits 12 to 15 = 1, bits 4 to 7 = 0 (To not detect low battery voltage) DM 6600 and DM 6602 to DM 6654 = As required by the application.
- 4. Set Fixed DM (including the Communications Board settings in DM 6144 to DM 6599) and Expansion DM as required by the application.
- 5. Check operation.
- 6. Transfer the program, Fixed DM, and the PC Setup to the SSS.
- 7. Write the program, Fixed DM, and the PC Setup to ROM using the SSS and a PROM writer.
- 8. Mount the ROM onto the Memory Cassette.
- 9. Mount the Memory Cassette in the CPU Unit.
- Turn OFF pin 1 and turn ON pin 2 on the DIP switch on the CPU Unit to automatically transfer the program, Fixed DM, and the PC Setup from the Memory Cassette when power is turned ON.

SECTION 3 Memory Areas

Various types of data are required to achieve effective and correct control. To facilitate managing this data, the PC is provided with various **memory areas** for data, each of which performs a different function. The areas generally accessible by the user for use in programming are classified as **data areas**. The other memory area is the UM Area, where the user's program is actually stored. This section describes these areas individually and provides information that will be necessary to use them. As a matter of convention, the TR area is described in this section, even though it is not strictly a memory area.

3-1		00	24
	3-1-1 3-1-2	Data Area Overview	24
	J	IR/SR Area Overview	25
3-2		Structure	25
3-3	IR (Interna	al Relay) Area	29
3-4		al Relay) Area	33
	3-4-1	SYSMAC NET/SYSMAC LINK System	38
	3-4-2 3-4-3	Remote I/O Systems	39
	3-4-3 3-4-4	Link System Flags and Control Bits Forced Status Hold Bit	40 41
	3-4-4	I/O Status Hold Bit	42
	3-4-6	Output OFF Bit	42
	3-4-7	FAL (Failure Alarm) Area	42
	3-4-8	Low Battery Flag	42
	3-4-9	Cycle Time Error Flag	43
	3-4-10	I/O Verification Error Flag	43
	3-4-11	First Cycle Flag	43
	3-4-12	Clock Pulse Bits	43
	3-4-13	Step Flag	44
	3-4-14 3-4-15	Group-2 Error Flag	44 44
	3-4-15	Instruction Execution Error Flag, ER	44
	3-4-17	Arithmetic Flags	44
	3-4-18	Interrupt Subroutine Areas	45
	3-4-19	RS-232C Port Communications Areas	45
	3-4-20	Peripheral Port Communications Areas	46
	3-4-21	Memory Cassette Areas	46
	3-4-22	Data Transfer Error Bits	47
	3-4-23	Ladder Diagram Memory Areas	47
	3-4-24 3-4-25	Memory Error Flags	47 48
	3-4-25 3-4-26	Data Save Flags	48
	3-4-20	Transfer Error Flags PC Setup Error Flags	48
	3-4-28	Clock and Keyboard Mapping	48
	3-4-29	Group-2 Error Flags	48
	3-4-30	Special I/O Unit Restart Bits and Error Flags	48
3-5	AR (Auxi	liary Relay) Area	48
	3-5-Ì	Restarting Special I/O Units	50
	3-5-2	Slave Rack Error Flags	51
	3-5-3	Group-2 Error Flags	51
	3-5-4	Optical I/O Unit and I/O Terminal Error Flags	51
	3-5-5 3-5-6	SYSMAC LINK/Controller Link System Data Link Settings	52 52
	3-5-0 3-5-7	Error History Bits Active Node Flags	32
	3-5-8	Active rout riags	52
			52 53
	3-5-9	SYSMAC LINK/SYSMAC NET Link System Service Time	53
	3-5-9 3-5-10	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits	
		SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter	53 53
	3-5-10 3-5-11 3-5-12	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags	53 53 54 54 54
	3-5-10 3-5-11 3-5-12 3-5-13	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag	53 53 54 54 54 55
	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags	53 53 54 54 54 55 55
	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag	53 53 54 54 54 55 55 55
	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit	53 53 54 54 54 55 55 55
	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits	53 53 54 54 54 55 55 55
3.6	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators	53 53 54 54 55 55 55 55 55
3-6	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area	53 53 54 54 54 55 55 55 55 55
3-6	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area	53 53 54 54 54 55 55 55 55 55 55 55 55
3-6	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data	53 53 54 54 54 55 55 55 55 55
3-6	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-4	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup	53 53 54 54 54 55 55 55 55 55 55 55 55 55
3-6	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-3 3-6-4 3-6-5	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings	53 53 54 54 54 55 55 55 55 55 55 55 56 57 58 58
	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-3 3-6-5 3-6-6	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings Special I/O Unit Area Settings	53 53 54 54 54 55 55 55 55 55 55 55 56 67
3-7	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-3 3-6-5 3-6-6	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings	53 53 54 54 54 55 55 55 55 55 55 55 56 67
	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-3 3-6-5 3-6-6 HR (Holdi	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings Special I/O Unit Area Settings	53 53 54 54 54 55 55 55 55 55 55 55 56 67 68
3-7	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-3 3-6-4 3-6-5 3-6-6 HR (Holdi	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings Special I/O Unit Area Settings ing Relay) Area	53 53 54 54 54 55 55 55 55 55 55 55 55 56 60 65 67 68
3-7 3-8	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-4 3-6-5 3-6-6 HR (Holdi TC (Timer LR (Link	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings ing Relay) Area r/Counter) Area	53 53 54 54 54 55 55 55 55 55 55 55 56 60 65 68 68
3-7 3-8 3-9	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-4 3-6-5 3-6-6 HR (Holdi TC (Timer LR (Link UM Area	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings special I/O Unit Area Settings ing Relay) Area Relay) Area Relay) Area	53 53 54 54 54 55 55 55 55 55 55 55 56 57 58 58
3-7 3-8 3-9 3-10	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-4 3-6-5 3-6-6 HR (Holdi TC (Timer LR (Link UM Area TR (Temp	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings Special I/O Unit Area Settings ing Relay) Area Relay) Area Relay) Area Relay) Area	53 53 54 54 54 55 55 55 55 55 55 55 56 67 68 68 68
3-7 3-8 3-9 3-10 3-11	3-5-10 3-5-11 3-5-12 3-5-13 3-5-14 3-5-15 3-5-16 3-5-17 3-5-18 DM (Data 3-6-1 3-6-2 3-6-3 3-6-4 3-6-5 3-6-6 HR (Holdi TC (Timer LR (Link UM Area TR (Temp	SYSMAC LINK/SYSMAC NET Link System Service Time Calendar/Clock Area and Bits TERMINAL Mode Key Bits Power OFF Counter SYSMAC LINK – Peripheral Device Flags Cycle Time Flag Link Unit Mounted Flags CPU Unit-mounting Device Mounted Flag FPD Trigger Bit Data Tracing Flags and Control Bits Cycle Time Indicators Memory) Area Expansion DM Area Special I/O Unit Data Error History Area PC Setup Communications Board Settings Special I/O Unit Area Settings ing Relay) Area Relay) Area Relay) Area Relay) Area	53 53 54 54 54 55 55 55 55 55 55 55 56 67 68 68 68 69 70

Introduction Section 3-1

3-1 Introduction

3-1-1 Data Area Overview

Details, including the name, size, and range of each area are summarized in the following table. Data and memory areas are normally referred to by their acronyms, e.g., the IR Area, the SR Area, etc.

Area		Size	Range	Comments
Internal Relay Area 1	3,776 bits		IR 000 to IR 235	Refer to 3-1-2 IR/SR Area Overview and 3-3 IR (Internal Relay) Area for more details.
Special Relay Area 1	312	bits	SR 236 to SR 255	Refer to 3-1-2 IR/SR Area Overview and 3-4 SR
Special Relay Area 2	704	bits	SR 256 to SR 299	(Special Relay) Area for more details.
Internal Relay Area 2	3,392 bits		IR 300 to IR 511	Refer to 3-1-2 IR/SR Area Overview and 3-3 IR (Internal Relay) Area for more details.
Temporary Relay Area	8 bits		TR 00 to TR 07	Used to temporarily store and retrieve execution conditions when programming certain types of branching ladder diagrams.
Holding Relay Area	1,60	0 bits	HR 00 to HR 99	Used to store data and to retain the data values when the power to the PC is turned OFF.
Auxiliary Relay Area	448	buts	AR 00 to AR 27	Contains flags and bits for special functions. Retains status during power failure.
Link Relay Area	1,02	4 bits	LR 00 to LR 63	Used for data links in the PC Link System. (These bits can be used as work words or work bits when not used in the PC Link System.)
Timer/Counter Area	Timer/Counter Area 512 counters/timers		TC 000 to TC 511	Used to define timers and counters, and to access completion flags, PV, and SV.
				TIM 000 through TIM 015 are refreshed via interrupt processing as high-speed timers.
Data Memory Area	6,14	4 words	DM 0000 to DM 6143	Read/Write
				DM 6031 is used for indirect DM addressing and EM bank information and should not be written by the user.
		1,000 words	DM 0000 to DM 0999	Normal DM.
		2,600 words	DM 1000 to DM 2599	Special I/O Unit Area
		3,400 words	DM 2600 to DM 5999	Normal DM.
		31 words	DM 6000 to DM 6030	History Log
		(44 words)	DM 6100 to DM 6143	Link test area (reserved)
Fixed DM Area	512	words	DM 6144 to DM 6599	Fixed DM Area (read only)
		56 words	DM 6600 to DM 6655	PC Setup
Extended Data Memory Area	6,14	4 words	EM 0000 to EM 6143	The amount of EM area memory depends on the PC model being used. PCs are available with no EM, one 6,144-word bank, or three 6,144-word banks.
				Like DM, the EM memory can be accessed in word units only and EM area data is retained when the power to the PC is turned OFF.

Work Bits and Words

When some bits and words in certain data areas are not being used for their intended purpose, they can be used in programming as required to control other bits. Words and bits available for use in this fashion are called work words and work bits. Most, but not all, unused bits can be used as work bits. Those that can be used are described area-by-area in the remainder of this section. Actual application of work bits and work words is described in Section 4 Writing and Inputting the Program.

Flags and Control Bits

Some data areas contain flags and/or control bits. Flags are bits that are automatically turned ON and OFF to indicate particular operation status. Although

some flags can be turned ON and OFF by the user, most flags are read only; they cannot be controlled directly.

Control bits are bits turned ON and OFF by the user to control specific aspects of operation. Any bit given a name using the word bit rather than the word flag is a control bit, e.g., Restart bits are control bits.

3-1-2 IR/SR Area Overview

When designating a data area, the acronym for the area is always required for any area except the IR and SR areas. Although the acronyms for the IR and SR areas are given for clarity in text explanations, they are not required, and not entered, when programming.

The IR and SR areas are divided into two 256-word sections; the boundary between these sections is located in the SR area between SR 255 and SR 256. When the SR area is used as an operand in an instruction, the operand cannot cross over this boundary. Also, basic instructions that access bits in the second section (SR 25600 through IR 51115) have somewhat longer execution times.

	Area	Range	Comments
IR Area 1	I/O Area 1	IR 000 to IR 029	I/O words are allocated to the CPU Rack and Expansion I/O Racks by slot position.
	Group-2 High-density I/O Unit and B7A Interface Unit Area	IR 030 to IR 049	Allocated to Group-2 High-density I/O Units and to B7A Interface Units 0 to 9.
	SYSMAC BUS and CompoBus/D Output Area	IR 050 to IR 099	Allocated to CompoBus/D outputs and Remote I/O Slave Racks 0 to 4.
	Special I/O Unit Area 1	IR 100 to IR 199	Allocated to Special I/O Units 0 to 9.
	Optical I/O Unit and I/O Terminal Area	IR 200 to IR 231	Allocated to Optical I/O Units and I/O Terminals.
	Work Area	IR 232 to IR 235	For use as work bits in the program.
SR Area 1		SR 23600 to SR 25507	Contains system clocks, flags, control bits, and status information.
SR Area 2		SR 256 to SR 299	Contains flags, control bits, and status information. SR 290 to SR 297 are used as I/O words by MCRO(99).
IR Area 2	I/O Area 2	IR 300 to IR 309	These I/O words are allocated to a third Expansion I/O Rack by slot position.
	Work Area	IR 310 to IR 329	For use as work bits in the program.
	Group-2 High-density I/O Unit Area 2	IR 330 to IR 341	Allocated to Group-2 High-density I/O Units.
	Work Area	IR 342 to IR 349	For use as work bits in the program.
	CompoBus/D Input Area	IR 350 to IR 399	Allocated to CompoBus/D inputs.
	Special I/O Unit Area 2	IR 400 to IR 459	Allocated to Special I/O Units A to F.
	Work Area	IR 460 to IR 511	For use as work bits in the program.

Note

- 1. Refer to 3-3 IR (Internal Relay) Area for more details on the IR area. Refer to 3-4 SR (Special Relay) Area for more details on the SR area.
- 2. Bits in IR Area 1 and IR Area 2 can can be used in programming as work bits when not used for their allocated purpose.

3-2 Data Area Structure

When designating a data area, the acronym for the area is always required for any but the IR and SR areas. Although the acronyms for the IR and SR areas are often given for clarity in text explanations, they are not required, and not entered, when programming. Any data area designation without an acronym is assumed to be in either the IR or SR area. Because IR and SR addresses run consecutively, the word or bit addresses are sufficient to differentiate these two areas.

An actual data location within any data area but the TC area is designated by its address. The address designates the bit or word within the area where the desired data is located. The TC area consists of TC numbers, each of which is used for a specific timer or counter defined in the program. Refer to 3-8 TC Area for more details on TC numbers and to 5-14 Timer and Counter Instructions for information on their application.

The rest of the data areas (i.e., the IR, SR, HR, DM, AR, and LR areas) consist of words, each of which consists of 16 bits numbered 00 through 15 from right to left. IR words 000 and 001 are shown below with bit numbers. Here, the content of each word is shown as all zeros. Bit 00 is called the rightmost bit; bit 15, the leftmost bit.

The term least significant bit is often used for rightmost bit; the term most significant bit, for leftmost bit. These terms are not used in this manual because a single data word is often split into two or more parts, with each part used for different parameters or operands. When this is done, the rightmost bits of a word may actually become the most significant bits, i.e., the leftmost bits in another word, when combined with other bits to form a new word.

Λ1

 $\cap \cap$

Bit number
IR word 000
IR word 001

10	17	13	12		10	03	00	01	00	03	0-	03	02	01	00
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

The DM area is accessible by word only; you cannot designate an individual bit within a DM word. Data in the IR, SR, HR, AR, and LR areas is accessible either by word or by bit, depending on the instruction in which the data is being used.

To designate one of these areas by word, all that is necessary is the acronym (if required) and the two-, three-, or four-digit word address. To designate an area by bit, the word address is combined with the bit number as a single four- or five-digit address. The following table show examples of this. The two rightmost digits of a bit designation must indicate a bit between 00 and 15, i.e., the rightmost digit must be 5 or less the next digit to the left, either 0 or 1.

The same TC number can be used to designate either the present value (PV) of the timer or counter, or a bit that functions as the Completion Flag for the timer or counter. This is explained in more detail in 3-8 TC Area.

Area	Word designation	Bit designation
IR	000	00015 (leftmost bit in word 000)
SR	252	25200 (rightmost bit in word 252)
DM	DM 1250	Not possible
TC	TC 215 (designates PV)	TC 215 (designates completion flag)
LR	LR 12	LR 1200

Data Structure

Word data input as decimal values is stored in binary-coded decimal (BCD); word data entered as hexadecimal is stored in binary form. Each four bits of a word represents one digit, either a hexadecimal or decimal digit, numerically equivalent to the value of the binary bits. One word of data thus contains four digits, which are numbered from right to left. These digit numbers and the corresponding bit numbers for one word are shown below.

Digit number
Bit number
Contents

	;	3			2	2				1				0	
15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

When referring to the entire word, the digit numbered 0 is called the rightmost digit; the one numbered 3, the leftmost digit.

When inputting data into data areas, it must be input in the proper form for the intended purpose. This is no problem when designating individual bits, which are merely turned ON (equivalent to a binary value of 1) or OFF (a binary value of 0). When inputting word data, however, it is important to input it either as decimal or as hexadecimal, depending on what is called for by the instruction it is to be used for. Section 5 Instruction Set specifies when a particular form of data is required for an instruction.

Converting Different Forms of Data

Binary and hexadecimal can be easily converted back and forth because each four bits of a binary number is numerically equivalent to one digit of a hexadecimal number. The binary number 0101111101011111 is converted to hexadecimal by considering each set of four bits in order from the right. Binary 1111 is hexadecimal F; binary 0101 is hexadecimal 5. The hexadecimal equivalent would thus be 5F5F, or 24,415 in decimal $(16^3 \times 5 + 16^2 \times 15 + 16 \times 5 + 15)$.

Decimal and BCD are easily converted back and forth. In this case, each BCD digit (i.e., each group of four BCD bits) is numerically equivalent of the corresponding decimal digit. The BCD bits 0101011101010111 are converted to decimal by considering each four bits from the right. Binary 0101 is decimal 5; binary 0111 is decimal 7. The decimal equivalent would thus be 5,757. Note that this is not the same numeric value as the hexadecimal equivalent of 0101011101010111, which would be 5,757 hexadecimal, or 22,359 in decimal $(16^3 \times 5 + 16^2 \times 7 + 16 \times 5 + 7)$.

Because the numeric equivalent of each four BCD binary bits must be numerically equivalent to a decimal value, any four bit combination numerically greater than 9 cannot be used, e.g., 1011 is not allowed because it is numerically equivalent to 11, which cannot be expressed as a single digit in decimal notation. The binary bits 1011 are of course allowed in hexadecimal are a equivalent to the hexadecimal digit C.

There are instructions provided to convert data either direction between BCD and hexadecimal. Refer to *5-18 Data Conversion* for details. Tables of binary equivalents to hexadecimal and BCD digits are provided in the appendices for reference.

Decimal Points

Decimal points are used in timers only. The least significant digit represents tenths of a second. All arithmetic instructions operate on integers only.

Signed and Unsigned Binary Data

This section explains signed and unsigned binary data formats. Many instructions can use either signed or unsigned data and a few (CPS(—), CPSL(—), DBS(—), DBSL(—), MBS(—), and MBSL(—)) use signed data exclusively.


Unsigned binary

Unsigned binary is the standard format used in OMRON PCs. Data in this manual are unsigned unless otherwise stated. Unsigned binary values are always positive and range from 0 (\$0000) to 65,535 (\$FFFF). Eight-digit values range from 0 (\$0000 0000) to 4,294,967,295 (\$FFFF FFFF).

Digit value		•	16 ³				16 ²				16 ¹				16 ⁰	
Bit number	15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
Contents	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Signed Binary

Signed binary data can have either a positive and negative value. The sign is indicated by the status of bit 15. If bit 15 is OFF, the number is positive and if bit 15 is ON, the number is negative. Positive signed binary values range from 0 (\$0000) to 32,767 (\$7FFF), and negative signed binary values range from -32,768 (\$8000) to -1 (\$FFFF).




Eight-digit positive values range from 0 ($$0000\ 0000$) to 2,147,483,647 (\$7FFFFFFF), and eight-digit negative values range from -2,147,483,648 ($$8000\ 0000$) to -1 (\$FFFFFFFF).

The following table shows the corresponding decimal, 16-bit hexadecimal, and 32-bit hexadecimal values.

Decimal	16-bit Hex	32-bit Hex
2147483647		7FFFFFF
2147483646		7FFFFFE
•		•
32768		0008000
32767	7FFF	00007FFF
32766	7FFE	00007FFE
		•
2	0002	00000002
0	0001 0000	00000001 00000000
_1	FFFF	FFFFFFF
-2	FFFE	FFFFFFE
•		-
-32767	8001	FFFF8001
-32768	8000	FFFF8000
-32769		FFFF7FFF
•		
		:
-2147483647		80000001
-2147483648		80000000

Converting Decimal to Signed Binary

Positive signed binary data is identical to unsigned binary data (up to 32,767) and can be converted using BIN(100). The following procedure converts negative decimal values between –32,768 and –1 to signed binary. In this example –12345 is converted to CFC7.



Reverse the procedure to convert negative signed binary data to decimal.

3-3 IR (Internal Relay) Area

The IR area is used both as data to control I/O points, and as work bits to manipulate and store data internally. It is accessible both by bit and by word. In the C200HX/HG/HE PC, the IR area is comprised of words IR 000 to IR 235 (IR area 1) and IR 300 to IR 511 (IR area 2). Basic instructions have somewhat longer execution times when they access IR area 2 rather than IR area 1.

Words in the IR area that are used to control I/O points are called I/O words. Bits in I/O words are called I/O bits. Bits in the IR area which are not assigned as I/O bits can be used as work bits. IR area work bits are reset when power is interrupted or PC operation is stopped.

	Area	Range
IR Area 1	I/O Area 1	IR 000 to IR 029
	Group-2 High-density I/O Unit Area 1 and B7A Interface Unit Area	IR 030 to IR 049
	SYSMAC BUS and CompoBus/D Output Area	IR 050 to IR 099
	Special I/O Unit Area 1	IR 100 to IR 199
	Optical I/O Unit and I/O Terminal Area	IR 200 to IR 231
	Work Area	IR 232 to IR 235
IR Area 2	I/O Area 2	IR 300 to IR 309
	Work Area	IR 310 to IR 329
	Group-2 High-density I/O Unit Area 2	IR 330 to IR 341
	Work Area	IR 342 to IR 349
	CompoBus/D Input Area	IR 350 to IR 399
	Special I/O Unit Area 2	IR 400 to IR 459
	Work Area	IR 460 to IR 511

I/O Words

If a Unit brings inputs into the PC, the bit assigned to it is an input bit; if the Unit sends an output from the PC, the bit is an output bit. To turn ON an output, the output bit assigned to it must be turned ON. When an input turns ON, the input bit assigned to it also turns ON. These facts can be used in the program to access input status and control output status through I/O bits.

Input Bit Usage

Input bits can be used to directly input external signals to the PC and can be used in any order in programming. Each input bit can also be used in as many instructions as required to achieve effective and proper control. They cannot be used in

instructions that control bit status, e.g., the OUTPUT, DIFFERENTIATION UP, and KEEP instructions.

Output Bit Usage

Output bits are used to output program execution results and can be used in any order in programming. Because outputs are refreshed only once during each cycle (i.e., once each time the program is executed), any output bit can be used in only one instruction that controls its status, including OUT, KEEP(11), DIFU(13), DIFD(14) and SFT(10). If an output bit is used in more than one such instruction, only the status determined by the last instruction will actually be output from the PC.

See 5-15-1 Shift Register – SFT(10) for an example that uses an output bit in two 'bit-control' instructions.

Word Allocation for Racks

I/O words are allocated to the CPU Rack and Expansion I/O Racks by slot position. One I/O word is allocated to each slot, as shown in the following table. Since each slot is allocated only one I/O word, a 3-slot rack uses only the first 3 words, a 5-slot rack uses only the first 5 words, and an 8-slot rack uses only the first 8 words. Words that are allocated to unused or nonexistent slots are available as work words.

← Left side of rack

Right side of a 10-slot rack →

Rack	Slot 1	Slot 2	Slot 3	Slot 4	Slot 5	Slot 6	Slot 7	Slot 8	Slot 9	Slot 10
CPU	IR 000	IR 001	IR 002	IR 003	IR 004	IR 005	IR 006	IR 007	IR 008	IR 009
1 st Expansion	IR 010	IR 011	IR 012	IR 013	IR 014	IR 015	IR 016	IR 017	IR 018	IR 019
2 nd Expansion	IR 020	IR 021	IR 022	IR 023	IR 024	IR 025	IR 026	IR 027	IR 028	IR 029
3 rd Expansion	IR 300	IR 301	IR 302	IR 303	IR 304	IR 305	IR 306	IR 307	IR 308	IR 309

Unused Words

Any words allocated to a Unit that does not use them can be used in programming as work words and bits. Units that do not used the words assigned to the slot they are mounted to include Link Units (e.g., Host Link Units, PC Link Units, SYSMAC NET Link Units, etc.), Remote I/O Master Units, Special I/O Units, Group-2 High-density I/O Units, B7A Interface Units, and Auxiliary Power Supply Units.

Allocation for Special I/O Units and Slave Racks

In most C200HX/HG/HE PCs, up to sixteen Special I/O Units may be mounted in any slot of the CPU Rack or Expansion I/O Racks. (A limited number of Special I/O Units can be installed in Remote I/O Slave Racks, too.) Each Special I/O Unit is allocated ten words based on its unit number (0 to F).

Up to ten Special I/O Units may be mounted in the C200HE-CPU□□-E and C200HG/HX-CPU3□-E/4□-E PCs. Each Unit is allocated ten words based on its unit number (0 to 9).

Unit number	I/O words	PC Restrictions
0	IR 100 to IR 109	None
1	IR 110 to IR 119	
2	IR 120 to IR 129	
3	IR 130 to IR 139	
4	IR 140 to IR 149	
5	IR 150 to IR 159	
6	IR 160 to IR 169	
7	IR 170 to IR 179	
8	IR 180 to IR 189	
9	IR 190 to IR 199	

Unit number	I/O words	PC Restrictions
Α	IR 400 to IR 409	Not available in C200HE-CPU□□-E and
В	IR 410 to IR 419	C200HG/HX-CPU3□-E/4□-E PCs.
С	IR 420 to IR 429	
D	IR 430 to IR 439	
E	IR 440 to IR 449	
F	IR 450 to IR 459	

Note I/O words that aren't allocated to Special I/O Units can be used as work words.

Up to five Slave Racks may be used, whether one or two Masters are used. IR area words are allocated to Slave Racks by the unit number on the Unit, as shown in the following tables.

Unit number	I/O words
0	IR 050 to IR 059
1	IR 060 to IR 069
2	IR 070 to IR 079
3	IR 080 to IR 089
4	IR 090 to IR 099

The C500-RT001/002-(P)V1 Remote I/O Slave Rack may be used, but it requires 20 I/O words, not 10, and therefore occupies the I/O words allocated to 2 C200H Slave Racks, both the words allocated to the unit number set on the rack and the words allocated to the following unit number. When using a C200HX/HG/HE CPU Unit, do not set the unit number on a C500 Slave Rack to 4, because there is no unit number 5. With the C500 Slave Rack, I/O words are allocated only to installed Units, from left to right, and not to slots as in the C200HX/HG/HE Racks.

Allocation for Optical I/O Units and I/O Terminals

I/O words between IR 200 and IR 231 are allocated to Optical I/O Units and I/O Terminals by unit number. The I/O word allocated to each Unit is IR 200+n, where n is the unit number set on the Unit.

Allocation for Remote I/O Master and Link Units

Remote Master I/O Units and Host Link Units do not use I/O words, and the PC Link Units use the LR area, so words allocated to the slots in which these Units are mounted are available as work words.

Bit Allocation for I/O Units

An I/O Unit may require anywhere from 8 to 16 bits, depending on the model. With most I/O Units, any bits not used for input or output are available as work bits. Transistor Output Units C200H-OD213 and C200H-OD411, as well as Triac Output Unit C200H-OA221, however, uses bit 08 for the Blown Fuse Flag. Transistor Output Unit C200H-OD214 uses bits 08 to 11 for the Alarm Flag. Bits 08 to 15 of any word allocated to these Units, therefore, cannot be used as work bits.

Bit Allocation for Interrupt Input Units

The Interrupt Input Unit uses the 8 bits of the first I/O word allocated to its slot in the CPU Rack. (An Interrupt Input Unit will operate as a normal Input Unit when installed in an Expansion I/O Rack.) The other 24 bits allocated to its slot in the CPU Rack can be used as work bits.

Allocation for Group-2 High-density I/O Units and **B7** Interface Units

Group-2 High-density I/O Units and B7A Interface Units are allocated words between IR 030 and IR 049 according to I/O number settings made on them and do not use the words allocated to the slots in which they are mounted. For 32-point Units, each Unit is allocated two words; for 64-point Units, each Unit is allocated four words. The words allocated for each I/O number are in the following tables. Any words or parts of words not used for I/O can be used as work words or bits in programming.

64-point Units

IR 330 to IR 333

IR 332 to IR 335

IR 334 to IR 337

IR 336 to IR 339

IR 338 to IR 341

Cannot be used.

I/O number I/O number Words Words IR 30 to IR 31 0 IR 30 to IR 33 1 IR 32 to IR 33 1 IR 32 to IR 35 2 IR 34 to IR 35 2 IR 34 to IR 37 3 IR 36 to IR 37 3 IR 36 to IR 39 4 4 IR 38 to IR 39 IR 38 to IR 41 5 5 IR 40 to IR 41 IR 40 to IR 43 6 IR 42 to IR 43 6 IR 42 to IR 45 7 IR 44 to IR 45 7 IR 44 to IR 47 8 IR 46 to IR 47 8 IR 46 to IR 49 9 IR 48 to IR 49 9 Cannot be used.

Α

В

С

D

Ε

F

32-point Units

IR 330 to IR 331

IR 332 to IR 333

IR 334 to IR 335

IR 336 to IR 337

IR 338 to IR 339

IR 340 to IR 341

See note.

Α

В

С

D

Е

Note Unit numbers A to F cannot be set when using the following CPU Units: C200HE-CPU32(-Z), C200HE-CPU42(-Z), C200HG-CPU33(-Z), C200HG-CPU43(-Z), C200HX-CPU34(-Z), and C200HX-CPU44(-Z). Set unit number 0 to 9 when using these CPU Units.

When setting I/O numbers on the High-density I/O Units and B7A Interface Units, be sure that the settings will not cause the same words to be allocated to more than one Unit. For example, if I/O number 0 is allocated to a 64-point Unit, I/O number 1 cannot be used for any Unit in the system.

Group-2 High-density I/O Units and B7A Interface Units are not considered Special I/O Units and do not affect the limit to the number of Special I/O Units allowed in the System, regardless of the number used.

The words allocated to Group-2 High-density I/O Units correspond to the connectors on the Units as shown in the following table.

Unit	Word	Connector/row
32-point Units	m	Row A
	m + 1	Row B
64-point Units	m	CN1, row A
	m + 1	CN1, row B
	m + 2	CN2, row A
	m + 3	CN2, row B

Note

- 1. Group-2 High-density I/O Units and B7A Interface Units cannot be mounted to Slave Racks.
- 2. Refer to the Installation Guide for limitations on the number of Special I/O Units that can be mounted to Slave Racks.

3-4 SR (Special Relay) Area

The SR area contains flags and control bits used for monitoring PC operation, accessing clock pulses, and signalling errors. SR area word addresses range from 236 through 299; bit addresses, from 23600 through 29915.

The SR areas is divided into two sections. The first section ends at SR 255 and the second section begins at SR 256. When an SR area word is used as an operand in an instruction, the operand mustn't cross over this boundary. Basic instructions that access bits in the SR Area 2 have longer execution times.

Area	Range
SR Area 1	SR 23600 to SR 25507
SR Area 2	SR 25600 to SR 29915

The following table lists the functions of SR area flags and control bits. Most of these bits are described in more detail following the table. Descriptions are in order by bit number except that Link System bits are grouped together.

Unless otherwise stated, flags are OFF until the specified condition arises, when they are turned ON. Restart bits are usually OFF, but when the user turns one ON then OFF, the specified Link Unit will be restarted. Other control bits are OFF until set by the user.

Not all SR words and bits are writeable by the user. Be sure to check the function of a bit or word before attempting to use it in programming.

Word(s)	Bit(s)	Function					
236	00 to 07	Node loop status output area for operating level 0 of SYSMAC NET Link System					
	08 to 15	Node loop status output area for operating level 1 of SYSMAC NET Link System					
237	00 to 07	Completion code output area for operating level 0 following execution of SEND(90)/RECV(98) for SYSMAC LINK/SYSMAC NET Link System or CMCR(—) for a PC Card					
	08 to 15	Completion code output area for operating level 1 following execution of SEND(90)/RECV(98) for SYSMAC LINK/SYSMAC NET Link System or CMCR(—) for a PC Card					
238 and 241	00 to 15	Data link status output area for operating level 0 of SYSMAC LINK or SYSMAC NET Link System					
242 and 245	00 to 15	Data link status output area for operating level 1 of SYSMAC LINK or SYSMAC NET Link System					
246	00 to 15	Not used					
247 and 248	00 to 07	PC Link Unit Run Flags for Units 16 through 31 or data link status for operating level 1					
	08 to 15	PC Link Unit Error Flags for Units 16 through 31 or data link status for operating level 1					
249 and 250	00 to 07	PC Link Unit Run Flags for Units 00 through 15 or data link status for operating level 0					
	08 to 15	PC Link Unit Error Flags for Units 00 through 15 or data link status for operating level 0					
251	00	Remote I/O Error Read Bit					
Writeable	01 to 02	Not used					
	03	Remote I/O Error Flag					
	04 to 06	Slave Rack number and unit number of Remote I/O Unit, Optical I/O Unit, or I/O Terminal with error					
	07	Not used					
	08 to 15	Master's unit number and word allocated to Remote I/O Unit, Optical I/O Unit, or I/O Terminal with error (Hexadecimal)					

Word(s)	Bit(s)	Function							
252	00	SEND(90)/RECV(98) Error Flag for operating level 0 of SYSMAC LINK or SYSMAC NET Link System or CMCR(—) Error Flag for PC Card							
	01	SEND(90)/RECV(98) Enable Flag for operating level 0 of SYSMAC LINK or SYSMAC NET Link System or CMCR(—) Enable Flag for PC Card							
	02	Operating Level 0 Data Link Operating Flag							
	03	SEND(90)/RECV(98) Error Flag for operating level 1 of SYSMAC LINK or SYSMAC NET Link System or CMCR(—) Error Flag for PC Card							
	04	SEND(90)/RECV(98) Enable Flag for operating level 1 of SYSMAC LINK or SYSMAC NET Link System or CMCR(—) Enable Flag for PC Card							
	05	Operating Level 1 Data Link Operating Flag							
	06	Rack-mounting Host Link Unit Level 1 Communications Error Flag							
	07	Rack-mounting Host Link Unit Level 1 Restart Bit							
	08	Peripheral Port Restart Bit							
	09	RS-232C Port Restart Bit							
	10	PC Setup Clear Bit							
	11	Forced Status Hold Bit							
	12	Data Retention Control Bit							
	13	Rack-mounting Host Link Unit Level 0 Restart Bit							
	14	Not used.							
	15	Output OFF Bit							
253	00 to 07	FAL number output area (see error information provided elsewhere)							
	08	Low Battery Flag							
	09	Cycle Time Error Flag							
	10	I/O Verification Error Flag							
	11	Rack-mounting Host Link Unit Level 0 Communications Error Flag							
	12	Remote I/O Error Flag							
	13	Always ON Flag							
	14	Always OFF Flag							
	15	First Cycle Flag							
254	00	1-minute clock pulse bit							
	01	0.02-second clock pulse bit							
	02	Negative (N) Flag							
	03	MTR Execution Flag							
	04	Overflow Flag (for signed binary calculations)							
	05	Underflow Flag (for signed binary calculations)							
	06	Differential Monitor End Flag							
	07	Step Flag							
	08	HKY Execution Flag							
	09	7SEG Execution Flag							
	10	DSW Execution Flag							
	11	Interrupt Input Unit Error Flag							
	12	Reserved by system (not accessible by user)							
	13	Interrupt Program Error Flag							
	14	Group-2 Error Flag							
	15	Special Unit Error Flag (includes Special I/O, PC Link, Host Link, Remote I/O Master Units)							

Word(s)	Bit(s)		Function								
255	00	0.1-second clock pulse bit									
	01	0.2-second clock pulse bit									
	02	1.0-second clock pulse bit									
	03	Instruction Execution Error (ER) Flag	These flags are turned OFF when the END(01)								
	04	Carry (CY) Flag	instruction is executed, so their status can't be								
	05	Greater Than (GR) Flag	monitored from a Programming Console.								
	06	Equals (EQ) Flag	Refer to Appendix C for a table showing which instructions affect these flags.								
	07	Less Than (LE) Flag	mondono direct meser hage.								
	08 to 15	Reserved by system (used for TR bits)									
256 to 261	00 to 15	Reserved by system									
262	00 to 15	Longest interrupt subroutine (action) ex	xecution time (0.1-ms units)								
263	00 to 15	Number of interrupt subroutine (action) (Bit 15 is the Interrupt Flag)	with longest execution time. (8000 to 8255)								
264	00 to 03	RS-232C Port Error Code									
		0: No error	1: Parity error								
		2: Framing error	3: Overrun error								
		4: FCS error									
	04	RS-232C Port Communications Error									
	05	RS-232C Port Send Ready Flag									
	06	RS-232C Port Reception Completed Flag									
	07	RS-232C Port Reception Overflow Flag									
	08 to 11	Peripheral Port Error Code in General I/O Mode									
		0: No error	1: Parity error								
		2: Framing error	error 3: Overrun error								
	12	Peripheral Port Communications Error in General I/O Mode									
	13	Peripheral Port Send Ready Flag in in General I/O Mode									
	14	Peripheral Port Reception Completed Flag in General I/O Mode									
	15	Peripheral Port Reception Overflow Flag in General I/O Mode									
265	00 to 15	NT Link (1:N) Mode Bits 00 to 07: Communicating Bits 08 to 15: Registering PT RS-232C Mode	with PT Flags for Units 0 to 7 Priority Flags for Units 0 to 7								
		Bits 00 to 15: RS-232C Port F	Reception Counter								
266	00 to 15	Peripheral Reception Counter in RS-23									
267	00 to 04	Reserved by system (not accessible by user)									
	05	Host Link Level 0 Send Ready Flag	•								
	06 to 12	Reserved by system (not accessible by	y user)								
	13	Host Link Level 1 Send Ready Flag	·								
	14 to 15	Reserved by system (not accessible by user)									
268	00 to 15	Communications Board Error Informati	•								
269	00 to 07	Memory Cassette Contents 00: Noth	ning; 01: UM; 02: IOM; 03: HIS								
	08 to 10	Memory Cassette Capacity									
		0: 0 KW (no cassette); 2: 4 or 8 KW; 3:									
	11 to 13	Reserved by system (not accessible by	•								
	14	·	or EPROM Memory Cassette Mounted Flag								
	15	Memory Cassette Flag									

Word(s)	Bit(s)		Function							
270	00	Save UM to Cassette Bit	Data transferred when the Bit is turned ON in PROGRAM mode. Bit will automatically turn OFF.							
	01	Load UM from Cassette Bit	A non-fatal error will occur if these bits are turned ON in RUN or MONITOR modes.							
	02	Compare UM to Cassette Bit								
	03	Comparison Results 0: Contents identical; 1: Contents differ or comparison not possible								
	04 to 10	Reserved by system (not accessible by user)								
	11	Transfer Error Flag: Transferring SYSMAC NET data link table on UM during active data link.	Data will not be transferred from UM to the Memory Cassette if an error occurs (except for Board Checksum Error). Detailed information on checksum							
	12	Transfer Error Flag: Not PROGRAM mode	errors occurring in the Memory Cassette will not be output to SR 272 because the information is not							
	13	Transfer Error Flag: Read Only	needed. Repeat the transmission if SR 27015 is ON.							
	14	Transfer Error Flag: Insufficient Capacity or No UM								
	15	Transfer Error Flag: Board Checksum Error								
271	00 to 07	Ladder program size stored in Memory Cassette								
		Ladder-only File: 04: 4 KW; 08: 8 KW; 12: 12 KW; (32: 32 KW)								
		00: No ladder program or a file other than a ladder program has been stored.								
	08 to 15	Ladder program size and type in CPU Unit (Specifications are the same as for bits 00 to 07.)								
272	00 to 10	Reserved by system (not accessible by	y user)							
	11	Memory Error Flag: PC Setup Checksum Error								
	12	Memory Error Flag: Ladder Checksum	Error							
	13	Memory Error Flag: Instruction Change	e Vector Area Checksum Error							
	14	Memory Error Flag: Memory Cassette	Online Disconnection							
	15	Memory Error Flag: Autoboot Error								
273	00	Save IOM to Cassette Bit	Data transferred to Memory Cassette when Bit is turned ON in PROGRAM mode. Bit will automatically							
	01	Load IOM from Cassette Bit	turn OFF. An error will be produced if turned ON in any other mode.							
	02	Set this bit to 0.								
	03 to 07	Reserved by system (not accessible by	•							
	08 to 11		ne Memory Cassette contains IOM data.							
	12	Transfer Error Flag: Not PROGRAM mode	Data will not be transferred from IOM to the Memory Cassette if an error occurs (except for Read Only							
	13	Transfer Error Flag: Read Only	Error).							
	14	Transfer Error Flag: Insufficient Capacity or No IOM								
	15	Always 0.								

Word(s)	Bit(s)	Function							
274	00	Special I/O Unit #0 Restart Flag	These flags will turn ON during restart processing.						
	01	Special I/O Unit #1 Restart Flag	These flags will not turn ON for Units on Slave						
	02	Special I/O Unit #2 Restart Flag	Racks.						
	03	Special I/O Unit #3 Restart Flag							
	04	Special I/O Unit #4 Restart Flag							
	05	Special I/O Unit #5 Restart Flag							
	06	Special I/O Unit #6 Restart Flag							
	07	Special I/O Unit #7 Restart Flag							
	08	Special I/O Unit #8 Restart Flag							
	09	Special I/O Unit #9 Restart Flag							
	10	Special I/O Unit #A Restart Flag							
	11	Special I/O Unit #B Restart Flag							
	12	Special I/O Unit #C Restart Flag							
	13	Special I/O Unit #D Restart Flag							
	14	Special I/O Unit #E Restart Flag							
	15	Special I/O Unit #F Restart Flag							
275	00	PC Setup Error (DM 6600 to DM 6605)							
	01	PC Setup Error (DM 6613 to DM 6623)							
	02	PC Setup Error (DM 6645 to DM 6655)							
	03	Reserved by system (not accessible by user)							
	04	Changing RS-232C Setup Flag							
	05	Reserved by system (not accessible by user)							
	06 to 07	Reserved by system (not accessible by user)							
	08 to 15	Reserved by system (not accessible by user)							
276	00 to 07	Minutes (00 to 59)	Indicates the current time in BCD.						
	08 to 15	Hours (00 to 23)							
277 to 279	00 to 15	Used for keyboard mapping. See page	414.						
280	00 to 15	Group-2 High-density I/O Unit Error Fla (AR 0205 to AR 0214 also function as							
281	00 to 15	Special I/O Unit Restart Bits for Units 0 (Units 0 to 9 can also be restarted with	to F Special I/O Unit Restart Bits AR 0100 to AR 0109.)						
		and OFF, or turn OFF the power and	•						
		Follow the same procedure as above	for starting PC Link Units.						
282	00 to 15	Special I/O Unit Error Flags for Units 0 (AR 0000 to AR 0009 also function as							
283 to 286	00 to 15	Communications Board monitoring are	a						
287 to 288	00 to 15	Communications Board interrupt data a	area						
289	00 to 07	Communications Board general monitor	-						
	08	Communications Board Port A Instruction	ion Execution Flag						
	09 to 10	Used by Communications Board Port A							
	11	Communications Board Port A Instruction							
	12	Communications Board Port B Instruction	•						
	13 to 14	Used by Communications Board Port E							
	15	Communications Board Port B Instructi	ion Abort Bit						
290 to 293	00 to 15	Macro Area inputs.							
294 to 297	00 to 15	Macro Area outputs.							
298 to 299	00 to 15	Reserved by system (not accessible by	/ user)						

3-4-1 SYSMAC NET/SYSMAC LINK System

Loop Status

SR 236 provides the local node loop status for SYSMAC NET Systems, as shown below.

		Bit in SR 236														
Level 0	07	06	6 05		05		6 05		05		05		03	02	01	00
Level 1	15	14	13	09	08											
Status/ Meaning	1	1	Central Power Supply 0: Connected 1: Not connected	1	Loop Status 11: Normal loop 10: Downstream 01: Upstream bad 00: Loop error		Reception Status 0: Reception enabled 1: Reception disabled	1								

Completion Codes

SR 23700 to SR23707 provide the SEND/RECV completion code for operating level 0 and SR 23708 to SR 23215 provide the SEND/RECV completion code for operating level 1. The completion codes are as given in the following tables.

SYSMAC LINK

Code	Item	Meaning
00	Normal end	Processing ended normally.
01	Parameter error	Parameters for network communication instruction is not within acceptable ranges.
02	Unable to send	Unit reset during command processing or local node in not in network.
03	Destination not in network	Destination node is not in network.
04	Busy error	The destination node is processing data and cannot receive the command.
05	Response timeout	The response monitoring time was exceeded.
06	Response error	There was an error in the response received from the destination node.
07	Communications controller error	An error occurred in the communications controller.
08	Setting error	There is an error in the node address settings.
09	PC error	An error occurred in the CPU Unit of the destination node.

SYSMAC NET

Code	Item	Meaning
00	Normal end	Processing ended normally.
01	Parameter error	Parameters for network communication instruction is not within acceptable ranges.
02	Routing error	There is a mistake in the routing tables for connection to a remote network.
03	Busy error	The destination node is processing data and cannot receive the command.
04	Send error (token lost)	The token was not received from the Line Server.
05	Loop error	An error occurred in the communications loop.
06	No response	The destination node does not exist or the response monitoring time was exceeded.
07	Response error	There is an error in the response format.

Data Link Status Flags

SR 238 to SR 245 contain the data link status for SYSMAC LINK/SYSMAC NET Systems. The data structure depends on the system used to create the data link.

SYSMAC LINK

Operating	Operating	Bit							
level 0	level 1	12 to 15	11 to 08	04 to 07	00 to 03				
SR 238	SR 242	Node 4	Node 3	Node 2	Node 1				
SR 239	SR 243	Node 8	Node 7	Node 6	Node 5				
SR 240	SR 244	Node 12	Node 11	Node 10	Node 9				
SR 241	SR 245	Node 16	Node 15	Node 14	Node 13				

Leftmost bit

Rightmost bit

1: Data link	1: Communica-	1: PC CPU Unit	1: PC RUN status
operating	tions error	error	

SYSMAC NET

Operating level 0	Operating	· · · · · · · · · · · · · · · · · · ·															
	level 1	15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
SR 238	SR 242	8	7	6	5	4	3	2	1	8	7	6	5	4	3	2	1
SR 239	SR 243	16	15	14	13	12	11	10	9	16	15	14	13	12	11	10	9
SR 240	SR 244	24	23	22	21	20	19	18	17	24	23	22	21	20	19	18	17
SR 241	SR 245	32	31	30	29	28	27	26	25	32	31	30	29	28	27	26	25

1: PC CPU Unit error

1: PC RUN status

3-4-2 Remote I/O Systems

SR 25312 turns ON to indicate an error has occurred in Remote I/O Systems. The ALM/ERR indicator will flash, but PC operation will continue. SR 251 contains information on the source and type of error and AR 0014 and AR 0015 contain information on the SYSMAC LINK status. The function of each bit is described below. Refer to *Optical* and *Wired Remote I/O System Manuals* for details.

SR 25100 - Error Check Bit

If there are errors in more than one Remote I/O Unit, word SR 251 will contain error information for only the first one. Data for the remaining Units will be stored in memory and can be accessed by turning the Error Check bit ON and OFF. Be sure to record data for the first error, which will be cleared when data for the next error is displayed.

SR 25101 and SR 25102

Not used.

SR 25103

Remote I/O Error Flag: Bit 03 turns ON when an error has occurred in a Remote I/O Unit.

SR 25104 through SR 25115

The content of bits 04 to 06 is a 3-digit binary number (04: 2^0 , 05: 2^1 , 06: 2^2) and the content of bits 08 to 15 is a 2-digit hexadecimal number (08 to 11: 16^0 , 12 to 15: 16^1).

If the content of bits 12 through 15 is B, an error has occurred in a Remote I/O Master or Slave Unit, and the content of bits 08 through 11 will indicate the unit number, either 0 or 1, of the Master involved. In this case, bits 04 to 06 contain the unit number of the Slave Rack involved.

If the content of bits 12 through 15 is a number from 0 to 31, an error has occurred in an Optical I/O Unit or I/O Terminal. The number is the unit number of the Optical I/O Unit or I/O Terminal involved, and bit 04 will be ON if the Unit is assigned leftmost word bits (08 through 15), and OFF if it is assigned rightmost word bits (00 through 07).

3-4-3 Link System Flags and Control Bits

Use of the following SR bits depends on the configuration of any Link Systems to which your PC belongs. These flags and control bits are used when Link Units, such as PC Link Units, Remote I/O Units, or Host Link Units, are mounted to the PC Racks or to the CPU Unit. For additional information, consult the System Manual for the particular Units involved.

The following bits can be employed as work bits when the PC does not belong to the Link System associated with them.

Host Link Systems

Both Error flags and Restart bits are provided for Host Link Systems. Error flags turn ON to indicate errors in Host Link Units. Restart bits are turned ON and then OFF to restart a Host Link Unit. SR bits used with Host Link Systems are summarized in the following table. Rack-mounting Host Link Unit Restart bits are not effective for the Multilevel Rack-mounting Host Link Units. Refer to the Host Link System Manual for details.

Bit	Flag
25206	Rack-mounting Host Link Unit Level 1 Error Flag
25207	Rack-mounting Host Link Unit Level 1 Restart Bit
25213	Rack-mounting Host Link Unit Level 0 Restart Bit
25311	Rack-mounting Host Link Unit Level 0 Error Flag

PC Link Systems

PC Link Unit Error and Run Flags

When the PC belongs to a PC Link System, words 247 through 250 are used to monitor the operating status of all PC Link Units connected to the PC Link System. This includes a maximum of 32 PC Link Units. If the PC is in a Multilevel PC Link System, half of the PC Link Units will be in a PC Link Subsystem in operating level 0; the other half, in a Subsystem in operating level 1. The actual bit assignments depend on whether the PC is in a Single-level PC Link System or a Multilevel PC Link System. Refer to the *PC Link System Manual* for details. Error and Run Flag bit assignments are described below.

Bits 00 through 07 of each word are the Run flags, which are ON when the PC Link Unit is in RUN mode. Bits 08 through 15 are the Error flags, which are ON when an error has occurred in the PC Link Unit. The following table shows bit assignments for Single-level and Multi-level PC Link Systems.

Single-level PC Link Systems

Flag type	Bit no.	SR 247	SR 248	SR 249	SR 250
Run flags	00	Unit #24	Unit #16	Unit #8	Unit #0
	01	Unit #25	Unit #17	Unit #9	Unit #1
	02	Unit #26	Unit #18	Unit #10	Unit #2
	03	Unit #27	Unit #19	Unit #11	Unit #3
	04	Unit #28	Unit #20	Unit #12	Unit #4
	05	Unit #29	Unit #21	Unit #13	Unit #5
	06	Unit #30	Unit #22	Unit #14	Unit #6
	07	Unit #31	Unit #23	Unit #15	Unit #7
Error flags	08	Unit #24	Unit #16	Unit #8	Unit #0
	09	Unit #25	Unit #17	Unit #9	Unit #1
	10	Unit #26	Unit #18	Unit #10	Unit #2
	11	Unit #27	Unit #19	Unit #11	Unit #3
	12	Unit #28	Unit #20	Unit #12	Unit #4
	13	Unit #29	Unit #21	Unit #13	Unit #5
	14	Unit #30	Unit #22	Unit #14	Unit #6
	15	Unit #31	Unit #23	Unit #15	Unit #7

Multilevel PC Link Systems

Flag type	Bit no.	SR 247	SR 248	SR 249	SR 250
Run flags	00	Unit #8, level 1	Unit #0, level 1	Unit #8, level 0	Unit #0, level 0
	01	Unit #9, level 1	Unit #1, level 1	Unit #9, level 0	Unit #1, level 0
	02	Unit #10, level 1	Unit #2, level 1	Unit #10, level 0	Unit #2, level 0
	03	Unit #11, level 1	Unit #3, level 1	Unit #11, level 0	Unit #3, level 0
	04	Unit #12, level 1	Unit #4, level 1	Unit #12, level 0	Unit #4, level 0
	05	Unit #13, level 1	Unit #5, level 1	Unit #13, level 0	Unit #5, level 0
	06	Unit #14, level 1	Unit #6, level 1	Unit #14, level 0	Unit #6, level 0
	07	Unit #15, level 1	Unit #7, level 1	Unit #15, level 0	Unit #7, level 0
Error flags	08	Unit #8, level 1	Unit #0, level 1	Unit #8, level 0	Unit #0, level 0
	09	Unit #9, level 1	Unit #1, level 1	Unit #9, level 0	Unit #1, level 0
	10	Unit #10, level 1	Unit #2, level 1	Unit #10, level 0	Unit #2, level 0
	11	Unit #11, level 1	Unit #3, level 1	Unit #11, level 0	Unit #3, level 0
	12	Unit #12, level 1	Unit #4, level 1	Unit #12, level 0	Unit #4, level 0
	13	Unit #13, level 1	Unit #5, level 1	Unit #13, level 0	Unit #5, level 0
	14	Unit #14, level 1	Unit #6, level 1	Unit #14, level 0	Unit #6, level 0
	15	Unit #15, level 1	Unit #7, level 1	Unit #15, level 0	Unit #7, level 0

Application Example

If the PC is in a Multilevel PC Link System and the content of word 248 is 02FF, then PC Link Units #0 through #7 of in the PC Link Subsystem assigned operating level 1 would be in RUN mode, and PC Link Unit #1 in the same Subsystem would have an error. The hexadecimal digits and corresponding binary bits of word 248 would be as shown below.

Bit no.	15			00
Binary	0000	0010	1111	1111
Hex	0	2	F	F

3-4-4 Forced Status Hold Bit

SR 25211 determines whether or not the status of bits that have been force-set or force-reset is maintained when switching between PROGRAM and MON-ITOR mode to start or stop operation. If SR 25211 is ON, bit status will be maintained; if SR 25211 is OFF, all bits will return to default status when operation is started or stopped. The Forced Status Hold Bit is only effective when enabled in the PC Setup.

The status of SR 25211 in not affected by a power interruption unless the I/O table is registered; in that case, SR 25211 will go OFF.

SR 25211 is not effective when switching to RUN mode.

SR 25211 should be manipulated from a Peripheral Device, e.g., a Programming Console or SSS.

Maintaining Status during Startup

The status of SR 25211 and thus the status of force-set and force-reset bits can be maintained when power is turned OFF and ON by enabling the Forced Status Hold Bit in the PC Setup. If the Forced Status Hold Bit is enabled, the status of SR 25211 will be preserved when power is turned OFF and ON. If this is done and SR 25211 is ON, then the status of force-set and force-reset bits will also be preserved, as shown in the following table.

Status before shutdown	Status at next startup		
SR 25211	SR 25211	Force-set/reset bits	
ON	ON	Status maintained	
OFF	OFF	Reset	

Note Refer to 3-6-4 PC Setup for details on enabling the Forced Status Hold Bit.

3-4-5 I/O Status Hold Bit

SR 25212 determines whether or not the status of IR and LR area bits is maintained when operation is started or stopped. If SR 25212 is ON, bit status will be maintained; if SR 25212 is OFF, all IR and LR area bits will be reset. The I/O Status Hold Bit is effective only if enabled in the PC Setup.

The status of SR 25212 in not affected by a power interruption unless the I/O table is registered; in that case, SR 25212 will go OFF.

SR 25212 should be manipulated from a Peripheral Device, e.g., a Programming Console or SSS.

Maintaining Status during Startup

The status of SR 25212 and thus the status of IR and LR area bits can be maintained when power is turned OFF and ON by enabling the I/O Status Hold Bit in the PC Setup. If the I/O Status Hold Bit is enabled, the status of SR 25212 will be preserved when power is turned OFF and ON. If this is done and SR 25212 is ON, then the status of IR and LR area bits will also be preserved, as shown in the following table.

Status before shutdown	Status at next startup		
SR 25212	SR 25212	IR and LR bits	
ON	ON	Status maintained	
OFF	OFF	Reset	

Note Refer to 3-6-4 PC Setup for details on enabling the I/O Status Hold Bit.

3-4-6 Output OFF Bit

SR bit 25215 is turned ON to turn OFF all outputs from the PC. The OUT INHIBIT indicator on the front panel of the CPU Unit will light. When the Output OFF Bit is OFF, all output bits will be refreshed in the usual way.

The status of the Output OFF Bit is maintained for power interruptions or when PC operation is stopped, unless the I/O table has been registered, or the I/O table has been registered and either the Forced Status Hold Bit or the I/O Status Hold Bit has not been enabled in the PC Setup.

3-4-7 FAL (Failure Alarm) Area

A 2-digit BCD FAL code is output to bits 25300 to 25307 when the FAL or FALS instruction is executed. These codes are user defined for use in error diagnosis, although the PC also outputs FAL codes to these bits, such as one caused by battery voltage drop.

This area can be reset by executing the FAL instruction with an operand of 00 or by performing a Failure Read Operation from the Programming Console.

3-4-8 Low Battery Flag

SR bit 25308 turns ON if the voltage of the CPU Unit's backup battery drops. The ALM/ERR indicator on the front of the CPU Unit will also flash.

This bit can be programmed to activate an external warning for a low battery voltage.

The operation of the battery alarm can be disabled in the PC Setup if desired. Refer to 3-6-4 PC Setup for details.

3-4-9 Cycle Time Error Flag

SR bit 25309 turns ON if the cycle time exceeds 100 ms. The ALM/ERR indicator on the front of the CPU Unit will also flash. Program execution will not stop, however, unless the maximum time limit set for the watchdog timer is exceeded. Timing may become inaccurate after the cycle time exceeds 100 ms.

3-4-10 I/O Verification Error Flag

SR bit 25310 turns ON when the Units mounted in the system disagree with the I/O table registered in the CPU Unit. The ALM/ERR indicator on the front of the CPU Unit will also flash, but PC operation will continue.

To ensure proper operation, PC operation should be stopped, Units checked, and the I/O table corrected whenever this flag goes ON.

3-4-11 First Cycle Flag


SR bit 25315 turns ON when PC operation begins and then turns OFF after one cycle of the program. The First Cycle Flag is useful in initializing counter values and other operations. An example of this is provided in *5-14 Timer and Counter Instructions*.


3-4-12 Clock Pulse Bits

Five clock pulses are available to control program timing. Each clock pulse bit is ON for the first half of the rated pulse time, then OFF for the second half. In other words, each clock pulse has a duty factor of 50%.

These clock pulse bits are often used with counter instructions to create timers. Refer to *5-14 Timer and Counter Instructions* for an example of this.

Pulse width	1 min	0.02 s	0.1 s	0.2 s	1.0 s
Bit	25400	25401	25500	25501	25502





tively, the CPU Unit may not be able to accurately read the pulses

if program execution time is too

long.

3-4-13 Step Flag

SR bit 25407 turns ON for one cycle when step execution is started with the STEP(08) instruction.

3-4-14 Group-2 Error Flag

SR bit 25414 turns ON for any of the following errors for Group-2 High-density I/O Units and B7A Interface Units: the same I/O number set twice, the same words allocated to more than one Unit, refresh errors. If one of these errors occurs, the Unit will stop operation and the ALARM indicator will flash, but the overall PC will continue operation.

When the Group-2 Error Flag is ON, the number of the Unit with the error will be provided in AR 0205 to AR 0214. If the Unit cannot be started properly even though the I/O number is set correctly and the Unit is installed properly, a fuse may be blown or the Unit may contain a hardware failure. If this should occur, replace the Unit with a spare and try to start the system again.

There is also an error flag for High-density I/O Units and B7A Interface Units in the AR area, AR 0215.

3-4-15 Special Unit Error Flag

SR bit 25415 turns ON to indicate errors in the following Units: Special I/O, PC Link, Host Link, and Remote I/O Master Units. SR bit 25415 will turn ON for any of the following errors.

- When more than one Special I/O Unit is set to the same unit number.
- When an error occurs in refreshing data between a Special I/O Unit and the PC's CPU Unit.
- When an error occurs between a Host Link Unit and the PC's CPU Unit.
- When an error occurs in a Remote I/O Master Unit.

Although the PC will continue operation if SR 25415 turns ON, the Units causing the error will stop operation and the ALM indicator will flash. Check the status of AR 0000 to AR 0015 to obtain the unit numbers of the Units for which the error occurred and investigate the cause of the error.

Unit operation can be restarted by using the Restart Bits (AR 0100 to AR 0115, SR 25207, and SR 25213), but will not be effective if the same unit number is set for more than one Special I/O Unit. Turn OFF the power supply, correct the unit number settings, and turn ON the power supply again to restart.

SR 25415 will not turn OFF even if AR 0100 to AR 0115 (Restart Bits) are turned ON. It can be turned OFF by reading errors from a Programming Device or by executing FAL(06) 00 from the ladder program.

3-4-16 Instruction Execution Error Flag, ER

SR bit 25503 turns ON if an attempt is made to execute an instruction with incorrect operand data. Common causes of an instruction error are non-BCD operand data when BCD data is required, or an indirectly addressed DM word that is non-existent. When the ER Flag is ON, the current instruction will not be executed.

3-4-17 Arithmetic Flags

The following flags are used in data shifting, arithmetic calculation, and comparison instructions. They are generally referred to only by their two-letter abbreviations.

Note These flags are all reset when the END(01) instruction is executed, and therefore cannot be monitored from a programming device.

Refer to 5-15 Data Shifting, 5-17 Data Comparison, 5-19 BCD Calculations, and 5-20 Binary Calculations for details.

Negative Flag, N SR bit 25402 turns ON when the result of a calculation is negative.

Overflow Flag, OF SR bit 25404 turns ON when the result of a binary addition or subtraction ex-

ceeds 7FFF or 7FFFFFF.

Underflow Flag, UF SR bit 25405 turns ON when the result of a signed binary addition or subtraction

exceeds 8000 or 80000000.

Carry Flag, CY SR bit 25504 turns ON when there is a carry in the result of an arithmetic opera-

tion or when a rotate or shift instruction moves a "1" into CY. The content of CY is also used in some arithmetic operations, e.g., it is added or subtracted along with other operands. This flag can be set and cleared from the program using the

Section 3-4

Set Carry and Clear Carry instructions.

Greater Than Flag, GR SR bit 25505 turns ON when the result of a comparison shows the first of two

operands to be greater than the second.

Equal Flag, EQ SR bit 25506 turns ON when the result of a comparison shows two operands to

be equal or when the result of an arithmetic operation is zero.

Less Than Flag, LESR bit 25507 turns ON when the result of a comparison shows the first of two

operands to be less than the second.

Note The four arithmetic flags are turned OFF when END(01) is executed.

3-4-18 Interrupt Subroutine Areas

The following areas are used in subroutine interrupt processing.

Interrupt Subroutine
Maximum Processing Time
Area

SR bits 26200 to 26215 are used to set the maximum processing time of the interrupt subroutine. Processing times are determined to within 0.1 ms increments.

Maximum Processing Time Interrupt Subroutine Number Area SR bits 26300 to 26315 contain the maximum processing time interrupt subrou-

tine number. Bit 15 will be ON if there is an interruption.

3-4-19 RS-232C Port Communications Areas

RS-232C Port Error Code SR bits 26400 to 26403 set when there is a RS-232C port error.

Error code	Error type	Error conditions	Valid modes
0	No error		All modes
1	Parity error	When data received differs from positive/negative parity setting.	All modes
2	Framing error	When step bit cannot be detected.	All modes
3	Overrun error	When data is not properly received.	All modes
4	Timeout error	When a timeout occurs for two PCs linked one-to-one.	1:1 PC Link slave or 1:1 PC Link master

RS-232C Port Communication Error Bit SR bit 26404 turns ON when there is a RS-232C port communication error.

RS-232C Port Send Ready Flag

SR bit 26405 turns ON when the PC is ready to transmit data.

RS-232C Port Reception Completed Flag

SR bit 26406 turns ON when the PC has completed reading data from a RS-232C device.

RS-232C Port Reception

OD 1:1 00407 (

Overflow Flag

SR bit 26407 turns ON when data overflow occurs following the reception of data.

RS-232C Reception Counter

SR 26500 to SR 26515 contains the number of RS-232C port receptions in General I/O Mode

eral I/O Mode.

Host Link Level 0 Send Ready Flag

SR bit 26705 turns ON when the PC is ready to transmit to the Host Link Unit.

Host Link Level 1 Send Ready Flag

SR bit 26713 turns ON when the PC is ready to transmit to the Host Link.

3-4-20 Peripheral Port Communications Areas

Peripheral Port Error Code SR bits 26408 to 26411 are set when there is a peripheral port error in the Gener-

al I/O Mode.

Error code	Error type	Error conditions	Valid modes
0	No error		All modes
1	Parity error	When data received differs from positive/negative parity setting.	All modes
2	Framing error	When step bit cannot be detected.	All modes
3	Overrun error	When data is not properly received.	All modes
4	Timeout error	When a timeout occurs for two PCs linked one-to-one.	1:1 PC Link slave or 1:1 PC Link master

Peripheral Port

Communication Error Bit

SR bit 26412 turns ON when there is a peripheral port communication error (effective in General I/O Mode).

Peripheral Port Send Ready Flag

SR bit 26413 turns ON when the PC is ready to transmit data in General I/O Mode.

Peripheral Port Reception Completed Flag

SR bit 26414 turns ON when the PC has completed reading data from a peripheral device. Effective in General I/O Mode.

Peripheral Port Reception Overflow Flag

SR bit 26415 turns ON when data overflow occurs following the reception of data. Effective in General I/O Mode.

Peripheral Reception Counter

SR 26600 to SR 26615 contains the number of peripheral port receptions in General I/O Mode (BCD).

Host Link Level 0 Send Ready Flag

SR bit 26705 turns ON when the PC is ready to transmit to the Host Link Unit.

Host Link Level 1 Receive Ready Flag

SR bit 26713 turns ON when the PC is ready to receive data from the Host Link.

3-4-21 Memory Cassette Areas

Memory Cassette Contents

SR 26900 to SR 26907 indicate the type of memory used for the Memory Cassette.

Memory Type	Code
Nothing	00
UM	01
IOM	02
HIS	03

Memory Cassette Capacity

SR 26908 to SR 26910 indicate the memory capacity of the Memory Cassette.

Capacity	Code
0 KW (no board mounted)	0
4 KW/8 KW	2
16 KW	3
32 KW	4

EEPROM/EPROM Memory Cassette Mounted Flag

SR bit 26914 turns ON when EEPROM Memory Cassette is protected or EPROM Memory Cassette is mounted.

Memory Cassette Flag SR bit 26915 turns ON when a Memory Cassette is mounted.

SR bit 27000 turns ON when UM data is read to a Memory Cassette in Program Save UM to Cassette Flag

Mode. Bit will automatically turn OFF. An error will be produced if turned ON in

any other mode.

Load UM from Cassette

Flag

SR bit 27001 turns ON when data is loaded into UM from a Memory Cassette in Program Mode. Bit will automatically turn OFF. An error will be produced if

turned ON in any other mode.

Collation (Between DM and

Memory Cassette)

SR bit 27002 turns ON when data has been compared between DM and a Memory Cassette. SR bit 27003 is turned OFF if the data in the Memory Cas-

sette matches and it is turned ON if the data does not match.

3-4-22 Data Transfer Error Bits

Data will not be transferred from UM to the Memory Cassette if an error occurs (except for Board Checksum Error). Detailed information on checksum errors occurring in the Memory Cassette will not be output to SR 272 because the information is not needed. Repeat the transmission if SR 27015 is ON.

Transfer Error Flag: **Active Data Link**

SR bit 27011 turns ON when an attempt is made to transfer the UM used for the

SYSMAC NET data link table while the data link is active.

Transfer Error Flag: **Not PROGRAM Mode** SR bit 27012 turns ON when the PC is not in Program Mode and data transfer is

attempted.

Transfer Error Flag:

Read Only

SR bit 27013 turns ON when the PC is in Read-only Mode and data transfer is

attempted.

Transfer Error Flag: **Insufficient Capacity or No**

UM

SR bit 27014 turns ON when data transfer is attempted and available UM is insufficient.

Transfer Error Flag: Board **Checksum Error**

SR bit 27015 turns ON when data transfer is attempted and a Board Checksum error occurs.

3-4-23 Ladder Diagram Memory Areas

Memory Cassette Ladder Diagram Size Area

SR 27100 to SR 27107 indicate the amount of ladder program stored in a Memory Cassette. Ladder-only Files:

04: 4 KW; 08: 8 KW; 12: 12 KW; ... (32: 32 KW)

00:Memory Cassette contents not UM or there is no file.

CPU Unit Ladder Diagram Size and Type

SR 27108 to SR 27115 indicate the CPU Unit's ladder program size and type. Specifications are the same as for bits 00 to 07.

3-4-24 Memory Error Flags

Memory Error Flag: PC Setup Érror

SR bit 27211 turns ON when a PC Setup Checksum error occurs.

Memory Error Flag: Ladder **Checksum Error**

SR bit 27212 turns ON when a Ladder Checksum error occurs.

Memory Error Flag: Instruction Change Error SR bit 27213 turns ON when an instruction change vector area error occurs.

Memory Error Flag: Memory Cassette Disconnect Error

SR bit 27214 turns ON when a Memory Cassette is connected or disconnected during operations.

Memory Error Flag: Autoboot Error

SR bit 27215 turns ON when an autoboot error occurs.

3-4-25 Data Save Flags

Data transferred to Memory Cassette when Bit is turned ON in PROGRAM mode. Bit will automatically turn OFF. An error will be produced if turned ON in

any other mode.

Save IOM to Cassette Bit SR bit 27300 turns ON when IOM is saved to a Memory Cassette.

Load IOM from Cassette Bit SR bit 27301 turns ON when loading to IOM from a Memory Cassette.

3-4-26 Transfer Error Flags

Data will not be transferred from IOM to the Memory Cassette if an error occurs

(except for Read Only Error).

Transfer Error Flag: Not PROGRAM mode

SR bit 27312 turns ON when attempting to transfer data in other than Program

Mode.

Transfer Error Flag SR bit 27313 turns ON when attempting to transfer data in Read-only Mode.

Transfer Error Flag SR bit 27314 turns ON when attempting to transfer data and IOM capacity is in-

sufficient.

3-4-27 PC Setup Error Flags

PC Setup Startup Error SR bit 27500 turns ON when a PC Setup Startup error occurs (DM6600 to

DM6605).

PC Setup RUN Error SR bit 27501 turns ON when a PC Setup Run error occurs (DM6613 to

DM6623).

PC Setup

Communications/Error Setting/Misc. Error

SR bit 27502 turns ON when a PC Setup Communications, Error setting or Mis-

cellaneous error occurs (DM 6635 to DM 6655).

3-4-28 Clock and Keyboard Mapping

Clock (SR 276) SR 276 contains the current time. SR bits 27600 to 27607 contain the minutes

(00 to 59) and SR bits 27608 to 27615 contain the hours (0 to 23).

Keyboard Mapping (SR 277) SR 277 through SR 279 are used for keyboard mapping.

3-4-29 Group-2 Error Flags

SR bits 28000 to SR 28015 are used as Error Flags for Group-2 High-density I/O Units with unit numbers 0 to F. The corresponding Error Flag is turned ON when an error occurs in that Unit. Ten bits in the AR area (AR 0205 to AR 0214) are also used as Error Flags for Units 0 to 9.

3-4-30 Special I/O Unit Restart Bits and Error Flags

SR bits 28100 to SR 28115 are used as Restart Bits for Special I/O Units with unit numbers 0 to F. Turn the corresponding bit ON and OFF to restart a Special I/O Unit. Ten bits in the AR area (AR 0100 to AR 0109) are also used as Restart Bits for Units 0 to 9.

SR bits 28200 to SR 28215 are used as Error Flags for Special I/O Units with unit numbers 0 to F. The corresponding Error Flag is turned ON when an error occurs in that Unit. Ten bits in the AR area (AR 0000 to AR 0009) are also used as Error Flags for Units 0 to 9.

3-5 AR (Auxiliary Relay) Area

AR word addresses extend from AR 00 to AR 27; AR bit addresses extend from AR 0000 to AR 2715. Most AR area words and bits are dedicated to specific

uses, such as transmission counters, flags, and control bits, and words AR 00 through AR 07 and AR 23 through AR 27 cannot be used for any other purpose. Words and bits from AR 08 to AR 17 are available as work words and work bits if not used for the following assigned purposes.

Word	Use
AR 08 to AR 15	SYSMAC LINK Units
AR 16, AR 17	SYSMAC LINK and SYSMAC NET Link Units

The AR area retains status during power interruptions, when switching from MONITOR or RUN mode to PROGRAM mode, or when PC operation is stopped. Bit allocations are shown in the following table and described in the following pages in order of bit number.

AR Area Flags and Control Bits

Word(s)	Bit(s)	Function
00	00 to 09	Error Flags for Special I/O Units 0 to 9 and PC Link Units 0 to 9 (The function of these flags is duplicated in SR 28200 through SR 28209.)
	10	Error Flag for operating level 1 of SYSMAC LINK or SYSMAC NET Link System
	11	Error Flag for operating level 0 of SYSMAC LINK or SYSMAC NET Link System
	12	Host Computer to Rack-mounting Host Link Unit Level 1 Error Flag
	13	Host Computer to Rack-mounting Host Link Unit Level 0 Error Flag
	14	Remote I/O Master Unit 1 Error Flag
	15	Remote I/O Master Unit 0 Error Flag
01	00 to 09	Restart Bits for Special I/O Units 0 to 9 and PC Link Units 0 to 9 (The operation of these bits is duplicated in SR 28100 through SR 28109.)
	10	Restart Bit for operating level 1 of SYSMAC LINK or SYSMAC NET Link System
	11	Restart Bit for operating level 0 of SYSMAC LINK or SYSMAC NET Link System
	12, 13	Not used.
	14	Remote I/O Master Unit 1 Restart Bit.
	15	Remote I/O Master Unit 0 Restart Bit.
02	00 to 04	Slave Rack Error Flags (#0 to #4)
	05 to 14	Group-2 Error Flags (Bits 05 through 14 correspond to Units 0 to 9.)
	15	Group-2 Error Flag
03	00 to 15	Error Flags for Optical I/O Units and I/O Terminals 0 to 7
04	00 to 15	Error Flags for Optical I/O Units and I/O Terminals 8 to 15
05	00 to 15	Error Flags for Optical I/O Units and I/O Terminals 16 to 23
06	00 to 15	Error Flags for Optical I/O Units and I/O Terminals 24 to 31
07	00 to 03	Data Link setting for operating level 0 of SYSMAC LINK or Controller Link System
	04 to 07	Data Link setting for operating level 1 of SYSMAC LINK or Controller Link System
	08	TERMINAL Mode Input Cancel Bit
	09	Expansion TERMINAL Mode ON/OFF Bit
	10 to 11	Not used.
	12	Same as status of pin 6 on CPU Unit's DIP switch
	13	Error History Overwrite Bit
	14	Error History Reset Bit
	15	Error History Enable Bit
08 to 11	00 to 15	Active Node Flags for SYSMAC LINK System nodes of operating level 0
12 to 15	00 to 15	Active Node Flags for SYSMAC LINK System nodes of operating level 1
16	00 to 15	SYSMAC LINK/SYSMAC NET Link System operating level 0 service time per cycle
17	00 to 15	SYSMAC LINK/SYSMAC NET Link System operating level 1 service time per cycle
18	00 to 07	Seconds: 00 to 59
	08 to 15	Minutes: 00 to 59

Word(s)	Bit(s)	Function
19	00 to 07	Hours: 00 to 23 (24-hour system)
	08 to 15	Day of Month: 01 to 31 (adjusted by month and for leap year)
20	00 to 07	Month: 1 to 12
	08 to 15	Year: 00 to 99 (Rightmost two digits of year)
21	00 to 07	Day of Week: 00 to 06 (00: Sunday; 01: Monday; 02: Tuesday; 03: Wednesday; 04: Thursday; 05: Friday; 06: Saturday)
	08 to 12	Not used.
	13	30-second Compensation Bit
	14	Clock Stop Bit
	15	Clock Set Bit
22	00 to 15	Keyboard Mapping
23	00 to 15	Power Off Counter (BCD)
24	00	SYSMAC LINK – RS-232C Peripheral Device Flag
	01	SYSMAC LINK – Port A Peripheral Device Flag
	02	SYSMAC LINK – Port B Peripheral Device Flag
	03	SYSMAC LINK – Peripheral Device Initialization Blt
	04	Not used.
05		Cycle Time Flag
	06	SYSMAC LINK System Network Parameter Flag for operating level 1
07		SYSMAC LINK System Network Parameter Flag for operating level 0
	08	SYSMAC LINK/SYSMAC NET Link Unit Level 1 Mounted Flag
	09	SYSMAC LINK/SYSMAC NET Link Unit Level 0 Mounted Flag
	10	Not used.
	11	PC Link Unit Level 1 Mounted Flag
	12	PC Link Unit Level 0 / Single Level Mounted Flag
	13	Rack-mounting Host Link Unit Level 1 Mounted Flag
	14	Rack-mounting Host Link Unit Level 0 Mounted Flag
	15	CPU Unit-mounting Device Mounted Flag
25	00 to 07	Password for access to the Online Edit Disable Bit (The Online Edit Disable Bit is valid when this byte contains 5A.)
	08	FPD(—) Trigger Bit
	09	Online Edit Disable Bit
	10	Online Edit Standby Flag
	11	Not used.
	12	Trace End Flag
	13	Tracing Flag
	14	Trace Trigger Bit (writeable)
	15	Trace Start Bit (writeable)
26	00 to 15	Maximum Cycle Time (0.1 ms)
27	00 to 15	Present Cycle Time (0.1 ms)

3-5-1 Restarting Special I/O Units

AR bits 0100 to AR 0109 correspond to the unit numbers of Special I/O Units 0 to 9. To restart Special I/O Units (including PC Link Units) turn the corresponding bit ON and OFF (or turn power ON and OFF). Do not access data refreshed for Special I/O Units during restart processing (see SR 27400 to SR 27409 on page 37).

Note Bits SR 28100 to SR 28115 also act as Restart Bits for Special I/O Units 0 to F.

3-5-2 Slave Rack Error Flags

AR bits 0200 to AR 0204 correspond to the unit numbers of Remote I/O Slave Units #0 to #4. These flags will turn ON if the same number is allocated to more then one Slave or if a transmission error occurs when starting the System. Refer to SR 251 for errors that occur after the System has started normally.

3-5-3 Group-2 Error Flags

Bits AR 0205 to AR 0215 correspond to Group-2 High-density I/O Units and B7A Interface Units 0 to 9 (I/O numbers) and will turn ON when the same number is set for more than one Unit, when the same word is allocated to more than one Unit, when I/O number 9 is set for a 64-point Unit, or when the fuse burns out in a Transistor High-density I/O Unit. AR bit 0215 will turn ON when a Unit is not recognized as a Group-2 High-density I/O Unit.

Note Bits SR 28000 to SR 28015 also act as Error Flags for Group-2 High-density I/O Units with unit numbers 0 to F.

3-5-4 Optical I/O Unit and I/O Terminal Error Flags

AR 03 through AR 06 contain the Error Flags for Optical I/O Units and I/O Terminals. An error indicates a duplication of a unit number. Up to 64 Optical I/O Units and I/O Terminals can be connected to the PC. Units are distinguished by unit number, 0 through 31, and a letter, L or H. Bits are allocated as shown in the following table.

Optical I/O Unit and I/O Terminal Error Flags

Bits	AR03 allocation	AR04 allocation	AR05 allocation	AR06 allocation
00	0 L	8 L	16 L	24 L
01	0 H	8 H	16 H	24 H
02	1 L	9 L	17 L	25 L
03	1 H	9 H	17 H	25 H
04	2 L	10 L	18 L	26 L
05	2 H	10 H	18 H	26 H
06	3 L	11 L	19 L	27 L
07	3 H	11 H	19 H	27 H
08	4 L	12 L	20 L	28 L
09	4 H	12 H	20 H	28 H
10	5 L	13 L	21 L	29 L
11	5 H	13 H	21 H	29 H
12	6 L	14 L	22 L	30 L
13	6 H	14 H	22 H	30 H
14	7 L	15 L	23 L	31 L
15	7 H	15 H	23 H	31 H

3-5-5 SYSMAC LINK/Controller Link System Data Link Settings

AR 0700 to AR 0703 and AR 0704 to AR 0707 are used to designate word allocations for operating levels 0 and 1 of the SYSMAC LINK/Controller Link System. Allocation can be set to occur either according to settings from the SSS or automatically in the LR and/or DM areas. If automatic allocation is designated, the number of words to be allocated to each node is also designated. These settings are shown below.

External/Automatic Allocation

Operatin	Operating level 0		ig level 1	Setting			
AR 0700	AR 0701	AR 0704	AR 0705				
0	0	0	0	Words set exter	nally (SSS)		
1	0	1	0	Automatic	LR area only		
0	1	0	1	allocation	DM area only		
1	1	1	1		LR and DM areas		

Words per Node

The following setting is necessary if automatic allocation is designated above.

Operatin	g level 0	Operating level 1		Words p	Max. no.	
AR 0702	AR 0703	AR 0706	AR 0707	LR area	DM area	of nodes
0	0	0	0	4	8	16
1	0	1	0	8	16	8
0	1	0	1	16	32	4
1	1	1	1	32	64	2

The above settings are read every cycle while the SYSMAC LINK/Controller Link System is in operation.

3-5-6 Error History Bits

AR 0713 (Error History Overwrite Bit) is turned ON or OFF by the user to control overwriting of records in the Error History Area in the DM area. Turn ON AR 0713 to overwrite the oldest error record each time an error occurs after 10 have been recorded. Turn OFF AR 0713 to store only the first 10 records that occur each time after the history area is cleared.

AR 0714 (Error History Reset Bit) is turned ON and then OFF by the user to reset the Error Record Pointer (DM 6000) and thus restart recording error records at the beginning of the history area.

AR 0715 (Error History Enable Bit) is turned ON by the user to enable error history storage and turned OFF to disable error history storage.

Refer to 3-6 DM Area for details on the Error History Area.

Error history bits are refreshed each cycle.

3-5-7 Active Node Flags

AR 08 through AR 11 and AR 12 through AR 15 provide flags that indicate which nodes are active in the SYSMAC LINK System at the current time. These flags are refreshed every cycle while the SYSMAC LINK System is operating.

The body of the following table show the node number assigned to each bit. If the bit is ON, the node is currently active.

Level 0	Level 1		Bit (body of table shows node numbers)														
		00	01	02	03	04	05	06	07	80	09	10	11	12	13	14	15
AR 08	AR 12	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
AR 09	AR 13	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
AR 10	AR 14	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48
AR 11	AR 15	49	50	51	52	53	54	55	56	57	58	59	60	61	62	*	**

^{*}Communication Controller Error Flag

^{**}EEPROM Error Flag

3-5-8 SYSMAC LINK/SYSMAC NET Link System Service Time

AR 16 provides the time allocated to servicing operating level 0 of the SYSMAC LINK System and/or SYSMAC NET Link System during each cycle when a SYS-MAC LINK Unit and/or SYSMAC NET Link Unit is mounted to a Rack.

AR 17 provides the time allocated to servicing operating level 1 of the SYSMAC LINK System and/or SYSMAC NET Link System during each cycle when a SYS-MAC LINK Unit and/or SYSMAC NET Link Unit is mounted to a Rack.

These times are recorded in 4-digit BCD to tenths of a millisecond (000.0 ms to 999.9 ms) and are refreshed every cycle.

Bits					
15 to 12					
10 ²	10 ¹	10 ⁰	10 ⁻¹		

3-5-9 Calendar/Clock Area and Bits

Calendar/Clock Area

A clock is built into the C200HX/HG/HE CPU Units. If AR 2114 (Clock Stop Bit) is OFF, then the date, day, and time will be available in BCD in AR 18 to AR 20 and AR 2100 to AR 2108 as shown below. This area can also be controlled with AR 2113 (30-second Compensation Bit) and AR 2115 (Clock Set Bit).

Calendar/Clock Bits

Bits	Contents	Possible values
AR 1800 to AR 1807	Seconds	00 to 59
AR 1808 to AR 1815	Minutes	00 to 59
AR 1900 to AR 1907	Hours	00 to 23 (24-hour system)
AR 1908 to AR 1915	Day of month	01 to 31 (adjusted by month and for leap year)
AR 2000 to AR 2007	Month	1 to 12
AR 2008 to AR 2015	Year	00 to 99 (Rightmost two digits of year)
AR 2100 to AR 2107	Day of week	00 to 06 (00: Sunday; 01: Monday; 02: Tuesday; 03: Wednesday; 04: Thursday; 05: Friday; 06: Saturday)

30-second Compensation Bit AR 2113 is turned ON to round the seconds of the Calendar/clock Area to zero, i.e., if the seconds is 29 or less, it is merely set to 00; if the seconds is 30 or greater, the minutes is incremented by 1 and the seconds is set to 00.

Clock Stop Bit

AR 2114 is turned OFF to enable the operation of the Calendar/clock Area and ON to stop the operation.

Clock Set Bit

AR 2115 is used to set the Calendar/clock Area as described below. This data must be in BCD and must be set within the limits for the Calendar/clock Area given above.

1, 2, 3... 1. Turn ON AR 2114 (Stop Bit).

- 2. Set the desired date, day, and time, being careful not to turn OFF AR 2114 (Clock Stop Bit) when setting the day of the week (they're in the same word). (On the Programming Console, the Bit/Digit Monitor and Force Set/Reset Operations are the easiest ways to set this data.)
- 3. Turn ON AR 2115 (Clock Set Bit). The Calendar/clock will automatically start operating with the designated settings and AR 2114 and AR 2115 will both be turned OFF.

The Calendar/clock Area and Bits are refreshed each cycle while operational.

Note The accuracy of the clock is as follows:

Temperature	Accuracy/month
55°C	-3 to 0 minutes
25°C	±1 minute
0°C	-2 to 0 minutes

3-5-10 TERMINAL Mode Key Bits

If the Programming Console is mounted to the PC and is in TERMINAL mode, any inputs on keys 0 through 9 (including characters A through F, i.e., keys 0 through 5 with SHIFT) will turn on a corresponding bit in AR 22. TERMINAL mode is entered by a Programming Console operation.

The bits in AR 22 correspond to Programming Console inputs as follows:

Bit	Programming Console input
AR 2200	0
AR 2201	1
AR 2202	2
AR 2203	3
AR 2204	4
AR 2205	5
AR 2206	6
AR 2207	7
AR 2208	8
AR 2209	9
AR 2210	Α
AR 2211	В
AR 2212	С
AR 2213	D
AR 2214	Е
AR 2215	F

Refer to Section 7 Program Monitoring and Execution for details on the TERMI-NAL mode.

3-5-11 Power OFF Counter

AR 23 provides in 4-digit BCD the number of times that the PC power has been turned OFF. This counter can be reset as necessary using the PV Change 1 operation from the Programming Console. (Refer to 7-2-4 Hexadecimal/BCD Data Modification for details.) The Power OFF Counter is refreshed every time power is turned ON.

3-5-12 SYSMAC LINK – Peripheral Device Flags

A Peripheral Device can be used through the SYSMAC LINK System from only one port at a time. When changing the port from which the Peripheral Device is being used, turn ON the SYSMAC LINK – Peripheral Device Initialization Bit (AR 2403).

Bit	Function
AR 2400	SYSMAC LINK – RS-232C Peripheral Device Flag (This flag is turned ON when a Peripheral Device is being used through the SYSMAC LINK System from the RS-232C port.)
AR 2401	SYSMAC LINK – Port A Peripheral Device Flag (This flag is turned ON when a Peripheral Device is being used through the SYSMAC LINK System from Communications Board port A.)
AR 2402	SYSMAC LINK – Port B Peripheral Device Flag (This flag is turned ON when a Peripheral Device is being used through the SYSMAC LINK System form Communications Board port B.)
AR 2403	SYSMAC LINK – Peripheral Device Initialization Bit (Turn this bit ON to initialize the usage of a Peripheral Device through the SYSMAC LINK System.)

3-5-13 Cycle Time Flag

AR 2405 turns ON when the cycle time set with SCAN(18) is shorter than the actual cycle time.

AR 2405 is refreshed every cycle while the PC is in RUN or MONITOR mode.

3-5-14 Link Unit Mounted Flags

The following flags indicate when the specified Link Units are mounted to the Racks. (Refer to 3-5-15 CPU Unit-mounting Device Mounted Flag for CPU Unit-mounting Host Link Units.) These flags are refreshed every cycle.

Name	Bit	Link Unit
SYSMAC LINK/SYSMAC NET Link Unit Level 1 Mounted Flag	AR 2408	SYSMAC LINK/SYSMAC NET Link Unit in operating level 1
SYSMAC LINK/SYSMAC NET Link Unit Level 0 Mounted Flag	AR 2409	SYSMAC LINK/SYSMAC NET Link Unit in operating level 0
Rack-mounting Host Link Unit Level 1	AR 2413	Rack-mounting Host Link Unit in operating level 1
Rack-mounting Host Link Unit Level 0	AR 2414	Rack-mounting Host Link Unit in operating level 0

3-5-15 CPU Unit-mounting Device Mounted Flag

AR 2415 turns ON when any device is mounted directly to the CPU Unit. This includes CPU Unit-mounting Host Link Units, Programming Consoles, and Interface Units. This flag is refreshed every cycle.

3-5-16 FPD Trigger Bit

AR 2508 is used to adjust the monitoring time of FPD(—) automatically. Refer to 5-25-12 FAILURE POINT DETECT – FPD(—) for details.

3-5-17 Data Tracing Flags and Control Bits

The following control bits and flags are used during data tracing with TRSM(45). The Tracing Flag will be ON during tracing operations. The Trace Completed Flag will turn ON when enough data has been traced to fill Trace Memory.

Bit	Name
AR 2512	Trace Completed Flag
AR 2513	Tracing Flag
AR 2514	Trace Trigger Bit (writeable)
AR 2515	Sampling Start Bit (writeable)

Note Refer to 5-25-3 TRACE MEMORY SAMPLING – TRSM(45) for details.

3-5-18 Cycle Time Indicators

AR 26 contains the maximum cycle time that has occurred since program execution was begun. AR 27 contains the present cycle time.

Both times are to tenths of a millisecond in 4-digit BCD (000.0 ms to 999.9 ms), and are refreshed every cycle.

DM (Data Memory) Area 3-6

The DM area is divided into various parts as described in the following table. A portion of UM (up to 3,000 words in 1,000-word increments) can be allocated as Expansion DM.

Addresses	User read/write	Usage
DM 0000 to DM 0999	Read/Write	Normal DM.
DM 1000 to DM 2599		Special I/O Unit Area ¹
DM 2600 to DM 5999		Normal DM.
DM 6000 to DM 6030		History Log
DM 6100 to DM 6143		Reserved
DM 6144 to DM 6599	Read only	System Settings
DM 6600 to DM 6655		PC Setup
DM 7000 to DM 9999		Expansion DM ²

Note

1. The PC Setup can be set to use DM 7000 through DM 8599 as the Special I/O Area instead of DM 1000 to DM 2599. Refer to 3-6-4 PC Setup for details.

When Special I/O Units are used, 100 words are occupied by each Unit, as follows:

Unit #0: DM 1000 to DM 1099 Unit #1: DM 1100 to DM 1199 (...) Unit #9: DM 1900 to DM 1999 Unit #A: DM 2000 to DM 2099 (...) Unit #F:

2. The UM Area Allocation Programming Console operation can be used to allocate up to 3000 words of UM as Expansion DM.

Although composed of 16-bit words like any other data area, data in the DM area cannot be specified by bit for use in instructions with bit operands. DM 0000 to DM 6143 can be written to by the program, but DM 6144 to DM 6655 can be overwritten only from a Peripheral Device, such as a Programming Console or computer with SSS.

The DM area retains status during power interruptions.

DM 2500 to DM 2599


DM 6031 cannot be used in user applications because it is used by the system to store EM bank number information and indirect DM addresses.

Indirect Addressing

Normally, when the content of a data area word is specified for an instruction, the instruction is performed directly on the content of that word. For example, suppose MOV(21) is performed with DM 0100 as the first operand and LR 20 as the second operand. When this instruction is executed, the content of DM 0100 is moved to LR 20.

Note Expansion DM cannot be used for indirect addressing.

It is possible, however, to use indirect DM addresses as the operands for many instructions. To indicate an indirect DM address, *DM is input with the address of the operand. With an indirect address, with content of this operand does not contain the actual data to be used. Instead, its contents is assumed to hold the address of another DM word, the content of which will actually be used in the instruction. If *DM 0100 was used in our example above and the content of DM 0100 is 0324, then *DM 0100 actually means that the content of DM 0324 is to be used as the operand in the instruction, and the content of DM 0324 will be moved to LR 00.



3-6-1 Expansion DM Area

The expansion DM area is designed to provide memory space for storing operating parameters and other operating data for Link Units and Special I/O Units. Up to 3,000 words of UM can be allocated as Expansion DM (in 1K-word increments) using the UM ALLOCATION operation in the Programming Console or SSS. Expansion DM area addresses run from DM 7000 to DM 9999.

The data in the expansion DM area can be transferred to the Special I/O Unit Default Area (DM 1000 to DM 1999) when starting the PC or via programming instruction to easily change operating parameters, enabling rapid switching between control processes. The expansion DM area can also be used to store parameters for other devices connected in the PC system, e.g., Programmable Terminal character string or numeral tables.

The expansion DM area is used to store operating parameters and cannot be used in programming like the normal DM area. Expansion DM can only be overwritten from a Peripheral Device, retains status during power interruptions, and cannot be used for indirect addressing.

The UM area can be allocated as expansion DM area in increments of 1K words. Once expansion DM area has been created, it is saved and transferred as part of the program, i.e., no special procedures are required when saving or transferring the program.

UM ALLOCATION Operation

The procedure for the Programming Console's UM ALLOCATION operation is shown below. Refer to *4-6-3 Clearing Memory* for details on the DATA CLEAR and UM ALLOCATION instructions.

1, 2, 3... 1. Clear memory.



Note UM allocation is not possible unless memory is cleared first.

2. The expansion DM area can be set to 0, 1, 2, or 3 K words. The following key sequence creates a 2-KW expansion DM area (DM 7000 to DM 8999).



Press the 0 Key to eliminate the expansion DM area (0 KW).

- or Press the 1 Key to allocate DM 7000 to DM 7999 (1 KW).
- or Press the 2 Key to allocate DM 7000 to DM 8999 (2 KW).
- or Press the 3 Key to allocate DM 7000 to DM 9999 (3 KW).

3-6-2 Special I/O Unit Data

Special I/O Units are allocated 1000 or 1600 words in the DM Area depending on the value set in word DM 6602 of the PC Setup. The DM 6602 setting determines whether the Special I/O Unit Data area is setup for 10 or 16 Units and whether the data is stored in read/write DM (DM 1000 to DM 2599) or read-only DM (DM 7000 to DM 8599). Refer to *Appendix E* for details.

Unit	Addresses
0	DM 1000 to DM 1099 or DM 7000 to DM 7099
1	DM 1100 to DM 1199 or DM 7100 to DM 7199
2	DM 1200 to DM 1299 or DM 7200 to DM 7299
3	DM 1300 to DM 1399 or DM 7300 to DM 7399
4	DM 1400 to DM 1499 or DM 7400 to DM 7499
5	DM 1500 to DM 1599 or DM 7500 to DM 7599
6	DM 1600 to DM 1699 or DM 7600 to DM 7699
7	DM 1700 to DM 1799 or DM 7700 to DM 7799
8	DM 1800 to DM 1899 or DM 7800 to DM 7899
9	DM 1900 to DM 1999 or DM 7900 to DM 7999
Α	DM 2000 to DM 2099 or DM 8000 to DM 8099
В	DM 2100 to DM 2199 or DM 8100 to DM 8199
С	DM 2200 to DM 2299 or DM 8200 to DM 8299
D	DM 2300 to DM 2399 or DM 8300 to DM 8399
Е	DM 2400 to DM 2499 or DM 8400 to DM 8499
F	DM 2500 to DM 2599 or DM 8500 to DM 8599

Note These DM words can be used for other purposes when not allocated to Special I/O Units.

3-6-3 Error History Area

DM 6000 to DM 6030 are used to store up to 10 records that show the nature, time, and date of errors that have occurred in the PC.

The Error History Area will store system-generated or FAL(06)/FALS(07)-generated error codes whenever AR 0715 (Error History Enable Bit) is ON. Refer to Section 9 Troubleshooting for details on error codes.

Area Structure

Error records occupy three words each stored between DM 6001 and DM 6030. The last record that was stored can be obtained via the content of DM 6000 (Error Record Pointer). The record number, DM words, and pointer value for each of the ten records are as follows:

Record	Addresses	Pointer value
None	N.A.	0000
1	DM 6001 to DM 6003	0001
2	DM 6004 to DM 6006	0002
3	DM 6007 to DM 6009	0003
4	DM 6010 to DM 6012	0004
5	DM 6013 to DM 6015	0005
6	DM 6016 to DM 6018	0006
7	DM 6019 to DM 6021	0007
8	DM 6022 to DM 6024	0008
9	DM 6025 to DM 6027	0009
10	DM 6028 to DM 6030	000A

Although each of them contains a different record, the structure of each record is the same: the first word contains the error code; the second and third words, the day and time. The error code will be either one generated by the system or by FAL(06)/FALS(07); the time and date will be the date and time from AR 18 and AR 19 (Calender/date Area). Also recorded with the error code is an indication of whether the error is fatal (08) or non-fatal (00). This structure is shown below.

Word	Bit	Content
First	00 to 07	Error code
	08 to 15	00 (non-fatal) or 80 (fatal)
Second	00 to 07	Seconds
	08 to 15	Minutes
Third	00 to 07 Hours	
	08 to 15	Day of month

The following table lists the possible error codes and corresponding errors.

Error severity	Error code	Error
Fatal errors	00	Power interruption
	01 to 99 or 9F	System error (FALS)
	C0 to C3	I/O bus error
	E0	Input-output I/O table error
	E1	Too many Units
	F0	No END(01) instruction
	F1	Memory error
Non-fatal errors	01 to 99	System error (FAL)
	8A	Interrupt Input error
	8B	Interrupt program error
	9A	Group 2 High-density I/O error
	9B	PC Setup error
	9C	Communications Board error
	9D	UM Memory Cassette transfer error
	B0 to B1	Remote I/O error
	D0	Special I/O error
	E7	I/O table verification error
	F7	Battery error
	F8	Cycle time overrun

Operation

When the first error code is generated with AR 0715 (Error History Enable Bit) turned ON, the relevant data will be placed in the error record after the one indicated by the History Record Pointer (initially this will be record 1) and the Pointer will be incremented. Any other error codes generated thereafter will be placed in consecutive records until the last one is used. Processing of further error records is based on the status of AR 0713 (Error History Overwrite Bit).

If AR 0713 is ON and the Pointer contains 000A, the next error will be written into record 10, the contents of record 10 will be moved to record 9, and so on until the contents of record 1 is moved off the end and lost, i.e., the area functions like a shift register. The Record Pointer will remain set to 000A.

If AR 0713 is OFF and the Pointer reaches 000A, the contents of the Error History Error will remain as it is and any error codes generate thereafter will not be recorded until AR 0713 is turned OFF or until the Error History Area is reset.

The Error History Area can be reset by turning ON and then OFF AR 0714 (Error History Reset Bit). When this is done, the Record Pointer will be reset to 0000, the Error History Area will be reset (i.e., cleared), and any further error codes will be recorded from the beginning of the Error History Area. AR 0715 (Error History Enable Bit) must be ON to reset the Error History Area.

3-6-4 PC Setup

The PC Setup (DM 6600 through DM 6655) contains settings that determine PC operation. Data in the PC Setup can be changed with a Programming Console or SSS if UM is not write-protected by pin 1 of the CPU Unit's DIP switch. Refer to page 20 for details on changing DIP switch pin settings.

The data in DM 6600 through DM 6634 can be set or changed only when the PC is in PROGRAM mode. The data in DM 6635 through DM 6655 can be set or changed when the PC is in PROGRAM or MONITOR mode. The following words can be changed from the SYSMAC Support Software's PC Setup menu. (The PC must be in PROGRAM mode.)

- 1, 2, 3... 1. Startup mode (DM 6600)
 - 2. Startup mode designation (DM 6601)
 - 3. Cycle monitor time (DM 6618)
 - 4. Cycle time setting (DM 6619)
 - 5. RS-232C Port Settings (DM 6645 through DM 6649)

The PC can be operated with the default PC Setup, which requires changing only when customizing the PC's operating environment to application needs. The PC Setup parameters are described in the following table.

If there is an error in the settings in DM 6600 to DM 6655, a non-fatal error (error code 9B) will occur when the data is read by the PC and one of the flags from SR 27500 to SR 27502 will turn ON to indicate the location of the error. If there is an error in the settings in DM 6550 to DM 6559, a non-fatal error (error code 9C) will occur.

Word(s)	Bit(s)	Function	Default
Startup Pro	cessing (D	M 6600 to DM 6612)	1
The following	g settings a	re accessed only once when the PC is turned ON.	
DM 6600	00 to 07	Startup mode (effective when bits 08 to 15 are set to 02). 00: PROGRAM; 01: MONITOR 02: RUN	PROGRAM
	08 to 15	Startup mode designation 00: Programming Console switch 01: Continue operating mode last used before power was turned off 02: Setting in 00 to 07	Programming Console switch
DM 6601	00 to 07	Reserved	
	08 to 11	IOM Hold Bit (SR 25212) Status 0: Reset; 1: Maintain	Reset
	12 to 15	Forced Status Hold Bit (SR 25211) Status 0: Reset; 1: Maintain	

Word(s)	Bit(s)	Function	Default
DM 6602	00 to 07	Not used.	
	08 to 15	00: C200H-compatible RAM Mode (Default) Use DM 1000 through DM 2599 for the initial data area for the Special I/O Unit Area.	DM 1000 to DM 2599
		Data in the Special I/O Unit Area can be read/written.	
		The data cannot be converted to ROM.	
		01: C200H-compatible ROM Mode 1 Transfer the contents of DM 7000 through DM 7999 to DM 1000 through DM 1999 at startup and use DM 1000 through DM 1999.	
		The UM Area Allocation operation must be performed beforehand.	
		The data is compatible with C200H applications that use EEPROM/ EPROM.	
		 ROM conversion is possible indirectly by writing DM 7000 through DM 7999 to ROM. 	
		02: DM Linear Mode 1 Use DM 7000 through DM 7999 for the initial data area for Special I/O Unit Area.	
		The UM Area Allocation operation must be performed beforehand.	
		DM 1000 through DM 1999 can be used as regular DM.	
		DM 7000 through DM 7999 can be converted to ROM.	
		11: C200H-compatible ROM Mode 2 Transfer the contents of DM 7000 through DM 8599 to DM 1000 through DM 2599 at startup and use DM 1000 through DM 2599.	
		The UM Area Allocation operation must be performed beforehand.	
		 ROM conversion is possible indirectly by converting DM 7000 through DM 8599 to ROM. 	
		12: DM Linear Mode 2 Use DM 7000 through DM 8599 for the Special I/O Unit Area.	
		The UM Area Allocation operation must be performed beforehand.	
		 DM 1000 through DM 2599 can be used as regular DM. 	
		DM 7000 through DM 8599 can be converted to ROM.	
		See also 3-6-6 Special I/O Unit Area Settings.	
DM 6603 to DM 6604	00 to 15	Not used.	
DM 6605		Momentary power interruption time (0 to 10 ms) Set the momentary power interruption time from 00 to 10 in BCD.	0 ms
	08 to 15	Not used.	
DM 6606 to DM 6612	00 to 15	Not used.	
Communica	tions and (Cycle Time Settings (DM 6613 to DM 6619)	
		re accessed only once when program execution begins.	
DM 6613	00 to 07	Servicing time for Communications Board port B (effective when bits 08 to 15 are set to 01) 00 to 99 (BCD): Percentage of cycle time used to service port B.	No setting (0000)
		Minimum: 0.26 ms; maximum 58.254 ms	
	08 to 15	Communications Board port B servicing setting enable 00: Do not set service time (Fixed at 5%, 0.26 ms min.) 01: Use time in 00 to 07.	
		Service time is 10 ms when operation is stopped, regardless of this setting.	

Word(s)	Bit(s)	Function	Default
DM 6614	00 to 07	Servicing time for Communications Board port A (effective when bits 08 to 15 are set to 01) 00 to 99 (BCD): Percentage of cycle time used to service port A.	No setting (0000)
		Minimum: 0.26 ms; maximum 58.254 ms	
	08 to 15	Communications Board port A servicing setting enable 00: Do not set service time (Fixed at 5%, 0.26 ms min.) 01: Use time in 00 to 07.	
		Service time is 10 ms when operation is stopped, regardless of this setting.	
DM 6615	00 to 15	Reserved	
DM 6616	00 to 07	Servicing time for RS-232C port (effective when bits 08 to 15 are set to 01) 00 to 99 (BCD): Percentage of cycle time used to service RS-232C port.	No setting (0000)
		Minimum: 0.228 ms; maximum 58.254 ms	
	08 to 15	(RS-232C port servicing setting enable) 00: Do not set service time (Fixed at 5%, 0.228 ms min.) 01: Use time in 00 to 07.	
		Service time is 10 ms when operation is stopped, regardless of this setting.	
DM 6617	00 to 07	Servicing time for peripheral port (effective when bits 08 to 15 are set to 01) 00 to 99 (BCD): Percentage of cycle time used to service peripheral.	No setting (0000)
		Minimum: 0.26 ms; maximum 58.254 ms	
	08 to 15	Peripheral port servicing setting enable 00: Do not set service time (Fixed at 5%, 0.26 ms min.) 01: Use time in 00 to 07.	
		Service time is 10 ms when operation is stopped, regardless of this setting.	
DM 6618	00 to 07	Cycle monitor time (effective when bits 08 to 15 are set to 01, 02, or 03) 00 to 99 (BCD) × setting unit (see 08 to 15)	00
	08 to 15	Cycle monitor enable (Setting in 00 to 07 × setting unit; 99 s max.) 00: 120 ms (setting in bits 00 to 07 disabled) 01: Setting unit: 10 ms 02: Setting unit: 100 ms 03: Setting unit: 1 s	00: 120 ms
DM 6619	00 to 15	Cycle time 0000: Variable (no minimum)	Variable
		0001 to 9999 (BCD): Minimum time in ms	
Interrupt/Re	fresh Proc	essing (DM 6620 to DM 6623)	•
The following	g settings a	re accessed only once when program execution begins.	
DM 6620	00 to 09	Special I/O Unit cyclic refresh (Bit number corresponds to unit number, PC Link Units included) 0: Enable cyclic refresh and I/O REFRESH (IORF(97)) from main program 1: Disable (refresh only for I/O REFRESH from interrupt programs)	Enable
		A setting of 01 (Disable) is valid only when the interrupt response is set to high-speed response mode. It is not valid for normal interrupt response or for Special I/O Units mounted in Slave Racks.	
	10 to 11	Reserved	
	12 to 15	Interrupt response	Normal
		0: Normal (C200H compatible) Interrupts cannot be received when Host Link servicing, execution of a single instruction, Remote I/O processing, or Special I/O processing is being performed. The interrupt subroutine will be executed after the processing is completed.	
		1: High-speed Response (C200HS or C200HX/HG/HE) Interrupts will be received when Host Link servicing, execution of a single instruction, Remote I/O processing, or Special I/O processing is being performed. If there is an interrupt input, the current processing will be interrupted and the interrupt subroutine will be executed.	

Word(s)	Bit(s)	Function	Default
DM 6621	00 to 07	Reserved	
	08 to 15	Special I/O Unit refresh (PC Link Units included) 00: Enable refresh for all Special I/O Units 01: Disable refresh for all Special I/O Units (but, not valid on Slave Racks)	Enable
		A setting of 1 (Disable) is not valid for Special I/O Units mounted in Slave Racks.	
DM 6622	00 to 07	Scheduled interrupt time unit 00: 10 ms 01: 1 ms	10 ms (0000)
	08 to 15	Scheduled interrupt time unit enable 00: Disable (10 ms) 01: Enable setting in 00 to 07	
DM 6623	00 to 15	Special I/O Unit cyclic refresh (PC Link Units included) (Bit numbers 00 to 15 correspond to unit numbers 0 to F.) 0: Enable cyclic refresh and I/O REFRESH (IORF(97)) from main program 1: Disable (refresh only for I/O REFRESH from interrupt programs)	Enable
		A setting of 01 (Disable) is valid only when the interrupt response is set to high-speed response mode. It is not valid for normal interrupt response or for Special I/O Units mounted in Slave Racks.	
DM 6624 to DM 6644	00 to 15	Reserved	
RS-232C Po	rt Settings	(DM 6645 to DM 6649)	
The following	settings a	re accessed continually while the PC is ON.	
DM 6645	00 to 03	Port settings 0: Standard (Host Link or peripheral bus serial communications mode, 1 start bit, 7-bit data, even parity, 2 stop bits, 9,600 bps) 1: Settings in DM 6646	Standard
	04 to 07	CTS control setting 0: Disable CTS control 1: Enable CTS control	Disable
	08 to 11	Words linked for 1:1 PC Link 0: LR 00 to LR 63; 1: LR 00 to LR 31; 2: LR 00 to LR 15 Maximum PT node number for 1:N NT Link	LR 00 to LR 63
	40.4- 45	1 to 7 BCD (1 to 3 with a C200HE-CPU —-E PC)	I I and I in I
	12 to 15	Serial communications mode 0: Host Link; 1: RS-232C; 2: 1:1 PC Link slave; 3: 1:1 PC Link master; 4: 1:1 NT Link; 5: 1:N NT Link	Host Link
DM 6646	00 to 07	Baud rate 00: 1.2K, 01: 2.4K, 02: 4.8K, 03: 9.6K, 04: 19.2K	1.2 K
	08 to 15	Frame format Start Length Stop Parity 00: 1 bit 7 bits 1 bit Even 01: 1 bit 7 bits 1 bit Odd 02: 1 bit 7 bits 1 bit None 03: 1 bit 7 bits 2 bit Even 04: 1 bit 7 bits 2 bit None 05: 1 bit 7 bits 2 bit None 06: 1 bit 8 bits 1 bit Even 07: 1 bit 8 bits 1 bit None 09: 1 bit 8 bits 2 bit Even 10: 1 bit 8 bits 2 bit Odd 11: 1 bit 8 bits 2 bit None	1 start bit, 7-bit data, 1 stop bit, even parity
DM 6647	00 to 15	Transmission delay 0000 to 9999: BCD in 10-ms units.	0 ms

Word(s)	Bit(s)	Function	Default
DM 6648	00 to 07	Node number (Host Link) 00 to 31 (BCD)	0
	08 to 11	Start code enable (RS-232C) 0: Disable; 1: Set	Disabled
	12 to 15	End code enable (RS-232C) 0: Disable (number of bytes received) 1: Set (specified end code) 2: CR, LF	Disabled
DM 6649	00 to 07	Start code (RS-232C) 00 to FF (binary)	Not used (0000)
	08 to 15	12 to 15 of DM 6648 set to 0: Number of bytes received 00: Default setting (256 bytes) 01 to FF: 1 to 255 bytes	
		12 to 15 of DM 6648 set to 1: End code (RS-232C) 00 to FF (binary)	

Peripheral Port Settings (DM 6650 to DM 6654)

The following settings are accessed continually while the PC is ON.

Note To use the peripheral port set to Host Link mode after using it in peripheral bus mode, turn OFF the power once and turn ON again or disconnect and reconnect the cable.

DM 6650	00 to 03	0 to 03 Port settings 0: Standard (Host Link or peripheral bus serial communications mode, 1 start bit, 7-bit data, even parity, 2 stop bits, 9,600 bps) 1: Settings in DM 6651				Standard
	04 to 11	Reserved				
	12 to 15	Serial communic 0: Host Link; 1: N				Host Link
DM 6651	00 to 07	Baud rate 00: 1.2K, 01: 2.4	K, 02: 4.8K, 03: 9	.6K, 04: 19.2K		1.2 K
	08 to 15	Frame format Start 00: 1 bit 01: 1 bit 02: 1 bit 03: 1 bit 04: 1 bit 05: 1 bit 06: 1 bit 07: 1 bit 08: 1 bit 09: 1 bit 10: 1 bit 11: 1 bit	Length 7 bits 8 bits	Stop 1 bit 1 bit 2 bit 2 bit 2 bit 1 bit 1 bit 1 bit 1 bit 2 bit 2 bit 2 bit 2 bit 2 bit	Parity Even Odd None Even Odd	1 start bit, 7-bit data, 1 stop bit, even parity
DM 6652	00 to 15	Transmission de 0000 to 9999: in				0 ms
DM 6653	00 to 07	Node number (H 00 to 31 (BCD)	ost Link)			0
	08 to 11	Start code enable 0: Disable; 1: Se				Disable
	12 to 15	End code enable 0: Disable (numb 1: Set (specified 2: CR, LF	er of bytes receiv	red)		Disable

Word(s)	Bit(s)	Function	Default
DM 6654	00 to 07	Start code (RS-232C) 00 to FF (binary)	0000
	08 to 15	12 to 15 of DM 6653 set to 0: Number of bytes received 00: Default setting (256 bytes) 01 to FF: 1 to 255 bytes	
		12 to 15 of DM 6653 set to 1: End code (RS-232C) 00 to FF (binary)	
Error Setting	ıs (DM 665	55)	
The following	settings ar	re accessed continually while the PC is ON.	
DM 6655	00 to 03	Interrupt programming error enable 0: Detect interrupt programming errors 1: Do not detect	Detect
	04 to 07	Reserved	
	08 to 11	Cycle time monitor enable 0: Detect long cycles as non-fatal errors 1: Do not detect long cycles	Detect
	12 to 15	Low battery error enable 0: Detect low battery voltage as non-fatal error 1: Do not detect low battery voltage	Detect

3-6-5 Communications Board Settings

DM 6550 through DM 6554 contain the communications settings for Communications Board port B and DM 6555 through DM 6559 contain the communications settings for Communications Board port A.

Word(s)	Bit(s)	Function	Default						
Communica	Communications Board Port B Settings (DM 6550 to DM 6554)								
The following	settings ar	re accessed continually while the PC is ON.							
DM 6550	00 to 03	Port settings 0: Standard (1 start bit, 7-bit data, even parity, 2 stop bits, 9,600 bps) 1: Settings in DM 6551	Standard						
	04 to 07	CTS control setting 0: Disable CTS control 1: Enable CTS control	Disable						
	08 to 11	Words linked for 1:1 PC Link (Cannot be changed once set in the 1:1 PC Link Master.) 0: LR 00 to LR 63; 1: LR 00 to LR 31; 2: LR 00 to LR 15	LR 00 to LR 63						
		Maximum PT node number for 1:N NT Link 1 to 7 BCD (1 to 3 with a C200HE-CPU□□-E PC)							
	12 to 15	Communications mode 0: Host Link; 1: RS-232C; 2: 1:1 PC Link slave; 3: 1:1 PC Link master; 4: 1:1 NT Link; 5: 1:N NT Link; 6: Protocol Macro	Host Link						

Word(s)	Bit(s)	Function	Default
DM 6551	00 to 07	Baud rate 00: 1.2K, 01: 2.4K, 02: 4.8K, 03: 9.6K, 04: 19.2K	1.2 K
	08 to 15	Frame format Start Length Stop Parity 00: 1 bit 7 bits 1 bit Even 01: 1 bit 7 bits 1 bit Odd 02: 1 bit 7 bits 1 bit None 03: 1 bit 7 bits 2 bit Odd 04: 1 bit 7 bits 2 bit None 05: 1 bit 7 bits 2 bit None 06: 1 bit 8 bits 1 bit Even 07: 1 bit 8 bits 1 bit Odd 08: 1 bit 8 bits 2 bit Even 09: 1 bit 8 bits 2 bit Odd 10: 1 bit 8 bits 2 bit None	1 start bit, 7-bit data, 1 stop bit, even parity
DM 6552	00 to 15	Transmission delay 0000 to 9999: BCD in 10-ms units.	0 ms
DM 6553	00 to 07	Node number (Host Link) 00 to 31 (BCD)	0
	08 to 11	Start code enable (RS-232C) 0: Disable; 1: Set	Disabled
	12 to 15	End code enable (RS-232C) 0: Disable (number of bytes received) 1: Set (specified end code) 2: CR, LF	Disabled
DM 6554	00 to 07	Start code (RS-232C) 00 to FF (binary)	0000
	08 to 15	12 to 15 of DM 6553 set to 0: Number of bytes received 00: Default setting (256 bytes) 01 to FF: 1 to 255 bytes 12 to 15 of DM 6553 set to 1:	
		End code (RS-232C) 00 to FF (binary)	
		re read continually while the PC is ON.	1
DM 6555	00 to 03	Port settings 0: Standard (1 start bit, 7-bit data, even parity, 2 stop bits, 9,600 bps) 1: Settings in DM 6556	Standard
	04 to 07	CTS control setting 0: Disable CTS control 1: Enable CTS control	Disable
	08 to 11	Words linked for 1:1 PC Link (Can't be changed once set in the 1:1 PC Link Master.) 0: LR 00 to LR 63; 1: LR 00 to LR 31; 2: LR 00 to LR 15	LR 00 to LR 63
		Maximum PT node number for 1:N NT Link 1 to 7 BCD (1 to 3 with a C200HE-CPU□□-E PC)	
	12 to 15	Communications mode 0: Host Link; 1: RS-232C; 2: 1-to-1 link slave; 3: 1-to-1 link master; 4: NT Link (1:1); 5: NT Link (1:N); 6: Protocol Macro	Host Link

Word(s)	Bit(s)		Fun	ction		Default
DM 6556	00 to 07	Baud rate 00: 1.2K, 01: 2.4K, 02: 4	.8K, 03: 9.6K,	04: 19.2K		1.2 K
	08 to 15	00: 1 bit 7 to 01: 1 bit 7 to 02: 1 bit 7 to 03: 1 bit 7 to 03: 1 bit 7 to 04: 1 bit 7 to 05: 1 bit 7 to 06: 1 bit 8 to 07: 1 bit 8 to 08: 1 bit 8 to 09: 1 bit 9 to 09: 1	ength bits bits bits bits bits bits bits bits	Stop 1 bit 1 bit 2 bit 2 bit 2 bit 1 bit 1 bit 1 bit 1 bit 1 bit 1 bit 2 bit 2 bit 2 bit 2 bit	Parity Even Odd None Even Odd	1 start bit, 7-bit data, 1 stop bit, even parity
DM 6557	00 to 15	Transmission delay 0000 to 9999: BCD in 10)-ms units.			0 ms
DM 6558	00 to 07	Node number (Host Link 00 to 31 (BCD)	x)			0
	08 to 11	Start code enable (RS-20): Disable; 1: Set	32C)			Disabled
	12 to 15	End code enable (RS-23 0: Disable (number of by 1: Set (specified end cod 2: CR, LF	rtes received)			Disabled
DM 6559	00 to 07	Start code (RS-232C) 00 to FF (binary)				0000
	08 to 15	12 to 15 of DM 6558 set Number of bytes receive 00: Default setting (256 k 01 to FF: 1 to 255 bytes 12 to 15 of DM 6558 set End code (RS-232C) 00 to FF (binary)	ed bytes)			

3-6-6 Special I/O Unit Area Settings

The setting in bits 08 through 15 of DM 6602 determines the size and location of the Special I/O Unit Area, as shown in the following table.

Setting	Mode	Function
00	C200H-compatible	DM 1000 through DM 2599 are used for the Special I/O Unit Area.
	RAM Mode	Data in the Special I/O Unit Area can be read/written.
		The data cannot be converted to ROM.
01	C200H-compatible ROM Mode 1	The contents of DM 7000 through DM 7999 are transferred to DM 1000 through DM 1999 at startup and DM 1000 through DM 1999 are used for the Special I/O Unit Area.
		The UM Area Allocation operation must be performed beforehand.
		The data is compatible with C200H applications that use EEPROM/EPROM.
		• ROM conversion is possible indirectly by converting DM 7000 through DM 7999 to ROM.
02	DM Linear Mode 1	DM 7000 through DM 7999 are used for the Special I/O Unit Area.
		The UM Area Allocation operation must be performed beforehand.
		DM 1000 through DM 1999 can be used as regular DM.
		DM 7000 through DM 7999 can be converted to ROM.

Setting	Mode	Function
11	C200H-compatible ROM Mode 2	The contents of DM 7000 through DM 8599 are transferred to DM 1000 through DM 2599 at startup and DM 1000 through DM 2599 are used for the Special I/O Unit Area.
		The UM Area Allocation operation must be performed beforehand.
		ROM conversion is possible indirectly by converting DM 7000 through DM 8599 to ROM.
12	DM Linear Mode 2	DM 7000 through DM 8599 are used for the Special I/O Unit Area.
		The UM Area Allocation operation must be performed beforehand.
		DM 1000 through DM 2599 can be used as regular DM.
		DM 7000 through DM 8599 can be converted to ROM.

DM 7000 through DM 9999 cannot be read or overwritten directly from the program. To read this data from the program, the data must be copied to another data area or regular DM using the EXPANSION DM READ – XDMR(—) instruction.

When C200H-compatible ROM Mode or DM Linear Mode is set, the UM Area Allocation operation must be performed in advance to allocate part of the ladder program area for use as expansion DM. A system error (FAL 9B) will occur if memory isn't allocated as expansion DM. Refer to 7-2-15 UM Area Allocation for details on the UM Area Allocation operation.

When DM Linear Mode is set, the Special I/O Unit's data area will begin from DM 7000 instead of DM 1000 so add 6000 to the DM addresses where they appear in the Special I/O Unit's Operation Manual.

When the Special I/O Unit Area setting is 01, 02, 11, or 12 and expansion DM beyond DM 8000 hasn't been allocated, a Special I/O Unit error will occur for a Unit with unit number A through F when the Unit accesses its allocated area.

3-7 HR (Holding Relay) Area

The HR area is used to store/manipulate various kinds of data and can be accessed either by word or by bit. Word addresses range from HR 00 through HR 99; bit addresses, from HR 0000 through HR 9915. HR bits can be used in any order required and can be programmed as often as required.

The HR area retains status when the system operating mode is changed, when power is interrupted, or when PC operation is stopped.

HR area bits and words can be used to preserve data whenever PC operation is stopped. HR bits also have various special applications, such as creating latching relays with the Keep instruction and forming self-holding outputs. These are discussed in *Section 4 Writing and Inputting the Program* and *Section 5 Instruction Set*.

Note The required number of words is allocated between HR 00 and HR 42 for routing tables and to monitor timers when using SYSMAC NET Systems.

3-8 TC (Timer/Counter) Area

The TC area is used to create and program timers and counters and holds the Completion flags, set values (SV), and present values (PV) for all timers and counters. All of these are accessed through TC numbers ranging from TC 000 through TC 511. Each TC number is defined as either a timer or counter using one of the following instructions: TIM, TIMH, CNT, CNTR(12), and TTIM(87). No prefix is required when using a TC number in a timer or counter instruction.

Once a TC number has been defined using one of these instructions, it cannot be redefined elsewhere in the program either using the same or a different instruction. If the same TC number is defined in more than one of these instructions or in the same instruction twice, an error will be generated during the program check. There are no restrictions on the order in which TC numbers can be used.

Once defined, a TC number can be designated as an operand in one or more of certain set of instructions other than those listed above. When defined as a timer, a TC number designated as an operand takes a TIM prefix. The TIM prefix is used regardless of the timer instruction that was used to define the timer. Once defined as a counter, the TC number designated as an operand takes a CNT prefix. The CNT is also used regardless of the counter instruction that was used to define the counter.

TC numbers can be designated for operands that require bit data or for operands that require word data. When designated as an operand that requires bit data, the TC number accesses the completion flag of the timer or counter. When designated as an operand that requires word data, the TC number accesses a memory location that holds the PV of the timer or counter.

TC numbers are also used to access the SV of timers and counters from a Programming Device. The procedures for doing so using the Programming Console are provided in 7-1 Monitoring Operation and Modifying Data.

The TC area retains the SVs of both timers and counters during power interruptions. The PVs of timers are reset when PC operation is begun and when reset in interlocked program sections, but the PVs of counters are retained. Refer to 5-10 INTERLOCK and INTERLOCK CLEAR – IL(02) and ILC(03) for details on timer and counter operation in interlocked program sections. The PVs of counters are not reset at these times.

Note that in programming "TIM 000" is used to designate three things: the Timer instruction defined with TC number 000, the completion flag for this timer, and the PV of this timer. The meaning in context should be clear, i.e., the first is always an instruction, the second is always a bit, and the third is always a word. The same is true of all other TC numbers prefixed with TIM or CNT.

3-9 LR (Link Relay) Area

The LR area is used as a common data area to transfer information between PCs. This data transfer is achieved through a PC Link System.

Certain words will be allocated as the write words of each PC. These words are written by the PC and automatically transferred to the same LR words in the other PCs in the System. The write words of the other PCs are transferred in as read words so that each PC can access the data written by the other PCs in the PC Link System. Only the write words allocated to the particular PC will be available for writing; all other words may be read only. Refer to the *PC Link System Manual* for details.

The LR area is accessible either by bit or by word. LR area word addresses range from LR 00 to LR 63; LR area bit addresses, from LR 0000 to LR 6315. Any part of the LR area that is not used by the PC Link System can be used as work words or for SYSMAC NET Link or SYSMAC LINK Systems.


LR area data is not retained when the power is interrupted, when the PC is changed to PROGRAM mode, or when it is reset in an interlocked program section. Refer to 5-10 INTERLOCK and INTERLOCK CLEAR – IL(02) and ILC(03) for details on interlocks.

UM Area Section 3-10

3-10 UM Area

With the C200HX/HG/HE PCs, the UM area contains the ladder program. Part of the UM area can be allocated for use as expansion DM or the I/O comment area. The usable size of the UM area ranges from 3.2 KW in the C200HE-CPU11-E to 31.2 KW in the C200HX-CPU \square 4-E.

A Programming Console or SYSMAC Support Software (SSS) can be used to allocate expansion DM, but the I/O comment area can be allocated with SSS only. The structure of the DM and UM areas is shown in the following illustration.



Note Refer to the SYSMAC Support Software (SSS) Manual for details on using SSS to allocate UM for expansion DM or I/O comments. Refer to 7-2-15 UM Area Allocation for details on using the Programming Console to allocate UM for expansion DM.

Area	Function
Normal DM	This area can be used freely for calculations and programming instructions. DM can be accessed in word units only.
	DM 1000 through DM 2599 are assigned to Special I/O Units when Special I/O Units are being used, but can be used as normal DM when the Special I/O Unit Area has been set to DM 7000 through DM 8599 in the PC Setup (DM 6602).
PC Setup	The PC Setup contains various settings that control PC operation.
Reserved	This area is reserved for system use. It cannot be accessed by the user.
Expansion DM	This area contains initialing data such as Special I/O Unit data, numerical or character string tables for PTs, and calculation data. Data can't be read directly from the expansion DM area as it can from normal DM.
	Expansion DM can be overwritten by performing the Hexadecimal/BCD Data Modification operation from a Programming Console or by transferring edited DM data from SYSMAC Support Software.
I/O comment	This area is used to store I/O comments, which can be saved together with the program. The I/O comments will be automatically uploaded with the program and automatically allocated to that monitoring can be perform with I/O comments.
Ladder program	This area is used to store the ladder program created by the user. UM area words allocated to expansion DM and/or the I/O Comment Area are taken from the ladder program area.

Note

- 1. The ladder program area is reduced proportionately when UM area words are allocated to expansion DM and/or the I/O Comment Area. Make sure that there is enough excess capacity in the ladder program area before allocating memory to expansion DM and/or the I/O Comment Area.
- The default setting for the UM area doesn't have any memory allocated to expansion DM or the I/O Comment Area. This memory must be allocated by the user as required.

3-11 TR (Temporary Relay) Area

The TR area provides eight bits that are used only with the LD and OUT instructions to enable certain types of branching ladder diagram programming. The use of TR bits is described in *Section 4 Writing and Inputting the Program*.

TR addresses range from TR 0 though TR 7. Each of these bits can be used as many times as required and in any order required as long as the same LR bit is not used twice in the same instruction block.

3-12 EM (Extended Data Memory) Area

In addition to the high-capacity DM area, C200HG and C200HX PCs are equipped with an EM area that can store up to 18K-words of data. The EM area is divided into banks which contain 6,144 words each (EM 0000 through EM 6143). The C200HG PCs have one bank (bank 0) and the C200HX PCs have three banks (banks 0, 1, and 2). The effective bank is called the current bank


3-12-1 Using the EM Area

The EM area can't be accessed directly by most instructions, but the PCs are provided with the EMBC(—), XFR2(—), BXF2(—), and IEMS(—) instructions to manage EM area data.

Instruction	Function
EMBC(—)	Changes the current bank to the specified bank number.
XFR2(—)	Transfers data within the current EM bank or between the current EM bank and one of the regular data areas.
BXF2(—)	Transfers data between the specified EM bank and another EM bank or a regular data area.
IEMS(—)	Switches the destination of indirect addressing (*DM) to the specified EM bank. Can also switch the destination back to DM.

Example 1

The following example uses EMBC(—) to set the current bank to bank 1 and XFR2(—) to transfer the contents of EM 2000 through EM 2999 to DM 0000 through DM 0999. After execution of a program section, the contents of DM 0000 through DM 0999 are transferred back to EM 2000 through EM 2999.




Note If BXF2(—) were used to perform the data transfers, any EM bank could be specified and EMBC(—) would not be required to select EM bank 1.

Example 2

The following example uses IEMS(—) to change the destination for indirect addressing (*DM) to EM bank 1. After this instruction is executed, *DM operands

access words in EM bank 1 and not the DM area. In this case, the second operand in the MOV(21) instruction transfers #1234 to a word in the EM bank. (For example, #1234 will be moved to EM 0100 if DM 0000 contains 0100.)

Later in the program, the destination for indirect addressing (*DM) is switched back to the DM area by executing IEMS(—) with an operand of 000.



Note

- 1. Be sure to return the indirect addressing destination to its default (the DM area) when necessary. The destination will be returned to the DM area automatically at the beginning of the next cycle.
- The destination for indirect addressing reverts to the DM area at the start of interrupt subroutines, but can be changed within a subroutine. The destination is returned to its original setting when control is returned to the main program.

3-12-2 The Current EM Bank

The current EM bank is set to bank 0 when the PC is turned on, and the current EM bank can be changed by EMBC(—) or IEMS(—). Unlike the destination for indirect addressing, the current bank number is not initialized at the start of a cycle or the start of an interrupt subroutine.

After the PC has been turned ON, the switched bank status will be resumed after the PC mode is changed or execution of an interrupt subroutine is completed.

SECTION 4

Writing and Inputting the Program

This section explains the basic steps and concepts involved in writing a basic ladder diagram program, inputting the program into memory, and executing it. It introduces the instructions that are used to build the basic structure of the ladder diagram and control its execution. The entire set of instructions used in programming is described in *Section 5 Instruction Set*.

4-1	Basic Procedure				
4-2		ion Terminology			
4-3	Progran	n Capacity			
4-4	Basic L	adder Diagrams			
	4-4-1	Basic Terms			
	4-4-2	Mnemonic Code			
	4-4-3	Ladder Instructions			
	4-4-4	OUTPUT and OUTPUT NOT			
	4-4-5	The END Instruction			
	4-4-6	Logic Block Instructions			
	4-4-7	Coding Multiple Right-hand Instructions			
4-5	The Pro	gramming Console			
	4-5-1	The Keyboard 88			
	4-5-2	PC Modes 9			
	4-5-3	The Display Message Switch			
4-6	Prepara	tion for Operation			
	4-6-1	Entering the Password			
	4-6-2	Buzzer			
	4-6-3	Clearing Memory			
	4-6-4	Registering the I/O Table			
	4-6-5	Clearing Error Messages			
	4-6-6	Verifying the I/O Table9'			
	4-6-7	Reading the I/O Table			
	4-6-8	Clearing the I/O Table			
	4-6-9	SYSMAC NET Link Table Transfer			
4-7	Inputting, Modifying, and Checking the Program				
	4-7-1	Setting and Reading from Program Memory Address			
	4-7-2	Entering and Editing Programs			
	4-7-3	Checking the Program			
	4-7-4	Displaying the Cycle Time			
	4-7-5	Program Searches			
	4-7-6	Inserting and Deleting Instructions			
	4-7-7	Branching Instruction Lines			
	4-7-8	Jumps			
4-8	Control	ling Bit Status			
	4-8-1	DIFFERENTIATE UP and DIFFERENTIATE DOWN			
	4-8-2	KEEP			
	4-8-3	Self-maintaining Bits (Seal)			
4-9	Work B	its (Internal Relays)			
4-10	Progran	nming Precautions			
4-11		n Execution			
4-12	Special	I/O Unit Interface Programs			
	4-12-1	Restarting Special I/O Units			
	4-12-2	Special I/O Unit Error Processing Program			
	4-12-3	Changing the Special I/O Unit Settings			
	4-12-4	Special I/O Unit I/O Refreshing Interval			
	4-12-5	Reducing the Cycle Time			
4-13		Timer Unit Programming			
	4-13-1	Operation 130			
	4-13-2	Bit Allocation and DIP Switch Settings			
	4-13-3	Example Program			

4-1 Basic Procedure

There are several basic steps involved in writing a program. Sheets that can be copied to aid in programming are provided in *Appendix F Word Assignment Recording Sheets* and *Appendix G Program Coding Sheet*.

- 1. Obtain a list of all I/O devices and the I/O points that have been assigned to them and prepare a table that shows the I/O bit allocated to each I/O device.
 - 2. If the PC has any Units that are allocated words in data areas other than the IR area or are allocated IR words in which the function of each bit is specified by the Unit, prepare similar tables to show what words are used for which Units and what function is served by each bit within the words. These Units include Special I/O Units and Link Units.
 - 3. Determine what words are available for work bits and prepare a table in which you can allocate these as you use them.
 - 4. Also prepare tables of TC numbers and jump numbers so that you can allocate these as you use them. Remember, the function of a TC number can be defined only once within the program; jump numbers 01 through 99 can be used only once each. (TC numbers are described in 5-14 Timer and Counter Instructions; jump numbers are described later in this section.)
 - 5. Draw the ladder diagram.
 - 6. Input the program into the CPU Unit. When using the Programming Console, this will involve converting the program to mnemonic form.
 - 7. Check the program for syntax errors and correct these.
 - 8. Execute the program to check for execution errors and correct these.
 - 9. After the entire Control System has been installed and is ready for use, execute the program and fine tune it if required.
 - 10. Make a backup copy of the program.

The basics of ladder-diagram programming and conversion to mnemonic code are described in 4-4 Basic Ladder Diagrams. Preparing for and inputting the program via the Programming Console are described in 4-5 The Programming Console through 4-7 Inputting, Modifying, and Checking the Program. The rest of Section 4 covers more advanced programming, programming precautions, and program execution. All special application instructions are covered in Section 5 Instruction Set. Debugging is described in Section 7 Program Monitoring and Execution. Section 9 Troubleshooting also provides information required for debugging.

4-2 Instruction Terminology


There are basically two types of instructions used in ladder-diagram programming: instructions that correspond to the conditions on the ladder diagram and are used in instruction form only when converting a program to mnemonic code and instructions that are used on the right side of the ladder diagram and are executed according to the conditions on the instruction lines leading to them.

Most instructions have at least one or more operands associated with them. Operands indicate or provide the data on which an instruction is to be performed. These are sometimes input as the actual numeric values, but are usually the addresses of data area words or bits that contain the data to be used. For instance, a MOVE instruction that has IR 000 designated as the source operand will move the contents of IR 000 to some other location. The other location is also designated as an operand. A bit whose address is designated as an operand is called an operand bit; a word whose address is designated as an operand is called an operand word. If the actual value is entered as a constant, it is preceded by # to indicate that it is not an address.

Other terms used in describing instructions are introduced in *Section 5 Instruction Set*.


4-3 Program Capacity

The maximum user program size varies with the amount of UM allocated to expansion DM and the I/O Comment Area. Approximately 10.1 KW are available for the ladder program when 3 KW are allocated to expansion DM and 2 KW are allocated to I/O comments as shown below. Refer to the *3-10 UM Area* for further information on UM allocation.



4-4 Basic Ladder Diagrams

A ladder diagram consists of one line running down the left side with lines branching off to the right. The line on the left is called the bus bar; the branching lines, instruction lines or rungs. Along the instruction lines are placed conditions that lead to other instructions on the right side. The logical combinations of these conditions determine when and how the instructions at the right are executed. A ladder diagram is shown below.




As shown in the diagram above, instruction lines can branch apart and they can join back together. The vertical pairs of lines are called conditions. Conditions without diagonal lines through them are called normally open conditions and correspond to a LOAD, AND, or OR instruction. The conditions with diagonal lines through them are called normally closed conditions and correspond to a LOAD NOT, AND NOT, or OR NOT instruction. The number above each condition indicates the operand bit for the instruction. It is the status of the bit associated with each condition that determines the execution condition for following instructions. The way the operation of each of the instructions corresponds to a condition is described below. Before we consider these, however, there are some basic terms that must be explained.

Note When displaying ladder diagrams with SSS, a second bus bar will be shown on the right side of the ladder diagram and will be connected to all instructions on the right side. This does not change the ladder-diagram program in any functional sense. No conditions can be placed between the instructions on the right side and the right bus bar, i.e., all instructions on the right must be connected directly to the right bus bar. Refer to the SSS Operation Manual: C Series for details.

4-4-1 Basic Terms

Normally Open and Normally Closed Conditions Each condition in a ladder diagram is either ON or OFF depending on the status of the operand bit that has been assigned to it. A normally open condition is ON if the operand bit is ON; OFF if the operand bit is OFF. A normally closed condition is ON if the operand bit is OFF; OFF if the operand bit is ON. Generally speaking, you use a normally open condition when you want something to happen when a bit is ON, and a normally closed condition when you want something to happen when a bit is OFF.



Execution Conditions

In ladder diagram programming, the logical combination of ON and OFF conditions before an instruction determines the compound condition under which the instruction is executed. This condition, which is either ON or OFF, is called the execution condition for the instruction. All instructions other than LOAD instructions have execution conditions.

Operand Bits

The operands designated for any of the ladder instructions can be any bit in the IR, SR, HR, AR, LR, or TC areas. This means that the conditions in a ladder diagram can be determined by I/O bits, flags, work bits, timers/counters, etc. LOAD and OUTPUT instructions can also use TR area bits, but they do so only in special applications. Refer to *4-7-7 Branching Instruction Lines* for details.

Logic Blocks

The way that conditions correspond to what instructions is determined by the relationship between the conditions within the instruction lines that connect them. Any group of conditions that go together to create a logic result is called a logic block. Although ladder diagrams can be written without actually analyzing individual logic blocks, understanding logic blocks is necessary for efficient programming and is essential when programs are to be input in mnemonic code.

4-4-2 Mnemonic Code

The ladder diagram cannot be directly input into the PC via a Programming Console; SSS is required. To input from a Programming Console, it is necessary to convert the ladder diagram to mnemonic code. The mnemonic code provides exactly the same information as the ladder diagram, but in a form that can be typed directly into the PC. Actually you can program directly in mnemonic code, although it in not recommended for beginners or for complex programs. Also, regardless of the Programming Device used, the program is stored in memory in mnemonic form, making it important to understand mnemonic code.

Because of the importance of the Programming Console as a peripheral device and because of the importance of mnemonic code in complete understanding of a program, we will introduce and describe the mnemonic code along with the ladder diagram. Remember, you will not need to use the mnemonic code if you are inputting via SSS (although you can use it with SSS too, if you prefer).

Program Memory Structure

The program is input into addresses in Program Memory. Addresses in Program Memory are slightly different to those in other memory areas because each address does not necessarily hold the same amount of data. Rather, each address holds one instruction and all of the definers and operands (described in more detail later) required for that instruction. Because some instructions require no operands, while others require up to three operands, Program Memory addresses can be from one to four words long.

Program Memory addresses start at 00000 and run until the capacity of Program Memory has been exhausted. The first word at each address defines the instruction. Any definers used by the instruction are also contained in the first word. Also, if an instruction requires only a single bit operand (with no definer), the bit operand is also programmed on the same line as the instruction. The rest of the words required by an instruction contain the operands that specify what data is to be used. When converting to mnemonic code, all but ladder diagram instructions are written in the same form, one word to a line, just as they appear in the ladder diagram symbols. An example of mnemonic code is shown below. The instructions used in it are described later in the manual.

Address	Instruction	Oper	ands
00000	LD	HR	0001
00001	AND		00001
00002	OR		00002
00003	LD NOT		00100
00004	AND		00101
00005	AND LD		00102
00006	MOV(21)		
			000
		DM	0000
00007	CMP(20)		
		DM	0000
		HR	00
80000	LD		25505
00009	OUT		00501
00010	MOV(21)		
		DM	0000
		DM	0500
00011	DIFU(13)		00502
00012	AND		00005
00013	OUT		00503

The address and instruction columns of the mnemonic code table are filled in for the instruction word only. For all other lines, the left two columns are left blank. If the instruction requires no definer or bit operand, the operand column is left blank for first line. It is a good idea to cross through any blank data column spaces (for all instruction words that do not require data) so that the data column can be quickly scanned to see if any addresses have been left out.


When programming, addresses are automatically displayed and do not have to be input unless for some reason a different location is desired for the instruction. When converting to mnemonic code, it is best to start at Program Memory address 00000 unless there is a specific reason for starting elsewhere.

4-4-3 Ladder Instructions

The ladder instructions are those instructions that correspond to the conditions on the ladder diagram. Ladder instructions, either independently or in combination with the logic block instructions described next, form the execution conditions upon which the execution of all other instructions are based.

LOAD and LOAD NOT

The first condition that starts any logic block within a ladder diagram corresponds to a LOAD or LOAD NOT instruction. Each of these instruction requires one line of mnemonic code. "Instruction" is used as a dummy instruction in the following examples and could be any of the right-hand instructions described later in this manual.




Address	Instruction	Operands
00000	LD	00000
00001	Instruction	
00002	LD NOT	00000
00003	Instruction	

When this is the only condition on the instruction line, the execution condition for the instruction at the right is ON when the condition is ON. For the LOAD instruction (i.e., a normally open condition), the execution condition will be ON when IR 00000 is ON; for the LOAD NOT instruction (i.e., a normally closed condition), it will be ON when 00000 is OFF.

AND and AND NOT

When two or more conditions lie in series on the same instruction line, the first one corresponds to a LOAD or LOAD NOT instruction; and the rest of the conditions correspond to AND or AND NOT instructions. The following example shows three conditions which correspond in order from the left to a LOAD, an AND NOT, and an AND instruction. Again, each of these instructions requires one line of mnemonic code.



Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00100
00002	AND	LR 0000
00003	Instruction	


The instruction will have an ON execution condition only when all three conditions are ON, i.e., when IR 00000 is ON, IR 00100 is OFF, and LR 0000 is ON.

AND instructions in series can be considered individually, with each taking the logical AND of the execution condition (i.e., the total of all conditions up to that point) and the status of the AND instruction's operand bit. If both of these are ON, an ON execution condition will be produced for the next instruction. If either is OFF, the result will also be OFF. The execution condition for the first AND instruction in a series is the first condition on the instruction line.

Each AND NOT instruction in series takes the logical AND of its execution condition and the inverse of its operand bit.

OR and OR NOT

When two or more conditions lie on separate instruction lines which run in parallel and then join together, the first condition corresponds to a LOAD or LOAD NOT instruction; the other conditions correspond to OR or OR NOT instructions. The following example shows three conditions which correspond (in order from the top) to a LOAD NOT, an OR NOT, and an OR instruction. Again, each of these instructions requires one line of mnemonic code.



Address	Instruction	Opera	ands
00000	LD NOT		00000
00001	OR NOT		00100
00002	OR	LR	0000
00003	Instruction		

The instruction will have an ON execution condition when any one of the three conditions is ON, i.e., when IR 00000 is OFF, when IR 00100 is OFF, or when LR 0000 is ON.

OR and OR NOT instructions can be considered individually, each taking the logical OR between its execution condition and the status of the OR instruction's operand bit. If either one of these were ON, an ON execution condition will be produced for the next instruction.

Combining AND and OR Instructions

When AND and OR instructions are combined in more complicated diagrams, they can sometimes be considered individually, with each instruction performing a logic operation on the execution condition and the status of the operand bit. The following is one example. Study this example until you are convinced that the mnemonic code follows the same logic flow as the ladder diagram.




Address	Instruction	Operands
00000	LD	00000
00001	AND	00001
00002	OR	00200
00003	AND	00002
00004	AND NOT	00003
00005	Instruction	

Here, an AND is taken between the status of IR 00000 and that of IR 00001 to determine the execution condition for an OR with the status of IR 00200. The result of this operation determines the execution condition for an AND with the status of IR 00002, which in turn determines the execution condition for an AND with the inverse (i.e., and AND NOT) of the status of IR 00003.

In more complicated diagrams, however, it is necessary to consider logic blocks before an execution condition can be determined for the final instruction, and that's where AND LOAD and OR LOAD instructions are used. Before we consider more complicated diagrams, however, we'll look at the instructions required to complete a simple "input-output" program.

4-4-4 OUTPUT and OUTPUT NOT

The simplest way to output the results of combining execution conditions is to output it directly with the OUTPUT and OUTPUT NOT. These instructions are used to control the status of the designated operand bit according to the execution condition. With the OUTPUT instruction, the operand bit will be turned ON as long as the execution condition is ON and will be turned OFF as long as the execution condition is OFF. With the OUTPUT NOT instruction, the operand bit will be turned ON as long as the execution condition is OFF and turned OFF as long as the execution condition is ON. These appear as shown below. In mnemonic code, each of these instructions requires one line.



Address	Instruction	Operands
00000	LD	00000
00001	OUT	00200


Address	Instruction	Operands
00000	LD	00001
00001	OUT NOT	00201

In the above examples, IR 00200 will be ON as long as IR 00000 is ON and IR 00201 will be OFF as long as IR 00001 is ON. Here, IR 00000 and IR 00001 will be input bits and IR 00200 and IR 00201 output bits assigned to the Units controlled by the PC, i.e., the signals coming in through the input points assigned IR 00000 and IR 00001 are controlling the output points assigned IR 00200 and IR 00201, respectively.

The length of time that a bit is ON or OFF can be controlled by combining the OUTPUT or OUTPUT NOT instruction with TIMER instructions. Refer to Examples under 5-14-1 TIMER – TIM for details.

4-4-5 The END Instruction

The last instruction required to complete a simple program is the END instruction. When the CPU Unit cycles the program, it executes all instruction up to the first END instruction before returning to the beginning of the program and beginning execution again. Although an END instruction can be placed at any point in a program, which is sometimes done when debugging, no instructions past the first END instruction will be executed until it is removed. The number following the END instruction in the mnemonic code is its function code, which is used when inputted most instruction into the PC. These are described later. The END instruction requires no operands and no conditions can be placed on the same instruction line with it.



If there is no END instruction anywhere in the program, the program will not be executed at all.


Now you have all of the instructions required to write simple input-output programs. Before we finish with ladder diagram basic and go onto inputting the program into the PC, let's look at logic block instruction (AND LOAD and OR LOAD), which are sometimes necessary even with simple diagrams.

4-4-6 Logic Block Instructions

Logic block instructions do not correspond to specific conditions on the ladder diagram; rather, they describe relationships between logic blocks. The AND LOAD instruction logically ANDs the execution conditions produced by two logic blocks. The OR LOAD instruction logically ORs the execution conditions produced by two logic blocks.

AND LOAD

Although simple in appearance, the diagram below requires an AND LOAD instruction.



Address	Instruction	Operands
00000	LD	00000
00001	OR	00001
00002	LD	00002
00003	OR NOT	00003
00004	AND LD	
00005	Instruction	

The two logic blocks are indicated by dotted lines. Studying this example shows that an ON execution condition will be produced when: either of the conditions in the left logic block is ON (i.e., when either IR 00000 or IR 00001 is ON), **and** when either of the conditions in the right logic block is ON (i.e., when either IR 00002 is ON or IR 00003 is OFF).


The above ladder diagram cannot, however, be converted to mnemonic code using AND and OR instructions alone. If an AND between IR 00002 and the results of an OR between IR 00000 and IR 00001 is attempted, the OR NOT between IR 00002 and IR 00003 is lost and the OR NOT ends up being an OR NOT between just IR 00003 and the result of an AND between IR 00002 and the first OR. What we need is a way to do the OR (NOT)'s independently and then combine the results.

To do this, we can use the LOAD or LOAD NOT instruction in the middle of an instruction line. When LOAD or LOAD NOT is executed in this way, the current execution condition is saved in a special buffer and the logic process is restarted. To combine the results of the current execution condition with that of a previous "unused" execution condition, an AND LOAD or an OR LOAD instruction is used. Here "LOAD" refers to loading the last unused execution condition. An unused execution condition is produced by using the LOAD or LOAD NOT instruction for any but the first condition on an instruction line.

Analyzing the above ladder diagram in terms of mnemonic instructions, the condition for IR 00000 is a LOAD instruction and the condition below it is an OR instruction between the status of IR 00000 and that of IR 00001. The condition at IR 00002 is another LOAD instruction and the condition below is an OR NOT instruction, i.e., an OR between the status of IR 00002 and the inverse of the status of IR 00003. To arrive at the execution condition for the instruction at the right, the logical AND of the execution conditions resulting from these two blocks will have to be taken. AND LOAD does this. The mnemonic code for the ladder diagram is shown below. The AND LOAD instruction requires no operands of its own, because it operates on previously determined execution conditions. Here too, dashes are used to indicate that no operands needs designated or input.

OR LOAD

The following diagram requires an OR LOAD instruction between the top logic block and the bottom logic block. An ON execution condition will be produced for the instruction at the right either when IR 00000 is ON and IR 00001 is OFF, or when IR 00002 and IR 00003 are both ON. The operation of the OR LOAD instruction and its mnemonic code are exactly the same as that for an AND LOAD instruction, except that the current execution condition is **ORed** with the last unused execution condition.




Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00001
00002	LD	00002
00003	AND	00003
00004	OR LD	
00005	Instruction	

Naturally, some diagrams will require both AND LOAD and OR LOAD instructions.

Logic Block Instructions in Series

To code diagrams with logic block instructions in series, the diagram must be divided into logic blocks. Each block is coded using a LOAD instruction to code the first condition, and then AND LOAD or OR LOAD is used to logically combine the blocks. With both AND LOAD and OR LOAD there are two ways to achieve this. One is to code the logic block instruction after the first two blocks and then after each additional block. The other is to code all of the blocks to be combined, starting each block with LOAD or LOAD NOT, and then to code the logic block instructions which combine them. In this case, the instructions for the last pair of blocks should be combined, working progressively back to the first block. Although either of these methods will produce exactly the same result, the second method, that of coding all logic block instructions together, can be used only if eight or fewer blocks are being combined, i.e., if seven or fewer logic block instructions are required.

The following diagram requires AND LOAD to be converted to mnemonic code because three pairs of parallel conditions lie in series. The two options for coding the programs are also shown.




Address	Instruction	Operands
00000	LD	00000
00001	OR NOT	00001
00002	LD NOT	00002
00003	OR	00003
00004	AND LD	
00005	LD	00004
00006	OR	00005
00007	AND LD	_
80000	OUT	00500

Address	Instruction	Operands
00000	LD	00000
00001	OR NOT	00001
00002	LD NOT	00002
00003	OR	00003
00004	LD	00004
00005	OR	00005
00006	AND LD	
00007	AND LD	
80000	OUT	00500

Again, with the method on the right, a maximum of eight blocks can be combined. There is no limit to the number of blocks that can be combined with the first method.

The following diagram requires OR LOAD instructions to be converted to mnemonic code because three pairs of series conditions lie in parallel to each other.



The first of each pair of conditions is converted to LOAD with the assigned bit operand and then ANDed with the other condition. The first two blocks can be coded first, followed by OR LOAD, the last block, and another OR LOAD; or the three blocks can be coded first followed by two OR LOADs. The mnemonic codes for both methods are shown below.

Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00001
00002	LD NOT	00002
00003	AND NOT	00003
00004	OR LD	
00005	LD	00004
00006	AND	00005
00007	OR LD	_
00008	OUT	00501


Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00001
00002	LD NOT	00002
00003	AND NOT	00003
00004	LD	00004
00005	AND	00005
00006	OR LD	_
00007	OR LD	
80000	OUT	00501

Again, with the method on the right, a maximum of eight blocks can be combined. There is no limit to the number of blocks that can be combined with the first method.

Combining AND LOAD and OR LOAD

Both of the coding methods described above can also be used when using AND LOAD and OR LOAD, as long as the number of blocks being combined does not exceed eight.


The following diagram contains only two logic blocks as shown. It is not necessary to further separate block b components, because it can be coded directly using only AND and OR.



Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00001
00002	LD	00002
00003	AND	00003
00004	OR	00201
00005	OR	00004
00006	AND LD	_
00007	OUT	00501

Although the following diagram is similar to the one above, block b in the diagram below cannot be coded without separating it into two blocks combined with OR LOAD. In this example, the three blocks have been coded first and then OR LOAD has been used to combine the last two blocks, followed by AND LOAD to combine the execution condition produced by the OR LOAD with the execution condition of block a.

When coding the logic block instructions together at the end of the logic blocks they are combining, they must, as shown below, be coded in reverse order, i.e., the logic block instruction for the last two blocks is coded first, followed by the one to combine the execution condition resulting from the first logic block instruction and the execution condition of the logic block third from the end, and on back to the first logic block that is being combined.




Address	Instruction	Operands
00000	LD NOT	00000
00001	AND	00001
00002	LD	00002
00003	AND NOT	00003
00004	LD NOT	00004
00005	AND	00202
00006	OR LD	
00007	AND LD	
00008	OUT	00502

Complicated Diagrams

When determining what logic block instructions will be required to code a diagram, it is sometimes necessary to break the diagram into large blocks and then continue breaking the large blocks down until logic blocks that can be coded without logic block instructions have been formed. These blocks are then coded, combining the small blocks first, and then combining the larger blocks. Either AND LOAD or OR LOAD is used to combine the blocks, i.e., AND LOAD or OR LOAD always combines the last two execution conditions that existed, regardless of whether the execution conditions resulted from a single condition, from logic blocks, or from previous logic block instructions.


When working with complicated diagrams, blocks will ultimately be coded starting at the top left and moving down before moving across. This will generally mean that, when there might be a choice, OR LOAD will be coded before AND LOAD.

The following diagram must be broken down into two blocks and each of these then broken into two blocks before it can be coded. As shown below, blocks a and b require an AND LOAD. Before AND LOAD can be used, however, OR LOAD must be used to combine the top and bottom blocks on both sides, i.e., to combine a1 and a2; b1 and b2.




Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00001
00002	LD NOT	00002
00003	AND	00003
00004	OR LD	_
00005	LD	00004
00006	AND	00005
00007	LD	00006
00008	AND	00007
00009	OR LD	_
00010	AND LD	_
00011	OUT	00503

The following type of diagram can be coded easily if each block is coded in order: first top to bottom and then left to right. In the following diagram, blocks a and b would be combined using AND LOAD as shown above, and then block c would be coded and a second AND LOAD would be used to combined it with the execution condition from the first AND LOAD. Then block d would be coded, a third AND LOAD would be used to combine the execution condition from block d with the execution condition from the second AND LOAD, and so on through to block n.




The following diagram requires an OR LOAD followed by an AND LOAD to code the top of the three blocks, and then two more OR LOADs to complete the mnemonic code.




Address	Instruction	Operands
00000	LD	00000
00001	LD	00001
00002	LD	00002
00003	AND NOT	00003
00004	OR LD	
00005	AND LD	
00006	LD NOT	00004
00007	AND	00005
80000	OR LD	
00009	LD NOT	00006
00010	AND	00007
00011	OR LD	_
00012	OUT	LR 0000

Although the program will execute as written, this diagram could be drawn as shown below to eliminate the need for the first OR LOAD and the AND LOAD, simplifying the program and saving memory space.




Address	Instruction	Operands
00000	LD	00002
00001	AND NOT	00003
00002	OR	00001
00003	AND	00000
00004	LD NOT	00004
00005	AND	00005
00006	OR LD	_
00007	LD NOT	00006
80000	AND	00007
00009	OR LD	_
00010	OUT	LR 0000

The following diagram requires five blocks, which here are coded in order before using OR LOAD and AND LOAD to combine them starting from the last two blocks and working backward. The OR LOAD at program address 00008 combines blocks blocks d and e, the following AND LOAD combines the resulting execution condition with that of block c, etc.




Address	Instruction	Operands
00000	LD	00000
00001	LD	00001
00002	AND	00002
00003	LD	00003
00004	AND	00004
00005	LD	00005
00006	LD	00006
00007	AND	00007
80000	OR LD	
00009	AND LD	
00010	OR LD	
00011	AND LD	
00012	OUT	LR 0000

Again, this diagram can be redrawn as follows to simplify program structure and coding and to save memory space.




Address	Instruction	Operands
00000	LD	00006
00001	AND	00007
00002	OR	00005
00003	AND	00003
00004	AND	00004
00005	LD	00001
00006	AND	00002
00007	OR LD	_
80000	AND	00000
00009	OUT	LR 0000

The next and final example may at first appear very complicated but can be coded using only two logic block instructions. The diagram appears as follows:




The first logic block instruction is used to combine the execution conditions resulting from blocks a and b, and the second one is to combine the execution condition of block c with the execution condition resulting from the normally closed condition assigned IR 00003. The rest of the diagram can be coded with OR, AND, and AND NOT instructions. The logical flow for this and the resulting code are shown below.



Address	Instruction	Operands
00000	LD	00000
00001	AND	00001
00002	LD	01000
00003	AND	01001
00004	OR LD	_
00005	OR	00500
00006	AND	00002
00007	AND NOT	00003
80000	LD	00004
00009	AND	00005
00010	OR	00006
00011	AND LD	_
00012	OUT	00500

4-4-7 Coding Multiple Right-hand Instructions

If there is more than one right-hand instruction executed with the same execution condition, they are coded consecutively following the last condition on the instruction line. In the following example, the last instruction line contains one more condition that corresponds to an AND with IR 00004.



Address	Instruction	Operands
00000	LD	00000
00001	OR	00001
00002	OR	00002
00003	OR	HR 0000
00004	AND	00003
00005	OUT	HR 0001
00006	OUT	00500
00007	AND	00004
80000	OUT	00506

4-5 The Programming Console

This and the next section describe the Programming Console and the operations necessary to prepare for program input. *4-7 Inputting, Modifying, and Checking the Program* describes actual procedures for inputting the program into memory.

Although the Programming Console can be used to write ladder programs, it is primarily used to support SSS operations and is very useful for on-site editing and maintenance. The main Programming Console functions are listed below.

- 1, 2, 3... 1. Displaying operating messages and the results of diagnostic checks.
 - 2. Writing and reading ladder programs, inserting and deleting instructions, searching for data or instructions, and monitoring I/O bit status.
 - 3. Monitoring I/O status, force-setting/resetting bits.
 - 4. The Programming Console can be connected to or disconnected from the PC with the power on.
 - 5. The Programming Console can be used with C-series PCs.
 - 6. Supports TERMINAL mode, which allows the display of a 32-character message, as well as operation of the keyboard mapping function. Refer to 5-25-6 TERMINAL MODE TERM(—) for details.

Note The Programming Console does not support all of the SSS operations, only those required for on-site editing and maintenance.

4-5-1 The Keyboard

The keyboard of the Programming Console is functionally divided by key color into the following four areas:

White: Numeric Keys

The ten white keys are used to input numeric program data such as program addresses, data area addresses, and operand values. The numeric keys are also used in combination with the function key (FUN) to enter instructions with function codes. The numeral keys 0 to 5 are also pressed after the SHIFT key to input hexadecimal numerals A to F.

Red: CLR Key

The CLR key clears the display and cancels current Programming Console operations. It is also used when you key in the password at the beginning of programming operations. Any Programming Console operation can be cancelled by pressing the CLR key, although the CLR key may have to be pressed two or three times to cancel the operation and clear the display.

Yellow: Operation Keys

The yellow keys are used for writing and correcting programs. Detailed explanations of their functions are given later in this section.

Gray: Instruction and Data Area Keys

Except for the SHIFT key on the upper right, the gray keys are used to input instructions and designate data area prefixes when inputting or changing a program. The SHIFT key is similar to the shift key of a typewriter, and is used to alter the function of the next key pressed. (It is not necessary to hold the SHIFT key down; just press it once and then press the key to be used with it.)

The gray keys other than the SHIFT key have either the mnemonic name of the instruction or the abbreviation of the data area written on them. The functions of these keys are described below.

FUN	Pressed before the function code when inputting an instruction via its function code.	
SFT	Pressed to enter SFT (the Shift Register instruction).	
NOT	Input either after a function code to designate the differentiated form of an instruction or after a ladder instruction to designate an inverse condition.	
AND -II-	Pressed to enter AND (the AND instruction) or used with NOT to enter AND NOT.	
OR -H ²	Pressed to enter OR (the OR instruction) or used with NOT to enter OR NOT.	
CNT	Pressed to enter CNT (the Counter instruction) or to designate a TC number that has already been defined as a counter.	
LD HH	Pressed to enter LD (the Load instruction) or used with NOT tenter LD NOT. Also pressed to indicate an input bit.	
OUT —O→	Pressed to enter OUT (the Output instruction) or used with NOT to enter OUT NOT. Also pressed to indicate an output bit.	
ТІМ	Pressed to enter TIM (the Timer instruction) or to designate a TC number that has already been defined as a timer.	
TR	Pressed before designating an address in the TR area.	
LR	Pressed before designating an address in the LR area.	
HR	Pressed before designating an address in the HR area.	
SHIFT HR	Pressed before designating an address in the AR area.	
DM	Pressed before designating an address in the DM area.	
SHIFT DM	Pressed before designating an address in the EM area.	
CH *	Pressed before designating an indirect DM address.	
SHIFT CH *	Pressed before designating a word address.	
CONT #	Pressed before designating an operand as a constant.	
SHIFT CONT #	Pressed before designating a bit address.	
SHIFT	Pressed to select either the upper or lower function for keys that have two functions. Pressing this key once selects the upper function, and pressing it again selects the lower function. Selects expanded functions when used in combination with other keys. Pressed before the numeric keys 0 to 5 to input the hexadecimal numerals A to F.	

4-5-2 PC Modes

The Programming Console is equipped with a switch to control the PC mode. To select one of the three operating modes—RUN, MONITOR, or PROGRAM—use the mode switch. The mode that you select will determine PC operation as well as the procedures that are possible from the Programming Console.

RUN mode is the mode used for normal program execution. When the switch is set to RUN and the START input on the CPU Power Supply Unit is ON, the CPU Unit will begin executing the program according to the program written in its Program Memory. Although monitoring PC operation from the Programming Console is possible in RUN mode, no data in any of the memory areas can be input or changed.

MONITOR mode allows you to visually monitor in-progress program execution while controlling I/O status, changing PV (present values) or SV (set values), etc. In MONITOR mode, I/O processing is handled in the same way as in RUN mode. MONITOR mode is generally used for trial system operation and final program adjustments.

In PROGRAM mode, the PC does not execute the program. PROGRAM mode is for creating and changing programs, clearing memory areas, and registering and changing the I/O table. A special Debug operation is also available within PROGRAM mode that enables checking a program for correct execution before trial operation of the system.



Do not leave the Programming Console connected to the PC by an extension cable when in RUN mode. Noise picked up by the extension cable can enter the PC, affecting the program and thus the controlled system.

4-5-3 The Display Message Switch

Pin 3 of the CPU Unit's DIP switch determines whether Japanese or English language messages will be displayed on the Programming Console. It is factory set to ON, which causes English language messages to be displayed.

4-6 Preparation for Operation

This section describes the procedures required to begin Programming Console operation. These include password entry, clearing memory, error message clearing, and I/O table operations. I/O table operations are also necessary at other times, e.g., when changes are to be made in Units used in the PC configuration.




Always confirm that the Programming Console is in PROGRAM mode when turning on the PC with a Programming Console connected unless another mode is desired for a specific purpose. If the Programming Console is in RUN mode when PC power is turned on, any program in Program Memory will be executed, possibly causing a PC-controlled system to begin operation.

The following sequence of operations must be performed before beginning initial program input.

- 1, 2, 3... 1. Insert the mode key into the Programming Console.
 - 2. Set the mode switch to PROGRAM mode. (The mode key cannot be removed while set to PROGRAM mode.)
 - 3. Turn ON PC power.

Note When I/O Units are installed, turn on those Units also. The Programming Console will not operate if these Units are not turned ON.

4. Confirm that the CPU Unit's POWER LED is lit and the following display appears on the Programming Console screen. (If the PC mode is not displayed, turn OFF and restart the power supply. If the ALM/ERR LED is lit or flashing or an error message is displayed, clear the error that has occurred.)




- 5. Enter the password. See 4-6-1 Entering the Password for details.
- 6. Clear memory. Skip this step if the program does not need to be cleared. See *4-6-3 Clearing Memory* for details.

4-6-1 Entering the Password

To gain access to the PC's programming functions, you must first enter the password. The password prevents unauthorized access to the program.

The PC prompts you for a password when PC power is turned ON or, if PC power is already ON, after the Programming Console has been connected to the PC. To gain access to the system when the "Password!" message appears, press CLR and then MONTR. Then press CLR to clear the display.

If the Programming Console is connected to the PC when PC power is already ON, the first display below will indicate the mode the PC was in before the Programming Console was connected. **Ensure that the PC is in PROGRAM mode before you enter the password.** When the password is entered, the PC will shift to the mode set on the mode switch, causing PC operation to begin if the mode is set to RUN or MONITOR. The mode can be changed to RUN or MONITOR with the mode switch after entering the password.



Indicates the mode set by the mode selector switch.

4-6-2 Buzzer

Immediately after the password is input or anytime immediately after the mode has been changed, SHIFT and then the 1 key can be pressed to turn ON and OFF the buzzer that sounds when Programming Console keys are pressed. If BZ is displayed in the upper right corner, the buzzer is operative. If BZ is not displayed, the buzzer is not operative.

This buzzer also will also sound whenever an error occurs during PC operation. Buzzer operation for errors is not affected by the above setting.

4-6-3 Clearing Memory

Using the Memory Clear operation it is possible to clear all or part of the UM area (RAM or EEPROM), and the IR, HR, AR, DM, EM and TC areas. Unless otherwise specified, the clear operation will clear all of the above memory areas. The UM area will not be cleared if the write-protect switch (pin 1 of the CPU Unit's DIP switch) is set to ON.

Before beginning to programming for the first time or when installing a new program, all areas should normally be cleared. Before clearing memory, check to see if a program is already loaded that you need. If you need the program, clear only the memory areas that you do not need, and be sure to check the existing program with the program check key sequence before using it. The check sequence is provided later in this section. Further debugging methods are provided in *Section 7 Program Monitoring and Execution*. To clear all memory areas press CLR until all zeros are displayed, and then input the keystrokes given in the top line of the following key sequence. The branch lines shown in the sequence are used only when performing a partial memory clear, which is described below.


Memory can be cleared in PROGRAM mode only. The following table shows which memory areas will be cleared for the 3 memory clearing operations (all clear, partial clear, memory clear).

Memory Area	All clear	Partial clear	Memory clear
I/O words	Cleared	Cleared	Cleared
Work words	Cleared		Cleared
HR, AR, TC, DM, fixed DM	Cleared	Cleared	Cleared
Expansion DM	Cleared		Cleared
EM	Cleared	Cleared	Cleared
I/O comments	Cleared		
Ladder program	Cleared	Cleared	Cleared
UM Allocation information	Cleared		


Note

- 1. The error history area (DM 6000 to DM 6030) will not be cleared when the DM area is cleared.
- 2. When the PC Setup area (DM 6600 to DM 6655 in fixed DM) is cleared, the settings will be returned to their factory-set defaults.
- 3. When the All Clear operation is executed, the ladder program area will be allocated entirely to the ladder program. (The expansion DM and I/O comment areas will be set to 0 KW.) Also, all EM banks will be cleared.

The key sequence for all clear is shown below.



All Clear



The following procedure is used to clear memory completely.


Partial Clear

It is possible to retain the data in specified areas or part of the ladder program. To retain the data in the HR and AR, TC, DM, and/or EM areas, press the appropriate key after entering REC/RESET. HR is pressed to designate both the HR and AR areas. In other words, specifying that HR is to be retained will ensure that AR is retained also. If not specified for retention, both areas will be cleared. CNT is used for the entire TC area. Press Shift + DM to specify the EM area. The display will show those areas that will be cleared.


It is possible to retain some EM banks and clear others. See the explanation under the heading "Clearing Selected EM Banks" on page 95.

It is also possible to retain a portion of the ladder program from the beginning to a specified address. After designating the data areas to be retained, specify the first program address to be cleared. For example, to leave addresses 00000 to 00122 untouched, but to clear addresses from 00123 to the end of Program Memory, input 00123.

The key sequence for a partial memory clear is shown below.




To leave the TC area uncleared and retain Program Memory addresses 00000 through 00122, input as follows:



Clearing Selected EM Banks When a partial memory clear operation is being performed, specific banks can be selected for clearing rather than selecting the entire EM area. In the following example, EM banks 0 and 2 are selected for clearing.


The Programming Console will display the following screens:



Memory Clear

The memory clear operation clears all memory areas except the I/O comments and UM Allocation information.

The Programming Console will display the following screens:



Note When the write-protect switch (pin 1 of the CPU Unit's DIP switch) is set to ON the UM area (from DM 6144 through the ladder program) will not be cleared. Other data areas, such as HR, AR, CNT, and DM from DM 0000 to DM 6143 will be cleared.

4-6-4 Registering the I/O Table

The I/O Table Registration operation records the types of I/O Units controlled by the PC and the Rack locations of the I/O Units. It also clears all I/O bits.

It is not absolutely necessary to register the I/O table with the C200HX/HG/HE. When the I/O table has not been registered, the PC will operate according to the I/O Units mounted when power is applied. The I/O verification/setting error will not occur.


It is necessary to register the I/O table if I/O Units are changed, otherwise an I/O verification error message, "I/O VER ERR" or "I/O SET ERROR", will appear when starting programming operations.

I/O Table Registration can be performed only in PROGRAM mode with the write-protection switch (pin 1 of the CPU Unit's DIP switch) set to OFF (OFF="WRITE").

Key Sequence



Initial I/O Table Registration




4-6-5 Clearing Error Messages

After the I/O table has been registered, any error messages recorded in memory should be cleared. It is assumed here that the causes of any of the errors for which error messages appear have already been taken care of. If the beeper sounds when an attempt is made to clear an error message, eliminate the cause of the error, and then clear the error message (refer to Section 9 Troubleshooting).

To display any recorded error messages, press CLR, FUN, and then MONTR. The first message will appear. Pressing MONTR again will clear the present message and display the next error message. Continue pressing MONTR until all messages have been cleared.

Although error messages for fatal errors can be accessed in any mode, they can be cleared only in PROGRAM mode.

Key Sequence




4-6-6 Verifying the I/O Table


The I/O Table Verification operation is used to check the I/O table registered in memory to see if it matches the actual sequence of I/O Units mounted. The first inconsistency discovered will be displayed as shown below. Every subsequent pressing of **VER** displays the next inconsistency.

Note This operation can be executed only when the I/O table has been registered.

Key Sequence



Example



Meaning of Displays


The following display indicates a C500, C1000H, or C2000H and C200H, C200HS, or C200HX/HG/HE have the same unit number on a Remote I/O Slave Rack.

The following display indicates a duplication in Optical I/O Unit unit numbers.

4-6-7 Reading the I/O Table


The I/O Table Read operation is used to access the I/O table that is currently registered in the CPU Unit memory. This operation can be performed in any PC mode.

Key Sequence



Press the EXT key to select Remote I/O Slave Racks or Optical I/O Units.

Example



Meaning of Displays

I/O Unit Designations for Displays

(see I/O Units Mounted in Remote Slave Racks, page 101)

C500, 1000H/C2000H I/O Units


No. of points	In	put l	Jnit		0	utpu	t Uni	t
16	I	*	*	*	0	*	*	*
32	I	I	*	*	0	O	:#:	:#:
64	I	I	I	I	0	0	Ü	0

C200H, C200HS I/O Units


No. of points	Input Unit	Output Unit	
8	i(*)* *	0 * * *	
16	i i * *	0 0 * *	

Note: (*) is i for non-fatal errors or F_


I/O Units




Interrupt Input Units




Special I/O Units



Remote I/O Master Units






4-6-8 Clearing the I/O Table

The I/O Table Clear operation is used to delete the contents of the I/O table that is currently registered in the CPU Unit memory. The PC will be set for operation based on the I/O Units mounted when the I/O Table Clear operation is performed.


The I/O Table Clear operation will reset all Special I/O Units and Link Units mounted at the time. Do not perform the I/O Table Clear operation when a Host Link Unit, PC Link Unit, Remote I/O Master Unit, High-speed Counter Unit, Position Control Unit, or other Special I/O Unit is in operation.

Note This operation can be performed only in PROGRAM mode with the write-protection switch (pin 1 of the CPU Unit's DIP switch) set to OFF (OFF="WRITE").

Key Sequence



Example



4-6-9 SYSMAC NET Link Table Transfer

The SYSMAC NET Link Table Transfer operation transfers a copy of the SYSMAC NET Link Data Link table to the UM Area program memory. This allows the user program and SYSMAC NET Link table to be written into EPROM together. The data link table must be created with the SYSMAC Support Software and transferred to the PC before copying the table to program memory.

The data link table is stored in RAM when it is transferred to the PC from the SYSMAC Support Software, so the table will be lost if the CPU Unit's backup battery dies. To prevent this loss, we recommend converting the program (with the data link table) to EPROM or storing the program in an EEPROM Memory Cassette.


Note When power is applied to a PC which has a copy of a SYSMAC NET Link table stored in its program memory, the SYSMAC NET Link table of the CPU Unit will be overwritten. Changes made in the SYSMAC NET Link table do not affect the copy of the SYSMAC NET Link table in program memory; SYSMAC NET Link Table Transfer must be repeated to change the copy in program memory.

The SYSMAC NET Link Table Transfer operation will not work if:


- The Memory Unit is not RAM or EEPROM, or the write protect switch is not set to write.
- There isn't an END(01) instruction.
- The contents of program memory exceeds 14.7 KW. The program capacity is reduced when memory is allocated to expansion DM or the I/O comment area. About 0.5 KW of program memory beyond the END(01) instruction are needed to store the data link table.

SYSMAC NET Link table transfer can only be done in PROGRAM mode.

Key Sequence



Example



4-7 Inputting, Modifying, and Checking the Program

Once a program is written in mnemonic code, it can be input directly into the PC from a Programming Console. Mnemonic code is keyed into Program Memory addresses from the Programming Console. Checking the program involves a syntax check to see that the program has been written according to syntax rules. Once syntax errors are corrected, a trial execution can begin and, finally, correction under actual operating conditions can be made.

The operations required to input a program are explained below. Operations to modify programs that already exist in memory are also provided in this section, as well as the procedure to obtain the current cycle time.

Before starting to input a program, check to see whether there is a program already loaded. If there is a program loaded that you do not need, clear it first using the program memory clear key sequence, then input the new program. If you need the previous program, be sure to check it with the program check key sequence and correct it as required. Further debugging methods are provided in *Section 7 Program Monitoring and Execution*.

4-7-1 Setting and Reading from Program Memory Address


When inputting a program for the first time, it is generally written to Program Memory starting from address 00000. Because this address appears when the display is cleared, it is not necessary to specify it.

When inputting a program starting from other than 00000 or to read or modify a program that already exists in memory, the desired address must be designated. To designate an address, press CLR and then input the desired address. Leading zeros of the address need not be input, i.e., when specifying an address such as 00053 you need to enter only 53. The contents of the designated address will not be displayed until the down key is pressed.

Once the down key has been pressed to display the contents of the designated address, the up and down keys can be used to scroll through Program Memory. Each time one of these keys is pressed, the next or previous word in Program Memory will be displayed.


If Program Memory is read in RUN or MONITOR mode, the ON/OFF status of any displayed bit will also be shown.

Key Sequence



Example

If the following mnemonic code has already been input into Program Memory, the key inputs below would produce the displays shown.



Instruction	Оре	erands
LD		00000
AND		00001
TIM		000
	#	0123
LD		00100
	LD AND	LD AND TIM

4-7-2 Entering and Editing Programs

Programs can be entered and edited only in PROGRAM mode with the write-protect switch (pin 1 of the CPU Unit's DIP switch) set to OFF (OFF="WRITE").

The same procedure is used to either input a program for the first time or to edit a program that already exists. In either case, the current contents of Program Memory is overwritten, i.e., if there is no previous program, the NOP(00) instruction, which will be written at every address, will be overwritten.

To enter a program, input the mnemonic code that was produced from the ladder diagram step-by-step, ensuring that the correct address is set before starting. Once the correct address is displayed, enter the first instruction word and press WRITE. Next, enter the required operands, pressing WRITE after each, i.e., WRITE is pressed at the end of each line of the mnemonic code. When WRITE is pressed at the end of each line, the designated instruction or operand is entered and the next display will appear. If the instruction requires two or more words, the next display will indicate the next operand required and provide a default value for it. If the instruction requires only one word, the next address will be displayed. Continue inputting each line of the mnemonic code until the entire program has been entered.

When inputting numeric values for operands, it is not necessary to input leading zeros. Leading zeros are required only when inputting function codes (see below). When designating operands, be sure to designate the data area for all but IR and SR addresses by pressing the corresponding data area key, and to designate each constant by pressing CONT/#. CONT/# is not required for counter or timer SVs (see below). The AR area is designated by pressing SHIFT and then HR. TC numbers as bit operands (i.e., completion flags) are designated by pressing either TIM or CNT before the address, depending on whether the TC number has been used to define a timer or a counter. To designate an indirect DM address, press CH/* before the address (pressing DM is not necessary for an indirect DM address).

Inputting SV for Counters and Timers

The SV (set value) for a timer or counter is generally entered as a constant, although inputting the address of a word that holds the SV is also possible. When inputting an SV as a constant, CONT/# is not required; just input the numeric value and press WRITE. To designate a word, press CLR and then input the word address as described above.

Designating Instructions

The most basic instructions are input using the Programming Console keys provided for them. All other instructions are entered using function codes. These function codes are always written after the instruction's mnemonic. If no function code is given, there should be a Programming Console key for that instruction.


To designate the differentiated form of an instruction, press NOT after the function code.

To input an instruction using a function code, set the address, press FUN, input the function code including any leading zeros, press NOT if the differentiated form of the instruction is desired, input any bit operands or definers required for the instruction, and then press WRITE.



Enter function codes with care and be sure to press SHIFT when required.

Key Sequence



Example

The following program can be entered using the key inputs shown below. Displays will appear as indicated.

CLR	00000
$\begin{bmatrix} c & & \\ 2 & & \\ & 0 & \end{bmatrix} \begin{bmatrix} A & & \\ & 0 & \\ & & \end{bmatrix}$	00200
LD C 2	00200 LD 00002
WRITE	00201READ NOP (00)
TIM	00201 TIM 000
WRITE	00201 TIM DATA #0000
B 1 C 2 D 3	00201 TIM #0123
WRITE	00202READ NOP (00)
FUN	00202 FUN (??)
B 1 F 5	00202 TIMH (15) 000
WRITE	00202 TIMH DATA #0000
^F 5 A 0 A 0	00202 TIMH #0500
WRITE	00203READ NOP (00)

Address	Instruction	Oper	ands
00200	LD		00002
00201	TIM		000
		#	0123
00202	TIMH(15)		000
		#	0500

Error Messages

The following error messages may appear when inputting a program. Correct the error as indicated and continue with the input operation. The asterisks in the displays shown below will be replaced with numeric data, normally an address, in the actual display.

Message	Cause and correction		
****REPL ROM	An attempt was made to write to write-protected RAM or EEPROM. Ensure that the write-protect switch is set to OFF.		
****PROG OVER	The instruction at the last address in memory is not NOP(00). Erase all unnecessary instructions at the end of the program.		
****ADDR OVER	An address was set that is larger than the highest memory address in the UM area. Input a smaller address		
****SETDATA ERR	Data has been input in the wrong format or beyond defined limits, e.g., a hexadecimal value has been input for BCD. Re-enter the data. This error will generate a FALS 00 error.		
****I/O NO. ERR	A data area address has been designated that exceeds the limit of the data area, e.g., an address is too large. Confirm the requirements for the instruction and re-enter the address.		

4-7-3 Checking the Program


Once a program has been entered, the syntax should be checked to verify that no programming rules have been violated. This check should also be performed if the program has been changed in any way that might create a syntax error.

To check the program, input the key sequence shown below. The numbers indicate the desired check level (see below). When the check level is entered, the program check will start. If an error is discovered, the check will stop and a display indicating the error will appear. Press SRCH to continue the check. If an error is not found, the program will be checked through to the first END(01), with a display indicating when each 64 instructions have been checked (e.g., display #1 of the example after the following table).

CLR can be pressed to cancel the check after it has been started, and a display like display #2, in the example, will appear. When the check has reached the first END, a display like display #3 will appear.

A syntax check can be performed on a program only in PROGRAM mode.

Key Sequence



Check Levels and Error Messages

Three levels of program checking are available. The desired level must be designated to indicate the type of errors that are to be detected. The following table provides the error types, displays, and explanations of all syntax errors. Check level 0 checks for type A, B, and C errors; check level 1, for type A and B errors; and check level 2, for type A errors only.


The address where the error was generated will also be displayed.

Many of the following errors are for instructions that have not yet been described yet. Refer to *4-8 Controlling Bit Status* or to *Section 5 Instruction Set* for details on these.

Туре	Message	Meaning and appropriate response
Type A	77777	The program has been lost. Re-enter the program.
	NO END INSTR	There is no END(01) in the program. Write END(01) at the final address in the program.
	CIRCUIT ERR	The number of logic blocks and logic block instructions does not agree, i.e., either LD or LD NOT has been used to start a logic block whose execution condition has not been used by another instruction, or a logic block instruction has been used that does not have the required number of logic blocks. Check your program.
	LOCH ERR	An instruction is in the wrong place in the program. Check instruction requirements and correct the program.
	DUPL	The same jump number or subroutine number has been used twice. Correct the program so that the same number is only used once for each. (Jump number 00 may be used as often as required.)
	SBN UNDEFD	SBS(91) has been programmed for a subroutine number that does not exist. Correct the subroutine number or program the required subroutine.
	JME UNDEFD	A JME(04) is missing for a JMP(05). Correct the jump number or insert the proper JME(04).
	OPERAND ERR	A constant entered for the instruction is not within defined values. Change the constant so that it lies within the proper range.
	STEP ERR	STEP(08) with a section number and STEP(08) without a section number have been used correctly. Check STEP(08) programming requirements and correct the program.
Type B	IL-ILC ERR	IL(02) and ILC(03) are not used in pairs. Correct the program so that each IL(02) has a unique ILC(03). Although this error message will appear if more than one IL(02) is used with the same ILC(03), the program will executed as written. Make sure your program is written as desired before proceeding.
	JMP-JME ERR	JMP(04) 00 and JME(05) 00 are not used in pairs. Although this error message will appear if more than one JMP(04) 00 is used with the same JME(05) 00, the program will be executed as written. Make sure your program is written as desired before proceeding.
	SBN-RET ERR	If the displayed address is that of SBN(92), two different subroutines have been defined with the same subroutine number. Change one of the subroutine numbers or delete one of the subroutines. If the displayed address is that of RET(93), RET(93) has not been used properly. Check requirements for RET(93) and correct the program.
Type C	JMP UNDEFD	JME(05) has been used with no JMP(04) with the same jump number. Add a JMP(04) with the same number or delete the JME(05) that is not being used.
	SBS UNDEFD	A subroutine exists that is not called by SBS(91). Program a subroutine call in the proper place, or delete the subroutine if it is not required.
	COIL DUPL	The same bit is being controlled (i.e., turned ON and/or OFF) by more than one instruction (e.g., OUT, OUT NOT, DIFU(13), DIFD(14), KEEP(11), SFT(10)). Although this is allowed for certain instructions, check instruction requirements to confirm that the program is correct or rewrite the program so that each bit is controlled by only one instruction.

Example

The following example shows some of the displays that can appear as a result of a program check.




4-7-4 Displaying the Cycle Time

Once the program has been cleared of syntax errors, the cycle time should be checked. This is possible only in RUN or MONITOR mode while the program is being executed. See *Section 6 Program Execution Timing* for details on the cycle time.

To display the current average cycle time, press CLR then MONTR. The time displayed by this operation is a typical cycle time. The differences in displayed values depend on the execution conditions that exist when MONTR is pressed.

Example



4-7-5 Program Searches


The program can be searched for occurrences of any designated instruction or data area address used in an instruction. Searches can be performed from any currently displayed address or from a cleared display.


To designate a bit address, press SHIFT, press CONT/#, then input the address, including any data area designation required, and press SRCH. To designate an instruction, input the instruction just as when inputting the program and press SRCH. Once an occurrence of an instruction or bit address has been found, any additional occurrences of the same instruction or bit can be found by pressing SRCH again. SRCH'G will be displayed while a search is in progress.

When the first word of a multiword instruction is displayed for a search operation, the other words of the instruction can be displayed by pressing the down key before continuing the search.

If Program Memory is read in RUN or MONITOR mode, the ON/OFF status of any bit displayed will also be shown.

Key Sequence





4-7-6 Inserting and Deleting Instructions

In PROGRAM mode, any instruction that is currently displayed can be deleted or another instruction can be inserted before it. These operations are possible only in PROGRAM mode with the write-protect switch (pin 1 of the CPU Unit's DIP switch) set to OFF (OFF="WRITE").


To insert an instruction, display the instruction before which you want the new instruction to be placed, input the instruction word in the same way as when inputting a program initially, and then press INS and the down key. If other words are required for the instruction, input these in the same way as when inputting the program initially.

To delete an instruction, display the instruction word of the instruction to be deleted and then press DEL and the up key. All the words for the designated instruction will be deleted.

⚠ Caution

Be careful not to inadvertently delete instructions; there is no way to recover them without re-inputting them completely.

Key Sequences




When an instruction is inserted or deleted, all addresses in Program Memory following the operation are adjusted automatically so that there are no blank addresses or no unaddressed instructions.


Example

The following mnemonic code shows the changes that are achieved in a program through the key sequences and displays shown below.

Original Program


Address	Instruction	Operands
00000	LD	00100
00001	AND	00101
00002	LD	00201
00003	AND NOT	00102
00004	OR LD	_
00005	AND	00103
00006	AND NOT	00104
00007	OUT	00201
80000	END(01)	_






The following key inputs and displays show the procedure for achieving the program changes shown above.

Inserting an Instruction



Deleting an Instruction



4-7-7 Branching Instruction Lines

When an instruction line branches into two or more lines, it is sometimes necessary to use either interlocks or TR bits to maintain the execution condition that existed at a branching point. This is because instruction lines are executed across to a right-hand instruction before returning to the branching point to execute instructions on a branch line. If a condition exists on any of the instruction lines after the branching point, the execution condition could change during this time making proper execution impossible. The following diagrams illustrate this. In both diagrams, instruction 1 is executed before returning to the branching point and moving on to the branch line leading to instruction 2.




Diagram A: Correct Operation




Diagram B: Incorrect Operation

	Address	Instruction	Operands
	00000	LD	00000
ĺ	00001	Instruction 1	
	00002	AND	00002
	00003	Instruction 2	

Address	Instruction	Operands
00000	LD	00000
00001	AND	00001
00002	Instruction 1	
00003	AND	00002
00004	Instruction 2	

If, as shown in diagram A, the execution condition that existed at the branching point cannot be changed before returning to the branch line (instructions at the far right do not change the execution condition), then the branch line will be executed correctly and no special programming measure is required.

If, as shown in diagram B, a condition exists between the branching point and the last instruction on the top instruction line, the execution condition at the branching point and the execution condition after completing the top instruction line will sometimes be different, making it impossible to ensure correct execution of the branch line.

There are two means of programming branching programs to preserve the execution condition. One is to use TR bits; the other, to use interlocks (IL(02)/IL(03)).

TR Bits

The TR area provides eight bits, TR 0 through TR 7, that can be used to temporarily preserve execution conditions. If a TR bit is placed at a branching point, the current execution condition will be stored at the designated TR bit. When returning to the branching point, the TR bit restores the execution status that was saved when the branching point was first reached in program execution.

The previous diagram B can be written as shown below to ensure correct execution. In mnemonic code, the execution condition is stored at the branching point using the TR bit as the operand of the OUTPUT instruction. This execution condition is then restored after executing the right-hand instruction by using the same TR bit as the operand of a LOAD instruction




Diagram B: Corrected Using a TR bit

Address	Instruction	Operands
00000	LD	00000
00001	OUT	TR 0
00002	AND	00001
00003	Instruction 1	
00004	LD	TR 0
00005	AND	00002
00006	Instruction 2	

In terms of actual instructions the above diagram would be as follows: The status of IR 00000 is loaded (a LOAD instruction) to establish the initial execution condition. This execution condition is then output using an OUTPUT instruction to TR 0 to store the execution condition at the branching point. The execution condition is then ANDed with the status of IR 00001 and instruction 1 is executed accordingly. The execution condition that was stored at the branching point is then re-loaded (a LOAD instruction with TR 0 as the operand), this is ANDed with the status of IR 00002, and instruction 2 is executed accordingly.

The following example shows an application using two TR bits.




Address	Instruction	Operands
00000	LD	00000
00001	OUT	TR 0
00002	AND	00001
00003	OUT	TR 1
00004	AND	00002
00005	Instruction 1	
00006	LD	TR 1
00007	AND	00003
80000	Instruction 2	
00009	LD	TR 0
00010	AND	00004
00011	Instruction 3	
00012	LD	TR 0
00013	AND NOT	00005
00014	Instruction 4	

In this example, TR 0 and TR 1 are used to store the execution conditions at the branching points. After executing instruction 1, the execution condition stored in TR 1 is loaded for an AND with the status IR 00003. The execution condition stored in TR 0 is loaded twice, the first time for an AND with the status of IR 00004 and the second time for an AND with the inverse of the status of IR 00005.

TR bits can be used as many times as required as long as the same TR bit is not used more than once in the same instruction block. Here, a new instruction block is begun each time execution returns to the bus bar. If, in a single instruction block, it is necessary to have more than eight branching points that require the execution condition be saved, interlocks (which are described next) must be used.

When drawing a ladder diagram, be careful not to use TR bits unless necessary. Often the number of instructions required for a program can be reduced and ease of understanding a program increased by redrawing a diagram that would otherwise required TR bits. In both of the following pairs of diagrams, the bottom versions require fewer instructions and do not require TR bits. In the first example, this is achieved by reorganizing the parts of the instruction block: the bottom one, by separating the second OUTPUT instruction and using another LOAD instruction to create the proper execution condition for it.

Note Although simplifying programs is always a concern, the order of execution of instructions is sometimes important. For example, a MOVE instruction may be required before the execution of a BINARY ADD instruction to place the proper data in the required operand word. Be sure that you have considered execution order before reorganizing a program to simplify it.




Note TR bits are only used when programming using mnemonic code. They are not necessary when inputting ladder diagrams directly. The above limitations on the number of branching points requiring TR bits, and considerations on methods to reduce the number of programming instructions, still hold.

The problem of storing execution conditions at branching points can also be handled by using the INTERLOCK (IL(02)) and INTERLOCK CLEAR (ILC(03)) instructions to eliminate the branching point completely while allowing a specific execution condition to control a group of instructions. The INTERLOCK and INTERLOCK CLEAR instructions are always used together.

Interlocks

When an INTERLOCK instruction is placed before a section of a ladder program, the execution condition for the INTERLOCK instruction will control the execution of all instruction up to the next INTERLOCK CLEAR instruction. If the execution condition for the INTERLOCK instruction is OFF, all right-hand instructions through the next INTERLOCK CLEAR instruction will be executed with OFF execution conditions to reset the entire section of the ladder diagram. The effect that this has on particular instructions is described in 5-10 INTERLOCK and INTERLOCK CLEAR – IL(02) and ILC(03).


Diagram B can also be corrected with an interlock. Here, the conditions leading up to the branching point are placed on an instruction line for the INTERLOCK instruction, all of lines leading from the branching point are written as separate instruction lines, and another instruction line is added for the INTERLOCK CLEAR instruction. No conditions are allowed on the instruction line for INTERLOCK CLEAR. Note that neither INTERLOCK nor INTERLOCK CLEAR requires an operand.



Address	Instruction	Operands
00000	LD	00000
00001	IL(02)	
00002	LD	00001
00003	Instruction 1	
00004	LD	00002
00005	Instruction 2	
00006	ILC(03)	

If IR 00000 is ON in the revised version of diagram B, above, the status of IR 00001 and that of IR 00002 would determine the execution conditions for instructions 1 and 2, respectively. Because IR 00000 is ON, this would produce the same results as ANDing the status of each of these bits. If IR 00000 is OFF, the INTERLOCK instruction would produce an OFF execution condition for instructions 1 and 2 and then execution would continue with the instruction line following the INTERLOCK CLEAR instruction.

As shown in the following diagram, more than one INTERLOCK instruction can be used within one instruction block; each is effective through the next INTERLOCK CLEAR instruction.



Address	Instruction	Operands
00000	LD	00000
00001	IL(02)	
00002	LD	00001
00003	Instruction 1	
00004	LD	00002
00005	IL(02)	
00006	LD	00003
00007	AND NOT	00004
80000	Instruction 2	
00009	LD	00005
00010	Instruction 3	
00011	LD	00006
00012	Instruction 4	
00013	ILC(03)	

If IR 00000 in the above diagram is OFF (i.e., if the execution condition for the first INTERLOCK instruction is OFF), instructions 1 through 4 would be executed with OFF execution conditions and execution would move to the instruction following the INTERLOCK CLEAR instruction. If IR 00000 is ON, the status of IR 00001 would be loaded as the execution condition for instruction 1 and then the status of IR 00002 would be loaded to form the execution condition for the second INTERLOCK instruction. If IR 00002 is OFF, instructions 2 through 4 will be executed with OFF execution conditions. If IR 00002 is ON, IR 00003, IR 00005, and IR 00006 will determine the first execution condition in new instruction lines.

4-7-8 **Jumps**

A specific section of a program can be skipped according to a designated execution condition. Although this is similar to what happens when the execution condition for an INTERLOCK instruction is OFF, with jumps, the operands for all instructions maintain status. Jumps can therefore be used to control devices that require a sustained output, e.g., pneumatics and hydraulics, whereas interlocks can be used to control devices that do not required a sustained output, e.g., electronic instruments.

Jumps are created using the JUMP (JMP(04)) and JUMP END (JME(05)) instructions. If the execution condition for a JUMP instruction is ON, the program is executed normally as if the jump did not exist. If the execution condition for the JUMP instruction is OFF, program execution moves immediately to a JUMP END instruction without changing the status of anything between the JUMP and JUMP END instruction.

All JUMP and JUMP END instructions are assigned jump numbers ranging between 00 and 99. There are two types of jumps. The jump number used determines the type of jump.

A jump can be defined using jump numbers 01 through 99 only once, i.e., each of these numbers can be used once in a JUMP instruction and once in a JUMP END instruction. When a JUMP instruction assigned one of these numbers is executed, execution moves immediately to the JUMP END instruction that has the same number as if all of the instruction between them did not exist. Diagram B from the TR bit and interlock example could be redrawn as shown below using a jump. Although 01 has been used as the jump number, any number between 01 and 99 could be used as long as it has not already been used in a different part of the program. JUMP and JUMP END require no other operand and JUMP END never has conditions on the instruction line leading to it.





Diagram B: Corrected with a Jump

Address	Instruction	Operands
00000	LD	00000
00001	JMP(04)	01
00002	LD	00001
00003	Instruction 1	
00004	LD	00002
00005	Instruction 2	
00006	JME(05)	015

This version of diagram B would have a shorter execution time when 00000 was OFF than any of the other versions.

The other type of jump is created with a jump number of 00. As many jumps as desired can be created using jump number 00 and JUMP instructions using 00 can be used consecutively without a JUMP END using 00 between them. It is even possible for all JUMP 00 instructions to move program execution to the same JUMP END 00, i.e., only one JUMP END 00 instruction is required for all JUMP 00 instruction in the program. When 00 is used as the jump number for a JUMP instruction, program execution moves to the instruction following the next JUMP END instruction with a jump number of 00. Although, as in all jumps, no status is changed and no instructions are executed between the JUMP 00 and JUMP END 00 instructions, the program must search for the next JUMP END 00 instruction, producing a slightly longer execution time.

Execution of programs containing multiple JUMP 00 instructions for one JUMP END 00 instruction is similar to that of interlocked sections. The following diagram is the same as that used for the interlock example above, except redrawn with jumps. The execution of this diagram would differ from that of the diagram described above (e.g., in the previous diagram interlocks would reset certain parts of the interlocked section, however, jumps do not affect the status of any bit between the JUMP and JUMP END instructions).




Address	Instruction	Operands
00000	LD	00000
00001	JMP(04)	00
00002	LD	00001
00003	Instruction 1	
00004	LD	00002
00005	JMP(04)	00
00006	LD	00003
00007	AND NOT	00004
80000	Instruction 2	
00009	LD	00005
00010	Instruction 3	
00011	LD	00006
00012	Instruction 4	
00013	JME(05)	00

4-8 Controlling Bit Status

There are five instructions that can be used generally to control individual bit status. These are the OUTPUT, OUTPUT NOT, DIFFERENTIATE UP, DIFFERENTIATE DOWN, and KEEP instructions. All of these instructions appear as the last instruction in an instruction line and take a bit address for an operand. Although details are provided in *5-9 Bit Control Instructions*, these instructions (except for OUTPUT and OUTPUT NOT, which have already been introduced) are described here because of their importance in most programs. Although these instructions are used to turn ON and OFF output bits in the IR area (i.e., to send or stop output signals to external devices), they are also used to control the status of other bits in the IR area or in other data areas.

4-8-1 DIFFERENTIATE UP and DIFFERENTIATE DOWN

DIFFERENTIATE UP and DIFFERENTIATE DOWN instructions are used to turn the operand bit ON for one cycle at a time. The DIFFERENTIATE UP instruction turns ON the operand bit for one cycle after the execution condition for it goes from OFF to ON; the DIFFERENTIATE DOWN instruction turns ON the operand bit for one cycle after the execution condition for it goes from ON to OFF. Both of these instructions require only one line of mnemonic code.



Address	Instruction	Operands
00000	LD	00000
00001	DIFU(13)	00200


Address	Instruction	Operands
00000	LD	00001
00001	DIFD(14)	00201

Here, IR 00200 will be turned ON for one cycle after IR 00000 goes ON. The next time DIFU(13) 00200 is executed, IR 00200 will be turned OFF, regardless of the status of IR 00000. With the DIFFERENTIATE DOWN instruction, IR 00201 will be turned ON for one cycle after IR 00001 goes OFF (IR 00201 will be kept OFF until then), and will be turned OFF the next time DIFD(14) 00201 is executed.

4-8-2 KEEP

The KEEP instruction is used to maintain the status of the operand bit based on two execution conditions. To do this, the KEEP instruction is connected to two instruction lines. When the execution condition at the end of the first instruction line is ON, the operand bit of the KEEP instruction is turned ON. When the execution condition at the end of the second instruction line is ON, the operand bit of the KEEP instruction is turned OFF. The operand bit for the KEEP instruction will maintain its ON or OFF status even if it is located in an interlocked section of the diagram.

In the following example, HR 0000 will be turned ON when IR 00002 is ON and IR 00003 is OFF. HR 0000 will then remain ON until either IR 00004 or IR 00005 turns ON. With KEEP, as with all instructions requiring more than one instruction line, the instruction lines are coded first before the instruction that they control.




Address	Instruction	Operands
00000	LD	00002
00001	AND NOT	00003
00002	LD	00004
00003	OR	00005
00004	KEEP(11)	HR 0000

4-8-3 Self-maintaining Bits (Seal)

Although the KEEP instruction can be used to create self-maintaining bits, it is sometimes necessary to create self-maintaining bits in another way so that they can be turned OFF when in an interlocked section of a program.

To create a self-maintaining bit, the operand bit of an OUTPUT instruction is used as a condition for the same OUTPUT instruction in an OR setup so that the operand bit of the OUTPUT instruction will remain ON or OFF until changes occur in other bits. At least one other condition is used just before the OUTPUT instruction to function as a reset. Without this reset, there would be no way to control the operand bit of the OUTPUT instruction.

The above diagram for the KEEP instruction can be rewritten as shown below. The only difference in these diagrams would be their operation in an interlocked program section when the execution condition for the INTERLOCK instruction was ON. Here, just as in the same diagram using the KEEP instruction, two reset bits are used, i.e., HR 0000 can be turned OFF by turning ON either IR 00004 or IR 00005.



Address	Instruction	Operands
00000	LD	00002
00001	AND NOT	00003
00002	OR	HR 0000
00003	AND NOT	00004
00004	AND NOT	00005
00005	OUT	HR 0000

4-9 Work Bits (Internal Relays)

In programming, combining conditions to directly produce execution conditions is often extremely difficult. These difficulties are easily overcome, however, by using certain bits to trigger other instructions indirectly. Such programming is achieved by using work bits. Sometimes entire words are required for these purposes. These words are referred to as work words.

Work bits are not transferred to or from the PC. They are bits selected by the programmer to facilitate programming as described above. I/O bits and other dedicated bits cannot be used as works bits. All bits in the IR area that are not allocated as I/O bits, and certain unused bits in the AR area, are available for use as work bits. Be careful to keep an accurate record of how and where you use work bits. This helps in program planning and writing, and also aids in debugging operations.

Work Bit Applications


Examples given later in this subsection show two of the most common ways to employ work bits. These should act as a guide to the almost limitless number of ways in which the work bits can be used. Whenever difficulties arise in programming a control action, consideration should be given to work bits and how they might be used to simplify programming.

Work bits are often used with the OUTPUT, OUTPUT NOT, DIFFERENTIATE UP, DIFFERENTIATE DOWN, and KEEP instructions. The work bit is used first as the operand for one of these instructions so that later it can be used as a condition that will determine how other instructions will be executed. Work bits can also be used with other instructions, e.g., with the SHIFT REGISTER instruction (SFT(10)). An example of the use of work words and bits with the SHIFT REGISTER instruction is provided in 5-15-1 SHIFT REGISTER — SFT(10).

Although they are not always specifically referred to as work bits, many of the bits used in the examples in *Section 5 Instruction Set* use work bits. Understanding the use of these bits is essential to effective programming.

Reducing Complex Conditions

Work bits can be used to simplify programming when a certain combination of conditions is repeatedly used in combination with other conditions. In the following example, IR 00000, IR 00001, IR 00002, and IR 00003 are combined in a logic block that stores the resulting execution condition as the status of IR 24600. IR 24600 is then combined with various other conditions to determine output conditions for IR 00100, IR 00101, and IR 00102, i.e., to turn the outputs allocated to these bits ON or OFF.




Address	Instruction	Operands
00000	LD	00000
00001	AND NOT	00001
00002	OR	00002
00003	OR NOT	00003
00004	OUT	24600
00005	LD	24600
00006	AND	00004
00007	AND NOT	00005
00008	OUT	00100
00009	LD	24600
00010	OR NOT	00004
00011	AND	00005
00012	OUT	00101
00013	LD NOT	24600
00014	OR	00006
00015	OR	00007
00016	OUT	00102

Differentiated Conditions

Work bits can also be used if differential treatment is necessary for some, but not all, of the conditions required for execution of an instruction. In this example, IR 00100 must be left ON continuously as long as IR 00001 is ON and both IR 00002 and IR 00003 are OFF, or as long as IR 00004 is ON and IR 00005 is OFF. It must be turned ON for only one cycle each time IR 00000 turns ON (unless one of the preceding conditions is keeping it ON continuously).


This action is easily programmed by using IR 22500 as a work bit as the operand of the DIFFERENTIATE UP instruction (DIFU(13)). When IR 00000 turns ON, IR 22500 will be turned ON for one cycle and then be turned OFF the next cycle by DIFU(13). Assuming the other conditions controlling IR 00100 are not keeping it ON, the work bit IR 22500 will turn IR 00100 ON for one cycle only.




Address	Instruction	Operands
00000	LD	00000
00001	DIFU(13)	22500
00002	LD	22500
00003	LD	00001
00004	AND NOT	00002
00005	AND NOT	00003
00006	OR LD	
00007	LD	00004
80000	AND NOT	00005
00009	OR LD	
00010	OUT	00100

4-10 Programming Precautions

The number of conditions that can be used in series or parallel is unlimited as long as the memory capacity of the PC is not exceeded. Therefore, use as many conditions as required to draw a clear diagram. Although very complicated diagrams can be drawn with instruction lines, there must not be any conditions on lines running vertically between two other instruction lines. Diagram A shown below, for example, is not possible, and should be drawn as diagram B. Mnemonic code is provided for diagram B only; coding diagram A would be impossible.






Address	Instruction	Operands
00000	LD	00001
00001	AND	00004
00002	OR	00000
00003	AND	00002
00004	Instruction 1	
00005	LD	00000
00006	AND	00004
00007	OR	00001
00008	AND NOT	00003
00009	Instruction 2	

The number of times any particular bit can be assigned to conditions is not limited, so use them as many times as required to simplify your program. Often, complicated programs are the result of attempts to reduce the number of times a bit is used.


Except for instructions for which conditions are not allowed (e.g., INTERLOCK CLEAR and JUMP END, see below), every instruction line must also have at least one condition on it to determine the execution condition for the instruction at the right. Again, diagram A , below, must be drawn as diagram B. If an instruction must be continuously executed (e.g., if an output must always be kept ON while the program is being executed), the Always ON Flag (SR 25313) in the SR area can be used.



Address	Instruction	Operands
00000	LD	25313
00001	Instruction	

There are a few exceptions to this rule, including the INTERLOCK CLEAR, JUMP END, and step instructions. Each of these instructions is used as the second of a pair of instructions and is controlled by the execution condition of the first of the pair. Conditions should not be placed on the instruction lines leading to these instructions. Refer to *Section 5 Instruction Set* for details.

When drawing ladder diagrams, it is important to keep in mind the number of instructions that will be required to input it. In diagram A, below, an OR LOAD instruction will be required to combine the top and bottom instruction lines. This can be avoided by redrawing as shown in diagram B so that no AND LOAD or OR LOAD instructions are required. Refer to 5-8-2 AND LOAD and OR LOAD for more details and Section 7 Program Monitoring and Execution for further examples.



Address	Instruction	Operands
00000	LD	00000
00001	LD	00001
00002	AND	00207
00003	OR LD	
00004	OUT	00207

00001 00207	00207
00000	
 	

Address	Instruction	Operands
00000	LD	00001
00001	AND	00207
00002	OR	00000
00003	OUT	00207

Diagram B

4-11 Program Execution

When program execution is started, the CPU Unit cycles the program from top to bottom, checking all conditions and executing all instructions accordingly as it moves down the bus bar. It is important that instructions be placed in the proper order so that, for example, the desired data is moved to a word before that word is used as the operand for an instruction. Remember that an instruction line is completed to the terminal instruction at the right before executing an instruction lines branching from the first instruction line to other terminal instructions at the right.


Program execution is only one of the tasks carried out by the CPU Unit as part of the cycle time. Refer to Section 6 Program Execution Timing for details.

4-12 Special I/O Unit Interface Programs

This section provides programming methods and precautions for Special I/O Unit operation.

4-12-1 Restarting Special I/O Units

When a Special I/O Unit is restarted, execution of IORF(97) is disabled until Special I/O Unit initialization is completed.



While the Restart Flag (SR 27400) is ON, normal END refreshing is performed and the Special I/O Unit is initialized. This processing occurs regardless of the settings in DM 6620, DM 6621, and DM 6623, which relate to Special I/O Unit refreshing. IORF(97) instructions in the program won't be executed for the initializing Unit until initialization is completed.


Special I/O Unit data that was to be refreshed might be lost during initialization. When writing a program to restart Special I/O Units, disable programming that depends on data from the initializing Special I/O Unit, such as data used in calculations, while its Restart Flag (SR 27400 to SR 27415) is ON. Normal program operations can continue for Units that aren't initializing.

The Restart Flag won't turn ON for Special I/O Units mounted on Slave Racks.

The standard Special I/O Unit restart time is $(20 \times \text{the cycle time})$.

4-12-2 Special I/O Unit Error Processing Program

Use a program like the one shown below to restart a Special I/O Unit in which an error has occurred. This example program restarts Unit 1.



4-12-3 Changing the Special I/O Unit Settings


In the C200HX/HG/HE, ladder instructions can be used to write data into the Special I/O Unit Areas (DM 1000 to DM 2599) and change the Special I/O Unit settings. Changing the settings is useful when different settings are required for different production processes.

In this example there are two production processes that require different Special I/O Unit settings. The settings for the first process are stored in DM 7000 through DM 7999 and the settings for the second process are stored in DM 8000 through DM 8999.

Programming Console Operations


Steps 1 through 5 in the following procedure aren't necessary when XFER(70) is used to overwrite DM 1000 through DM 1999 directly from the program with the contents of fixed DM (DM 6144 through DM 6599). In this case, just restart the Unit from the program after overwriting DM 1000 through DM 1999.

1, 2, 3... 1. Clear the memory (all clear).




The UM Area Allocation operation can't be performed unless the memory has been cleared.

2. Perform the UM Area Allocation operation to allocate 2K words to the expansion DM area (DM 7000 through DM 8999).



- 3. Perform the Hexadecimal/BCD Data Modification operation to set the Special I/O Unit mode to "C200H-compatible ROM mode 1" by setting DM 6602 to #0100. This mode transfers the contents of DM 7000 through DM 7999 to DM 1000 through DM 1999 at PC startup. This new PC Setup setting won't be effective until the PC is restarted by turning it off and then on again.
- 4. Set pin 4 of the CPU Unit's DIP switch to ON. This setting enables the user to assign expansion instruction function codes.


5. Perform the Expansion Instruction Function Code Assignment operation to assign a function code to XDMR(—).



6. Input the program.

Example Program (Special I/O Unit 2)

The following program changes the Special I/O Unit Area settings for Unit 2, restarts the Unit, and disables calculations using data from Unit 2 while the Unit is initializing.



4-12-4 Special I/O Unit I/O Refreshing Interval

When the interval between I/O refreshes is too short, the processing in the Special I/O Unit can be delayed causing Special I/O Unit errors or otherwise interfering with proper Unit operation. In this case, use the following methods to restore normal operation.

Short Interval between END Refreshes

There are two ways to extend the interval between I/O refreshes. Either of these methods can be used.

- Disable cyclic Special I/O Unit refreshing in the PC Setup (DM 6621) and use IORF(97) to refresh the Special I/O Unit's I/O only when necessary.
 To disable cyclic refreshing for all Special I/O Units mounted to the CPU
 - To disable cyclic refreshing for all Special I/O Units mounted to the CPU Rack or Expansion I/O Racks, set DM 6621 to #0100.
 - 2. Increase the PC's cycle time by setting a minimum cycle time in the PC Setup (DM 6619) or executing SCAN(18) in the program. (SCAN(18) is an expansion instruction with default function code 18.)

Short Interval between IORF(97) and END Refresh

Change the program to use either IORF(97) refreshing or END refreshing. It is also possible to increase the PC's cycle time by setting a minimum cycle time in the PC Setup (DM 6619) or executing SCAN(18) in the program.

Short Interval between IORF(97) Instructions

Change the program to increase the spacing between IORF(97) instructions or use just one IORF(97) instruction.

4-12-5 Reducing the Cycle Time


When a Special I/O Unit is mounted in a C200HX/HG/HE PC, END refreshing is performed automatically each cycle without making any special settings. When several Special I/O Units are being used, the cycle time might become too long because of the time required for this automatic I/O refreshing.

To reduce the time devoted to I/O refreshing, disable cyclic Special I/O Unit refreshing in the PC Setup (DM 6621) and use IORF(97) to refresh the Special I/O Units instead. I/O refreshing for all Special I/O Units mounted to the CPU Rack or Expansion I/O Racks can be disabled in the PC Setup by setting DM 6621 to #0100.

The following example program reduces the Special I/O Unit refreshing time for a PC with four Special I/O Units by refreshing just one Unit each cycle. The Units are refreshed in order: Unit 0, Unit 1, Unit 2, Unit 3, Unit 0, and so on.

Unit 0 Unit 1 Unit 2 Unit 3	C200HX/HG/HE
--------------------------------------	--------------

The following program example is relevant for Special I/O Units mounted to the CPU Rack or Expansion I/O Racks only, because END refreshing is always performed on Special I/O Units mounted to Slave Racks regardless of the PC Setup settings.



Note IR 30000 is used in an OUT instruction twice in this program. Although acceptable in the above example, this type of duplication is not usually allowed unless there is a specific reason and then only when proper operation can be ensured.

4-13 Analog Timer Unit Programming


An Analog Timer Unit's timer SV can be changed easily without a Programming Console. The Unit is equipped with an external variable resistor connector, so a variable resistor can be installed in the control panel and connected to the Analog Timer Unit to set or adjust the timer SV manually.

4-13-1 Operation

When the Timer Start Input is turned ON, the Timer Set Bits allocated to the Analog Timer Unit (bits 00 to 03 of n) are turned ON, the analog timer begins to operate, and the timer set indicator (SET) on the Unit will light.

When the Unit's timer SV (set internally or externally) elapses, the Unit's Completion Flags (bits 08 to 11 of n) and the Time-up Output will be turned ON. Also, the time-up indicator on the Unit (TIME UP) will light.

Refer to the Analog Timer Unit's Operation Manual for details on switching between internal and external timer SV settings, connecting a variable resistor, and switch settings.



4-13-2 Bit Allocation and DIP Switch Settings

The following table shows the use of the word (n) allocated to the Analog Timer Unit. This word address depends upon the slot in which the Unit is mounted.

Bit	I/O class	Function	Comments
00	Output	Timer 0 Set Bit	ON when timer is set.
01		Timer 1 Set Bit	
02		Timer 2 Set Bit	
03		Timer 3 Set Bit	
04		Timer 0 Stop Bit	OFF: Enable timer operation
05		Timer 1 Stop Bit	ON: Stop timer operation
06		Timer 2 Stop Bit	
07		Timer 3 Stop Bit	
08	Input	Timer 0 Completion Flag	ON when timer has timed out.
09		Timer 1 Completion Flag	
10		Timer 2 Completion Flag	
11		Timer 3 Completion Flag	
12 to 15		Not used.	

Timer Range Setting

Set the timer range with the upper DIP switch on the front of the Unit. Each timer's range can be set independently.

Range	Timer 0		Timer 1		Timer 2		Timer 3	
	Pin 8	Pin 7	Pin 6	Pin 5	Pin 4	Pin 3	Pin 2	Pin 1
0.1 to 1 s	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
1 to 10 s	ON	OFF	ON	OFF	ON	OFF	ON	OFF
10 to 60 s	OFF	ON	OFF	ON	OFF	ON	OFF	ON
1 to 10 minutes	ON	ON	ON	ON	ON	ON	ON	ON

Selecting Internal/External Timer SV Setting

Select internal or external setting with the lower DIP switch on the front of the Unit.

Setting	Timer 0 (pin 4)	Timer 1 (pin 3)	Timer 2 (pin 2)	Timer 3 (pin 1)
Internal	ON	ON	ON	ON
External	OFF	OFF	OFF	OFF

4-13-3 Example Program

Unit Configuration

The following table shows the word allocations for the Units in this example.


Item	Word
IR word allocated to the Analog Timer Unit	IR 002
IR word allocated to the Input Unit	IR 000
IR word allocated to the Output Unit	IR 005

The Analog Timer Unit's SV settings and external variable resistor control connections are shown below.

Timer	Set value	Range	Variable resistor setting	Variable resistor control
0	0.6 s	0.1 to 1 s	60% clockwise	Internal
1	3 s	1 to 10 s	30% clockwise	Internal
2	20 s	10 to 60 s	20% clockwise	External
3	8 minutes	1 to 10 minutes	80% clockwise	External

Unit Settings and Wiring


The following diagram shows the switch settings and wiring connections required to achieve the Unit configuration shown above.



Ladder Program

The following diagram shows the example ladder program.

- 1. Output IR 00500 will go ON about 0.6 s (T0) after input IR 00002 goes ON.
 - 2. Output IR 00501 will go ON about 3 s (T1) after input IR 00003 goes ON.
 - 3. Output IR 00502 will go ON about 20 s (T2) after input IR 00004 goes ON and IR 00503 will go ON about 8 minutes (T3) after input IR 00004 goes ON.
 - 4. Timers 2 and 3 are stopped by input IR 00005.



Timers 2 and 3 stop operating when the emergency stop input goes ON.

Timer 0 (00200) starts operating and the Unit's SET indicator lights when IR 00002 goes ON.

When the time set on the internal volume control elapses, the Completion Flag (00208) goes ON and the Unit's TIME UP indicator lights. Output IR 00500 goes ON at the same time.

Timer 1 (00201) starts operating and the Unit's SET indicator lights when IR 00003 goes ON.

When the time set on the internal variable resistor control elapses, the Completion Flag (00209) goes ON and the Unit's TIME UP indicator lights. Output IR 00501 goes ON at the same time.

Timer 2 (00202) and timer 3 (00203) start operating and the Unit's SET indicator lights when IR 00004 goes ON.

When the time set on the external variable resistor control elapses, the Completion Flag (00210) goes ON and the Unit's TIME UP indicator lights. Output IR 00502 goes ON at the same time.

When the time set on the external variable resistor control elapses, the Completion Flag (00211) goes ON and the Unit's TIME UP indicator lights. Output IR 00503 goes ON at the same time.

SECTION 5 Instruction Set

The C200HX/HG/HE PCs have large programming instruction sets that allow for easy programming of complicated control processes. This section explains instructions individually and provides the ladder diagram symbol, data areas, and flags used with each.

The C200HX/HG/HS PCs can process more than 100 instructions that require function codes, but only 100 function codes (00 to 99) are available. Some instructions, called expansion instructions, do not have fixed function codes and must be assigned function codes from the 18 function codes set aside for expansion instructions before they can be used.

The many instructions provided by the C200HX/HG/HE PCs are organized in the following subsections by instruction group. These groups include Ladder Diagram Instructions, Bit Control Instructions, Timer and Counter Instructions, Data Shifting Instructions, Data Movement Instructions, Data Comparison Instructions, Data Conversion Instructions, BCD Calculation Instructions, Binary Calculation Instructions, Logic Instructions, Subroutines, Special Instructions, Network Instructions, Serial Communications Instructions, Advanced I/O Instructions, and Special I/O Unit Instructions.

Some instructions, such as Timer and Counter instructions, are used to control execution of other instructions, e.g., a TIM Completion Flag might be used to turn ON a bit when the time period set for the timer has expired. Although these other instructions are often used to control output bits through the Output instruction, they can be used to control execution of other instructions as well. The Output instructions used in examples in this manual can therefore generally be replaced by other instructions to modify the program for specific applications other than controlling output bits directly.

5-1	Notation							
5-2	Instruction Format							
5-3	Data Areas, Definer Values, and Flags							
5-4	Differentiated Instructions							
5-5	Expansio	on Instructions						
5-6	Coding I	Right-hand Instructions						
5-7		on Set Lists						
	5-7-1	Function Codes						
	5-7-2	Alphabetic List by Mnemonic						
5-8	Ladder I	Diagram Instructions						
	5-8-1	LOAD, LOAD NOT, AND, AND NOT, OR, and OR NOT						
	5-8-2	AND LOAD and OR LOAD						
5-9	Bit Cont	rol Instructions						
	5-9-1	OUTPUT and OUTPUT NOT – OUT and OUT NOT						
	5-9-2	DIFFERENTIATE UP and DOWN – DIFU(13) and DIFD(14)						
	5-9-3	SET and RESET – SET and RSET						
	5-9-4	KEEP – KEEP(11)						
5-10	INTERL	OCK and INTERLOCK CLEAR – IL(02) and ILC(03)						
5-11		nd JUMP END – JMP(04) and JME(05)						
5-12	END – E	END(01)						
5-13	NO OPE	RATION – NOP(00)						
5-14	Timer an	d Counter Instructions						
	5-14-1	TIMER – TIM						
	5-14-2	HIGH-SPEED TIMER – TIMH(15)						
	5-14-3	TOTALIZING TIMER – TTIM(87)						
	5-14-4	COUNTER - CNT						
	5-14-5	REVERSIBLE COUNTER – CNTR(12)						
5-15	Data Shi	fting						
	5-15-1	SHIFT REGISTER – SFT(10)						
	5-15-2	REVERSIBLE SHIFT REGISTER – SFTR(84)						
	5-15-3	ARITHMETIC SHIFT LEFT – ASL(25)						
	5-15-4	ARITHMETIC SHIFT RIGHT – ASR(26)						
	5-15-5	ROTATE LEFT – ROL(27)						
	5-15-6	ROTATE RIGHT – ROR(28)						
	5-15-7	ONE DIGIT SHIFT LEFT – SLD(74)						
	5-15-8	ONE DIGIT SHIFT RIGHT – SRD(75)						
	5-15-9	WORD SHIFT – WSFT(16)						
	5-15-10	ASYNCHRONOUS SHIFT REGISTER – ASFT(17)						
5-16	Data Mo	vement						
	5-16-1	MOVE – MOV(21)						
	5-16-2	MOVE NOT – MVN(22)						
	5-16-3	BLOCK SET – BSET(71)						
	5-16-4	BLOCK TRANSFER - XFER(70)						

	5-16-5	DATA EXCHANGE – XCHG(73)
	5-16-6	SINGLE WORD DISTRIBUTE – DIST(80)
	5-16-7	DATA COLLECT – COLL(81)
	5-16-8	MOVE BIT – MOVB(82)
	5-16-9	MOVE DIGIT – MOVD(83)
	5-16-10	TRANSFER BITS – XFRB(62)
		EM BLOCK TRANSFER – XFR2(—)
		EM BANK TRANSFER – BXF2(—)
5-17	Data Cor	mparison
	5-17-1	MULTI-WORD COMPARE – MCMP(19)
	5-17-2	COMPARE – CMP(20)
	5-17-3	DOUBLE COMPARE – CMPL(60)
	5-17-4	BLOCK COMPARE – BCMP(68)
	5-17-5	TABLE COMPARE – TCMP(85)
	5-17-6	AREA RANGE COMPARE – ZCP(88)
	5-17-7	DOUBLE AREA RANGE COMPARE – ZCPL(—)
	5-17-8	SIGNED BINARY COMPARE – CPS(—)
	5-17-9	DOUBLE SIGNED BINARY COMPARE – CPSL(—)
5-18	Data Cor	nversion
	5-18-1	BCD-TO-BINARY – BIN(23)
	5-18-2	DOUBLE BCD-TO-DOUBLE BINARY – BINL(58)
	5-18-3	BINARY-TO-BCD – BCD(24)
	5-18-3 5-18-4	DOUBLE BINARY-TO-DOUBLE BCD – BCDL(59)
	5-18-5	HOURS-TO-SECONDS – SEC(65)
	5-18-6	SECONDS-TO-HOURS – HMS(66)
	5-18-7	4-TO-16/8-TO-256 DECODER – MLPX(76)
	5-18-8	16-TO-4/256-TO-8 ENCODER – DMPX(77)
	5-18-9	7-SEGMENT DECODER – SDEC(78)
	5-18-10	ASCII CONVERT – ASC(86)
	5-18-11	ASCII-TO-HEXADECIMAL – HEX(—)
		SCALING – SCL(—)
		COLUMN TO LINE – LINE(63)
		LINE TO COLUMN – COLM(64)
	5-18-15	2'S COMPLEMENT – NEG(—)
	5-18-16	DOUBLE 2'S COMPLEMENT – NEGL(—)
5-19	BCD Ca	culations
	5-19-1	INCREMENT – INC(38)
	5-19-2	DECREMENT – DEC(39)
	5-19-3	SET CARRY – STC(40)
	5-19-4	CLEAR CARRY – CLC(41)
	5-19-5	BCD ADD – ADD(30)
	5-19-6	DOUBLE BCD ADD – ADDL(54)
	5-19-7	BCD SUBTRACT – SUB(31)
	5-19-8	DOUBLE BCD SUBTRACT – SUBL(55)
	5-19-9	BCD MULTIPLY – MUL(32)
	5-19-10	DOUBLE BCD MULTIPLY – MULL(56)
	5-19-11	BCD DIVIDE – DIV(33)
		DOUBLE BCD DIVIDE – DIVL(57)
		FLOATING POINT DIVIDE – FDIV(79)
	5-19-14	SQUARE ROOT – ROOT(72)
20		
-20		alculations
	5-20-1	BINARY ADD – ADB(50)
	5-20-2	BINARY SUBTRACT – SBB(51)
	5-20-3	BINARY MULTIPLY – MLB(52)
	5-20-4	BINARY DIVIDE – DVB(53)
	5-20-5	DOUBLE BINARY ADD – ADBL(—)
	5-20-6	DOUBLE BINARY SUBTRACT – SBBL(—)
	5-20-7	SIGNED BINARY MULTIPLY – MBS(—)
	5-20-7	DOUBLE SIGNED BINARY MULTIPLY – MBSL(—)
	5-20-9	SIGNED BINARY DIVIDE – DBS(—)
	5-20-10	DOUBLE SIGNED BINARY DIVIDE – DBSL(—)
5-21		Math Instructions
	5-21-1	FIND MAXIMUM – MAX(—)
	5-21-2	FIND MINIMUM – MIN(—)
	5-21-3	AVERAGE VALUE – AVG(—)
	5 21 4	CIIM CIIM()

	5-21-5	ARITHMETIC PROCESS – APR(69)
	5-21-6	PID CONTROL – PID(—)
5-22	Logic In	structions
	5-22-1	COMPLEMENT – COM(29)
	5-22-2	LOGICAL AND – ANDW(34)
	5-22-3	LOGICAL OR – ORW(35)
	5-22-4	EXCLUSIVE OR – XORW(36)
	5-22-5	EXCLUSIVE NOR – XNRW(37)
5-23	Subrouti	nes and Interrupt Control
	5-23-1	Subroutines
	5-23-2	Interrupts
	5-23-3	SUBROUTINE ENTER – SBS(91)
	5-23-4	SUBROUTINE DEFINE and RETURN – SBN(92)/RET(93)
	5-23-5	MACRO – MCRO(99)
	5-23-6	INTERRUPT CONTROL – INT(89)
5-24	Step Inst	ructions
	5-24-1	STEP DEFINE and STEP START–STEP(08)/SNXT(09)
5-25	Special I	nstructions
	5-25-1	FAILURE ALARM – FAL(06) and
		SEVERE FAILURE ALARM – FALS(07)
	5-25-2	CYCLE TIME – SCAN(18)
	5-25-3	TRACE MEMORY SAMPLING – TRSM(45)
	5-25-4	MESSAGE DISPLAY – MSG(46)
	5-25-5	LONG MESSAGE – LMSG(47)
	5-25-6	TERMINAL MODE – TERM(48)
	5-25-7	WATCHDOG TIMER REFRESH – WDT(94)
	5-25-8	I/O REFRESH – IORF(97)
	5-25-9	GROUP-2 HIGH-DENSITY I/O REFRESH – MPRF(61)
	5-25-10	BIT COUNTER – BCNT(67)
		FRAME CHECKSUM – FCS(—)
	5-25-12	FAILURE POINT DETECTION – FPD(—)
		DATA SEARCH – SRCH(—)
		EXPANSION DM READ – XDMR(—)
		INDIRECT EM ADDRESSING – IEMS(—)
	5-25-16	SELECT EM BANK – EMBC(—)
5-26		Instructions
	5-26-1	NETWORK SEND – SEND(90)
	5-26-2	NETWORK RECEIVE – RECV(98)
	5-26-3	About Network Communications
5-27	Serial Co	ommunications Instructions
	5-27-1	RECEIVE – RXD(—)
	5-27-2	TRANSMIT – TXD(—)
	5-27-3	CHANGE RS-232C SETUP – STUP(—)
	5-27-4	PROTOCOL MACRO – PMCR(—)
5-28		d I/O Instructions
	5-28-1	7-SEGMENT DISPLAY OUTPUT – 7SEG(—)
	5-28-2	DIGITAL SWITCH INPUT – DSW(—)
	5-28-3	HEXADECIMAL KEY INPUT – HKY(—)
	5-28-4	TEN KEY INPUT – TKY(—)
	5-28-5	MATRIX INPUT – MTR(—)
5-29		/O Unit Instructions
J-47	5-29-1	SPECIAL I/O UNIT READ – IORD(—)
	5-29-2	SPECIAL I/O UNIT WRITE – IOWR(—)
	5-29-2 5-29-3	PCMCIA CARD MACRO – CMCR(—)
	J-47-J	$1 \text{ CIVICITY CTAND INTACKO} - \text{CIVICK}(-) \dots \dots$

5-1 Notation

In the remainder of this manual, all instructions will be referred to by their mnemonics. For example, the Output instruction will be called OUT; the AND Load instruction, AND LD. If you're not sure of the instruction a mnemonic is used for, refer to *Appendix B Programming Instructions*.

If an instruction is assigned a function code, it will be given in parentheses after the mnemonic. These function codes, which are 2-digit decimal numbers, are used to input most instructions into the CPU Unit and are described briefly below and in more detail in 4-7 Inputting, Modifying, and Checking the Program. A table of instructions listed in order of function codes, is also provided in Appendix B.

An @ before a mnemonic indicates the differentiated version of that instruction. Differentiated instructions are explained in *Section 5-4*.

5-2 Instruction Format

Most instructions have at least one or more operands associated with them. Operands indicate or provide the data on which an instruction is to be performed. These are sometimes input as the actual numeric values (i.e., as constants), but are usually the addresses of data area words or bits that contain the data to be used. A bit whose address is designated as an operand is called an operand bit; a word whose address is designated as an operand is called an operand word. In some instructions, the word address designated in an instruction indicates the first of multiple words containing the desired data.

Each instruction requires one or more words in Program Memory. The first word is the instruction word, which specifies the instruction and contains any definers (described below) or operand bits required by the instruction. Other operands required by the instruction are contained in following words, one operand per word. Some instructions require up to four words.

A definer is an operand associated with an instruction and contained in the same word as the instruction itself. These operands define the instruction rather than telling what data it is to use. Examples of definers are TC numbers, which are used in timer and counter instructions to create timers and counters, as well as jump numbers (which define which Jump instruction is paired with which Jump End instruction). Bit operands are also contained in the same word as the instruction itself, although these are not considered definers.

5-3 Data Areas, Definer Values, and Flags

In this section, each instruction description includes its ladder diagram symbol, the data areas that can be used by its operands, and the values that can be used as definers. Details for the data areas are also specified by the operand names and the type of data required for each operand (i.e., word or bit and, for words, hexadecimal or BCD).

Not all addresses in the specified data areas are necessarily allowed for an operand, e.g., if an operand requires two words, the last word in a data area cannot be designated as the first word of the operand because all words for a single operand must be within the same data area. Also, not all words in the SR and DM areas are writeable as operands (see Section 3 Memory Areas for details.) Other specific limitations are given in a Limitations subsection. Refer to Section 3 Memory Areas for addressing conventions and the addresses of flags and control bits.



The IR and SR areas are considered as separate data areas. If an operand has access to one area, it doesn't necessarily mean that the same operand will have access to the other area. The border between the IR and SR areas can, however, be crossed for a single operand, i.e., the last bit in the IR area may be specified for an operand that requires more than one word as long as the SR area is also allowed for that operand.


The *Flags* subsection lists flags that are affected by execution of an instruction. These flags include the following SR area flags.

Abbreviation	Name	Bit
ER	Instruction Execution Error Flag	25503
CY	Carry Flag	25504
GR	Greater Than Flag	25505
EQ	Equals Flag	25506
LE	Less Than Flag	25507
N	Negative Flag	25402
OF	Overflow Flag	25404
UF	Underflow Flag	25405

ER is the flag most commonly used for monitoring an instruction's execution. When ER goes ON, it indicates that an error has occurred in attempting to execute the current instruction. The *Flags* subsection of each instruction lists possible reasons for ER being ON. ER will turn ON if operands are not entered correctly. Instructions are not executed when ER is ON. A table of instructions and the flags they affect is provided in *Appendix C Error and Arithmetic Flag Operation*.

Indirect Addressing

When the DM area is specified for an operand, an indirect address can be used. Indirect DM addressing is specified by placing an asterisk before the DM: *DM. When an indirect DM address is specified, the designated DM word will contain the address of the DM word that contains the data that will be used as the operand of the instruction. If, for example, *DM 0001 was designated as the first operand and LR 00 as the second operand of MOV(21), the contents of DM 0001 was 1111, and DM 1111 contained 5555, the value 5555 would be moved to LR 00.



When using indirect addressing, the address of the desired word must be in BCD and it must specify a word within the DM area. In the above example, the content of *DM 0000 would have to be in BCD between 0000 and 6655.

The IEMS(—) instruction can be used to change the destination of *DM from the DM area to one of the banks in the EM area. Refer to 5-25-15 INDIRECT EM ADDRESSING – IEMS(—) for details.


Designating Constants

Although data area addresses are most often given as operands, many operands and all definers are input as constants. The available value range for a given definer or operand depends on the particular instruction that uses it. Constants must also be entered in the form required by the instruction, i.e., in BCD or in hexadecimal.

5-4 Differentiated Instructions

Most instructions are provided in both differentiated and non-differentiated forms. Differentiated instructions are distinguished by an @ in front of the instruction mnemonic.

A non-differentiated instruction is executed each time it is cycled as long as its execution condition is ON. A differentiated instruction is executed only once after its execution condition goes from OFF to ON. If the execution condition has not changed or has changed from ON to OFF since the last time the instruction was cycled, the instruction will not be executed. The following two examples show how this works with MOV(21) and @MOV(21), which are used to move the data in the address designated by the first operand to the address designated by the second operand.



Address	Instruction	Opera	ands
00000	LD		00000
00001	MOV(21)		
		HR	10
		DM	0000

Address	Instruction	Opera	ands
00000	LD		00000
00001	@MOV(21)		
		HR	10
		DM	0000

In diagram A, the non-differentiated MOV(21) will move the content of HR 10 to DM 0000 whenever it is cycled with 00000. If the cycle time is 80 ms and 00000 remains ON for 2.0 seconds, this move operation will be performed 25 times and only the last value moved to DM 0000 will be preserved there.

In diagram B, the differentiated @MOV(21) will move the content of HR 10 to DM 0000 only once after 00000 goes ON. Even if 00000 remains ON for 2.0 seconds with the same 80 ms cycle time, the move operation will be executed only once during the first cycle in which 00000 has changed from OFF to ON. Because the content of HR 10 could very well change during the 2 seconds while 00000 is ON, the final content of DM 0000 after the 2 seconds could be different depending on whether MOV(21) or @MOV(21) was used.

All operands, ladder diagram symbols, and other specifications for instructions are the same regardless of whether the differentiated or non-differentiated form of an instruction is used. When inputting, the same function codes are also used, but NOT is input after the function code to designate the differentiated form of an instruction. Most, but not all, instructions have differentiated forms.

Refer to 5-10 INTERLOCK and INTERLOCK CLEAR – IL(02) and IL(03) for the effects of interlocks on differentiated instructions.

The C200HX/HG/HE PCs also provide differentiation instructions: DIFU(13) and DIFD(14). DIFU(13) operates the same as a differentiated instruction, but is used to turn ON a bit for one cycle. DIFD(14) also turns ON a bit for one cycle, but does it when the execution condition has changed from ON to OFF. Refer to 5-9-2 DIFFERENTIATE UP and DOWN - DIFU(13) and DIFD(14) for details.

Note Do not use SR 25313 and SR 25315 for differentiated instructions. These bits never change status and will not trigger differentiated instructions.

5-5 Expansion Instructions

The C200HX/HG/HE PCs have more instructions that require function codes (121) than function codes (100), so some instructions do not have fixed function codes. These instructions, called expansion instructions, are listed in the following table. Default function codes are given for the instructions that have them.

An expansion instruction can be assigned one of 18 function codes using the Programming Console's Expansion Instruction Function Code Assignments operation. The 18 function codes are: 17, 18, 19, 47, 48, 60 to 69, 87, 88, and 89. Refer to 7-2-14 Expansion Instruction Function Code Assignments for details on assigning function codes.

Code	Mnemonic	Name	Page
17	(@)ASFT	ASYNCHRONOUS SHIFT REGISTER	178
18	(@)SCAN	CYCLE TIME	303
19	(@)MCMP	MULTI-WORD COMPARE	192
47	(@)LMSG	32-CHARACTER MESSAGE	306
48	(@)TERM	TERMINAL MODE	307
60	CMPL	DOUBLE COMPARE	196
61	(@)MPRF	GROUP-2 HIGH-DENSITY I/O REFRESH	309
62	(@)XFRB	TRANSFER BITS	189
63	(@)LINE	COLUMN TO LINE	224
64	(@)COLM	LINE TO COLUMN	225
65	(@)SEC	HOURS TO SECONDS	207
66	(@)HMS	SECONDS TO HOURS	208
67	(@)BCNT	BIT COUNTER	310
68	(@)BCMP	BLOCK COMPARE	197
69	(@)APR	ARITHMETIC PROCESS	263
87	TTIM	TOTALIZING TIMER	165
88	ZCP	AREA RANGE COMPARE	200
89	(@)INT	INTERRUPT CONTROL	289
	7SEG	7-SEGMENT DISPLAY OUTPUT	338
	(@)ADBL	DOUBLE BINARY ADD	249
	AVG	AVERAGE VALUE	259
	(@)BXF2	EM BANK TRANSFER	191
	CPS	SIGNED BINARY COMPARE	202
	CPSL	DOUBLE SIGNED BINARY COMPARE	203
	CMCR	PCMCIA CARD MACRO	355
	(@)DBS	SIGNED BINARY DIVIDE	255
	(@)DBSL	DOUBLE SIGNED BINARY DIVIDE	256
	DSW	DIGITAL SWITCH INPUT	341
	@EMBC	SELECT EM BANK	319
	(@)FCS	FCS CALCULATE	310
	FPD	FAILURE POINT DETECT	312
	(@)HEX	ASCII-TO-HEXADECIMAL	219
	HKY	HEXADECIMAL KEY INPUT	345
	(@)IEMS	INDIRECT EM ADDRESSING	318
	(@)IORD	SPECIAL I/O UNIT READ	352
	(@)IOWR	SPECIAL I/O UNIT WRITE	353
	(@)MAX	FIND MAXIMUM	257
	(@)MBS	SIGNED BINARY MULTIPLY	253
	(@)MBSL	DOUBLE SIGNED BINARY MULTIPLY	254

Code	Mnemonic	Name	Page
	(@)MIN	FIND MINIMUM	258
	MTR	MATRIX INPUT	350
	(@)NEG	2'S COMPLEMENT	226
	(@)NEGL	DOUBLE 2'S COMPLEMENT	227
	PID	PID CONTROL	266
	(@)PMCR	PROTOCOL MACRO	337
	(@)RXD	RECEIVE	331
	(@)SBBL	DOUBLE BINARY SUBTRACT	251
	(@)SCL	SCALING	222
	(@)SRCH	DATA SEARCH	316
	(@)STUP	CHANGE RS-232C SETUP	335
	(@)SUM	SUM CALCULATE	261
	(@)TKY	TEN KEY INPUT	348
	(@)TXD	TRANSMIT	333
	(@)XDMR	EXPANSION DM READ	317
	(@)XFR2	EM BLOCK TRANSFER	190
	ZCPL	DOUBLE AREA RANGE COMPARE	201

5-6 Coding Right-hand Instructions

Writing mnemonic code for ladder instructions is described in *Section 4 Writing* and *Inputting the Program*. Converting the information in the ladder diagram symbol for all other instructions follows the same pattern, as described below, and is not specified for each instruction individually.


The first word of any instruction defines the instruction and provides any definers. If the instruction requires only a signal bit operand with no definer, the bit operand is also placed on the same line as the mnemonic. All other operands are placed on lines after the instruction line, one operand per line and in the same order as they appear in the ladder symbol for the instruction.

The address and instruction columns of the mnemonic code table are filled in for the instruction word only. For all other lines, the left two columns are left blank. If the instruction requires no definer or bit operand, the data column is left blank for first line. It is a good idea to cross through any blank data column spaces (for all instruction words that do not require data) so that the data column can be quickly scanned to see if any addresses have been left out.

If an IR or SR address is used in the data column, the left side of the column is left blank. If any other data area is used, the data area abbreviation is placed on the left side and the address is place on the right side. If a constant to be input, the number symbol (#) is placed on the left side of the data column and the number to be input is placed on the right side. Any numbers input as definers in the instruction word do not require the number symbol on the right side. TC bits, once defined as a timer or counter, take a TIM (timer) or CNT (counter) prefix.

When coding an instruction that has a function code, be sure to write in the function code, which will be necessary when inputting the instruction via the Programming Console. Also be sure to designate the differentiated instruction with the @ symbol.


The following diagram and corresponding mnemonic code illustrates the points described above.



		ı	
Address	Instruction	Data	a
00000	LD		00000
00001	AND		00001
00002	OR	1	00002
00003	DIFU(13)		22500
00004	LD		00100
00005	AND NOT		00200
00006	LD		01001
00007	AND NOT		01002
80000	AND NOT	LR	6300
00009	OR LD		. –
00010	AND		22500
00011	BCNT(67)		
		#	0001
			004
		HR	00
00012	LD		00005
00013	TIM		000
		#	0150
00014	LD	TIM	000
00015	MOV(21)		
		HR	00
		LR	00
00016	LD	HR	0015
00017	OUT NOT		00500

Multiple Instruction Lines

If a right-hand instruction requires multiple instruction lines (such as KEEP(11)), all of the lines for the instruction are entered before the right-hand instruction. Each of the lines for the instruction is coded, starting with LD or LD NOT, to form 'logic blocks' that are combined by the right-hand instruction. An example of this for SFT(10) is shown below.



Address	Instruction	Data	1
00000	LD		00000
00001	AND		00001
00002	LD		00002
00003	LD	1	00100
00004	AND NOT		00200
00005	LD		01001
00006	AND NOT		01002
00007	AND NOT	LR	6300
80000	OR LD		_
00009	AND		22500
00010	SFT(10)		
		HR	00
		HR	00
00011	LD	HR	0015
00012	OUT NOT		00500

END(01)

When you have finished coding the program, make sure you have placed END(01) at the last address.

5-7 Instruction Set Lists

This section provides tables of the instructions available in the C200HX/HG/HE. The first table can be used to find instructions by function code. The second table can be used to find instruction by mnemonic. In both tables, the @ symbol indicates instructions with differentiated variations.

Note Refer to *5-5 Expansion Instructions* for a list of the expansion instructions.

5-7-1 Function Codes

The following table lists the instructions that have fixed function codes. Each instruction is listed by mnemonic and by instruction name. Use the numbers in the leftmost column as the left digit and the number in the column heading as the right digit of the function code.

Left					Right	t digit				
digit	0	1	2	3	4	5	6	7	8	9
0	NOP NO OPERATION	END END	IL INTERLOCK	ILC INTERLOCK CLEAR	JMP JUMP	JME JUMP END	(@) FAL FAILURE ALARM AND RESET	FALS SEVERE FAILURE ALARM	STEP STEP DEFINE	SNXT STEP START
1	SFT SHIFT REGISTER	KEEP KEEP	CNTR REVERS- IBLE COUNTER	DIFU DIFFER- ENTIATE UP	DIFD DIFFER- ENTIATE DOWN	TIMH HIGH- SPEED TIMER	(@) WSFT WORD SHIFT	(@) ASFT ASYNCHRO- NOUS SHIFT REGISTER	(@) SCAN CYCLE TIME	(@) MCMP MULTI- WORD COMPARE
2	CMP COMPARE	(@) MOV MOVE	(@) MVN MOVE NOT	(@) BIN BCD TO BINARY	(@) BCD BINARY TO BCD	(@) ASL SHIFT LEFT	(@) ASR SHIFT RIGHT	(@) ROL ROTATE LEFT	(@) ROR ROTATE RIGHT	(@) COM COMPLE- MENT
3	(@) ADD BCD ADD	(@) SUB BCD SUBTRACT	(@) MUL BCD MULTIPLY	(@) DIV BCD DIVIDE	(@) ANDW LOGICAL AND	(@) ORW LOGICAL OR	(@) XORW EXCLUSIVE OR	(@) XNRW EXCLUSIVE NOR	(@) INC INCREMENT	(@) DEC DECRE- MENT
4	(@) STC SET CARRY	(@) CLC CLEAR CARRY				TRSM TRACE MEMORY SAMPLE	(@) MSG MESSAGE DISPLAY	(@) LMSG LONG MES- SAGE	(@) TERM TERMINAL MODE	
5	(@) ADB BINARY ADD	(@) SBB BINARY SUBTRACT	(@) MLB BINARY MULTIPLY	(@) DVB BINARY DIVIDE	(@) ADDL DOUBLE BCD ADD	(@) SUBL DOUBLE BCD SUBTRACT	(@) MULL DOUBLE BCD MULTIPLY	(@) DIVL DOUBLE BCD DIVIDE	(@) BINL DOUBLE BCD-TO- DOUBLE BINARY	(@) BCDL DOUBLE BINARY-TO- DOUBLE BCD
6	CMPL DOUBLE COMPARE	(@) MPRF GROUP-2 HIGH-DENSI- TY I/O RE- FRESH	(@) XFRB TRANSFER BITS	(@) LINE COLUMN TO LINE	(@) COLM LINE TO COLUMN	(@) SEC HOURS-TO- SECONDS	(@) HMS SECONDS- TO-HOURS	(@) BCNT BIT COUNT- ER	(@) BCMP BLOCK COMPARE	(@) APR ARITHMETIC PROCESS
7	(@) XFER BLOCK TRANSFER	(@) BSET BLOCK SET	(@) ROOT SQUARE ROOT	(@) XCHG DATA EXCHANGE	(@) SLD ONE DIGIT SHIFT LEFT	(@) SRD ONE DIGIT SHIFT RIGHT	(@) MLPX 4-TO-16/ 8-TO-256 DECODER	(@) DMPX 16-TO-4/ 256-TO-8 ENCODER	(@) SDEC 7-SEGMENT DECODER	(@) FDIV FLOATING POINT DIVIDE
8	(@) DIST SINGLE WORD DISTRIBUTE	(@) COLL DATA COLLECT	(@) MOVB MOVE BIT	(@) MOVD MOVE DIGIT	(@) SFTR REVERS- IBLE SHIFT REGISTER	(@) TCMP TABLE COMPARE	(@) ASC ASCII CONVERT	TTIM TOTALIZING COUNTER	ZCP AREA RANGE COMPARE	(@) INT INTERRUPT CONTROL
9	(@) SEND NETWORK SEND	(@) SBS SUBROU- TINE ENTRY	SBN SUBROU- TINE DEFINE	RET SUBROU- TINE RETURN	(@) WDT WATCHDOG TIMER REFRESH			(@) IORF I/O REFRESH	(@) RECV NETWORK RECEIVE	(@) MCRO MACRO

5-7-2 Alphabetic List by Mnemonic

Mnemonic	Code	Words	Name	Page
7SEG		4	7-SEGMENT DISPLAY OUTPUT	338
ADB (@)	50	4	BINARY ADD	243
ADBL (@)		4	DOUBLE BINARY ADD	249
ADD (@)	30	4	BCD ADD	229
ADDL (@)	54	4	DOUBLE BCD ADD	230
AND	None	1	AND	149
AND LD	None	1	AND LOAD	150
AND NOT	None	1	AND NOT	149
ANDW (@)	34	4	LOGICAL AND	278
APR (@)	69	4	ARITHMETIC PROCESS	263
ASC (@)	86	4	ASCII CONVERT	218

Mnemonic	Code	Words	Name	Page
ASFT(@)	17	4	ASYNCHRONOUS SHIFT REGISTER	178
ASL (@)	25	2	ARITHMETIC SHIFT LEFT	175
ASR (@)	26	2	ARITHMETIC SHIFT RIGHT	175
AVG (@)		4	AVERAGE VALUE	259
BCD (@)	24	3	BINARY TO BCD	205
BCDL (@)	59	3	DOUBLE BINARY-TO-DOUBLE BCD	206
BCMP (@)	68	4	BLOCK COMPARE	197
BCNT (@)	67	4	BIT COUNTER	310
BIN (@)	23	3	BCD-TO-BINARY	204
BINL (@)	58	3	DOUBLE BCD-TO-DOUBLE BINARY	205
BSET (@)	71	4	BLOCK SET	181
BXF2 (@)		4	EM BLOCK TRANSFER	190
CLC (@)	41	1	CLEAR CARRY	229
CMCR (@)		4	PCMCIA CARD MACRO	355
CMP	20	3	COMPARE	193
CMPL	60	4	DOUBLE COMPARE	196
CNT	None	2	COUNTER	166
CNTR	12	3	REVERSIBLE COUNTER	169
COLL (@)	81	4	DATA COLLECT	185
COLM(@)	64	4	LINE TO COLUMN	225
COM (@)	29	2	COMPLEMENT	277
CPS		4	SIGNED BINARY COMPARE	202
CPSL		4	DOUBLE SIGNED BINARY COMPARE	203
DBS (@)		4	SIGNED BINARY DIVIDE	255
DBSL (@)		4	DOUBLE SIGNED BINARY DIVIDE	256
DEC (@)	39	2	BCD DECREMENT	228
DIFD	14	2	DIFFERENTIATE DOWN	151
DIFU	13	2	DIFFERENTIATE UP	151
DIST (@)	80	4	SINGLE WORD DISTRIBUTE	183
DIV (@)	33	4	BCD DIVIDE	236
DIVL (@)	57	4	DOUBLE BCD DIVIDE	237
DMPX (@)	77	4	16-TO-4/256-TO-8 ENCODER	212
DSW		4	DIGITAL SWITCH	341
DVB (@)	53	4	BINARY DIVIDE	248
EMBC (@)		2	SELECT EM BANK	319
END	01	1	END	158
FAL (@)	06	2	FAILURE ALARM AND RESET	302
FALS	07	2	SEVERE FAILURE ALARM	302
FCS (@)		4	FCS CALCULATE	310
FDIV (@)	79	4	FLOATING POINT DIVIDE	238
FPD FPD	<u> </u>	4	FAILURE POINT DETECT	312
HEX (@)		4	ASCII-TO-HEXADECIMAL	219
HKY	<u> </u>	4	HEXADECIMAL KEY INPUT	345
HMS (@)	66	4	SECONDS TO HOURS 208	
IEMS (@)		2	INDIRECT EM ADDRESSING 318	
IL	02	1	INTERLOCK 155	
ILC	03	1	INTERLOCK CLEAR	155
INC (@)	38	2	INCREMENT	228
INT (@)	89	4	INTERRUPT CONTROL	289


Mnemonic	Code	Words	Name	Page
IORD (@)		4	SPECIAL I/O UNIT READ	352
IORF (@)	97	3	I/O REFRESH	308
IOWR (@)		4	SPECIAL I/O UNIT WRITE	353
JME	05	2	JUMP END	157
JMP	04	2	JUMP	157
KEEP	11	2	KEEP	154
LD	None	1	LOAD	149
LD NOT	None	1	LOAD NOT	149
LINE (@)	63	4	COLUMN TO LINE	224
LMSG (@)	47	4	32-CHARACTER MESSAGE	306
MAX (@)		4	FIND MAXIMUM	257
MBS (@)		4	SIGNED BINARY MULTIPLY	253
MBSL (@)		4	DOUBLE SIGNED BINARY MULTIPLY	254
MCMP (@)	19	4	MULTI-WORD COMPARE	192
MCRO (@)	99	4	MACRO	287
MIN (@)	_	4	FIND MINIMUM	258
MLB (@)	52	4	BINARY MULTIPLY	248
MLPX (@)	76	4	4-TO-16/8-TO-256 DECODER	209
MOV (@)	21	3	MOVE	180
MOVB (@)	82	4	MOVE BIT	187
MOVD (@)	83	4	MOVE DIGIT	188
MPRF (@)	61	4	GROUP-2 HIGH-DENSITY I/O REFRESH	309
MSG (@)	46	2	MESSAGE	305
MTR		4	MATRIX INPUT	350
MUL (@)	32	4	BCD MULTIPLY	235
MULL (@)	56	4	DOUBLE BCD MULTIPLY	236
MVN (@)	22	3	MOVE NOT	180
NEG		4	2'S COMPLEMENT	226
NEGL		4	DOUBLE 2'S COMPLEMENT	227
NOP	00	1	NO OPERATION	158
OR	None	1	OR	149
OR LD	None	1	OR LOAD	150
OR NOT	None	1	OR NOT	149
ORW (@)	35	4	LOGICAL OR	279
OUT	None	2	OUTPUT	150
OUT NOT	None	2	OUTPUT NOT	150
PID (@)		4	PID CONTROL	266
PMCR (@)		4	PROTOCOL MACRO	337
RECV (@)	98	4	NETWORK RECEIVE	325
RET	93	1	SUBROUTINE RETURN	286
ROL (@)	27	2	ROTATE LEFT	176
ROOT (@)	72	3	SQUARE ROOT	241
ROR (@)	28	2	ROTATE RIGHT	176
RSET	None	2	RESET 153	
RXD(@)		4	RECEIVE 331	
SBB (@)	51	4	BINARY SUBTRACT 245	
SBBL (@)		4	DOUBLE BINARY SUBTRACT 251	
SBN	92	2	SUBROUTINE DEFINE	286
SBS (@)	91	2	SUBROUTINE ENTRY	285

Mnemonic	Code	Words	Name	Page
SCAN (@)	18	4	CYCLE TIME	303
SCL (@)	_	4	SCALING	222
SDEC (@)	78	4	7-SEGMENT DECODER	215
SEC (@)	65	4	HOURS TO SECONDS	207
SEND (@)	90	4	NETWORK SEND	320
SET	None	2	SET	153
SFT	10	3	SHIFT REGISTER	171
SFTR (@)	84	4	REVERSIBLE SHIFT REGISTER	173
SLD (@)	74	3	ONE DIGIT SHIFT LEFT	177
SNXT	09	2	STEP START	293
SRCH (@)	_	4	DATA SEARCH	316
SRD (@)	75	3	ONE DIGIT SHIFT RIGHT	177
STC (@)	40	1	SET CARRY	229
STEP	08	2	STEP DEFINE	293
STUP (@)	_	2	CHANGE RS-232C SETUP	335
SUB (@)	31	4	BCD SUBTRACT	231
SUBL (@)	55	4	DOUBLE BCD SUBTRACT	233
SUM (@)	_	4	SUM CALCULATION	261
TCMP (@)	85	4	TABLE COMPARE	199
TERM (@)	48	4	TERMINAL MODE	307
TIM	None	2	TIMER	159
TIMH	15	3	HIGH-SPEED TIMER	164
TKY (@)	_	4	TEN KEY INPUT	348
TRSM	45	1	TRACE MEMORY SAMPLE	304
TTIM	87	4	TOTALIZING TIMER	165
TXD (@)	_	4	TRANSMIT	333
WDT (@)	94	2	WATCHDOG TIMER REFRESH	308
WSFT (@)	16	3	WORD SHIFT	178
XCHG (@)	73	3	DATA EXCHANGE	183
XDMR (@)	_	4	EXPANSION DM READ	317
XFER (@)	70	4	BLOCK TRANSFER	182
XFR2 (@)	_	4	EM BLOCK TRANSFER	190
XFRB (@)	62	4	TRANSFER BITS	189
XNRW (@)	37	4	EXCLUSIVE NOR	281
XORW (@)	36	4	EXCLUSIVE OR	280
ZCP	88	4	AREA RANGE COMPARE 200	
ZCPL		4	DOUBLE AREA RANGE COMPARE	201

5-8 Ladder Diagram Instructions

Ladder Diagram instructions include Ladder instructions and Logic Block instructions and correspond to the conditions on the ladder diagram. Logic block instructions are used to relate more complex parts.

5-8-1 LOAD, LOAD NOT, AND, AND NOT, OR, and OR NOT



Limitations

There is no limit to the number of any of these instructions, or restrictions in the order in which they must be used, as long as the memory capacity of the PC is not exceeded.

Description

These six basic instructions correspond to the conditions on a ladder diagram. As described in *Section 4 Writing and Inputting the Program*, the status of the bits assigned to each instruction determines the execution conditions for all other instructions. Each of these instructions and each bit address can be used as many times as required. Each can be used in as many of these instructions as required.

The status of the bit operand (B) assigned to LD or LD NOT determines the first execution condition. AND takes the logical AND between the execution condition and the status of its bit operand; AND NOT, the logical AND between the execution condition and the inverse of the status of its bit operand. OR takes the logical OR between the execution condition and the status of its bit operand; OR NOT, the logical OR between the execution condition and the inverse of the status of its bit operand. The ladder symbol for loading TR bits is different from that shown above. Refer to *4-4-3 Ladder Instructions* for details.


Flags

There are no flags affected by these instructions.

5-8-2 AND LOAD and OR LOAD


AND LOAD - AND LD

Ladder Symbol



OR LOAD - OR LD

Ladder Symbol



Description

When instructions are combined into blocks that cannot be logically combined using only OR and AND operations, AND LD and OR LD are used. Whereas AND and OR operations logically combine a bit status and an execution condition, AND LD and OR LD logically combine two execution conditions, the current one and the last unused one.

In order to draw ladder diagrams, it is not necessary to use AND LD and OR LD instructions, nor are they necessary when inputting ladder diagrams directly, as is possible from SSS. They are required, however, to convert the program to and input it in mnemonic form. The procedures for these, limitations for different procedures, and examples are provided in *4-7 Inputting, Modifying, and Checking the Program*.

In order to reduce the number of programming instructions required, a basic understanding of logic block instructions is required. For an introduction to logic blocks, refer to *4-4-6 Logic Block Instructions*.

Flags

There are no flags affected by these instructions.

5-9 Bit Control Instructions

There are five instructions that can be used generally to control individual bit status. These are OUT, OUT NOT, DIFU(13), DIFD(14), and KEEP(11). These instructions are used to turn bits ON and OFF in different ways.

5-9-1 OUTPUT and OUTPUT NOT - OUT and OUT NOT

OUTPUT – OUT

Ladder Symbol

B: Bit

IR, SR, AR, HR, TC, LR, TR

OUTPUT NOT – OUT NOT

Ladder Symbol

Operand Data Areas

B: Bit

IR, SR, AR, HR, TC, LR

Limitations

Any output bit can generally be used in only one instruction that controls its status. Refer to 3-3 *IR Area* for details.

Description

OUT and OUT NOT are used to control the status of the designated bit according to the execution condition.

OUT turns ON the designated bit for an ON execution condition, and turns OFF the designated bit for an OFF execution condition. With a TR bit, OUT appears at a branching point rather than at the end of an instruction line. Refer to *4-7-7 Branching Instruction Lines* for details.

OUT NOT turns ON the designated bit for a OFF execution condition, and turns OFF the designated bit for an ON execution condition.

OUT and OUT NOT can be used to control execution by turning ON and OFF bits that are assigned to conditions on the ladder diagram, thus determining execution conditions for other instructions. This is particularly helpful and allows a complex set of conditions to be used to control the status of a single work bit, and then that work bit can be used to control other instructions.

The length of time that a bit is ON or OFF can be controlled by combining the OUT or OUT NOT with TIM. Refer to Examples under *5-14-1 TIMER – TIM* for details.

Flags

There are no flags affected by these instructions.

5-9-2 DIFFERENTIATE UP and DOWN – DIFU(13) and DIFD(14)

Limitations

Any output bit can generally be used in only one instruction that controls its status. Refer to 3-3 *IR Area* for details.

Description

DIFU(13) and DIFD(14) are used to turn the designated bit ON for one cycle only.

Whenever executed, DIFU(13) compares its current execution with the previous execution condition. If the previous execution condition was OFF and the current one is ON, DIFU(13) will turn ON the designated bit. If the previous execution condition was ON and the current execution condition is either ON or OFF, DIFU(13) will either turn the designated bit OFF or leave it OFF (i.e., if the designated bit is already OFF). The designated bit will thus never be ON for longer than one cycle, assuming it is executed each cycle (see *Precautions*, below).

Whenever executed, DIFD(14) compares its current execution with the previous execution condition. If the previous execution condition was ON and the current one is OFF, DIFD(14) will turn ON the designated bit. If the previous execution condition was OFF and the current execution condition is either ON or OFF, DIFD(14) will either turn the designated bit OFF or leave it OFF. The designated bit will thus never be ON for longer than one cycle, assuming it is executed each cycle (see *Precautions*, below).

These instructions are used when differentiated instructions (i.e., those prefixed with an @) are not available and single-cycle execution of a particular instruction is desired. They can also be used with non-differentiated forms of instructions that have differentiated forms when their use will simplify programming. Examples of these are shown below.

Flags


There are no flags affected by these instructions.

Precautions

DIFU(13) and DIFD(14) operation can be uncertain when the instructions are programmed between IL and ILC, between JMP and JME, or in subroutines. Refer to 5-10 INTERLOCK and INTERLOCK CLEAR – IL(02) and ILC(03), 5-11 JUMP and JUMP END – JMP(04) and JME(05), and 5-23 Subroutines and Interrupt Control for details.

Example 1: When There is No Differentiated Instruction

In diagram A, below, whenever CMP(20) is executed with an ON execution condition it will compare the contents of the two operand words (HR 10 and DM 0000) and set the arithmetic flags (GR, EQ, and LE) accordingly. If the execution condition remains ON, flag status may be changed each cycle if the content of one or both operands change. Diagram B, however, is an example of how DIFU(13) can be used to ensure that CMP(20) is executed only once each time the desired execution condition goes ON.




Address	Instruction	Oper	ands
00000	LD		00000
00001	CMP(20)		
		HR	10
		DM	0000

Address	Instruction	Operands
00000	LD	00000
00001	DIFU(13)	22500
00002	LD	22500
00003	CMP(20)	
		HR 10
		DM 0000

Example 2: Simplifying Programming

Although a differentiated form of MOV(21) is available, the following diagram would be very complicated to draw using it because only one of the conditions determining the execution condition for MOV(21) requires differentiated treatment.




Address	Instruction	Oper	ands
00000	LD		00000
00001	DIFU(13)		22500
00002	LD		22500
00003	LD		00001
00004	AND NOT		00002
00005	AND NOT		00003
00006	OR LD		
00007	LD		00004
00008	AND NOT		00005
00009	OR LD		
00010	MOV(21)		
		HR	10
		DM	0000

5-9-3 SET and RESET – SET and RSET

Ladder Symbols

Operand Data Areas



B : Bit	
IR, SR, AR, HR, LR	



B : Bit	
IR, SR, AR, HR, LR	

Description

SET turns the operand bit ON when the execution condition is ON, and does not affect the status of the operand bit when the execution condition is OFF. RSET turns the operand bit OFF when the execution condition is ON, and does not affect the status of the operand bit when the execution condition is OFF.

The operation of SET differs from that of OUT because the OUT instruction turns the operand bit OFF when its execution condition is OFF. Likewise, RSET differs from OUT NOT because OUT NOT turns the operand bit ON when its execution condition is OFF.

Note The instructions SET and RESET are input as follows:



Precautions

The status of operand bits for SET and RSET programmed between IL(02) and ILC(03) or JMP(04) and JME(05) will not change when the interlock or jump condition is met (i.e., when IL(02) or JMP(04) is executed with an OFF execution condition).


Flags

There are no flags affected by these instructions.


Examples

The following examples demonstrate the difference between OUT and SET/RSET. In the first example (Diagram A), IR 10000 will be turned ON or OFF whenever IR 00000 goes ON or OFF.

In the second example (Diagram B), IR 10000 will be turned ON when IR 00001 goes ON and will remain ON (even if IR 00001 goes OFF) until IR 00002 goes ON.



Address	Instruction	Operands
00000	LD	00000
00001	OUT	10000



Address	Instruction	Operands
00000	LD	00001
00001	SET	10000
00002	LD	00002
00003	RSET	10000

5-9-4 KEEP - KEEP(11)

Ladder Symbol S KEEP(11) B

Operand Data Areas

B: Bit IR, AR, HR, LR


Limitations

Any output bit can generally be used in only one instruction that controls its status. Refer to 3-3 IR Area for details.


Description

KEEP(11) is used to maintain the status of the designated bit based on two execution conditions. These execution conditions are labeled S and R. S is the set input; R, the reset input. KEEP(11) operates like a latching relay that is set by S and reset by R.

When S turns ON, the designated bit will go ON and stay ON until reset, regardless of whether S stays ON or goes OFF. When R turns ON, the designated bit will go OFF and stay OFF until reset, regardless of whether R stays ON or goes OFF. The relationship between execution conditions and KEEP(11) bit status is shown below.



KEEP(11) operates like the self-maintaining bit described in *4-8-3 Self-maintaining Bits*. The following two diagrams would function identically, though the one using KEEP(11) requires one less instruction to program and would maintain status even in an interlocked program section.



Address	Instruction	Operands
00000	LD	00002
00001	OR	00500
00002	AND NOT	00003
00003	OUT	00500

Address	Instruction	Operands
00000	LD	00002
00001	LD	00003
00002	KEEP(11)	00500


Flags

There are no flags affected by this instruction.

Precautions

Exercise caution when using a KEEP reset line that is controlled by an external normally closed device. Never use an input bit in an inverse condition on the reset (R) for KEEP(11) when the input device uses an AC power supply. The delay in shutting down the PC's DC power supply (relative to the AC power supply to


the input device) can cause the designated bit of KEEP(11) to be reset. This situation is shown below.



Bits used in KEEP are not reset in interlocks. Refer to the *5-10 INTERLOCK – and INTERLOCK CLEAR IL(02) and ILC(03)* for details.

Example


If a HR bit or an AR bit is used, bit status will be retained even during a power interruption. KEEP(11) can thus be used to program bits that will maintain status after restarting the PC following a power interruption. An example of this that can be used to produce a warning display following a system shutdown for an emergency situation is shown below. Bits 00002, 00003, and 00004 would be turned ON to indicate some type of error. Bit 00005 would be turned ON to reset the warning display. HR 0000, which is turned ON when any one of the three bits indicates an emergency situation, is used to turn ON the warning indicator through 00500.



Address	Instruction	Operands
00000	LD	00002
00001	OR	00003
00002	OR	00004
00003	LD	00005
00004	KEEP(11)	HR 0000
00005	LD	HR 0000
00006	OUT	00500

KEEP(11) can also be combined with TIM to produce delays in turning bits ON and OFF. Refer to *5-14-1 TIMER – TIM* for details.

5-10 INTERLOCK and INTERLOCK CLEAR – IL(02) and ILC(03)



Description

IL(02) is always used in conjunction with ILC(03) to create interlocks. Interlocks are used to enable branching in the same way as can be achieved with TR bits, but treatment of instructions between IL(02) and ILC(03) differs from that with TR bits when the execution condition for IL(02) is OFF. If the execution condition of IL(02) is ON, the program will be executed as written, with an ON execution condition used to start each instruction line from the point where IL(02) is located through the next ILC(03). Refer to *4-7-7 Branching Instruction Lines* for basic descriptions of both methods.


If the execution condition for IL(02) is OFF, the interlocked section between IL(02) and ILC(03) will be treated as shown in the following table:

Instruction	Treatment
OUT and OUT NOT	Designated bit turned OFF.
SET and RSET	Bit status maintained.
TIM and TIMH(15)	Reset.
TTIM(87)	PV maintained.
CNT, CNTR(12)	PV maintained.
KEEP(11)	Bit status maintained.
DIFU(13) and DIFD(14)	Not executed (see the following DIFU(13) and DIFD(14) in Interlocks).
All others	Not executed.

IL(02) and ILC(03) do not necessarily have to be used in pairs. IL(02) can be used several times in a row, with each IL(02) creating an interlocked section through the next ILC(03). ILC(03) cannot be used unless there is at least one IL(02) between it and any previous ILC(03).

DIFU(13) and DIFD(14) in Interlocks

Changes in the execution condition for a DIFU(13) or DIFD(14) are not recorded if the DIFU(13) or DIFD(14) is in an interlocked section and the execution condition for the IL(02) is OFF. When DIFU(13) or DIFD(14) is execution in an interlocked section immediately after the execution condition for the IL(02) has gone ON, the execution condition for the DIFU(13) or DIFD(14) will be compared to the execution condition that existed before the interlock became effective (i.e., before the interlock condition for IL(02) went OFF). The ladder diagram and bit status changes for this are shown below. The interlock is in effect while 00000 is OFF. Notice that 01000 is not turned ON at the point labeled A even though 00001 has turned OFF and then back ON.



Address	Instruction	Operands
00000	LD	00000
00001	IL(02)	
00002	LD	00001
00003	DIFU(13)	01000
00004	II C(03)	

Precautions

There must be an ILC(03) following any one or more IL(02).

Although as many IL(02) instructions as are necessary can be used with one ILC(03), ILC(03) instructions cannot be used consecutively without at least one IL(02) in between, i.e., nesting is not possible. Whenever a ILC(03) is executed, all interlocks between the active ILC(03) and the preceding ILC(03) are cleared.


When more than one IL(02) is used with a single ILC(03), an error message will appear when the program check is performed, but execution will proceed normally.

Flags

There are no flags affected by these instructions.

Example


The following diagram shows IL(02) being used twice with one ILC(03).



Address	Instruction	Operands
00000	LD	00000
00001	IL(02)	
00002	LD	00001
00003	TIM	511
		# 0015
00004	LD	00002
00005	IL(02)	
00006	LD	00003
00007	AND NOT	00004
80000	LD	00100
00009	CNT	001
		010
00010	LD	00005
00011	OUT	00502
00012	ILC(03)	

When the execution condition for the first IL(02) is OFF, TIM 511 will be reset to 1.5 s, CNT 001 will not be changed, and 00502 will be turned OFF. When the execution condition for the first IL(02) is ON and the execution condition for the second IL(02) is OFF, TIM 511 will be executed according to the status of 00001, CNT 001 will not be changed, and 00502 will be turned OFF. When the execution conditions for both the IL(02) are ON, the program will execute as written.

5-11 JUMP and JUMP END – JMP(04) and JME(05)



Limitations

Jump numbers 01 through 99 may be used only once in JMP(04) and once in JME(05), i.e., each can be used to define one jump only. Jump number 00 can be used as many times as desired.

Description

JMP(04) is always used in conjunction with JME(05) to create jumps, i.e., to skip from one point in a ladder diagram to another point. JMP(04) defines the point from which the jump will be made; JME(05) defines the destination of the jump. When the execution condition for JMP(04) in ON, no jump is made and the program is executed consecutively as written. When the execution condition for JMP(04) is OFF, a jump is made to the JME(05) with the same jump number and the instruction following JME(05) is executed next.

If the jump number for JMP(04) is between 01 and 99, jumps, when made, will go immediately to JME(05) with the same jump number without executing any instructions in between. The status of timers, counters, bits used in OUT, bits used in OUT NOT, and all other status bits controlled by the instructions between JMP(04) and JMP(05) will not be changed. Each of these jump numbers can be used to define only one jump. Because all of instructions between JMP(04) and JME(05) are skipped, jump numbers 01 through 99 can be used to reduce cycle time.

If the jump number for JMP(04) is 00, the CPU Unit will look for the next JME(05) with a jump number of 00. To do so, it must search through the program, causing a longer cycle time (when the execution condition is OFF) than for other jumps. The status of timers, counters, bits used in OUT, bits used in OUT NOT, and all other status controlled by the instructions between JMP(04) 00 and JMP(05) 00 will not be changed. jump number 00 can be used as many times as desired. A jump from JMP(04) 00 will always go to the next JME(05) 00 in the program. It is thus possible to use JMP(04) 00 consecutively and match them all with the same JME(05) 00. It makes no sense, however, to use JME(05) 00 consecutively, because all jumps made to them will end at the first JME(05) 00.

DIFU(13) and DIFD(14) in Jumps

Although DIFU(13) and DIFD(14) are designed to turn ON the designated bit for one cycle, they will not necessarily do so when written between JMP(04) and JME (05). Once either DIFU(13) or DIFD(14) has turned ON a bit, it will remain ON until the next time DIFU(13) or DIFD(14) is executed again. In normal programming, this means the next cycle. In a jump, this means the next time the jump from JMP(04) to JME(05) is not made, i.e., if a bit is turned ON by DIFU(13) or DIFD(14) and then a jump is made in the next cycle so that DIFU(13) or DIFD(14) are skipped, the designated bit will remain ON until the next time the execution condition for the JMP(04) controlling the jump is ON.

Precautions

When JMP(04) and JME(05) are not used in pairs, an error message will appear when the program check is performed. Although this message also appears if JMP(04) 00 and JME(05) 00 are not used in pairs, the program will execute properly as written.

Flags

There are no flags affected by these instructions.

Examples

Examples of jump programs are provided in 4-7-8 Jumps.

5-12 END - END(01)

Ladder Symbol —— END(01)

Description

END(01) is required as the last instruction in any program. If there are subroutines, END(01) is placed after the last subroutine. No instruction written after END(01) will be executed. END(01) can be placed anywhere in the program to execute all instructions up to that point, as is sometimes done to debug a program, but it must be removed to execute the remainder of the program.

If there is no END(01) in the program, no instructions will be executed and the error message "NO END INST" will appear.

Flags

END(01) turns OFF the ER, CY, GR, EQ, and LE Flags.

5-13 NO OPERATION – NOP(00)

Description

NOP(00) is not generally required in programming and there is no ladder symbol for it. When NOP(00) is found in a program, nothing is executed and the program execution moves to the next instruction. When memory is cleared prior to programming, NOP(00) is written at all addresses. NOP(00) can be input through the 00 function code.

Flags

There are no flags affected by NOP(00).

5-14 Timer and Counter Instructions

TIM and TIMH are decrementing ON-delay timer instructions which require a TC number and a set value (SV).

CNT is a decrementing counter instruction and CNTR is a reversible counter instruction. Both require a TC number and a SV. Both are also connected to multiple instruction lines which serve as an input signal(s) and are reset.

Any one TC number cannot be defined twice, i.e., once it has been used as the definer in any of the timer or counter instructions, it cannot be used again. Once defined, TC numbers can be used as many times as required as operands in instructions other than timer and counter instructions.

TC numbers run from 000 through 511. No prefix is required when using a TC number as a definer in a timer or counter instruction. Once defined as a timer, a TC number can be prefixed with TIM for use as an operand in certain instructions. The TIM prefix is used regardless of the timer instruction that was used to define the timer. Once defined as a counter, a TC number can be prefixed with CNT for use as an operand in certain instructions. The CNT is also used regardless of the counter instruction that was used to define the counter.

TC numbers can be designated as operands that require either bit or word data. When designated as an operand that requires bit data, the TC number accesses a bit that functions as a 'Completion Flag' that indicates when the time/count has expired, i.e., the bit, which is normally OFF, will turn ON when the designated SV has expired. When designated as an operand that requires word data, the TC number accesses a memory location that holds the present value (PV) of the timer or counter. The PV of a timer or counter can thus be used as an operand in CMP(20), or any other instruction for which the TC area is allowed. This is done by designating the TC number used to define that timer or counter to access the memory location that holds the PV.

Note that "TIM 000" is used to designate the TIMER instruction defined with TC number 000, to designate the Completion Flag for this timer, and to designate the PV of this timer. The meaning of the term in context should be clear, i.e., the first is always an instruction, the second is always a bit operand, and the third is always a word operand. The same is true of all other TC numbers prefixed with TIM or CNT.

An SV can be input as a constant or as a word address in a data area. If an IR area word assigned to an Input Unit is designated as the word address, the Input Unit can be wired so that the SV can be set externally through thumbwheel switches or similar devices. Timers and counters wired in this way can only be set externally during RUN or MONITOR mode. All SVs, including those set externally, must be in BCD.

5-14-1 TIMER - TIM

Ladder Symbol N: TC number # (000 through 511) Operand Data Areas SV: Set value (word, BCD) IR, AR, DM, HR, LR,

Limitations

SV is between 000.0 and 999.9. The decimal point is not entered.

Each TC number can be used as the definer in only one TIMER or COUNTER instruction.


TC 000 through TC 015 should not be used in TIM if they are required for TIMH(15). Refer to 5-14-2 HIGH-SPEED TIMER – TIMH(15) for details.

Description

A timer is activated when its execution condition goes ON and is reset (to SV) when the execution condition goes OFF. Once activated, TIM measures in units of 0.1 second from the SV.

If the execution condition remains ON long enough for TIM to time down to zero, the Completion Flag for the TC number used will turn ON and will remain ON until TIM is reset (i.e., until its execution condition is goes OFF).

The following figure illustrates the relationship between the execution condition for TIM and the Completion Flag assigned to it.



Precautions

Interlocks and Power Interruptions

Timers in interlocked program sections are reset when the execution condition for IL(02) is OFF. Power interruptions also reset timers. If a timer that is not reset under these conditions is desired, SR area clock pulse bits can be counted to produce timers using CNT. Refer to 5-14-4 COUNTER – CNT for details.

Program execution will continue even if a non-BCD SV is used, but timing will not be accurate.

<u>Jumps</u>

Never program TIM between JMP(04) 00 and JME(05) 00 with an SV of #0000. The Completion Flag will turn ON even when the execution condition for JMP(04) 00 is ON (i.e., even when the program section with TIM is jumped). TIM can be programmed successfully between JMP(04) and JME(05) as long as a jump number between 01 and 99 is used.

Step Instructions

Never program TIM between STEP(08) and SNXT(09) with an SV of #0000. The Completion Flag will turn ON even when the step containing TIM is reset.

The SV of the timers can be set in the range #0000 to #9999 (BCD). If the SV for a timer is set to #0000 or #0001, it will operate in the following way. If the SV is set to #0000, when the timer input goes from OFF to ON, the Completion Flag will turn ON. If the SV is set to #0001, because the timer accuracy is 0 to -0.1 s, the actual time will be a value between 0 and 0.1 s, and the Completion Flag may turn ON as soon as the timer input goes from OFF to ON. With other values also, allow for a timer accuracy of 0 to -0.1 s when setting the SV.

Flags

ER: SV is not in BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)


Examples

All of the following examples use OUT in diagrams that would generally be used to control output bits in the IR area. There is no reason, however, why these diagrams cannot be modified to control execution of other instructions.

Example 1: Basic Application

The following example shows two timers, one set with a constant and one set via input word 005. Here, 00200 will be turned ON after 00000 goes ON and stays ON for at least 15 seconds. When 00000 goes OFF, the timer will be reset and 00200 will be turned OFF. When 00001 goes ON, TIM 001 is started from the SV provided through IR word 005. Bit 00201 is also turned ON when 00001 goes


ON. When the SV in 005 has expired, 00201 is turned OFF. This bit will also be turned OFF when TIM 001 is reset, regardless of whether or not SV has expired.



Address	Instruction	Ope	rands
00000	LD		00000
00001	TIM		000
		#	0150
00002	LD	TIM	000
00003	OUT		00200
00004	LD		00001
00005	TIM		001
			005
00006	AND NOT	TIM	001
00007	OUT		00200

Example 2: Extended Timers

There are two ways to achieve timers that operate for longer than 999.9 seconds. One method is to program consecutive timers, with the Completion Flag of each timer used to activate the next timer. A simple example with two 900.0-second (15-minute) timers combined to functionally form a 30-minute timer.



Address	Instruction	Opera	ands
00000	LD		00000
00001	TIM		001
		#	9000
00002	LD	TIM	001
00003	TIM		002
		#	9000
00004	LD	TIM	002
00005	OUT		00200

In this example, 00200 will be turned ON 30 minutes after 00000 goes ON.

TIM can also be combined with CNT or CNT can be used to count SR area clock pulse bits to produce longer timers. An example is provided in *5-14-4 COUNTER – CNT*.


Example 3: ON/OFF Delays

TIM can be combined with KEEP(11) to delay turning a bit ON and OFF in reference to a desired execution condition. KEEP(11) is described in 5-9-4 KEEP – KEEP(11).


To create delays, the Completion Flags for two TIM are used to determine the execution conditions for setting and reset the bit designated for KEEP(11). The bit whose manipulation is to be delayed is used in KEEP(11). Turning ON and OFF the bit designated for KEEP(11) is thus delayed by the SV for the two TIM. The two SV could naturally be the same if desired.

In the following example, 00500 would be turned ON 5.0 seconds after 00000 goes ON and then turned OFF 3.0 seconds after 00000 goes OFF. It is necessary to use both 00500 and 00000 to determine the execution condition for TIM

002; 00000 in an inverse condition is necessary to reset TIM 002 when 00000 goes ON and 00500 is necessary to activate TIM 002 (when 00000 is OFF).




Address	Instruction	Opera	nds
00000	LD		00000
00001	TIM		001
		#	0050
00002	LD		00500
00003	AND NOT		00000
00004	TIM		002
		#	0030
00005	LD	TIM	001
00006	LD	TIM	002
00007	KEEP(11)	00500	



Example 4: One-Shot Bits

The length of time that a bit is kept ON or OFF can be controlled by combining TIM with OUT or OUT NO. The following diagram demonstrates how this is possible. In this example, 00204 would remain ON for 1.5 seconds after 00000 goes ON regardless of the time 00000 stays ON. This is achieved by using 01000 as a self-maintaining bit activated by 00000 and turning ON 00204 through it. When TIM 001 comes ON (i.e., when the SV of TIM 001 has expired), 00204 will be turned OFF through TIM 001 (i.e., TIM 001 will turn ON which, as an inverse condition, creates an OFF execution condition for OUT 00204).




1.5 s

1.5 s

Address	Instruction	Operands	
00000	LD		01000
00001	AND NOT	TIM	001
00002	OR		00000
00003	OUT		01000
00004	LD		01000
00005	TIM		001
		#	0015
00006	LD		01000
00007	AND NOT	TIM	001
80000	OUT	·	00204


The following one-shot timer may be used to save memory.



Address	Instruction	Operands
00000	LD	00000
00001	OR	00100
00002	TIM	001
		# 0015
00003	AND NOT	TIM 001
00004	OUT	00100

Example 5: Flicker Bits


Bits can be programmed to turn ON and OFF at regular intervals while a designated execution condition is ON by using TIM twice. One TIM functions to turn ON and OFF a specified bit, i.e., the Completion Flag of this TIM turns the specified bit ON and OFF. The other TIM functions to control the operation of the first TIM, i.e., when the first TIM's Completion Flag goes ON, the second TIM is started and when the second TIM's Completion Flag goes ON, the first TIM is started.



Address	Instruction	Operands	
00000	LD		00000
00001	AND	TIM	002
00002	TIM		001
		#	0010
00003	LD	TIM	001
00004	TIM		002
		#	0015
00005	LD	TIM	001
00006	OUT		00205

A simpler but less flexible method of creating a flicker bit is to AND one of the SR area clock pulse bits with the execution condition that is to be ON when the flicker bit is operating. Although this method does not use TIM, it is included here for comparison. This method is more limited because the ON and OFF times must be the same and they depend on the clock pulse bits available in the SR area.

In the following example the 1-second clock pulse is used (25502) so that 00206 would be turned ON and OFF every second, i.e., it would be ON for 0.5 seconds and OFF for 0.5 seconds. Precise timing and the initial status of 00206 would depend on the status of the clock pulse when 00000 goes ON.



Address	Instruction	Operands
00000	LD	00000
00001	AND	25502
00002	OUT	00206

5-14-2 HIGH-SPEED TIMER - TIMH(15)

Ladder Symbol TIMH(15) N SV

Definer Values

N: TC number

(000 through 511, although 000 through 015 preferred)

Operand Data Areas

SV: Set value (word, BCD)

IR, AR, DM, HR, LR, #

Limitations

SV is between 00.00 and 99.99. (Although 00.00 and 00.01 may be set, 00.00 will disable the timer, i.e., turn ON the Completion Flag immediately, and 00.01 is not reliably cycled.) The decimal point is not entered.

Each TC number can be used as the definer in only one TIMER or COUNTER instruction.

If the cycle time is greater than 10 ms, use TC 000 through TC 015. The PVs and completion flags of timers 000 through 015 are refreshed every 10 ms, but the PVs of timers 016 through TC 511 are refreshed each time that TIMH(15) is executed in the program.

Description

TIMH(15) operates in the same way as TIM except that TIMH measures in units of 0.01 second.

The cycle time affects TIMH(15) accuracy if TC 016 through TC 511 are used. If the cycle time is greater than 10 ms, use TC 000 through TC 015.

Refer to *5-14-1 TIMER – TIM* for operational details and examples. Except for the above, and all aspects of operation are the same.

Precautions

Timers in interlocked program sections are reset when the execution condition for IL(02) is OFF. Power interruptions also reset timers. If a timer that is not reset under these conditions is desired, SR area clock pulse bits can be counted to produce timers using CNT. Refer to 5-14-4 COUNTER – CNT for details.

Program execution will continue even if a non-BCD SV is used, but timing will not be accurate.

The SV of the timers can be set in the range #0000 to #9999 (BCD). If the SV for a timer is set to #0000 or #0001, it will operate in the following way. If the SV is set to #0000, when the timer input goes from OFF to ON, the Completion Flag will turn ON. There may be a time delay if TC 000 to TC 003 are used. If the SV is set to #0001, because the timer accuracy is 0 to -0.1 s, the actual time will be a value between 0 and 0.1 s, and the Completion Flag may turn ON as soon as the timer input goes from OFF to ON. With other values also, allow for a timer accuracy of 0 to -0.1 s when setting the SV.


Flags

ER: SV is not in BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-14-3 TOTALIZING TIMER – TTIM(87)

Ladder Symbol



Definer Values

N: TC number	
# (000 through 511)	
# (000 tillough 311)	

Operand Data Areas

SV: Set value (word, BCD)
IR, AR, DM, HR, LR
RB: Reset bit
IR, SR, AR, HR, LR

Limitations

SV is between 0000 and 9999 (000.0 and 999.9 s) and must be in BCD. The decimal point is not entered.

Each TC number can be used as the definer in only one TIMER or COUNTER instruction.

Description

TTIM(87) is used to create a timer that increments the PV every 0.1 s to time between 0.1 and 999.9 s. TTIM(87) increments in units of 0.1 second from zero. TTIM(87) accuracy is +0.0/–0.1 second. A TTIM(87) timer will time as long as its execute condition is ON until it reaches the SV or until RB turns ON to reset the timer. TTIM(87) timers will time only as long as they are executed every cycle, i.e., they do not time, but maintain the current PV, in interlocked program sections or when they are jumped in the program.

Precautions

The PVs of totalizing timers in interlocked program sections are maintained when the execution condition for IL(02) is OFF. Unlike timers and high-speed timers, totalizing timers in jumped program sections do not continue timing, but maintain the PV.

Power interruptions will reset timers.

Totalizing timers will not restart after timing out unless the PV is changed to a value below the SV or the reset input is turned ON.

A delay of one cycle is sometimes required for a Completion Flag to be turned ON after the timer times out.

The SV of the timers can be set in the range #0000 to #9999 (BCD). If the SV for a timer is set to #0000 or #0001, it will operate in the following way. If the SV is set to #0000, when the timer input goes from OFF to ON, the Completion Flag will turn ON. If the SV is set to #0001, because the timer accuracy is 0 to -0.1 s, the actual time will be a value between 0 and 0.1 s, and the Completion Flag may turn ON as soon as the timer input goes from OFF to ON. With other values also, allow for a timer accuracy of 0 to -0.1 s when setting the SV.

Flags


ER (SR 25503): Content of *DM word is not BCD when set for BCD. SV is not BCD.

Example

The following figure illustrates the relationship between the execution conditions for a totalizing timer with a set value of 2 s, its PV, and the Completion Flag.




Address	Instruction	Operands	
00000	LD		00000
00001	TTIM(87)		
		TIM	000
		#	0020
		LR	2100



5-14-4 COUNTER - CNT





Definer Values

N: TC number	
# (000 through 511)	

Operand Data Areas

SV: Set value (word, BCD)	
or. con raido (mora, bob)	
ID AD DM UD ID #	_
IR, AR, DM, HR, LR, #	

Limitations


Each TC number can be used as the definer in only one TIMER or COUNTER instruction.

Description

CNT is used to count down from SV when the execution condition on the count pulse, CP, goes from OFF to ON, i.e., the present value (PV) will be decremented by one whenever CNT is executed with an ON execution condition for CP and the execution condition was OFF for the last execution. If the execution condition has not changed or has changed from ON to OFF, the PV of CNT will not be changed. The Completion Flag for a counter is turned ON when the PV reaches zero and will remain ON until the counter is reset.

CNT is reset with a reset input, R. When R goes from OFF to ON, the PV is reset to SV. The PV will not be decremented while R is ON. Counting down from SV will begin again when R goes OFF. The PV for CNT will not be reset in interlocked program sections or by power interruptions.

Changes in execution conditions, the Completion Flag, and the PV are illustrated below. PV line height is meant only to indicate changes in the PV.



Precautions

Program execution will continue even if a non-BCD SV is used, but the SV will not be correct.

Jumps

Never program CNT between JMP(04) 00 and JME(05) 00 with an SV of #0000. The Completion Flag will turn ON even when the execution condition for JMP(04) 00 is ON (i.e., even when the program section with CNT is jumped). CNT can be programmed successfully between JMP(04) and JME(05) as long as a jump number between 01 and 99 is used.

Step Instructions

Never program CNT between STEP(08) and SNXT(09) with an SV of #0000. The Completion Flag will turn ON even when the step containing CNT is reset.


Flags

ER: SV is not in BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example 1: Basic Application


In the following example, the PV will be decremented whenever both 00000 and 00001 are ON provided that 00002 is OFF and either 00000 or 00001 was OFF the last time CNT 004 was executed. When 150 pulses have been counted down (i.e., when PV reaches zero), 00205 will be turned ON.



Address	Instruction	Operands
00000	LD	00000
00001	AND	00001
00002	LD	00002
00003	CNT	0004
		# 0150
00004	LD	CNT 004
00005	OUT	00205

Here, 00000 can be used to control when CNT is operative and 00001 can be used as the bit whose OFF to ON changes are being counted.

The previously-shown CNT can be modified to restart from SV each time power is turned ON to the PC. This is done by using the First Cycle Flag in the SR area (25315) to reset CNT as shown below.




Address	Instruction	Operands	
00000	LD	00000	
00001	AND	00001	
00002	LD	00002	
00003	OR	25315	
00004	CNT	004	
		# 0150	
00005	LD	CNT 004	
00006	OUT	00205	

Example 2: Extended Counter

Counters that can count past 9,999 can be programmed by using one CNT to count the number of times another CNT has counted to zero from SV.

In the following example, 00000 is used to control when CNT 001 operates. CNT 001, when 00000 is ON, counts down the number of OFF to ON changes in 00001. CNT 001 is reset by its Completion Flag, i.e., it starts counting again as soon as its PV reaches zero. CNT 002 counts the number of times the Completion Flag for CNT 001 goes ON. Bit 00002 serves as a reset for the entire extended counter, resetting both CNT 001 and CNT 002 when it is OFF. The Completion Flag for CNT 002 is also used to reset CNT 001 to inhibit CNT 001 operation, once SV for CNT 002 has been reached, until the entire extended counter is reset via 00002.

Because in this example the SV for CNT 001 is 100 and the SV for CNT 002 is 200, the Completion Flag for CNT 002 turns ON when 100 x 200 or 20,000 OFF to ON changes have been counted in 00001. This would result in 00203 being turned ON.



Address	Instruction	Operands	
00000	LD		00000
00001	AND		00001
00002	LD NOT		00002
00003	OR	CNT	001
00004	OR	CNT	002
00005	CNT		001
		#	0100
00006	LD	CNT	001
00007	LD NOT		00002
80000	CNT		002
		#	0200
00009	LD	CNT	002
00010	OUT		00203

CNT can be used in sequence as many times as required to produce counters capable of counting any desired values.


Example 3: Extended Timers

CNT can be used to create extended timers in two ways: by combining TIM with CNT and by counting SR area clock pulse bits.

In the following example, CNT 002 counts the number of times TIM 001 reaches zero from its SV. The Completion Flag for TIM 001 is used to reset TIM 001 so that it runs continuously and CNT 002 counts the number of times the Completion Flag for TIM 001 goes ON (CNT 002 would be executed once each time be-

tween when the Completion Flag for TIM 001 goes ON and TIM 001 is reset by its Completion Flag). TIM 001 is also reset by the Completion Flag for CNT 002 so that the extended timer would not start again until CNT 002 was reset by 00001, which serves as the reset for the entire extended timer.


Because in this example the SV for TIM 001 is 5.0 seconds and the SV for CNT 002 is 100, the Completion Flag for CNT 002 turns ON when 5 seconds x 100 times, i.e., 500 seconds (or 8 minutes and 20 seconds) have expired. This would result in 00201 being turned ON.



Address	Instruction	Operands	
00000	LD	0000	0
00001	AND NOT	TIM 00	1
00002	AND NOT	CNT 00:	2
00003	TIM	00	1
		# 005	0
00004	LD	TIM 00	1
00005	LD	0000	1
00006	CNT	000	2
		# 010	0
00007	LD	CNT 00	2
80000	OUT	0020	1

In the following example, CNT 001 counts the number of times the 1-second clock pulse bit (25502) goes from OFF to ON. Here again, 00000 is used to control the times when CNT is operating.

Because in this example the SV for CNT 001 is 700, the Completion Flag for CNT 002 turns ON when 1 second x 700 times, or 11 minutes and 40 seconds have expired. This would result in 00202 being turned ON.




Address	Instruction	Operands	
00000	LD	00000	
00001	AND	25502	
00002	LD NOT	00001	
00003	CNT	001	
		# 0700	
00004	LD	CNT 001	
00005	OUT	00202	

Note The shorter clock pulses will not necessarily produce accurate timers because their short ON times might not be read accurately during longer cycles. In particular, the 0.02-second and 0.1-second clock pulses should not be used to create timers with CNT instructions.

5-14-5 REVERSIBLE COUNTER - CNTR(12)

Ladder Symbol



Definer Values

N: TC number	
# (000 through 511)	

Operand Data Areas

SV: Set value (word, BCD)	
IR, AR, DM, HR, LR, #	

Limitations

Description

Each TC number can be used as the definer in only one TIMER or COUNTER instruction.

The CNTR(12) is a reversible, up/down circular counter, i.e., it is used to count between zero and SV according to changes in two execution conditions, those in the increment input (II) and those in the decrement input (DI).


The present value (PV) will be incremented by one whenever CNTR(12) is executed with an ON execution condition for II and the last execution condition for II was OFF. The present value (PV) will be decremented by one whenever CNTR(12) is executed with an ON execution condition for DI and the last execution condition for DI was OFF. If OFF to ON changes have occurred in both II and DI since the last execution, the PV will not be changed.

If the execution conditions have not changed or have changed from ON to OFF for both II and DI, the PV of CNT will not be changed.

When decremented from 0000, the present value is set to SV and the Completion Flag is turned ON until the PV is decremented again. When incremented past the SV, the PV is set to 0000 and the Completion Flag is turned ON until the PV is incremented again.

CNTR(12) is reset with a reset input, R. When R goes from OFF to ON, the PV is reset to zero. The PV will not be incremented or decremented while R is ON. Counting will begin again when R goes OFF. The PV for CNTR(12) will not be reset in interlocked program sections or by the effects of power interruptions.

Changes in II and DI execution conditions, the Completion Flag, and the PV are illustrated below starting from part way through CNTR(12) operation (i.e., when reset, counting begins from zero). PV line height is meant to indicate changes in the PV only.



Precautions

Program execution will continue even if a non-BCD SV is used, but the SV will not be correct.

Flags

ER: SV is not in BCD.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-15 Data Shifting

All of the instructions described in this section are used to shift data, but in differing amounts and directions. The first shift instruction, SFT(10), shifts an execution condition into a shift register; the rest of the instructions shift data that is already in memory.

5-15-1 SHIFT REGISTER - SFT(10)

Ladder Symbol



Operand Data Areas

St: Starting word
IR, SR, AR, HR, LR
E: End word
IR, SR, AR, HR, LR


Limitations

St must be less than or equal to E, and St and E must be in the same data area.

If a bit address in one of the words used in a shift register is also used in an instruction that controls individual bit status (e.g., OUT, KEEP(11)), an error ("COIL DUPL") will be generated when program syntax is checked on the Programming Console or another Programming Device. The program, however, will be executed as written. See *Example 2: Controlling Bits in Shift Registers* for a programming example that does this.

Description

SFT(10) is controlled by three execution conditions, I, P, and R. If SFT(10) is executed and 1) execution condition P is ON and was OFF the last execution, and 2) R is OFF, then execution condition I is shifted into the rightmost bit of a shift register defined between St and E, i.e., if I is ON, a 1 is shifted into the register; if I is OFF, a 0 is shifted in. When I is shifted into the register, all bits previously in the register are shifted to the left and the leftmost bit of the register is lost.



The execution condition on P functions like a differentiated instruction, i.e., I will be shifted into the register only when P is ON and was OFF the last time SFT(10) was executed. If execution condition P has not changed or has gone from ON to OFF, the shift register will remain unaffected.

St designates the rightmost word of the shift register; E designates the leftmost. The shift register includes both of these words and all words between them. The same word may be designated for St and E to create a 16-bit (i.e., 1-word) shift register.


When execution condition R goes ON, all bits in the shift register will be turned OFF (i.e., set to 0) and the shift register will not operate until R goes OFF again.

Flags

There are no flags affected by SFT(10).

Example 1: Basic Application


The following example uses the 1-second clock pulse bit (25502) so that the execution condition produced by 00005 is shifted into a 3-word register between IR 010 and IR 012 every second.



Address	Instruction	Operands
00000	LD	00005
00001	LD	25502
00002	LD	00006
00003	SFT(10)	
		010
		012

Example 2: Controlling Bits in Shift Registers

The following program is used to control the status of the 17th bit of a shift register running from AR 00 through AR 01. When the 17th bit is to be set, 00004 is turned ON. This causes the jump for JMP(04) 00 not to be made for that one cycle, and AR 0100 (the 17th bit) will be turned ON. When 12800 is OFF (i.e., at all times except during the first cycle after 00004 has changed from OFF to ON), the jump is executed and the status of AR 0100 will not be changed.




Address	Instruction	Operands
00000	LD	00200
00001	AND	00201
00002	LD	00202
00003	LD	00203
00004	SFT(10)	
		AR 00
		AR 01
00005	LD	00004
00006	DIFU(13)	12800
00007	LD	12800
80000	JMP(04)	00
00009	LD	12800
00010	OUT	AR 0100
00011	JME(05)	00


When a bit that is part of a shift register is used in OUT (or any other instruction that controls bit status), a syntax error will be generated during the program check, but the program will executed properly (i.e., as written).

Example 3: Control Action

The following program controls the conveyor line shown below so that faulty products detected at the sensor are pushed down a shoot. To do this, the execution condition determined by inputs from the first sensor (00001) are stored in a shift register: ON for good products; OFF for faulty ones. Conveyor speed has been adjusted so that HR 0003 of the shift register can be used to activate a pusher (00500) when a faulty product reaches it, i.e., when HR 0003 turns ON, 00500 is turned ON to activate the pusher.

The program is set up so that a rotary encoder (00000) controls execution of SFT(10) through a DIFU(13), the rotary encoder is set up to turn ON and OFF each time a product passes the first sensor. Another sensor (00002) is used to detect faulty products in the shoot so that the pusher output and HR 0003 of the shift register can be reset as required.






Address	Instruction	Oper	ands
00000	LD		00001
00001	LD		00000
00002	LD		00003
00003	SFT(10)		
		HR	00
		HR	01
00004	LD	HR	0003
00005	OUT		00500
00006	LD		00002
00007	OUT NOT		00500
80000	OUT NOT	HR	0003

5-15-2 REVERSIBLE SHIFT REGISTER – SFTR(84)

Ladder Symbols



Operand Data Areas


C: Control word
IR, AR, DM, HR, LR
St: Starting word
IR, SR, AR, DM, HR, LR
E: End word
IR, SR, AR, DM, HR LR

Limitations

St and E must be in the same data area and St must be less than or equal to E.

Description

SFTR(84) is used to create a single- or multiple-word shift register that can shift data to either the right or the left. To create a single-word register, designate the same word for St and E. The control word provides the shift direction, the status to be put into the register, the shift pulse, and the reset input. The control word is allocated as follows:



The data in the shift register will be shifted one bit in the direction indicated by bit 12, shifting one bit out to CY and the status of bit 13 into the other end whenever SFTR(84) is executed with an ON execution condition as long as the reset bit is OFF and as long as bit 14 is ON. If SFTR(84) is executed with an OFF execution condition or if SFTR(84) is executed with bit 14 OFF, the shift register will remain unchanged. If SFTR(84) is executed with an ON execution condition and the reset bit (bit 15) is OFF, the entire shift register and CY will be set to zero.

Flags


ER: St and E are not in the same data area or ST is greater than E.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: Receives the status of bit 00 of St or bit 15 of E, depending on the shift direction.

Example

In the following example, IR 00005, IR 00006, IR 00007, and IR 00008 are used to control the bits of C used in @SHIFT(84). The shift register is between LR 20 and LR 21, and it is controlled through IR 00009.





Address	Instruction	Operands	
00000	LD		00005
00001	OUT		05012
00002	LD		00006
00003	OUT		05013
00004	LD		00007
00005	OUT		05014
00006	LD		80000
00007	OUT		05015
80000	LD		00009
00009	@SFT(10)		
			050
		LR	20
		LR	21

5-15-3 ARITHMETIC SHIFT LEFT – ASL(25)

Ladder Symbols


Operand Data Areas





Description

When the execution condition is OFF, ASL(25) is not executed. When the execution condition is ON, ASL(25) shifts a 0 into bit 00 of Wd, shifts the bits of Wd one bit to the left, and shifts the status of bit 15 into CY.



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

CY: Receives the status of bit 15.


EQ: ON when the content of Wd is zero; otherwise OFF.


N: ON when a 1 is shifted into bit 15 of Wd.

5-15-4 ARITHMETIC SHIFT RIGHT - ASR(26)

Ladder Symbols


Operand Data Areas





Description

When the execution condition is OFF, ASR(25) is not executed. When the execution condition is ON, ASR(25) shifts a 0 into bit 15 of Wd, shifts the bits of Wd one bit to the right, and shifts the status of bit 00 into CY.



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


CY: Receives the data of bit 00.

EQ: ON when the content of Wd is zero; otherwise OFF.

5-15-5 ROTATE LEFT - ROL(27)

Ladder Symbols


Operand Data Areas



Wd: Rotate word
IR, SR, AR, DM, HR, LR

Description

When the execution condition is OFF, ROL(27) is not executed. When the execution condition is ON, ROL(27) shifts all Wd bits one bit to the left, shifting CY into bit 00 of Wd and shifting bit 15 of Wd into CY.



Precautions

Use STC(41) to set the status of CY or CLC(41) to clear the status of CY before doing a rotate operation to ensure that CY contains the proper status before execution ROL(27).

The status of CY is cleared at the end of each cycle (when END(01) is executed).

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: Receives the data of bit 15.


EQ: ON when the content of Wd is zero; otherwise OFF.


N: ON when a 1 is shifted into bit 15 of Wd.

5-15-6 ROTATE RIGHT – ROR(28)

Ladder Symbols


Operand Data Areas





Description

When the execution condition is OFF, ROR(28) is not executed. When the execution condition is ON, ROR(28) shifts all Wd bits one bit to the right, shifting CY into bit 15 of Wd and shifting bit 00 of Wd into CY.



Precautions

Use STC(41) to set the status of CY or CLC(41) to clear the status of CY before doing a rotate operation to ensure that CY contains the proper status before execution ROR(28).

The status of CY is cleared at the end of each cycle (when END(01) is executed).

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ROR(28) receives the data of bit 00.

EQ: ON when the content of Wd is zero; otherwise OFF.

N: ON when a 1 is shifted into bit 15 of Wd.

5-15-7 ONE DIGIT SHIFT LEFT - SLD(74)

Ladder Symbols

SLD(74) @SLD(74) St St E E

Operand Data Areas


St: Starting word
IR, SR, AR, DM, HR, LR
E: Fnd word
IR, SR, AR, DM, HR, LR

Limitations

St and E must be in the same data area, and St must be less than or equal to E.

Description

When the execution condition is OFF, SLD(74) is not executed. When the execution condition is ON, SLD(74) shifts data between St and E (inclusive) by one digit (four bits) to the left. 0 is written into the rightmost digit of the St, and the content of the leftmost digit of E is lost.



Precautions

If a power failure occurs during a shift operation across more than 50 words, the shift operation might not be completed.


Flags

ER: The St and E words are in different areas, or St is greater than E.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-15-8 ONE DIGIT SHIFT RIGHT - SRD(75)






Operand Data Areas

Limitations

St and E must be in the same data area, and St must be less than or equal to E.

Description

When the execution condition is OFF, SRD(75) is not executed. When the execution condition is ON, SRD(75) shifts data between St and E (inclusive) by one digit (four bits) to the right. 0 is written into the leftmost digit of St and the rightmost digit of E is lost.



Precautions


If a power failure occurs during a shift operation across more than 50 words, the shift operation might not be completed. Set the range between E and St to a maximum of 50 words.

Flags

ER: The St and E words are in different areas, or St is less than E.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-15-9 **WORD SHIFT – WSFT(16)**



Operand Data Areas


St: Starting word	
IR, SR, AR, DM, HR, LR	

E: End word	
IR, SR, AR, DM, HR, LR	

Limitations
Description

St and E must be in the same data area, and St must be less than or equal to E.

When the execution condition is OFF, WSFT(16) is not executed. When the execution condition is ON, WSFT(16) shifts data between St and E in word units. Zeros are written into St and the content of E is lost.





Flags

ER: The St and E words are in different areas, or St is greater than E.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-15-10 ASYNCHRONOUS SHIFT REGISTER - ASFT(17)





Operand Data Areas



Limitations

St and E must be in the same data area, and St must be less than or equal to E.

Description

Control Word

When the execution condition is OFF, ASFT(17) does nothing and the program moves to the next instruction. When the execution condition is ON, ASFT(17) is used to create and control a reversible asynchronous word shift register between St and E. This register only shifts words when the next word in the register is zero, e.g., if no words in the register contain zero, nothing is shifted. Also, only one word is shifted for each word in the register that contains zero. When the contents of a word are shifted to the next word, the original word's contents are set to zero. In essence, when the register is shifted, each zero word in the register trades places with the next word. (See *Example* below.)

The shift direction (i.e. whether the "next word" is the next higher or the next lower word) is designated in C. C is also used to reset the register. All of any portion of the register can be reset by designating the desired portion with St and E.

Bits 00 through 12 of C are not used. Bit 13 is the shift direction: turn bit 13 ON to shift down (toward lower addressed words) and OFF to shift up (toward higher addressed words). Bit 14 is the Shift Enable Bit: turn bit 14 ON to enable shift register operation according to bit 13 and OFF to disable the register. Bit 15 is the Reset bit: the register will be reset (set to zero) between St and E when ASFT(17) is executed with bit 15 ON. Turn bit 15 OFF for normal operation.

Control word value	Function	
#4000	Shifts upward (towards higher addressed words).	
#6000	Shifts downward (towards lower addressed words).	
#8000	Clears the contents of St through E to #0000.	


Flags

ER: The St and E words are in different areas, or St is greater than E.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example

The following example shows instruction ASFT(17) used to shift words in an 11-word shift register created between DM 0100 and DM 0110 with a control word value of #6000 (bits 13 and 14 ON). The data changes that would occur for the given register and control word contents are also shown.



Address	Instruction	Opera	ands
00100	LD		00000
00101	ASFT(17)		
		#	6000
		DM	0100
		DM	0110

0000

0000

	Before		After 1	
	execution	n	executio	n
DM 0100	1234		1234	
DM 0101	0000		0000	
DM 0102	0000		2345	
DM 0103	2345		0000	
DM 0104	3456		3456	
DM 0105	0000		4567	
DM 0106	4567		0000	
DM 0107	5678		5678	
DM 0108	6789		6789	
DM 0109	0000		789A	
DM 0110	789A		0000	
		="		


5-16 Data Movement


This section describes the instructions used for moving data between different addresses in data areas. These movements can be programmed to be within the same data area or between different data areas. Data movement is essential for utilizing all of the data areas of the PC. Effective communications in Link Systems also requires data movement. All of these instructions change only the content of the words to which data is being moved, i.e., the content of source words is the same before and after execution of any of the data movement instructions.

5-16-1 MOVE - MOV(21)

Ladder Symbols

Operand Data Areas





Description

When the execution condition is OFF, MOV(21) is not executed. When the execution condition is ON, MOV(21) copies the content of S to D.



Precautions

TC numbers cannot be designated as D to change the PV of the timer or counter. You can, however, easily change the PV of a timer or a counter by using BSET(71).

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


EQ: ON when all zeros are transferred to D.

N: ON when bit 15 of D is set to 1.

5-16-2 MOVE NOT - MVN(22)

Ladder Symbols

Operand Data Areas



S: Source word				
IR, SR, AR, DM, HR, TC, LR, #				
D: Destination word				
IR, SR, AR, DM, HR, LR				

Description

When the execution condition is OFF, MVN(22) is not executed. When the execution condition is ON, MVN(22) transfers the inverted content of S (specified word or four-digit hexadecimal constant) to D, i.e., for each ON bit in S, the corresponding bit in D is turned OFF, and for each OFF bit in S, the corresponding bit in D is turned ON.



Precautions

TC numbers cannot be designated as D to change the PV of the timer or counter. However, these can be easily changed using BSET(71).

Flags


ER: Indirectly addressed DM word is non-existent. (Content of *DM word is


not BCD, or the DM area boundary has been exceeded.)

EQ: ON when all zeros are transferred to D.

N: ON when bit 15 of D is set to 1.

5-16-3 BLOCK SET - BSET(71)





Operand Data Areas


S: Source data		
IR, SR, AR, DM, HR, TC, LR, #		
St: Starting word		
IR, SR, AR, DM, HR, TC, LR		
E: End Word		
IR, SR, AR, DM, HR, TC, LR		

Limitations

St must be less than or equal to E, and St and E must be in the same data area.

Description

When the execution condition is OFF, BSET(71) is not executed. When the execution condition is ON, BSET(71) copies the content of S to all words from St through E.



BSET(71) can be used to change timer/counter PV. (This cannot be done with MOV(21) or MVN(22).) BSET(71) can also be used to clear sections of a data area, i.e., the DM area, to prepare for executing other instructions.


Flags

ER: St and E are not in the same data area or St is greater than E.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example


The following example shows how to use BSET(71) to change the PV of a timer depending on the status of IR 00003 and IR 00004. When IR 00003 is ON, TIM 010 will operate as a 50-second timer; when IR 00004 is ON, TIM 010 will operate as a 30-second timer.



Address	Instruction	Oper	ands
00000	LD		00003
00001	AND NOT		00004
00002	@BSET(71)		
		#	0500
		TIM	010
		TIM	010
00003	LD		00004
00004	AND NOT		00003
00005	@BSET(71)		
		#	0300
		TIM	010
		TIM	010
00006	LD		00003
00007	OR		00004
80000	TIM		010
		#	9999

5-16-4 BLOCK TRANSFER - XFER(70)

Ladder Symbols



Operand Data Areas

N: Number of words (BCD)	
IR, SR, AR, DM, HR, TC, LR, #	

S: Starting source word						
IR	SR	AR	DM	HR	TC I	R


D : Starting destination word	D: Starting destination word		
IR, SR, AR, DM, HR, TC, LR			

Limitations

Both S and D may be in the same data area, but their respective block areas must not overlap. S and S+N must be in the same data area, as must D and D+N. N must be BCD between 0000 and 6144.

Description

When the execution condition is OFF, XFER(70) is not executed. When the execution condition is ON, XFER(70) copies the contents of S, S+1, ..., S+N to D, D+1, ..., D+N.



Flags

ER: N is not BCD between 0000 and 2000.


S and S+N or D and D+N are not in the same data area.

Indirectly addressed DM word is non-existent. (Content of *DM word is


not BCD, or the DM area boundary has been exceeded.)

5-16-5 DATA EXCHANGE – XCHG(73)

Ladder Symbols



Operand Data Areas



Description

When the execution condition is OFF, XCHG(73) is not executed. When the execution condition is ON, XCHG(73) exchanges the content of E1 and E2.



If you want to exchange content of blocks whose size is greater than 1 word, use work words as an intermediate buffer to hold one of the blocks using XFER(70) three times.

Flags


ER:

Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

5-16-6 SINGLE WORD DISTRIBUTE - DIST(80)

Ladder Symbols



Operand Data Areas

S: Source data

IR, SR, AR, DM, HR, TC, LR, #

DBs: Destination base word
IR, SR, AR, DM, HR, TC, LR

C: Control word (BCD)

IR, SR, AR, DM, HR, TC, LR, #

Limitations

C must be a BCD. If C≤6655, DBs must be in the same data area as DBs+C. If C≥9000, DBs must be in the same data area as DBs+C–9000.

Description

Depending on the value of C, DIST(80) will operate as a data distribution instruction or stack instruction. If C is between 0000 and 6655, DIST(80) will operate as a data distribution instruction and copy the content of S to DBs+C. If the leftmost digit of C is 9, DIST(80) will operate as a stack instruction and create a stack with the number of words specified in the rightmost 3 digits of C.

Precautions

Stack operation will be unreliable if the specified stack length is different from the length specified in the last execution of DIST(80) or COLL(81).


Data Distribution Operation (C=0000 to 6655)

When the execution condition is OFF, DIST(80) is not executed. When the execution condition is ON, DIST(80) copies the content of S to DBs+C, i.e.,C is added to DBs to determine the destination word.



Stack Operation (C=9000 to 9999)


When the execution condition is OFF, DIST(80) is not executed. When the execution condition is ON, DIST(80) operates a stack from DBs to DBs+C-9000. DBs is the stack pointer, so S is copied to the word indicated by DBs and DBs is incremented by 1. The Negative Flag also changes.




Data can be added to the stack until it is full. DIST(80) is normally used together with COLL(81), which can be set to read from the stack on a FIFO or LIFO basis. Refer to 5-16-7 DATA COLLECT – COLL(81) for details.

Example of Stack Operation

In the following example, the content of C (LR 10) is 9010, and DIST(80) is used to write the numerical data #00FF to the 10-word stack from HR 20 to HR 29. During the first cycle when IR 00001 is ON, the data is written to DBs+1 (HR 21) and the stack pointer is incremented by 1. In the second cycle the data is written to DBs+2 (HR 22) and the stack pointer is incremented, and so on.



Address	Instruction	Operands	
00000	LD		00001
00001	DIST(80)		
		#	00FF
		HR	20
		LR	10



Flags

ER: The content of C is not BCD or 6655<C<9000.

When C≤6655, DBs and DBs+C are not in the same data area.

When C≥9000, DBs and DBs+C−9000 are not in the same data area.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the content of S is zero; otherwise OFF.

5-16-7 DATA COLLECT - COLL(81)

Ladder Symbols

COLL(81) SBs C C D D

Operand Data Areas

SBs: Source base word
IR, SR, AR, DM, HR, TC, LR
C: Offset data (BCD)
IR, SR, AR, DM, HR, TC, LR, #
D: Destination word
IR, SR, AR, DM, HR, TC, LR

Limitations

C must be a BCD. If C \leq 6655, SBs must be in the same data area as SBs+C. If the leftmost digit of C is 8 or 9, DBs must be in the same data area as SBs+N (N=the 3 rightmost digits of C).

Description

Depending on the value of C, COLL(81) will operate as a data collection instruction, FIFO stack instruction, or LIFO stack instruction. If C is between 0000 and 6655, COLL(81) will operate as a data collection instruction and copy the content of SBs+C to D.

If the leftmost digit of C is 9 , COLL(81) will operate as a FIFO stack instruction. If the leftmost digit of C is 8, COLL(81) will operate as a LIFO stack instruction. Both stack operations use a stack beginning at SBs with a length specified in the rightmost 3 digits of C.

Precautions

Stack operation will be unreliable if the specified stack length is different from the length specified in the last execution of DIST(80) or COLL(81).


Data Collection Operation (C=0000 to 6655)

When the execution condition is OFF, COLL(81) is not executed. When the execution condition is ON, COLL(81) copies the content of SBs + C to D, i.e., C is added to SBs to determine the source word.



FIFO Stack Operation (C=9000 to 9999)

When the execution condition is OFF, COLL(81) is not executed. When the execution condition is ON, COLL(81) copies the data from the oldest word recorded in the stack to D. The stack pointer, SBs, is then decremented by 1.




COLL(81) can be used together with DIST(80). Refer to *5-16-6 SINGLE WORD DISTRIBUTE – DIST(80*) for details.


Note FIFO stands for First-In-First-Out.

Example

In the following example, the content of C (HR 00) is 9010, and COLL(81) is used to copy the oldest entries from a10-word stack (IR 001 to IR 010) to LR 20.




Address	Instruction	Opera	nds
00000	LD		00001
00001	COLL(81)		
			001
		HR	00
		LR	20



LIFO Stack Operation (C=8000 to 8999)

When the execution condition is OFF, COLL(81) is not executed. When the execution condition is ON, COLL(81) copies the data most recently recorded in the stack to D. The stack pointer, SBs, is then decremented by 1.




Data can be added to the stack until it is full. DIST(80)'s stack operation can be used together with COLL(81)'s read stack operation. COLL(81) can be set to read on a FIFO or LIFO basis. Refer to 5-16-6 SINGLE WORD DISTRIBUTE (80) for details.


Note LIFO stands for Last-In-First-Out.

Example

In the following example, the content of C (HR 00) is 8010, and COLL(81) is used to copy the most recent entries from a 10-word stack (IR 001 to IR 010) to LR 20.



Address	Instruction	Operands	
00000	LD		00001
00001	COLL(81)		
			001
		HR	00
		LR	20



Flags

ER: The content of C is not BCD or 6655<C<8000.

When C≤6655, DBs and DBs+C are not in the same data area.

When C≥8000, the beginning and end of the stack are not in the same data area or the value of the stack pointer exceeds the length of the stack.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the transferred data is zero; otherwise OFF.

5-16-8 MOVE BIT - MOVB(82)

| MOVB(82) | @MOVB(82) | S | S | Bi | D | D

Operand Data Areas

S: Source word

IR, SR, AR, DM, HR, LR, #

Bi: Bit designator (BCD)

IR, SR, AR, DM, HR, TC, LR, #

D: Destination word


IR, SR, AR, DM, HR, LR

Limitations

The rightmost two digits and the leftmost two digits of Bi must each be between 00 and 15.

Description

When the execution condition is OFF, MOVB(82) is not executed. When the execution condition is ON, MOVB(82) copies the specified bit of S to the specified bit in D. The bits in S and D are specified by Bi. The rightmost two digits of Bi designate the source bit; the leftmost two bits designate the destination bit.



Flags

ER: C is not BCD, or it is specifying a non-existent bit (i.e., bit specification

must be between 00 and 15).


Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

N: ON if the leftmost bit of the content of word D is 1, otherwise OFF.

5-16-9 **MOVE DIGIT – MOVD(83)**

Ladder Symbols




Operand Data Areas

S: Source word
IR, SR, AR, DM, HR, TC, LR, #
Di: Digit designator (BCD)
IR, SR, AR, DM, HR, TC, LR, #
D: Destination word
IR, SR, AR, DM, HR, TC, LR

Limitations
Description


The rightmost three digits of Di must each be between 0 and 3.

When the execution condition is OFF, MOVD(83) is not executed. When the execution condition is ON, MOVD(83) copies the content of the specified digit(s) in S to the specified digit(s) in D. Up to four digits can be transferred at one time. The first digit to be copied, the number of digits to be copied, and the first digit to receive the copy are designated in Di as shown below. Digits from S will be copied to consecutive digits in D starting from the designated first digit and continued for the designated number of digits. If the last digit is reached in either S or D, further digits are used starting back at digit 0.



Digit Designator

The following show examples of the data movements for various values of Di.




Flags

ER: At least one of the rightmost three digits of Di is not between 0 and 3.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-16-10 TRANSFER BITS - XFRB(62)





Operand Data Areas

C: Control word
IR, SR, AR, DM, TC, HR, LR, #
S: First source word
IR, SR, AR, DM, HR, TC, LR
D: First destination word
IR, SR, AR, DM, HR, LR


Limitations

The specified source bits must be in the same data area.

The specified destination bits must be in the same data area.

Description


When the execution condition is OFF, XFRB(62) is not executed. When the execution condition is ON, XFRB(62) copies the specified source bits to the specified destination bits. The two rightmost digits of C specify the starting bits in S and D and the leftmost two digits indicate the number of bits that will be copied.




Note Up to 255 (FF) bits can be copied at one time.

Example

In the following example, XFRB(62) is used to transfer 5 bits from IR 020 to LR 21 when IR 00001 is ON. The starting bit in IR 020 is 0, and the starting bit in LR 21 is 4, so IR 02000 to IR 02004 are copied to LR 2104 to LR 2108.



Address	Instruction	Operands	
00000	LD		00001
00001	XFRB(62)		
		#	0540
			020
		LR	21



Flags


ER: The specified source bits are not all in the same data area.

The specified destination bits are not all in the same data area.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-16-11 EM BLOCK TRANSFER - XFR2(—)

Ladder Symbols



Operand Data Areas

N: Number of words (BCD)
IR, SR, AR, DM, HR, TC, LR, #
S: Starting source word
IR, SR, AR, DM, HR, TC, LR, #
D: Starting destination word
IR, SR, AR, DM, HR, TC, LR, #

Limitations

S and S+N must be in the same data area, as must D and D+N.

N must be BCD.

Description

When the execution condition is OFF, XFR2(—) is not executed. When the execution condition is ON, XFR2(—) copies the contents of S, S+1, ..., S+N to D, D+1, ..., D+N. If a constant is used for S or D, the constant specifies an address in the current EM bank.

Flags

ER: N is not BCD.


S and S+N or D and D+N are not in the same data area.

Indirectly addressed DM word is non-existent. (Content of *DM word is not RCD, or the DM area boundary has been exceeded.)

not BCD, or the DM area boundary has been exceeded.)

Example


The following example copies the contents of the 300 words from DM 0000 through DM 0299 to EM 2000 through EM 2299 in the current EM bank.



Address	Instruction	Operands	
00200	LD		00000
00201	XFR2(—)		
		#	0300
		DM	0000
		#	2000

5-16-12 EM BANK TRANSFER – BXF2(—)

Ladder Symbols



Operand Data Areas

C: First control word
IR, SR, AR, DM, HR, TC, LR, #
S: Starting source word
IR, SR, AR, DM, HR, TC, LR, #
D: Starting destination word
IR, SR, AR, DM, HR, TC, LR, #

Limitations

The value in C+1 must be BCD from 1 to 6144.

S and S+N must be in the same data area, as must D and D+N.

Description

When the execution condition is OFF, BXF2(—) is not executed. When the execution condition is ON, BXF2(—) copies the contents of S, S+1, ..., S+N to D, D+1, ..., D+N. If a constant is used for S or D, the constant specifies an address in the source or destination EM bank specified in C.

Control Words

C contains the source and destination bank numbers if data is being transferred to or from EM. The bank numbers are ignored unless a constant is used for S or D.

C+1 contains the number of words to transfer and must be BCD (1 to 6144).

Control word	Bits	Function	
С	0 to 7	Specifies the source bank number (00 to 02).	
	8 to 15	Specifies the destination bank number (00 to 02).	
C+1	0 to 15	Specifies the number of words to transfer (1 to 6144).	

Flags


ER: N is not BCD.

S and S+N or D and D+N are not in the same data area.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example

The following example copies the contents of the 300 words from DM 0000 through DM 0299 to EM 2000 through EM 2299 in the EM bank 01. (EM bank 00 isn't used as the source because S isn't a constant.)



Address	Instruction	Operands	
00200	LD		00000
00201	BXF2()		
		DM	1000
		DM	0000
		#	2000



0 3 0 0 Number of words (300)


C+1: DM 1001

Destination bank number (01)

5-17 Data Comparison

5-17-1 MULTI-WORD COMPARE – MCMP(19)

Ladder Symbols



Operand Data Areas

TB1: First word of table 1
IR, SR, AR, DM, HR, TC, LR
TB2: First word of table 2
IR, SR, AR, DM, HR, TC, LR
R: Result word
IR, AR, DM, HR, TC, LR

Limitations

TB1 and TB1+15 must be in the same data area, as must TB2 and TB2+15.

Description

When the execution condition is OFF, MCMP(19) is not executed. When the execution condition is ON, MCMP(19) compares the content of TB1 to TB2, TB1+1 to TB2+1, TB1+2 to TB2+2, ..., and TB1+15 to TB2+15. If the first pair is equal, the first bit in R is turned OFF, etc., i.e., if the content of TB1 equals the content of TB2, bit 00 is turned OFF, if the content of TB1+1 equals the content of TB2+1, bit 01 is turned OFF, etc. The rest of the bits in R will be turned ON.


Flags

ER: One of the tables (i.e., TB1 through TB1+15, or TB2 through TB2+15) exceeds the data area.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example

The following example shows the comparisons made and the results provided for MCMP(19). Here, the comparison is made during each cycle when 00000 is ON.



5-17-2 **COMPARE - CMP(20)**



CMP(20) Cp1 Cp2

Operand Data Areas

Cp1: First compare word

IR, SR, AR, DM, HR, TC, LR, #

Cp2: Second compare word

IR, SR, AR, DM, HR, TC, LR, #

Limitations

When comparing a value to the PV of a timer or counter, the value must be in BCD.

Description

When the execution condition is OFF, CMP(20) is not executed. When the execution condition is ON, CMP(20) compares Cp1 and Cp2 and outputs the result to the GR, EQ, and LE flags in the SR area.

Precautions

Placing other instructions between CMP(20) and the operation which accesses the EQ, LE, and GR flags may change the status of these flags. Be sure to access them before the desired status is changed.

CMP(20) cannot be used to compare signed binary data. Use CPS(—) instead. Refer to 5-17-8 SIGNED BINARY COMPARE – CPS(—) for details.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON if Cp1 equals Cp2.


LE: ON if Cp1 is less than Cp2.

GR: ON if Cp1 is greater than Cp2.

Flag	Address	C1 < C2	C1 = C2	C1 > C2
GR	25505	OFF	OFF	ON
EQ	25506	OFF	ON	OFF
LE	25507	ON	OFF	OFF

Example 1: Saving CMP(20) Results

The following example shows how to save the comparison result immediately. If the content of HR 09 is greater than that of 010, 00200 is turned ON; if the two contents are equal, 00201 is turned ON; if content of HR 09 is less than that of 010, 00202 is turned ON. In some applications, only one of the three OUTs would be necessary, making the use of TR 0 unnecessary. With this type of programming, 00200, 00201, and 00202 are changed only when CMP(20) is executed.




Address	Instruction	Operands	
00000	LD	00000	
00001	OUT	TR 0	_
00002	CMP(20)		
		010	_
		HR 09	_
00003	LD	TR 0	_
00004	AND	25505	

Address	Instruction	Operands	
00005	OUT	00200	
00006	LD	TR 0	
00007	AND	25506	
80000	OUT	00201	
00009	LD	TR 0	
00010	AND	25507	
00011	OUT	00202	

Example 2: Obtaining Indications during Timer Operation The following example uses TIM, CMP(20), and the LE flag (25507) to produce outputs at particular times in the timer's countdown. The timer is started by turning ON 00000. When 00000 is OFF, TIM 010 is reset and the second two CMP(20)s are not executed (i.e., executed with OFF execution conditions). Output 00200 is produced after 100 seconds; output 00201, after 200 seconds; output 00202, after 300 seconds; and output 00204, after 500 seconds.

The branching structure of this diagram is important in order to ensure that 00200, 00201, and 00202 are controlled properly as the timer counts down. Because all of the comparisons here use to the timer's PV as reference, the other operand for each CMP(20) must be in 4-digit BCD.




Address	Instruction	Operands	
00000	LD		00000
00001	TIM		010
		#	5000
00002	CMP(20)		
		TIM	010
		#	4000
00003	AND		25507
00004	OUT		00200
00005	LD		00200
00006	CMP(20)		•
		TIM	010
		#	3000

Address	Instruction	Operands	
00007	AND	25507	
80000	OUT	00201	
00009	LD	00201	
00010	CMP(20)		
		TIM 010	
		# 2000	
00011	AND	25507	
00012	OUT	00202	
00013	LD	TIM 010	
00014	OUT	00204	

5-17-3 DOUBLE COMPARE - CMPL(60)

Ladder Symbols

Operand Data Areas



Cp1: First word of first compare word pair

IR, SR, AR, DM, HR, TC, LR

Cp2: First word of second compare word pair

IR, SR, AR, DM, HR, TC, LR

Limitations

Cp1 and Cp1+1 must be in the same data area, as must Cp2 and Cp2+1.

Description

When the execution condition is OFF, CMPL(60) is not executed. When the execution condition is ON, CMPL(60) joins the 4-digit hexadecimal content of Cp1+1 with that of Cp1, and that of Cp2+1 with that of Cp2 to create two 8-digit hexadecimal numbers, Cp+1,Cp1 and Cp2+1,Cp2. The two 8-digit numbers are then compared and the result is output to the GR, EQ, and LE flags in the SR area.

Precautions

Placing other instructions between CMPL(60) and the operation which accesses the EQ, LE, and GR flags may change the status of these flags. Be sure to access them before the desired status is changed.

CMPL(60) cannot be used to compare signed binary data. Use CPSL(—) instead. Refer to 5-17-9 DOUBLE SIGNED BINARY COMPARE – CPSL(—) for details.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


GR: ON if Cp1+1,Cp1 is greater than Cp2+1,Cp2.

EQ: ON if Cp1+1,Cp1 equals Cp2+1,Cp2.

LE: ON if Cp1+1,Cp1 is less than Cp2+1,Cp2.

Example: Saving CMPL(60) Results

The following example shows how to save the comparison result immediately. If the content of HR 10, HR 09 is greater than that of 011, 010, then 00200 is turned ON; if the two contents are equal, 00201 is turned ON; if content of HR 10, HR 09 is less than that of 011, 010, then 00202 is turned ON. In some applications, only one of the three OUTs would be necessary, making the use of TR 0 unnecessary. With this type of programming, 00200, 00201, and 00202 are changed only when CMPL(60) is executed.




Address	Instruction	Operands	
00000	LD	00000	
00001	OUT	TR 0	
00002	CMPL(60)		
		HR 09	
		010	
00003	AND	25505	

Address	Instruction	Operands	
00004	OUT	00200	
00005	LD	TR 0	
00006	AND	25506	
00007	OUT	00201	
80000	LD	TR 0	
00009	AND	25507	
00010	OUT	00202	

5-17-4 BLOCK COMPARE – BCMP(68)

Ladder Symbols



Operand Data Areas

CD: Compare data	
IR, SR, AR, DM, HR, TC, LR, #	
CB: First comparison block word	
IR, DM, HR, TC, LR	
R: Result word	
IR, SR, AR, DM, HR, TC, LR	

Limitations


Each lower limit word in the comparison block must be less than or equal to the upper limit.

Description

When the execution condition is OFF, BCMP(68) is not executed. When the execution condition is ON, BCMP(68) compares CD to the ranges defined by a block consisting of of CB, CB+1, CB+2, ..., CB+31. Each range is defined by two words, the first one providing the lower limit and the second word providing the upper limit. If CD is found to be within any of these ranges (inclusive of the upper and lower limits), the corresponding bit in R is set. The comparisons that are made and the corresponding bit in R that is set for each true comparison are shown below. The rest of the bits in R will be turned OFF.

$CB \le CD \le CB+1$	Bit 00
$CB+2 \le CD \le CB+3$	Bit 01
$CB+4 \le CD \le CB+5$	Bit 02
$CB+6 \le CD \le CB+7$	Bit 03
$CB+8 \le CD \le CB+9$	Bit 04
CB+10 ≤ CD ≤ CB+11	Bit 05
CB+12 ≤ CD ≤ CB+13	Bit 06
CB+14 ≤ CD ≤ CB+15	Bit 07
CB+16 ≤ CD ≤ CB+17	Bit 08
CB+18 ≤ CD ≤ CB+19	Bit 09
CB+20 ≤ CD ≤ CB+21	Bit 10
$CB+22 \le CD \le CB+23$	Bit 11
$CB+24 \le CD \le CB+25$	Bit 12
$CB+26 \le CD \le CB+27$	Bit 13
$CB+28 \le CD \le CB+29$	Bit 14
$CB+30 \le CD \le CB+31$	Bit 15

Normally the first word in the range is less than the second, but if the first word in the range is greater than the second, the corresponding bit in R will be turned OFF when CD is <u>outside</u> of the range defined by the two words, as shown in the following diagram.



Flags


ER: The comparison block (i.e., CB through CB+31) exceeds the data area. Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example

The following example shows the comparisons made and the results provided for BCMP(68). Here, the comparison is made during each cycle when 00000 is ON.




Address	Instruction	Operands	
00000	LD	00000	
00001	BCMP(68)		
		001	
		HR 10	
		HR 05	



5-17-5 TABLE COMPARE - TCMP(85)

Ladder Symbols



Operand Data Areas

CD: Compare data

IR, SR, AR, DM, HR, TC, LR, #

TB: First comparison table word

IR, AR, DM, HR, TC, LR

R: Result word

IR, SR, AR, DM, HR, TC, LR

Limitations

Description

TB and TB+15 must be in the same data area.

When the execution condition is OFF, TCMP(85) is not executed. When the execution condition is ON, TCMP(85) compares CD to the content of TB, TB+1, TB+2, ..., and TB+15. If CD is equal to the content of any of these words, the corresponding bit in R is set, e.g., if the CD equals the content of TB, bit 00 is turned ON, if it equals that of TB+1, bit 01 is turned ON, etc. The rest of the bits in R will be turned OFF.


Flags

ER: The comparison table (i.e., TB through TB+15) exceeds the data area. Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)


EQ: ON if none of the words in the comparison table match CD, i.e., all of the bits in R are OFF.

Example

The following example shows the comparisons made and the results provided for TCMP(85). Here, the comparison is made during each cycle when 00000 is ON.




Address	Instruction	Oper	ands
00000	LD		00000
00001	TCMP(85)		
			001
		HR	10
		HR	05



5-17-6 AREA RANGE COMPARE – ZCP(88)

Ladder Symbols



Operand Data Areas

CD: Compare data	
IR, SR, AR, DM, HR, TC, LR, #	
LL: Lower limit of range	
IR, SR, AR, DM, HR, TC, LR, #	
UL : Upper limit of range	
IR, SR, AR, DM, HR, TC, LR, #	

Limitations

LL must be less than or equal to UL.

Description

When the execution condition is OFF, ZCP(88) is not executed. When the execution condition is ON, ZCP(88) compares CD to the range defined by lower limit LL and upper limit UL and outputs the result to the GR, EQ, and LE flags in the SR area. The resulting flag status is shown in the following table.

Comparison result	Flag status		
	GR (SR 25505)	EQ (SR 25506)	LE (SR 25507)
CD < LL	0	0	1
$LL \le CD \le UL$	0	1	0
UL < CD	1	0	0

Precautions

Placing other instructions between ZCP(88) and the operation which accesses the EQ, LE, and GR flags may change the status of these flags. Be sure to access them before the desired status is changed.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

LL is greater than UL.


EQ: ON if $LL \le CD \le UL$

LE: ON if CD < LL.

GR: ON if CD > UL.

Example: Saving ZCP(88) Results

The following example shows how to save the comparison result immediately. If IR 100 > AB1F, IR 00200 is turned ON; if #0010 \leq IR 100 \leq AB1F, IR 00201 is turned ON; if IR 100 < 0010, IR 00202 is turned ON.




Address	Instruction	Operands	
00000	LD		00000
00001	OUT	TR	0
00002	ZCP(88)		
		IR	100
		#	0010
		#	AB1F
00003	AND		25505

Address	Instruction	Operands	
00004	OUT	00200	
00005	LD	TR 0	
00006	AND	25506	
00007	OUT	00201	
80000	LD	TR 0	
00009	AND	25507	
00010	OUT	00202	

5-17-7 DOUBLE AREA RANGE COMPARE – ZCPL(—)

Ladder Symbols



Operand Data Areas

CD: Compare data

IR, SR, AR, DM, HR, LR

LL: Lower limit of range

IR, SR, AR, DM, HR, LR

UL: Upper limit of range

IR, SR, AR, DM, HR, LR

Limitations

The 8-digit value in LL+1,LL must be less than or equal to UL+1,UL. CD and CD+1 must be in the same data area, as must LL and LL+1, and UL and UL+1.

Description

When the execution condition is OFF, ZCPL(—) is not executed. When the execution condition is ON, ZCPL(—) compares the 8-digit value in CD, CD+1 to the range defined by lower limit LL+1,LL and upper limit UL+1,UL and outputs the result to the GR, EQ, and LE flags in the SR area. The resulting flag status is shown in the following table.

Comparison result	Flag status		
	GR (SR 25505)	EQ (SR 25506)	LE (SR 25507)
CD , CD+1< LL+1,LL	0	0	1
$LL+1,LL \le CD, CD+1 \le UL+1,UL$	0	1	0
UL+1,UL < CD, CD+1	1	0	0

Precautions

Placing other instructions between ZCPL(—) and the operation which accesses the EQ, LE, and GR flags may change the status of these flags. Be sure to access them before the desired status is changed.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

LL+1,LL is greater than UL+1,UL.

EQ: ON if LL+1,LL \leq CD, CD+1 \leq UL+1,UL


LE: ON if CD, CD+1 < LL+1,LL. **GR**: ON if CD, CD+1 > UL+1,UL.

Example

Refer to 5-17-6 AREA RANGE COMPARE – ZCP(88) for an example. The only difference between ZCP(88) and ZCPL(—) is the number of digits in the comparison data.

5-17-8 SIGNED BINARY COMPARE – CPS(—)

Ladder Symbols



Operand Data Areas

Cp1: First compare word

IR, SR, AR, DM, HR, TC, LR, #

Cp2: Second compare word

IR, SR, AR, DM, HR, TC, LR, #

Third operand: Set to 000.

Description

When the execution condition is OFF, CPS(—) is not executed. When the execution condition is ON, CPS(—) compares the 16-bit (4-digit) signed binary contents in Cp1 and Cp2 and outputs the result to the GR, EQ, and LE flags in the SR area.

Note

- 1. Refer to page 27 for details on 16-bit signed binary data.
- 2. Refer to 5-17-2 Compare CMP(20) for details on saving comparison results.

Precautions

Placing other instructions between CPS(—) and the operation which accesses the EQ, LE, and GR flags may change the status of these flags. Be sure to access them before the desired status is changed.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON if Cp1 equals Cp2.


LE: ON if Cp1 is less than Cp2.

GR: ON if Cp1 is greater than Cp2.

Comparison result	Flag status		
	GR (SR 25505)	EQ (SR 25506)	LE (SR 25507)
Cp1 < Cp2	0	0	1
Cp1 = Cp2	0	1	0
Cp1 > Cp2	1	0	0

5-17-9 DOUBLE SIGNED BINARY COMPARE - CPSL(---)

Ladder Symbols



Operand Data Areas

Cp1: First compare word		
IR, SR, AR, DM, HR, TC, LR		

Cp2: Second compare word		
IR SR AR DM	HR TC LR	

Third operand: S	Set to 000.

Limitations

Cp1 and Cp1+1 must be in the same data area, as must Cp2 and Cp2+1.

Description

When the execution condition is OFF, CPSL(—) is not executed. When the execution condition is ON, CPSL(—) compares the 32-bit (8-digit) signed binary contents in Cp1+1, Cp1 and Cp2+1, Cp2 and outputs the result to the GR, EQ, and LE flags in the SR area.

Note

- 1. Refer to page 27 for details on 32-bit signed binary data.
- 2. Refer to 5-17-2 Compare CMP(20) for details on saving comparison results.

Precautions

Placing other instructions between CPSL(—) and the operation which accesses the EQ, LE, and GR flags may change the status of these flags. Be sure to access them before the desired status is changed.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON if Cp1+1, Cp1 equals Cp2+1, Cp2.

LE: ON if Cp1+1, Cp1 is less than Cp2+1, Cp2.

GR: ON if Cp1+1, Cp1 is greater than Cp2+1, Cp2.


Comparison result	Flag status		
	GR (SR 25505)	EQ (SR 25506)	LE (SR 25507)
Cp1+1, Cp1 < Cp2+1, Cp2	0	0	1
Cp1+1, Cp1 = Cp2+1, Cp2	0	1	0
Cp1+1, Cp1 > Cp2+1, Cp2	1	0	0


Data Conversion Section 5-18

5-18 Data Conversion

The conversion instructions convert word data that is in one format into another format and output the converted data to specified result word(s). Conversions are available to convert between binary (hexadecimal) and BCD, to 7-segment display data, to ASCII, and between multiplexed and non-multiplexed data. All of these instructions change only the content of the words to which converted data is being moved, i.e., the content of source words is the same before and after execution of any of the conversion instructions.

5-18-1 BCD-TO-BINARY - BIN(23)






Operand Data Areas

S: Source word (BCD)	
IR, SR, AR, DM, HR, TC, LR	
R: Result word	
IR, SR, AR, DM, HR, LR	

Description

When the execution condition is OFF, BIN(23) is not executed. When the execution condition is ON, BIN(23) converts the BCD content of S into the numerically equivalent binary bits, and outputs the binary value to R. Only the content of R is changed; the content of S is left unchanged.



BIN(23) can be used to convert BCD to binary so that displays on the Programming Console or any other programming device will appear in hexadecimal rather than decimal. It can also be used to convert to binary to perform binary arithmetic operations rather than BCD arithmetic operations, e.g., when BCD and binary values must be added.

Flags

ER: The content of S is not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is zero.

N: 25402 is always OFF.


Section 5-18 Data Conversion

DOUBLE BCD-TO-DOUBLE BINARY – BINL(58) 5-18-2

Ladder Symbols

@BINL(58)


Operand Data Areas



S: First source word (BCD)	
IR, SR, AR, DM, HR, TC, LR	
R: First result word	
IR, SR, AR, DM, HR, LR	_

Description

When the execution condition is OFF, BINL(58) is not executed. When the execution condition is ON, BINL(58) converts an eight-digit number in S and S+1 into 32-bit binary data, and outputs the converted data to R and R+1.



Flags

ER: The contents of S and/or S+1 words are not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is


not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is zero.

N: 25402 is always OFF.

5-18-3 BINARY-TO-BCD - BCD(24)

Ladder Symbols




Operand Data Areas

S : Source word (binary)
IR, SR, AR, DM, HR, LR
R: Result word
IR, SR, AR, DM, HR, LR

Description

BCD(24) converts the binary (hexadecimal) content of S into the numerically equivalent BCD bits, and outputs the BCD bits to R. Only the content of R is changed; the content of S is left unchanged.



BCD(24) can be used to convert binary to BCD so that displays on the Programming Console or any other programming device will appear in decimal rather than hexadecimal. It can also be used to convert to BCD to perform BCD arithmetic operations rather than binary arithmetic operations, e.g., when BCD and binary values must be added.

Note If the content of S exceeds 270F, the converted result would exceed 9999 and BCD(24) will not be executed. When the instruction is not executed, the content of R remains unchanged.

Signed Binary Data

BCD(24) cannot be used to convert signed binary data directly to BCD. To convert signed binary data, first determine whether the data is positive or negative. If it is positive, BCD(24) can be used to convert the data to BCD. If it is negative, use the 2's COMPLEMENT – NEG(—) instruction to convert the data to unsigned binary before executing BCD(24). Refer to page 27 for details on signed binary data.

Flags ER: S is greater than 270F.

Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is zero.

5-18-4 DOUBLE BINARY-TO-DOUBLE BCD – BCDL(59)

Ladder Symbols

BCDL(59) S R R @BCDL(59) R

Operand Data Areas

S: First source word (binary)	
IR, SR, AR, DM, HR, LR	
R: First result word	
IR, SR, AR, DM, HR, LR	_


Limitations

If the content of S exceeds 05F5E0FF, the converted result would exceed 99999999 and BCDL(59) will not be executed. When the instruction is not executed, the content of R and R+1 remain unchanged.

S and S+1 must be in the same data area as must R and R+1.

Description

BCDL(59) converts the 32-bit binary content of S and S+1 into eight digits of BCD data, and outputs the converted data to R and R+1.



Signed Binary Data

BCD(24) cannot be used to convert signed binary data directly to BCD. To convert signed binary data, first determine whether the data is positive or negative. If it is positive, BCD(24) can be used to convert the data to BCD. If it is negative, use the DOUBLE 2's COMPLEMENT – NEGL(—) instruction to convert the data to unsigned binary before executing BCD(24). Refer to page 27 for details on signed binary data.

Flags

ER: Content of R and R+1 exceeds 99999999.


Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is zero.

5-18-5 HOURS-TO-SECONDS - SEC(65)

Ladder Symbols



Operand Data Areas

S: Beginning source word (BCD)
IR, SR, AR, DM, HR, TC, LR
R: Beginning result word (BCD)
IR, SR, AR, DM, HR, TC, LR
000 : Set to 000.

Limitations

S and S+1 must be within the same data area. R and R+1 must be within the same data area. S and S+1 must be BCD and must be in the proper hours/minutes/seconds format.

Description

SEC(65) is used to convert time notation in hours/minutes/seconds to an equivalent in just seconds.

For the source data, the seconds are designated in bits 00 through 07 and the minutes are designated in bits 08 through 15 of S. The hours are designated in S+1. The maximum is thus 9,999 hours, 59 minutes, and 59 seconds.

The result is output to R and R+1. The maximum obtainable value is 35,999,999 seconds.

Flags

ER: S and S+1 or R and R+1 are not in the same data area.

S and/or S+1 do not contain BCD.


Number of seconds and/or minutes exceeds 59.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: Turns ON when the result is zero.

Example


When 00000 is OFF (i.e., when the execution condition is ON), the following instruction would convert the hours, minutes, and seconds given in HR 12 and HR 13 to seconds and store the results in DM 0100 and DM 0101 as shown.



Address	Instruction	Opera	ands
00000	LD NOT		00000
00001	SEC(65)		
		HR	12
		DM	0100
			000

5-18-6 SECONDS-TO-HOURS - HMS(66)

Ladder Symbols



Operand Data Areas

S: Beginning source word (BCD)
IR, SR, AR, DM, HR, TC, LR
R: Beginning result word (BCD)
IR, SR, AR, DM, HR, TC, LR
000 : Set to 000.

Limitations

S and S+1 must be within the same data area. R and R+1 must be within the same data area. S and S+1 must be BCD and must be between 0 and 35,999,999 seconds.

Description

HMS(66) is used to convert time notation in seconds to an equivalent in hours/minutes/seconds.

The number of seconds designated in S and S+1 is converted to hours/minutes/ seconds and placed in R and R+1.

For the results, the seconds is placed in bits 00 through 07 and the minutes is placed in bits 08 through 15 of R. The hours is placed in R+1. The maximum will be 9,999 hours, 59 minutes, and 59 seconds.

Flags

ER: S and S+1 or R and R+1 are not in the same data area.


S and/or S+1 do not contain BCD or exceed 36,000,000 seconds.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: Turns ON when the result is zero.

Example


When 00000 is OFF (i.e., when the execution condition is ON), the following instruction would convert the seconds given in HR 12 and HR 13 to hours, minutes, and seconds and store the results in DM 0100 and DM 0101 as shown.



Address	Instruction	Opera	ands
00000	LD NOT		00000
00001	HMS(66)		
		HR	12
		DM	0100
			000

5-18-7 4-TO-16/8-TO-256 DECODER - MLPX(76)

Ladder Symbols



Operand Data Areas

S: Source word
IR, SR, AR, DM, HR, TC, LR
C: Control word
IR, SR, AR, DM, HR, TC, LR, #
R: First result word
IR, SR, AR, DM, HR, LR

Limitations

When the leftmost digit of C is 0, the rightmost two digits of C must each be between 0 and 3.

When the leftmost digit of C is 1, the rightmost two digits of C must each be between 0 and 1.

All result words must be in the same data area.

Description

Depending on the value of C, MLPX(76) operates as a 4-bit to 16-bit decoder or an 8-bit to 256-bit decoder.


4-bit to 16-bit Decoder

MLPX(76) operates as a 4-bit to 16-bit decoder when the leftmost digit of C is 0. The hexadecimal value of the digits in S are used to specify bits in up to 4 result words. The specified bit in each result word is turned on, and the other 15 bits in each word are turned off.


When the execution condition is OFF, MLPX(76) is not executed. When the execution condition is ON, MLPX(76) converts up to four, four-bit hexadecimal digits from S into decimal values from 0 to 15, each of which is used to indicate a bit position. The bit whose number corresponds to each converted value is then turned ON in a result word. If more than one digit is specified, then one bit will be turned ON in each of consecutive words beginning with R. (See examples, below.)

Control Word


The digits of C are set as shown below. Set the leftmost digit of C to 0 to specify 4-bit to 16-bit decoding.



Some example C values and the digit-to-word conversions that they produce are shown below.



The following is an example of a one-digit decode operation from digit number 1 of S, i.e., here C would be 0001.




The first digit and the number of digits to be converted are designated in C. If more digits are designated than remain in S (counting from the designated first digit), the remaining digits will be taken starting back at the beginning of S. The final word required to store the converted result (R plus the number of digits to be converted) must be in the same data area as R, e.g., if two digits are converted, the last word address in a data area cannot be designated; if three digits are converted, the last two words in a data area cannot be designated.

8-bit to 256-bit Decoder


MLPX(76) operates as an 8-bit to 256-bit decoder when the leftmost digit of C is set to 1. The hexadecimal value of the two bytes in S are used to specify a bit in one or two groups of 16 consecutive result words (256 bits). The specified bit in each group is turned on, and the other 255 bits in the group are turned off.

Control Word


The digits of C are set as shown below. Set the leftmost digit of C to 1 to specify 8-bit to 256-bit decoding.



The 4 possible C values and the conversions that they produce are shown below. (In S, 0 indicates the rightmost byte and 1 indicates the leftmost byte.)



The following is an example of a one-byte decode operation from the rightmost byte of S (C would be 1000 in this case).



Flags


ER: Undefined control word.

The result words are not all in the same data area.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example: 4-bit to 16-bit Decoding

The following program converts three digits of data from LR 20 to bit positions and turns ON the corresponding bits in three consecutive words starting with HR 10.




Address	Instruction	Opera	ands
00000	LD		00000
00001	MLPX(76)		
		LR	20
		#	0021
		HR	10



5-18-8 16-TO-4/256-TO-8 ENCODER – DMPX(77)

Ladder Symbols



Operand Data Areas

S: First source word
IR, SR, AR, DM, HR, TC, LR
R: Result word
IR, SR, AR, DM, HR, LR
C: Control Word
IR, SR, AR, DM, HR, TC, LR, #

Limitations

When the leftmost digit of C is 0, the rightmost two digits of C must each be between 0 and 3.

When the leftmost digit of C is 1, the rightmost two digits of C must each be between 0 and 1.

All source words must be in the same data area.

Description


Depending on the value of C, MLPX(76) operates as a 16-bit to 4-bit encoder or an 256-bit to 8-bit encoder.

16-bit to 4-bit Encoder


DMPX(77) operates as a 16-bit to 4-bit encoder when the leftmost digit of C is 0. When the execution condition is OFF, DMPX(77) is not executed. When the execution condition is ON, DMPX(77) determines the position of the highest ON bit in S, encodes it into single-digit hexadecimal value corresponding to the bit number, then transfers the hexadecimal value to the specified digit in R. The digits to receive the results are specified in C, which also specifies the number of digits to be encoded.

Control Word


The digits of C are set as shown below. Set the leftmost digit of C to 0 to specify 16-bit to 4-bit encoding.



Some example C values and the word-to-digit conversions that they produce are shown below.



The following is an example of a one-digit encode operation to digit number 1 of R, i.e., here C would be 0001.



Up to four digits from four consecutive source words starting with S may be encoded and the digits written to R in order from the designated first digit. If more digits are designated than remain in R (counting from the designated first digit), the remaining digits will be placed at digits starting back at the beginning of R. The final word to be converted (S plus the number of digits to be converted) must be in the same data area as SB.


256-bit to 8-bit Encoder

DMPX(77) operates as a 256-bit to 8-bit encoder when the leftmost digit of C is set to 1.


When the execution condition is OFF, DMPX(77) is not executed. When the execution condition is ON, DMPX(77) determines the position of the highest (leftmost) ON bit in the group of 16 source words from S to S+15 or S+16 to S+31, encodes it into a two-digit hexadecimal value corresponding to the location of the bit among the 256 bits in the group, then transfers the hexadecimal value to the specified byte in R. The byte to receive the result is specified in C, which also specifies the number of bytes to be encoded.

Control Word


The digits of C are set as shown below. Set the leftmost digit of C to 1 to specify 256-bit to 8-bit decoding.



Three possible C values and the conversions that they produce are shown below. (In R, 0 indicates the rightmost byte and 1 indicates the leftmost byte.)



The following is an example of a one-byte encode operation to the rightmost byte of R (C would be 1000 in this case).



Flags

ER: Undefined control word.


The source words are not all in the same data area.

Content of the source words is zero. (There isn't an ON bit in the source words.)

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example: 16-bit to 4-bit Encoding

When 00000 is ON, the following diagram encodes IR words 010 and 011 to the first two digits of HR 20 and then encodes LR 10 and 11 to the last two digits of HR 20. Although the status of each source word bit is not shown, it is assumed that the bit with status 1 (ON) shown is the highest bit that is ON in the word.



LR 1108

LR 1109

LR 1115

0


5-18-9 7-SEGMENT DECODER – SDEC(78)

LR 1002

LR 1015

0

Ladder Symbols



Operand Data Areas

S: Source word (binary)
IR, SR, AR, DM, HR, TC, LR
Di : Digit designator
IR, SR, AR, DM, HR, TC, LR, #
D: First destination word
IR, SR, AR, DM, HR, LR

Limitations

Di must be within the values given below

All destination words must be in the same data area.

Description

When the execution condition is OFF, SDEC(78) is not executed. When the execution condition is ON, SDEC(78) converts the designated digit(s) of S into the equivalent 8-bit, 7-segment display code and places it into the destination word(s) beginning with D.

00000

010

20 0010

10


20

0012


Any or all of the digits in S may be converted in sequence from the designated first digit. The first digit, the number of digits to be converted, and the half of D to receive the first 7-segment display code (rightmost or leftmost 8 bits) are designated in Di. If multiple digits are designated, they will be placed in order starting from the designated half of D, each requiring two digits. If more digits are designated than remain in S (counting from the designated first digit), further digits will be used starting back at the beginning of S.

Digit Designator

The digits of Di are set as shown below.




Some example Di values and the 4-bit binary to 7-segment display conversions that they produce are shown below.



Example

The following example shows the data to produce an 8. The lower case letters show which bits correspond to which segments of the 7-segment display. The table underneath shows the original data and converted code for all hexadecimal digits.



	Original data					Converted code (segments)						Display	
Digit		Bi	ts		-	g	f	е	d	С	b	а	
0	0	0	0	0	0	0	1	1	1	1	1	1	0
1	0	0	0	1	0	0	0	0	0	1	1	0	1
2	0	0	1	0	0	1	0	1	1	0	1	1	5
3	0	0	1	1	0	1	0	0	1	1	1	1	3
4	0	1	0	0	0	1	1	0	0	1	1	0	Ч
5	0	1	0	1	0	1	1	0	1	1	0	1	5
6	0	1	1	0	0	1	1	1	1	1	0	1	8
7	0	1	1	1	0	0	1	0	0	1	1	1	ņ
8	1	0	0	0	0	1	1	1	1	1	1	1	8
9	1	0	0	1	0	1	1	0	1	1	1	1	٩
Α	1	0	1	0	0	1	1	1	0	1	1	1	Я
В	1	0	1	1	0	1	1	1	1	1	0	0	Ь
С	1	1	0	0	0	0	1	1	1	0	0	1	[
D	1	1	0	1	0	1	0	1	1	1	1	0	d
E	1	1	1	0	0	1	1	1	1	0	0	1	8
F	1	1	1	1	0	1	1	1	0	0	0	1	۶


not BCD, or the DM area boundary has been exceeded.)

Flags ER: Incorrect digit designator, or data area for destination exceeded

Indirectly addressed DM word is non-existent. (Content of *DM word is

5-18-10 ASCII CONVERT - ASC(86)

Ladder Symbols



Operand Data Areas

S: Source word
IR, SR, AR, DM, HR, TC, LR
Di: Digit designator
IR, SR, AR, DM, HR, TC, LR, #
D: First destination word
IR, SR, AR, DM, HR, LR

Limitations

Di must be within the values given below

All destination words must be in the same data area.

Description


When the execution condition is OFF, ASC(86) is not executed. When the execution condition is ON, ASC(86) converts the designated digit(s) of S into the equivalent 8-bit ASCII code and places it into the destination word(s) beginning with D.

Any or all of the digits in S may be converted in order from the designated first digit. The first digit, the number of digits to be converted, and the half of D to receive the first ASCII code (rightmost or leftmost 8 bits) are designated in Di. If multiple digits are designated, they will be placed in order starting from the designated half of D, each requiring two digits. If more digits are designated than remain in S (counting from the designated first digit), further digits will be used starting back at the beginning of S.


Refer to *Appendix I* for a table of extended ASCII characters.

Digit Designator

The digits of Di are set as shown below.



Some examples of Di values and the 4-bit binary to 8-bit ASCII conversions that they produce are shown below.



Parity

The leftmost bit of each ASCII character (2 digits) can be automatically adjusted for either even or odd parity. If no parity is designated, the leftmost bit will always be zero.

When even parity is designated, the leftmost bit will be adjusted so that the total number of ON bits is even, e.g., when adjusted for even parity, ASCII "31" (00110001) will be "B1" (10110001: parity bit turned ON to create an even number of ON bits); ASCII "36" (00110110) will be "36" (00110110: parity bit turned OFF because the number of ON bits is already even). The status of the parity bit does not affect the meaning of the ASCII code.


When odd parity is designated, the leftmost bit of each ASCII character will be adjusted so that there is an odd number of ON bits.

Flags

ER: Incorrect digit designator, or data area for destination exceeded.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

5-18-11 ASCII-TO-HEXADECIMAL – HEX(—)



S: First source word IR, SR, AR, DM, HR, TC, LR Di: Digit designator IR, SR, AR, DM, HR, TC, LR D: Destination word

IR, SR, AR, DM, HR, LR

Operand Data Areas

Limitations

Di must be within the values given below.

All source words must be in the same data area.

Bytes in the source words must contain the ASCII code equivalent of hexadecimal values, i.e., 30 to 39 (0 to 9), 41 to 46 (A to F), or 61 to 66 (a to f).

Description


When the execution condition is OFF, HEX(—) is not executed. When the execution condition is ON, HEX(—) converts the designated byte(s) of ASCII code from the source word(s) into the hexadecimal equivalent and places it into D.

Up to 4 ASCII codes may be converted beginning with the designated first byte of S. The converted hexadecimal values are then placed in D in order from the designated digit. The first byte (rightmost or leftmost 8 bits), the number of bytes to be converted, and the digit of D to receive the first hexadecimal value are designated in Di. If multiple bytes are designated, they will be converted in order starting from the designated half of S and continuing to S+1 and S+2, if necessary.


If more digits are designated than remain in D (counting from the designated first digit), further digits will be used starting back at the beginning of D. Digits in D that do not receive converted data will not be changed.

Digit Designator

The digits of Di are set as shown below.



Some examples of Di values and the 8-bit ASCII to 4-bit hexadecimal conversions that they produce are shown below.



ASCII Code Table

The following table shows the ASCII codes before conversion and the hexadecimal values after conversion. Refer to *Appendix I* for a table of ASCII characters.

Original data							Conve	erted d	ata				
ASCII Code	Bit status (See note.)						Digit		Bi	ts			
30	*	0	1	1	0	0	0	0	0	0	0	0	0
31	*	0	1	1	0	0	0	1	1	0	0	0	1
32	*	0	1	1	0	0	1	0	2	0	0	1	0
33	*	0	1	1	0	0	1	1	3	0	0	1	1
34	*	0	1	1	0	1	0	0	4	0	1	0	0
35	*	0	1	1	0	1	0	1	5	0	1	0	1
36	*	0	1	1	0	1	1	0	6	0	1	1	0
37	*	0	1	1	0	1	1	1	7	0	1	1	1
38	*	0	1	1	1	0	0	0	8	1	0	0	0
39	*	0	1	1	1	0	0	1	9	1	0	0	1
41	*	1	0	1	0	0	0	1	Α	1	0	1	0
42	*	1	0	1	0	0	1	0	В	1	0	1	1
43	*	1	0	1	0	0	1	1	С	1	1	0	0
44	*	1	0	1	0	1	0	0	D	1	1	0	1
45	*	1	0	1	0	1	0	1	E	1	1	1	0
46	*	1	0	1	0	1	1	0	F	1	1	1	1

Note The leftmost bit of each ASCII code is adjusted for parity.

Parity

The leftmost bit of each ASCII character (2 digits) is automatically adjusted for either even or odd parity.

With no parity, the leftmost bit should always be zero. With odd or even parity, the leftmost bit of each ASCII character should be adjusted so that there is an odd or even number of ON bits.

If the parity of the ASCII code in S does not agree with the parity specified in Di, the ER Flag (SR 25503) will be turned ON and the instruction will not be executed.


Flags

ER: Incorrect digit designator, or data area for destination exceeded.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)


Example

In the following example, the 2nd byte of LR 10 and the 1st byte of LR 11 are converted to hexadecimal values and those values are written to the first and second bytes of IR 010.




Address		Instruction	Oper	ands
00000)	LD		00000
0000	1	@HEX()		
			LR	10
			HR	10
				010





5-18-12 SCALING - SCL(---)

Ladder Symbols



Operand Data Areas

S: Source word				
IR, SR, AR, DM, HR, TC, LR, #				
P1: First parameter word				
IR, SR, AR, DM, HR, TC, LR				
R: Result word				
IR, SR, AR, DM, HR, LR				

Limitations

P1 and P1+2 must be BCD.

P1 through P1+3 must be in the same data area.

P1+1 and P1+3 must not be set to the same value.

Description


SCL(—) is used to linearly convert a 4-digit hexadecimal value to a 4-digit BCD value. Unlike BCD(24), which converts a 4-digit hexadecimal value to its 4-digit BCD equivalent ($S_{hex} \rightarrow S_{BCD}$), SCL(—) can convert the hexadecimal value according to a specified linear relationship. The conversion line is defined by two points specified in the parameter words P1 to P1+3.

When the execution condition is OFF, SCL(—) is not executed. When the execution condition is ON, SCL(—) converts the 4-digit hexadecimal value in S to the 4-digit BCD value on the line defined by points (P1, P1+1) and (P1+2, P1+3) and places the result in R. The result is rounded off to the nearest integer. If the result is less than 0000, then 0000 is written to R, and if the result is greater than 9999, then 9999 is written to R.

The following table shows the functions and ranges of the parameter words:

Parameter	Function	Range	Comments
P1	BCD point #1 (A _Y)	0000 to 9999	
P1+1	Hex. point #1 (A _X)	0000 to FFFF	Do not set P1+1=P1+3.
P1+2	BCD point #2 (B _Y)	0000 to 9999	
P1+3	Hex. point #2 (B _X)	0000 to FFFF	Do not set P1+3=P1+1.

The following diagram shows the source word, S, converted to D according to the line defined by points (A_Y, A_X) and (B_Y, B_X) .



The results can be calculated by first converting all values to BCD and then using the following formula.

Results =
$$B_Y - [(B_Y - A_Y)/(B_X - A_X) X (B_X - S)]$$

Flags

ER: The value in P1+1 equals that in P1+3.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

P1 and P1+3 are not in the same data area, or other setting error.

EQ: ON when the result, R, is 0000.

Example

When 00000 is turned ON in the following example, the BCD source data in DM 0100 (#0100) is converted to hexadecimal according to the parameters in DM 0150 to DM 0153. The result (#0512) is then written to DM 0200.



Address Instruction		Opera	ands
00000	LD		00000
00001	@SCL()		
		DM	0100
		DM	0150
		DM	0200

DM 0150	0010
DM 0151	0005
DM 0152	0050
DM 0153	0019

5-18-13 COLUMN TO LINE – LINE(63)

Ladder Symbols

Operand Data Areas

S: First word of 16 word source set
IR, SR, AR, DM, HR, TC, LR
C: Column bit designator (BCD)

IR, SR, AR, DM, HR, TC, LR, #		
5 5 6 6 1		
D : Destination word		
IR, SR, AR, DM, HR, TC, LR		


Limitations

S and S+15 must be in the same data area.

C must be between #0000 and #0015.

Description

When the execution condition is OFF, LINE(63) is not executed. When the execution condition is ON, LINE(63) copies bit column C from the 16-word set (S to S+15) to the 16 bits of word D (00 to 15).



Flags

ER: The column bit designator C is not BCD, or it is specifying a non-existent bit (i.e., bit specification must be between 00 and 15).

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the content of D is zero; otherwise OFF.

Example

The following example shows how to use LINE(63) to move bit column 07 from the set (IR 100 to IR 115) to DM 0100.



Address	Instruction	Opera	ands
00000	LD		00000
00001	LINE(63)		
			100
		#	0007
		DM	0100

5-18-14 LINE TO COLUMN - COLM(64)

Ladder Symbols

COLM(64) S D C C

Operand Data Areas

S: Source word
IR, SR, AR, DM, HR, TC, LR
D: First word of the destination set
IR, AR, DM, HR, TC, LR
C: Column bit designator (BCD)
IR, SR, AR, DM, HR, TC, LR, #


Limitations

D and D+15 must be in the same data area.

C must be between #0000 and #0015.

Description

When the execution condition is OFF, COLM(64) is not executed. When the execution condition is ON, COLM(64) copies the 16 bits of word S (00 to 15) to the column of bits, C, of the 16-word set (D to D+15).



Flags

ER: The bit designator C is not BCD, or it is specifying a non-existent bit (i.e., bit specification must be between 00 and 15).

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the content of S is zero; otherwise OFF.

Example

The following example shows how to use COLM(64) to move the contents of word DM 0100 (00 to 15) to bit column 15 of the set (DM 0200 to DM 0215).



Address	Instruction	Oper	ands
00000	LD		00000
00001	COLM(64)		
		DM	0100
		DM	0200
		#	0015

5-18-15 2'S COMPLEMENT - NEG(---)

Ladder Symbols

NEG(—) S R

Operand Data Areas

S: Source word			
IR, SR, AR, DM, HR, TC, LR, #			
R: Result word			
IR, SR, AR, DM, HR, LR			

Description

Converts the four-digit hexadecimal content of the source word (S) to its 2's complement and outputs the result to the result word (R). This operation is effectively the same as subtracting S from 0000 and outputting the result to R.

If the content of S is 0000, the content of R will also be 0000 after execution, and EQ (SR 25506) will be turned on.

If the content of S is 8000, the content of R will also be 8000 after execution, and UF (SR 25405) will be turned on.

Note Refer to page 27 for details on 16-bit signed binary data.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


EQ: ON when the content of S is 0000; otherwise OFF.

UF: ON when the content of S is 8000; otherwise OFF.


N: ON when bit 15 of R is set to 1; otherwise OFF.

Example

The following example shows how to use NEG(—) to find the 2's complement of the hexadecimal value 001F and output the result to DM 0020.




Address	Instruction	Oper	ands
00000	LD		00000
00001	NEG(—)		
		#	001F
		DM	0020



5-18-16 DOUBLE 2'S COMPLEMENT - NEGL(---)

Ladder Symbols



Operand Data Areas

S: First source word				
IR, SR, AR, DM, HR, TC, LR				
R: First result word				
IR, SR, AR, DM, HR, LR				

Limitations

S and S+1 must be in the same data area, as must R and R+1.

Description

Converts the eight-digit hexadecimal content of the source words (S and S+1) to its 2's complement and outputs the result to the result words (R and R+1). This operation is effectively the same as subtracting the eight-digit content S and S+1 from \$0000 0000 and outputting the result to R and R+1.

If the content of S is 0000 0000, the content of R will also be 0000 0000 after execution and EQ (SR 25506) will be turned on.

If the content of S is 8000 0000, the content of R will also be 8000 0000 after execution and UF (SR 25405) will be turned on.

Note Refer to page 27 for details on 32-bit signed binary data.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


EQ: ON when the content of S+1, S is 0000 0000; otherwise OFF.

UF: ON when the content of S+1, S is 8000 0000; otherwise OFF.


N: ON when bit 15 of R+1 is set to 1; otherwise OFF.

Example

The following example shows how to use NEGL(—) to find the 2's complement of the hexadecimal value in LR 21, LR 20 (001F FFFF) and output the result to DM 0021, DM 0020.



Address	Instruction	Operands	
00000	LD		00000
00001	NEGL()		
		LR	20
		DM	0020



5-19 BCD Calculations

The BCD calculation instructions – INC(38), DEC(39), ADD(30), ADDL(54), SUB(31), SUBL(55), MUL(32), MULL(56), DIV(33), DIVL(57), FDIV(79), and ROOT(72) – all perform arithmetic operations on BCD data.

For INC(38) and DEC(39) the source and result words are the same. That is, the content of the source word is overwritten with the instruction result. All other instructions change only the content of the words in which results are placed, i.e., the contents of source words are the same before and after execution of any of the other BCD calculation instructions.


STC(40) and CLC(41), which set and clear the carry flag, are included in this group because most of the BCD operations make use of the Carry Flag (CY) in their results. Binary calculations and shift operations also use CY.


The addition and subtraction instructions include CY in the calculation as well as in the result. Be sure to clear CY if its previous status is not required in the calculation, and to use the result placed in CY, if required, before it is changed by execution of any other instruction.

5-19-1 **INCREMENT – INC(38)**

Ladder Symbols

Operand Data Areas





Description

When the execution condition is OFF, INC(38) is not executed. When the execution condition is ON, INC(38) increments Wd, without affecting Carry (CY).

Flags

ER: Wd is not BCD

EQ:


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

ON when the incremented result is 0.

5-19-2 **DECREMENT – DEC(39)**

Ladder Symbols

Operand Data Areas



Wd: Decrement word (BCD)			
IR, SR, AR, DM, HR, LR			

Description

When the execution condition is OFF, DEC(39) is not executed. When the execution condition is ON, DEC(39) decrements Wd, without affecting CY. DEC(39) works the same way as INC(38) except that it decrements the value instead of incrementing it.

Flags

ER: Wd is not BCD


Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the decremented result is 0.

5-19-3 SET CARRY - STC(40)

Ladder Symbols




When the execution condition is OFF, STC(40) is not executed. When the execution condition is ON, STC(40) turns ON CY (SR 25504).

Note Refer to *Appendix C Error and Arithmetic Flag Operation* for a table listing the instructions that affect CY.

5-19-4 **CLEAR CARRY – CLC(41)**

Ladder Symbols



When the execution condition is OFF, CLC(41) is not executed. When the execution condition is ON, CLC(41) turns OFF CY (SR 25504).


CLEAR CARRY is used to reset (turn OFF) CY (SR 25504) to "0."

CY is automatically reset to "0" when END(01) is executed at the end of each cycle.

Note Refer to *Appendix C Error and Arithmetic Flag Operation* for a table listing the instructions that affect CY.

5-19-5 BCD ADD - ADD(30)

Ladder Symbols



Operand Data Areas

Au: Augend word (BCD)			
IR, SR, AR, DM, HR, TC, LR, #			
Ad: Addend word (BCD)			
IR, SR, AR, DM, HR, TC, LR, #			
R: Result word			
IR, SR, AR, DM, HR, LR			

Description

When the execution condition is OFF, ADD(30) is not executed. When the execution condition is ON, ADD(30) adds the contents of Au, Ad, and CY, and places the result in R. CY will be set if the result is greater than 9999.

$$Au + Ad + CY \rightarrow CY R$$

Flags

ER: Au and/or Ad is not BCD.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when there is a carry in the result.

EQ: ON when the result is 0.

Example

If 00002 is ON, the program represented by the following diagram clears CY with CLC(41), adds the content of LR 25 to a constant (6103), places the result in DM 0100, and then moves either all zeros or 0001 into DM 0101 depending on the status of CY (25504). This ensures that any carry from the last digit is preserved in R+1 so that the entire result can be later handled as eight-digit data.




Address	Instruction	Oper	ands
00000	LR		00002
00001	OUT	TR	0
00002	CLC(41)		
00003	ADD(30)		
		LR	25
		#	6103
		DM	0100
00004	AND		25504
00005	MOV(21)		
		#	0001
		DM	0101
00006	LD	TR	0
00007	AND NOT		25504
80000	MOV(21)		
		#	0000
		DM	0101


Although two ADD(30) can be used together to perform eight-digit BCD addition, ADDL(54) is designed specifically for this purpose.

5-19-6 DOUBLE BCD ADD – ADDL(54)

Ladder Symbols



Operand Data Areas




Limitations

Each of the following pairs must be in the same data area: Au and Au+1, Ad and Ad+1, and R and R+1.

Description

When the execution condition is OFF, ADDL(54) is not executed. When the execution condition is ON, ADDL(54) adds the contents of CY to the 8-digit value in Au and Au+1 to the 8-digit value in Ad and Ad+1, and places the result in R and R+1. CY will be set if the result is greater than 99999999.



Flags

ER: Au and/or Ad is not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is


not BCD, or the DM area boundary has been exceeded.)

CY: ON when there is a carry in the result.

EQ: ON when the result is 0.

Example


When 00000 is ON, the following program adds two 12-digit numbers, the first contained in LR 20 through LR 22 and the second in DM 0012. The result is placed in LR 10 through HR 13. In the second addition (using ADD(30)), any carry from the first addition is included. The carry from the second addition is placed in HR 13 by using @ADB(50) (see 5-20-1 BINARY ADD – ADB(50)) with two all-zero constants to indirectly place the content of CY into HR 13.



Address	Instruction	Operands	
00000	LD		00000
00001	CLC(41)		
00002	@ADDL(54)		
		LR	20
		DM	0010
		HR	10
00003	@ADD(30)		
		LR	22
		DM	0012
		HR	12
00004	@ADB(50)		
		#	0000
		#	0000
		HR	13

5-19-7 BCD SUBTRACT – SUB(31)

Ladder Symbols



Operand Data Areas

Mi: Minuend word (BCD)				
IR, SR, AR, DM, HR, TC, LR, #				
Su: Subtrahend word (BCD)				
IR, SR, AR, DM, HR, TC, LR, #				
R: Result word				

IR, SR, AR, DM, HR, LR

Description

When the execution condition is OFF, SUB(31) is not executed. When the execution condition is ON, SUB(31) subtracts the contents of Su and CY from Mi, and places the result in R. If the result is negative, CY is set and the 10's complement of the actual result is placed in R. To convert the 10's complement to the true result, subtract the content of R from zero (see example below).

$$Mi - Su - CY \rightarrow CY R$$

Note The 2's COMPLEMENT – NEG(—) instruction can be used to convert binary data only, it cannot be used with BCD data.

Flags

ER: Mi and/or Su is not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when the result is negative, i.e., when Mi is less than Su plus CY.

EQ: ON when the result is 0.

∠! Caution

Be sure to clear the carry flag with CLC(41) before executing SUB(31) if its previous status is not required, and check the status of CY after doing a subtraction with SUB(31). If CY is ON as a result of executing SUB(31) (i.e., if the result is negative), the result is output as the 10's complement of the true answer. To convert the output result to the true value, subtract the value in R from 0.


Example

When 00002 is ON, the following ladder program clears CY, subtracts the contents of DM 0100 and CY from the content of 010 and places the result in HR 20.

If CY is set by executing SUB(31), the result in HR 20 is subtracted from zero (note that CLC(41) is again required to obtain an accurate result), the result is placed back in HR 20, and HR 2100 is turned ON to indicate a negative result.

If CY is not set by executing SUB(31), the result is positive, the second subtraction is not performed, and HR 2100 is not turned ON. HR 2100 is programmed as a self-maintaining bit so that a change in the status of CY will not turn it OFF when the program is recycled.

In this example, differentiated forms of SUB(31) are used so that the subtraction operation is performed only once each time 00002 is turned ON. When another subtraction operation is to be performed, 00002 will need to be turned OFF for at least one cycle (resetting HR 2100) and then turned back ON.



Address	Instruction	Oper	ands
00000	LD		00002
00001	OUT	TR	0
00002	CLC(41)		
00003	@SUB(31)		
			010
		DM	0100
		HR	20
00004	AND		25504
00005	CLC(41)		
00006	@SUB(31)		
		#	0000
		HR	20
		HR	20
00007	LD	TR	0
80000	AND		25504
00009	OR	HR	2100
00010	OUT	HR	2100

The first and second subtractions for this diagram are shown below using example data for 010 and DM 0100.

Note The actual SUB(31) operation involves subtracting Su and CY from 10,000 plus Mi. For positive results the leftmost digit is truncated. For negative results the 10s complement is obtained. The procedure for establishing the correct answer is given below.

First Subtraction

IR 010 1029
DM 0100 - 3452
CY - 0
HR 20 7577 (1029 + (10000 - 3452))
CY 1 (negative result)


Second Subtraction

0000 HR 20 -7577 <u>CY -0</u> HR 20 2423 (0000 + (10000 - 7577)) CY 1 (negative result)

In the above case, the program would turn ON HR 2100 to indicate that the value held in HR 20 is negative.

5-19-8 DOUBLE BCD SUBTRACT - SUBL(55)

Ladder Symbols



Operand Data Areas


Mi: First minuend word (BCD)				
IR, SR, AR, DM, HR, TC, LR				
Su: First subtrahend word (BCD)				
IR, SR, AR, DM, HR, TC, LR				
R: First result word				
IR, SR, AR, DM, HR, LR				

Limitations

Each of the following pairs must be in the same data area: Mi and Mi+1, Su and Su+1, and R and R+1.

Description

When the execution condition is OFF, SUBL(55) is not executed. When the execution condition is ON, SUBL(55) subtracts CY and the 8-digit contents of Su and Su+1 from the 8-digit value in Mi and Mi+1, and places the result in R and R+1. If the result is negative, CY is set and the 10's complement of the actual result is placed in R. To convert the 10's complement to the true result, subtract the content of R from zero. Since an 8-digit constant cannot be directly entered, use the BSET(71) instruction (see 5-16-3 BLOCK SET – BSET(71)) to create an 8-digit constant.



Note The DOUBLE 2's COMPLEMENT – NEGL(—) instruction can be used to convert binary data only, it cannot be used with BCD data.

Flags

ER: Mi, M+1,Su, and Su+1 are not BCD.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when the result is negative, i.e., when Mi is less than Su.

EQ: ON when the result is 0.

The following example works much like that for single-word subtraction. In this example, however, BSET(71) is required to clear the content of DM 0000 and DM 0001 so that a negative result can be subtracted from 0 (inputting an 8-digit constant is not possible).

Example




Address	Instruction	Ope	rands
00000	LD		00003
00001	OUT	TR	0
00002	CLC(41)		
00003	@SUBL(55)		
		HR	20
			120
		DM	0100
00004	AND		25504
00005	@BSET(71)		
		#	0000
		DM	0000
		DM	0001

Address	Instruction	Operands	
00006	CLC(41)		
00007	@SUBL(55)		
		DM	0000
		DM	0100
		DM	0100
80000	LD	TR	0
00009	AND		25504
00010	OR	HR	2100
00011	OUT	HR	2100

5-19-9 BCD MULTIPLY - MUL(32)

Ladder Symbols



Operand Data Areas

Md: Multiplicand (BCD)		
IR, SR, AR, DM, HR, TC, LR, #		
Mr: Multiplier (BCD)		
IR, SR, AR, DM, HR, TC, LR, #		
R: First result word		
IR, SR, AR, DM, HR LR		

Limitations

R and R+1 must be in the same data area.

Description

When the execution condition is OFF, MUL(32) is not executed. When the execution condition is ON, MUL(32) multiplies Md by the content of Mr, and places the result In R and R+1.




Example

When IR 00000 is ON with the following program, the contents of IR 013 and DM 0005 are multiplied and the result is placed in HR 07 and HR 08. Example data and calculations are shown below the program.



Address	Instruction	Oper	ands
00000	LD		00000
00001	MUL(32)		
			013
		DM	00005
		HR	07



Flags

ER: Md and/or Mr is not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


EQ: ON when the result is 0.

5-19-10 DOUBLE BCD MULTIPLY - MULL(56)

Ladder Symbols

MULL(56) Md Mr Mr R

Operand Data Areas



Limitations

Md and Md+1 must be in the same data area, as must Mr and Mr+1.

R through R+3 must be in the same data area.

Description

When the execution condition is OFF, MULL(56) is not executed. When the execution condition is ON, MULL(56) multiplies the eight-digit content of Md and Md+1 by the content of Mr and Mr+1, and places the result in R to R+3.



Flags

ER: Md, Md+1,Mr, or Mr+1 is not BCD.


Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

5-19-11 BCD DIVIDE – DIV(33)

Ladder Symbol



Operand Data Areas


Dd : Dividend word (BCD)		
IR, SR, AR, DM, HR, TC, LR, #		
Dr : Divisor word (BCD)		
IR, SR, AR, DM, HR, TC, LR, #		
R: First result word (BCD)		
IR, SR, AR, DM, HR, LR		

Limitations

R and R+1 must be in the same data area.

Description

When the execution condition is OFF, DIV(33) is not executed and the program moves to the next instruction. When the execution condition is ON, Dd is divided by Dr and the result is placed in R and R + 1: the quotient in R and the remainder in R + 1.



Flags

ER: Dd or Dr is not in BCD or when Dr is #0000.


Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

Example


When IR 00000 is ON with the following program, the content of IR 020 is divided by the content of HR 09 and the result is placed in DM 0017 and DM 0018. Example data and calculations are shown below the program.



Address	Instruction	Opera	ands
00000	LD		00000
00001	DIV(33)		
			020
		HR	09
		DM	0017

5-19-12 DOUBLE BCD DIVIDE - DIVL(57)

Ladder Symbols



Operand Data Areas

Dd : First dividend word (BCD)		
IR, SR, AR, DM, HR, TC, LR		
Dr : First divisor word (BCD)		
IR, SR, AR, DM, HR, TC, LR		
R: First result word		
IR, SR, AR, DM, HR, LR		


Limitations

Dd and Dd+1 must be in the same data area, as must Dr and Dr+1.

R through R+3 must be in the same data area.

Description

When the execution condition is OFF, DIVL(57) is not executed. When the execution condition is ON, DIVL(57) the eight-digit content of Dd and D+1 is divided by the content of Dr and Dr+1 and the result is placed in R to R+3: the quotient in R and R+1, the remainder in R+2 and R+3.



Flags

ER: Dr and Dr+1 contain 0.

Dd, Dd+1, Dr, or Dr+1 is not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

5-19-13 FLOATING POINT DIVIDE - FDIV(79)

Ladder Symbols

FDIV(79) @FDIV(79) Dd Dd Dr Dr R R

Operand Data Areas

Dd : First dividend word (BCD)
IR, SR, AR, DM, HR, TC, LR
Dr : First divisor word (BCD)
IR, SR, AR, DM, HR, TC, LR
R: First result word
IR, SR, AR, DM, HR, LR


Limitations

Dr and Dr+1 cannot contain zero. Dr and Dr+1 must be in the same data area, as must Dd and Dd+1; R and R+1.


The dividend and divisor must be between 0.0000001×10^{-7} and 0.9999999×10^{7} . The results must be between 0.1×10^{-7} and 0.99999999×10^{7} .

Description

When the execution condition is OFF, FDIV(79) is not executed. When the execution condition is ON, FDIV(79) divides the floating-point value in Dd and Dd+1 by that in Dr and Dr+1 and places the result in R and R+1.



To represent the floating point values, the rightmost seven digits are used for the mantissa and the leftmost digit is used for the exponent, as shown below. The mantissa is expressed as a value less than one, i.e., to seven decimal places.



Flags ER: Dr and Dr+1 contain 0.

Dd, Dd+1, Dr, or Dr+1 is not BCD.

The result is not between 0.1×10^{-7} and 0.999999×10^{7} .


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

Example

The following example shows how to divide two whole four-digit numbers (i.e., numbers without fractions) so that a floating-point value can be obtained.

First the original numbers must be placed in floating-point form. Because the numbers are originally without decimal points, the exponent will be 4 (e.g., 3452 would equal 0.3452×10^4). All of the moves are to place the proper data into consecutive words for the final division, including the exponent and zeros. Data movements for Dd and Dd+1 are shown at the right below. Movements for Dr and Dr+1 are basically the same. The original values to be divided are in DM 0000 and DM 0001. The final division is also shown.



Address	Instruction	Operands	
00000	LD		00000
00001	@MOV(21)		
		#	0000
		HR	00
00002	@MOV(21)		
		#	0000
		HR	02
00003	@MOV(21)		
		#	4000
		HR	01
00004	@MOV(21)		
		#	4000
		HR	03
00005	@MOVD(83)		
		DM	0000
		#	0021
		HR	01

Address	Instruction	Operands	
00006	@MOVD(83)		
		DM	0000
		#	0300
		HR	00
00007	@MOVD(83)		
		DM	0001
		#	0021
		HR	03
80000	@MOVD(83)		
		DM	0001
		#	0300
		HR	02
00009	@FDIV(79)		
		HR	00
		HR	02
		DM	0002

BCD Calculations Section 5-19

5-19-14 SQUARE ROOT - ROOT(72)

Ladder Symbols

ROOT(72) @ROOT(72) Sq Sq R

Operand Data Areas


Sq: First source word (BCD)
IR, SR, AR, DM, HR, TC, LR
R: Result word
IR, SR, AR, DM, HR, LR,

Limitations

Description

Sq and Sq+1 must be in the same data area.

When the execution condition is OFF, ROOT(72) is not executed. When the execution condition is ON, ROOT(72) computes the square root of the eight-digit content of Sq and Sq+1 and places the result in R. The fractional portion is truncated.



Flags

ER: Sq or Sq+1 is not BCD.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.


Example

The following example shows how to take the square root of a four-digit number and then round the result.

First the words to be used are cleared to all zeros and then the value whose square root is to be taken is moved to Sq+1. The result, which has twice the number of digits required for the answer (because the number of digits in the original value was doubled), is placed in DM 0102, and the digits are split into two different words, the leftmost two digits to IR 011 for the answer and the rightmost two digits to DM 0103 so that the answer in IR 011 can be rounded up if required. The last step is to compare the value in DM 0103 so that IR 011 can be incremented using the Greater Than flag.

BCD Calculations Section 5-19

In this example, $\sqrt{6017} = 77.56$, and 77.56 is rounded off to 78.



Address	Instruction	Operands	
00000	LD		00000
00001	@BSET(71)		
		#	0000
		DM	0100
		DM	0101
00002	@MOV(21)		
			010
		DM	0101
00003	@ROOT(72)		
		DM	0100
		DM	0102
00004	@MOV(21)		
		#	0000
			011
00005	@MOV(21)		
		#	0000
		DM	0103

Address	Instruction	Operands	
00006	@MOVD(83)		
		DM	0102
		#	0012
			011
00007	@MOVD(83)		
		DM	0102
		#	0210
		DM	0103
80000	@CMP(20)		
		DM	0103
		#	4900
00009	LD	25505	
00010	@INC(38)		
			011

5-20 Binary Calculations

Binary calculation instructions — ADB(50), SBB(51), MLB(52), DVB(53), ADBL(—), SBBL(—), MBS(—), MBSL(—), DBS(—), and DBSL(—) — perform arithmetic operations on hexadecimal data.


Four of these instructions (ADB(50), SBB(51), ADBL(—), and SBBL(—)) can act on both normal and signed data, two (MLB(52) and DVB(53)) act only on normal data, and four (MBS(—), MBSL(—), DBS(—), and DBSL(—)) act only on signed binary data.

The addition and subtraction instructions include CY in the calculation as well as in the result. Be sure to clear CY if its previous status is not required in the calculation, and to use the result placed in CY, if required, before it is changed by the execution of any other instruction. STC(40) and CLC(41) can be used to control CY. Refer to *5-19 BCD Calculations*.

Signed binary addition and subtraction instructions use the underflow and overflow flags (UF and OF) to indicate whether the result exceeds the acceptable range for 16-bit or 32-bit signed binary data. Refer to page 27 for details on signed binary data.

5-20-1 BINARY ADD - ADB(50)

Ladder Symbols



Operand Data Areas

Au: Augend word (binary)
IR, SR, AR, DM, HR, TC, LR, #
Ad: Addend word (binary)
IR, SR, AR, DM, HR, TC, LR, #
R: Result word
IR, SR, AR, DM, HR, LR

Description

When the execution condition is OFF, ADB(50) is not executed. When the execution condition is ON, ADB(50) adds the contents of Au, Ad, and CY, and places the result in R. CY will be set if the result is greater than FFFF.

$$Au + Ad + CY \rightarrow CY R$$

ADB(50) can also be used to add signed binary data. The overflow and underflow flags (SR 25404 and SR 25405) indicate whether the result has exceeded the lower or upper limits of the 16-bit signed binary data range. Refer to page 27 for details on signed binary data.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when the result is greater than FFFF.

EQ: ON when the result is 0.


OF: ON when the result exceeds +32,767 (7FFF).

UF: ON when the result is below -32,768 (8000).

N: ON when bit 15 of the result is set to 1.


Example 1: Adding Normal Data

The following example shows a four-digit addition with CY used to place either #0000 or #0001 into R+1 to ensure that any carry is preserved.



Address	Instruction	Operands	
00000	LD		00000
00001	OUT	TR	0
00002	CLC(41)		
00003	ADB(50)		
			010
		DM	0100
		HR	10
00004	AND NOT		25504
00005	MOV(21)		
		#	0000
		HR	11
00006	LD	TR	0
00007	AND		25504
80000	MOV(21)		
		#	00001
		HR	11

In the case below, A6E2 + 80C5 = 127A7. The result is a 5-digit number, so CY (SR 25504) = 1, and the content of R + 1 becomes #0001.




Note The UF and OF flags would also be turned ON during this addition, but they can be ignored since they are relevant only in the addition of signed binary data.

Example 2: Adding Signed Binary Data


In the following example, ADB(50) is used to add two 16-bit signed binary values. (The 2's complement is used to express negative values.)

The effective range for 16-bit signed binary values is -32,768 (8000) to +32,768 (7FFF). The overflow flag (OF: SR 25404) is turned ON if the result exceeds +32,767 (7FFF) and the underflow flag (UF: SR 25405) is turned ON if the result falls below -32,768 (8000).




Address	Instruction	Oper	ands
00000	LD		00000
00001	CLC(41)		
00002	ADB(50)		
		LR	20
		DM	0010
		DM	0020


In the case below, 25,321 + (-13,253) = 12,068 (62E9 + CC3B = 2F24). Neither OF nor UF are turned ON.



Note The status of the CY flag can be ignored when adding signed binary data since it is relevant only in the addition of normal hexadecimal values.

5-20-2 BINARY SUBTRACT - SBB(51)





Operand Data Areas

Mi: Minuend word (binary)
IR, SR, AR, DM, HR, TC, LR, #
Su: Subtrahend word (binary)
IR, SR, AR, DM, HR, TC, LR, #
R: Result word
IR, SR, AR, DM, HR, LR

Description

When the execution condition is OFF, SBB(51) is not executed. When the execution condition is ON, SBB(51) subtracts the contents of Su and CY from Mi and places the result in R. If the result is negative, CY is set and the 2's complement of the actual result is placed in R.

$$Mi$$
 – Su – CY — CY R

SBB(51) can also be used to subtract signed binary data. The overflow and underflow flags (SR 25404 and SR 25405) indicate whether the result has exceeded the lower or upper limits of the 16-bit signed binary data range. Refer to page 27 for details on signed binary data.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when the result is negative, i.e., when Mi is less than Su plus CY.

EQ: ON when the result is 0.


OF: ON when the result exceeds +32,767 (7FFF).

UF: ON when the result is below -32,768 (8000).

N: ON when bit 15 of the result is set to 1.


Example 1: Normal Data

The following example shows a four-digit subtraction with CY used to place either #0000 or #0001 into R+1 to ensure that any carry is preserved.



In the case below, the content of LR 20 (#7A03) and CY are subtracted from IR 001 (#F8C5). The result is stored in HR 21 and the content of HR 22 (#0000) indicates that the result is positive.

If the result had been negative, CY would have been set, #0001 would have been placed in HR 22, and the result would have been converted to its 2's compliment.




Note The status of the UF and OF flags can be ignored since they are relevant only in the subtraction of signed binary data.

Example 2: Signed Binary Data


In the following example, SBB(51) is used to subtract one 16-bit signed binary value from another. (The 2's complement is used to express negative values).

The effective range for 16-bit signed binary values is -32,768 (8000) to +32,767 (7FFF). The overflow flag (OF: SR 25404) is turned ON if the result exceeds +32,767 (7FFF) and the underflow flag (UF: SR 25405) is turned ON if the result falls below -32,768 (8000).




Address	Instruction	Opera	ands
00000	LD		00000
00001	CLC(41)		
00002	SBB(51)		
		LR	20
		DM	0010
		DM	0020

In the case shown below, 30,020 - (-15,238) = 45,258 (7544 - C47A = 60CA). The OF flag would be turned ON to indicate that this result exceeds the upper limit of the 16-bit signed binary data range. (In other words, the result is a positive value that exceeds 32,767 (7FFF), not a negative number expressed as signed binary data.)



In the case shown below, -30,000 - 3,000 = -33,000 (8AD0 - 0BB8 = 7F18). The UF flag would be turned ON to indicate that this result is below the lower limit of 16-bit signed binary data range. (In other words, the result is a negative number below -32,768 (8000), not a positive number expressed as signed binary data.)




The absolute value of the true result (80E8=33,000) can be obtained by taking the 2's complement of 7F18 using NEG(—).

Note The status of the CY flag can be ignored when adding signed binary data since it is relevant only in the addition of normal hexadecimal values.

5-20-3 BINARY MULTIPLY - MLB(52)

Ladder Symbols



Operand Data Areas


Md: Multiplicand word (binary)
IR, SR, AR, DM, HR, TC, LR, #
Mr: Multiplier word (binary)
IR, SR, AR, DM, HR, TC, LR, #
R: First result word
IR, SR, AR, DM, HR LR

Limitations

Description

R and R+1 must be in the same data area.

When the execution condition is OFF, MLB(52) is not executed. When the execution condition is ON, MLB(52) multiplies the content of Md by the contents of Mr, places the rightmost four digits of the result in R, and places the leftmost four digits in R+1.



Precautions

MLB(52) cannot be used to multiply signed binary data. Use MBS(—) instead. Refer to 5-20-7 SIGNED BINARY MULTIPLY – MBS(—) for details.

Flags


ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.


N: ON when bit 15 of R+1 is set to 1.

5-20-4 BINARY DIVIDE - DVB(53)

Ladder Symbols




Operand Data Areas



Description

When the execution condition is OFF, DVB(53) is not executed. When the execution condition is ON, DVB(53) divides the content of Dd by the content of Dr and the result is placed in R and R+1: the quotient in R, the remainder in R+1.



Precautions

DVB(53) cannot be used to divide signed binary data. Use DBS(—) instead. Refer to 5-20-9 SIGNED BINARY DIVIDE – DBS(—) for details.

Flags

ER: Dr contains 0.

Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)


EQ: ON when the result is 0.

N: ON when bit 15 of R is set to 1.

Example



Address	Instruction	Operands	
00000	LD		00000
00001	DVB(53)		
			001
		LR	0020
		HR	05




	R+1: HR 06			R: HR 05		
0	0	0	2	0 5 A		7

Remainder (2)

Quotient (1447)

5-20-5 DOUBLE BINARY ADD – ADBL(—)

Ladder Symbols



Operand Data Areas

Au: First augend word (binary)

IR, SR, AR, DM, HR, LR

Ad: First addend word (binary)

IR, SR, AR, DM, HR, LR

R: First result word


IR, SR, AR, DM, HR, LR

Limitations

Au and Au+1 must be in the same data area, as must Ad and Ad+1, and R and R+1.

Description

When the execution condition is OFF, ADBL(—) is not executed. When the execution condition is ON, ADBL(—)) adds the eight-digit contents of Au+1 and Au, the eight-digit contents of Ad+1 and Ad, and CY, and places the result in R and R+1. CY will be set if the result is greater than FFFF FFFF.



ADBL(—) can also be used to add signed binary data. The overflow and underflow flags (SR 25404 and SR 25405) indicate whether the result has exceeded the lower or upper limits of the 32-bit signed binary data range. Refer to page 27 for details on signed binary data.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when the result is greater than FFFF FFFF.

EQ: ON when the result is 0.


OF: ON when the result exceeds +2,147,483,647 (7FFF FFFF).

UF: ON when the result is below -2,147,483,648 (8000 0000).

N: ON when bit 15 of R is set to 1.


Example 1: Normal Data

The following example shows an eight-digit addition with CY (SR 25504) used to represent the status of the 9th digit.



Address	Instruction	Opera	ands
00000	LD		00000
00001	CLC(41)		
00002	ADBL()		
			000
		DM	0020
		LR	21

14020187 + 00A3F8C5 = 14A5FA4C




Note The status of the UF and OF flags can be ignored since they are relevant only in the addition of signed binary data.

Example 2: Signed Binary Data


In the following example, ADBL(—) is used to add two 32-bit signed binary values and output the 32-bit signed binary result to R and R+1. (The 2's complement is used to express negative values).

The effective range for 32-bit signed binary values is -2,147,483,648 (8000 0000) to +2,147,483,647 (7FFF FFFF). The overflow flag (OF: SR 25404) is turned ON if the result exceeds +2,147,483,647 (7FFF FFFF) and the underflow flag (UF: SR 25405) is turned ON if the result falls below -2,147,483,648 (8000 0000).



Address	Instruction	Opera	ands
00000	LD		00000
00001	CLC(41)		
00002	ADBL()		
		LR	20
		DM	0010
		DM	0020


In the case below, 1,799,100,099 + (-282,751,929) = 1,516,348,100 (6B3C167D + EF258C47 = 5A61A2C4). Neither OF nor UF are turned ON.




Note The status of the CY flag can be ignored when adding signed binary data since it is relevant only in the addition of normal hexadecimal values.

5-20-6 DOUBLE BINARY SUBTRACT - SBBL(---)








Limitations

Mi and Mi+1 must be in the same data area, as must Su and Su+1, and R and R+1

Description

When the execution condition is OFF, SBBL(—) is not executed. When the execution condition is ON, SBBL(—) subtracts CY and the eight-digit value in Su and Su+1 from the eight-digit value in Mi and Mi+1, and places the result in R and R+1. If the result is negative, CY is set and the 2's complement of the actual result is placed in R+1 and R. Use the DOUBLE 2's COMPLEMENT instructions to convert the 2's complement to the true result.



SBBL(—) can also be used to subtract signed binary data. The overflow and underflow flags (SR 25404 and SR 25405) indicate whether the result has exceeded the lower or upper limits of the 32-bit signed binary data range. Refer to page 27 for details on signed binary data.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

CY: ON when the result is negative, i.e., when Mi is less than Su plus CY.

EQ: ON when the result is 0.


OF: ON when the result exceeds +2,147,483,647 (7FFF FFFF).

UF: ON when the result is below –2,147,483,648 (8000 0000).

N: ON when bit 15 of R+1 is set to 1.


Example 1: Normal Data

In this example, the eight-digit number in IR 002 and IR 001 is subtracted from the eight-digit number in DM 0021 and DM 0020, and the result is output to LR 22 and LR 21. If the result is negative, CY (SR 25504) is turned ON.



Address	Instruction	Opera	ands
00000	LD		00000
00001	CLC(41)		
00002	SBBL(—)		
			001
		DM	0020
		LR	21

14020187 + 00A3F8C5 = 14A5FA4C




Note The status of the UF and OF flags can be ignored since they are relevant only in the subtraction of signed binary data.

Example 2: Signed Binary Data

In the following example, SBBL(—) is used to subtract one 32-bit signed binary value from another and output the 32-bit signed binary result to R and R+1.


The effective range for 32-bit signed binary values is -2,147,483,648 (8000 0000) to +2,147,483,647 (7FFF FFFF). The overflow flag (OF: SR 25404) is turned ON if the result exceeds +2,147,483,647 (7FFF FFFF) and the underflow flag (UF: SR 25405) is turned ON is the result falls below -2,147,483,648 (8000 0000).



Address	Instruction	Opera	ands
00000	LD		00000
00001	CLC(41)		
00002	SBBL(—)		
			001
		DM	0020
		LR	21


Section 5-20 Binary Calculations


> In the case below, 1,799,100,099 - (-282,751,929) = 2,081,851,958(6B3C 167D - {EF25 8C47 - 1 0000 0000} = 7C16 8A36). Neither OF nor UF are turned ON.



Note The status of the CY flag can be ignored when adding signed binary data since it is relevant only in the addition of normal hexadecimal values.

5-20-7 SIGNED BINARY MULTIPLY - MBS(---)





Operand Data Areas

Md: Multiplicand word
IR, SR, AR, DM, HR, TC, LR, #
Mr: Multiplier word
IR, SR, AR, DM, HR, TC, LR, #
R: First result word
IR, SR, AR, DM, HR LR

Limitations

R and R+1 must be in the same data area.

Description

MBS(---) multiplies the signed binary content of two words and outputs the 8-digit signed binary result to R+1 and R. The rightmost four digits of the result are placed in R, and the leftmost four digits are placed in R+1. Refer to page 27 for details on signed binary data.



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0000 0000, otherwise OFF.


N: ON when bit 15 of R+1 is set to 1.

Example

In the following example, MBS(—) is used to multiply the signed binary contents of IR 001 with the signed binary contents of DM 0020 and output the result to LR 21 and LR 22.




Address	Instruction	Opera	ands
00000	LD		00000
00001	MBS(—)		
			001
		DM	0020
		LR	21




5-20-8 DOUBLE SIGNED BINARY MULTIPLY – MBSL(—)

Ladder Symbols








Limitations

Md and Md+1 must be in the same data area, as must Mr and Mr+1, and R through R+3.

Description

MBSL(—) multiplies the 32-bit (8-digit) signed binary data in Md+1 and Md with the 32-bit signed binary data in Mr+1 and Mr, and outputs the 16-digit signed binary result to R+3 through R. Refer to page 27 for details on signed binary data.



Flags


ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is zero (content of R+3 through R all zeroes), otherwise OFF.


N: ON when bit 15 of R+3 is set to 1.

Example

In the following example, MBSL(—) is used to multiply the signed binary contents of IR 101 and IR 100 with the signed binary contents of DM 0021 and DM 0020 and output the result to LR 24 through LR 21.




Address	Instruction	Opera	ands
00000	LD		00000
00001	MBSL()		
			100
		DM	0020
		LR	21




5-20-9 SIGNED BINARY DIVIDE - DBS(---)





Operand Data Areas




Limitations

R and R+1 must be in the same data area.

Description

DBS(—) divides the signed binary content of Dd by the signed binary content of Dr, and outputs the 8-digit signed binary result to R+1 and R. The quotient is placed in R, and the remainder is placed in R+1. Refer to page 27 for details on signed binary data.



Flags

ER: Dr contains 0.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the content of R (the quotient) is 0000, otherwise OFF.


N: ON when bit 15 of R is set to 1.

Example

In the following example, DBS(—) is used to divide the signed binary contents of IR 001 with the signed binary contents of DM 0020 and output the result to LR 21 and LR 22.




Address	Instruction	Opera	ands
00000	LD		00000
00001	DBS(—)		
			001
		DM	0020
		LR	21




5-20-10 DOUBLE SIGNED BINARY DIVIDE - DBSL(--)

Ladder Symbols



Operand Data Areas



Limitations

Dd and Dd+1 must be in the same data area, as must Dr and Dr+1, and R through R+3.

Description

DBS(—) divides the 32-bit (8-digit) signed binary data in Dd+1 and Dd by the 32-bit signed binary data in Dr+1 and Dr, and outputs the 16-digit signed binary result to R+3 through R. The quotient is placed in R+1 and R, and the remainder is placed in R+3 and R+2. Refer to page 27 for details on signed binary data.

Remainder			Quo	tient		
R+3		R+2		R+1	R	
Dr+1	Dr			Dd+1	Dd	
	•		_			-

Flags

ER: Dr+1 and Dr contain 0.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the content of R+1 and R (the quotient) is 0, otherwise OFF.


N: ON when bit 15 of R+1 is set to 1.

Example

In the following example, DBSL(—) is used to divide the signed binary contents of IR 002 and IR 001 with the signed binary contents of DM 0021 and DM 0020 and output the result to LR 24 through LR 21.





Address	Instruction	Opera	ınds
00000	LD		00000
00001	DBSL()		
			001
		DM	0020
		LR	21



5-21 Special Math Instructions

5-21-1 FIND MAXIMUM – MAX(—)





Operand Data Areas

C: Control data
IR, SR, AR, DM, HR, LR, #
R ₁ : First word in range
IR, SR, AR, DM, HR, TC, LR
D: Destination word
IR, SR, AR, DM, HR, LR

Limitations

N in C must be BCD between 001 to 999.

 R_1 and R_1+N-1 must be in the same data area.

Description

When the execution condition is OFF, MAX(—) is not executed. When the execution condition is ON, MAX(—) searches the range of memory from R_1 to R_1+N-1 for the address that contains the maximum value and outputs the maximum value to the destination word (D).


If bit 14 of C is ON, MAX(—) identifies the address of the word containing the maximum value in D+1. The address is identified differently for the DM area:

- 1, 2, 3...
 1. For an address in the DM area, the word address is written to D+1. For example, if the address containing the maximum value is DM 0114, then #0114 is written in D+1.
 - 2. For an address in another data area, the number of addresses from the beginning of the search is written to D+1. For example, if the address containing the maximum value is IR 114 and the first word in the search range is IR 014, then #0100 is written in D+1.

If bit 15 of C is ON and more than one address contains the same maximum value, the position of the lowest of the addresses will be output to D+1.

The number of words within the range (N) is contained in the 3 rightmost digits of C, which must be BCD between 001 and 999.

When bit 15 of C is OFF, data within the range is treated as normal binary and when it is ON the data is treated as signed binary.



∕!\ Caution

If bit 14 of C is ON, values above #8000 are treated as negative numbers, so the results will differ depending on the specified data type. Be sure that the correct data type is specified.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

The number of words specified in C is not BCD (000 to 999).


 R_1 and R_1+N-1 are not in the same data area.

EQ: ON when the maximum value is #0000.

N: ON when bit 15 of D is set to 1.

5-21-2 **FIND MINIMUM – MIN(—)**

Ladder Symbols



Operand Data Areas

C: Control data
IR, SR, AR, DM, HR, LR, #
R ₁ : First word in range
IR, SR, AR, DM, HR, TC, LR
D: Destination word
IR, SR, AR, DM, HR, LR

Limitations

N in C must be BCD between 001 to 999.

 R_1 and R_1+N-1 must be in the same data area.

Description

When the execution condition is OFF, MIN(—) is not executed. When the execution condition is ON, MIN(—) searches the range of memory from R_1 to R_1+N-1 for the address that contains the minimum value and outputs the minimum value to the destination word (D).

If bit 14 of C is ON, MIN(—) identifies the address of the word containing the minimum value in D+1. The address is identified differently for the DM area:


1, 2, 3...
 1. For an address in the DM area, the word address is written to D+1. For example, if the address containing the minimum value is DM 0114, then #0114 is written in D+1.

2. For an address in another data area, the number of addresses from the beginning of the search is written to D+1. For example, if the address containing the minimum value is IR 114 and the first word in the search range is IR 014, then #0100 is written in D+1.

If bit 14 of C is ON and more than one address contains the same minimum value, the position of the lowest of the addresses will be output to D+1.

The number of words within the range (N) is contained in the 3 rightmost digits of C, which must be BCD between 001 and 999.

When bit 15 of C is OFF, data within the range is treated as unsigned binary and when it is ON the data is treated as signed binary. Refer to page 27 for details on signed binary data.



∕! Caution

If bit 14 of C is ON, values above #8000 are treated as negative numbers, so the results will differ depending on the specified data type. Be sure that the correct data type is specified.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

The number of words specified in C is not BCD (000 to 999).

R₁ and R₁+N-1 are not in the same data area.

EQ: ON when the minimum value is #0000.

N: ON when bit 15 of D is set to 1.

5-21-3 AVERAGE VALUE - AVG(---)

Ladder Symbols

AVG(—) S N N D D

Operand Data Areas

S: Source word
IR, SR, AR, DM, HR, TC, LR, #
N: Number of cycles
IR, SR, AR, DM, HR, TC, LR, #
D: First destination word
IR, SR, AR, DM, HR, LR

Limitations

Data of S must be hexadecimal.

N must be BCD from #0001 to #0064.

D and D+N+1 must be in the same data area.

Description

AVG(—) is used to calculate the average value of S over N cycles.

When the execution condition is OFF, AVG(—) is not executed.


For the first N-1 cycles when the execution condition is ON, AVG(—) writes the value of S to D. Each time that AVG(—) is executed, the previous value of S is stored in words D+2 to D+N+1. The first 2 digits of D+1 are incremented with each execution and act as a pointer to indicate where the previous value is stored. Bit 15 of D+1 remains OFF for the first N-1 cycles.

On the Nth cycle, the previous value of S is written to last word in the range D+2 to D+N+1. The average value of the previous values stored in D+2 to D+N+1 is calculated and written to D, bit 15 of D+1 is turned ON, and the previous value pointer (the first 2 digits of D+1) is reset to zero. Each time that AVG(—) is executed, the previous value of S overwrites the content of the word indicated by the pointer and the new average value is calculated and written to D. The pointer will be reset again after reaching N-1.

The following diagram shows the function of words D to D+N+1.

D	Average value (after N or more cycles)		
D+1	Previous value pointer and cycle indicator		
D+2	Previous value #1		
D+3	Previous value #2		
:			
D+N+1	Previous value #N		

The function of bits in D+1 are shown in the following diagram and explained in more detail below.



Previous Value Pointer

The previous value pointer indicates the location where the most recent value of S was stored relative to D+2, i.e., a pointer value of 0 indicates D+2, a value of 1 indicates D+3, etc.

Cycle Indicator

The cycle indicator is turned ON after AVG(—) has been executed N times. At this point, D will contain the average value of the contents of words D+2 through D+N+1. The average value is 4-digit hexadecimal and is rounded off to the nearest integer value.


Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

One or more operands have been set incorrectly.

Example

In the following example, the content of IR 040 is set to #0000 and then incremented by 1 each cycle. For the first two cycles, AVG(—) moves the content of IR 040 to DM 1002 and DM 1003. The contents of DM 1001 will also change (which can be used to confirm that the results of AVG(—) has changed). On the third and later cycles AVG(—) calculates the average value of the contents of DM 1002 to DM 1004 and writes that average value to DM 1000.



Address	Instruction	Oper	ands
00000	LD		00001
00001	@MOV(21)		
		#	0000
			040
00002	AVG()		
			040
		#	0003
		DM	1000
00003	CLC(41)		
00004	ADB(50)		
			040
		#	0001
			040

	1 st cycle	2 nd cycle	3 rd cycle	4 th cycle
IR 40	0000	0001	0002	0003

	1 st cycle	2 ^{na} cycle	3 ^{ra} cycle	4 th cycle
DM 1000	0000	0001	0001	0002
DM 1001	0001	0002	8000	8001
DM 1002	0000	0000	0000	0003
DM 1003		0001	0001	0001
DM 1004			0002	0002

Pointer

Average

3 previous values of IR 40

5-21-4 SUM - SUM(---)



SUM(—) C R₁ D C R₁ D

Operand Data Areas

C: Control data		
IR, SR, AR, DM, HR, LR, #		
R ₁ : First word in range		
IR, SR, AR, DM, HR, TC, LR		
D: First destination word		
IR, SR, AR, DM, HR, LR		

Limitations


The 3 rightmost digits of C must be BCD between 001 and 999.

If bit 14 of C is OFF (setting for BCD data), all data within the range R_1 to $R_1 + N - 1$ must be BCD.

Description

When the execution condition is OFF, SUM(—) is not executed. When the execution condition is ON, SUM(—) adds either the contents of words R_1 to R_1+N-1 or the bytes in words R_1 to $R_1+N/2-1$ and outputs that value to the destination words (D and D+1). The data can be summed as binary or BCD and will be output in the same form. Binary data can be either signed or unsigned.

The function of bits in C are shown in the following diagram and explained in more detail below.



Number of Items in Range

The number of items within the range (N) is contained in the 3 rightmost digits of C, which must be BCD between 001 and 999. This number will indicate the number of words or the number of bytes depending the items being summed.

Addition Units

Words will be added if bit 13 is OFF and bytes will be added if bit 13 is ON.

If bytes are specified, the range can begin with the leftmost or rightmost byte of R_1 . The leftmost byte of R_1 will not be added if bit 12 is ON.

	MSI	B LSB
R ₁	1	2
R ₁ +1	3	4
R ₁ +2	5	6
R ₁ +3	7	8

The bytes will be added in this order when bit 12 is OFF: 1+2+3+4....

The bytes will be added in this order when bit 12 is ON: 2+3+4....

Data Type

Data within the range is treated as unsigned binary when bit 14 of C is ON and bit 15 is OFF, and it is treated as signed binary when both bits 14 and 15 are ON. Refer to page 27 for details on signed binary data.

Data within the range is treated as BCD when bit 14 of C is OFF, regardless of the status of bit 15.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

 R_1 and R_1+N-1 are not in the same data area.

The number of items in C is not BCD between 001 and 999.

The data being summed is not BCD when BCD was designated.

EQ: ON when the result is zero.

N: ON when bit 15 of D is set to 1.


Example

In the following example, the BCD contents of the 10 words from DM 0000 to DM 0009 are added when IR 00001 is ON and the result is written to DM 0100 and DM 0101.



Address	Instruction	Oper	ands
00000	LD		00001
00001	@SUM(—)		
		#	4010
		DM	0000
		DM	0100

DM 0000	3F2A
DM 0001	51C3
DM 0002	E02A
DM 0003	7C9F
DM 0004	2A20
DM 0005	A827
DM 0006	2A20
DM 0007	E02A
DM 0008	C755
DM 0009	94DC



5-21-5 ARITHMETIC PROCESS - APR(69)

Ladder Symbols

APR(69) C S D O QAPR(69) D

Operand Data Areas

C: Control word		
IR, SR, AR, DM, HR, TC, LR, #		
S: Input data source word		
IR, SR, AR, DM, HR, TC, LR		
D: Result destination word		
IR, SR, AR, DM, HR,TC, LR		

Limitations

Description

For trigonometric functions S must be BCD from 0000 to 0900 ($0^{\circ} \le \theta \le 90^{\circ}$).

When the execution condition is OFF, APR(69) is not executed. When the execution condition is ON, the operation of APR(69) depends on the control word C.

If C is #0000 or #0001, APR(69) computes $sin(\theta)$ or $cos(\theta)$. The BCD value of S specifies θ in tenths of degrees.

If C is an address, APR(69) computes f(x) of the function entered in advance beginning at word C. The function is a series of line segments (which can approximate a curve) determined by the operator. The BCD or hexadecimal value of S specifies x.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

For trigonometric functions, x > 0900. (x is the content of S.)

A constant other than #0000 or #0001 was designated for C.

The linear approximation data is not readable.


EQ: The result is 0000.

N: ON when bit 15 of D is set to 1.

Examples

Sine Function

The following example demonstrates the use of the APR(69) sine function to calculate the sine of 30° . The sine function is specified when C is #0000.



Address	Instruction	Opera	ands
00000	LD		00000
00001	APR(69)		
		#	0000
		DM	0000
		DM	0100

Input data, x

I	S: DM 0000				
0 10^1 10^0 10^{-1}				10 ⁻¹	
	0	3	0	0	

Enter input data not exceeding #0900 in BCD.

Result data

D: DM 0100				
10 ⁻¹ 10 ⁻² 10 ⁻³ 10 ⁻⁴				
5	0	0	0	

Result data has four significant digits, fifth and higher digits are ignored. The result for sin(90) will be 0.9999, not 1.

Cosine Function

The following example demonstrates the use of the APR(69) cosine function to calculate the cosine of 30°. The cosine function is specified when C is #0001.



Address	Instruction	Opera	ands
00000	LD		00000
00001	APR(69)		
		#	0001
		DM	0010
		DM	0110

Input data, x

S: DM 0010				
0	10 ¹	10 ⁰	10 ⁻¹	
0	3	0	0	

Enter input data not exceeding #0900 in BCD.

Result data


D: DM 0110				
10 ⁻¹ 10 ⁻² 10 ⁻³ 10 ⁻⁴				
8	6	6	0	

Result data has four significant digits, fifth and higher digits are ignored. The result for cos(0) will be 0.9999, not 1.


Linear Approximation

APR(69) linear approximation is specified when C is a memory address. Word C is the first word of the continuous block of memory containing the linear approximation data.

The content of word C specifies the number of line segments in the approximation, and whether the input and output are in BCD or BIN form. Bits 00 to 07 contain the number of line segments less 1, m–1, as binary data. Bits 14 and 15 determine, respectively, the output and input forms: 0 specifies BCD and 1 specifies BIN.




Enter the coordinates of the m+1 end-points, which define the m line segments, as shown in the following table. Enter all coordinates in BIN form. Always enter the coordinates from the lowest X value (X_1) to the highest (X_m) . X_0 is 0000, and does not have to be entered.




Word	Coordinate
C+1	X _m (max. X value)
C+2	Y_0
C+3	X ₁
C+4	Y ₁
C+5	X ₂
C+6	Y ₂
\downarrow	\
C+(2m+1)	X _m
C+(2m+2)	Ym


If bit 13 of C is set to 1, the graph will be reflected from left to right, as shown in the following diagram.




The following example demonstrates the construction of a linear approximation with 12 line segments. The block of data is continuous, as it must be, from DM 0000 to DM 0026 (C to C + $(2 \times 12 + 2)$). The input data is taken from IR 010, and the result is output to IR 011.



Address	Instruction	Opera	ands
00000	LD		00000
00001	APR(69)		
		DM	0000
			010
			011




In this case, the input data word, IR 010, contains #0014, and f(0014) = #0726 is output to R, IR 011.



5-21-6 PID CONTROL – PID(—)

Ladder Symbol



Operand Data Areas

S: Input word		
IR, SR, AR, DM, HR, LR		
C: First parameter word		
IR, SR, DM, HR, LR		
D : Output word		
IR, SR, AR, DM, HR, LR		

Limitations

C and C+32 must be within the same data area.

Note Do not program PID(—) in the following situations. Doing so may produce unexpected behavior: In interrupt programs, in subroutines, between IL(02) and ILC(03), between JMP(04) and JME(05), and in step programming (when using STEP(08) and SNXT(09)).

Description

PID(—) carries out PID control according to the designated parameters. It takes the specified input range of binary data from the contents of input word S and carries out the PID operation according to the parameters that are set. The results are then stored as the operation output amount in output word D.

PID parameter words range from C through C+32. The PID parameters are configured as shown below.

Word	15 to 12	11 to 8	7 to 4	3 to 0
С	Set value (SV)			
C+1	Proportional ba	and (P)		
C+2	Tik = Integral ti	Tik = Integral time T_1 /sampling period γ (See note 1.)		
C+3	Tdk = Derivative time Td/sampling period γ (See note 1.)			
C+4	Sampling period γ			
C+5	2-PID parameter (α) (See note 2.) PID forward/ reverse designation			PID forward/ reverse designation
C+6	0	Input range	Time unit for sampling pe- riod and inte- gral/deriva- tive times	Output range
C+7 to C+32	Work area (Cannot be accessed directly from program.)			

Note

- 1. The actual integral and derivative times are calculated using the values set in C+2 and C+3 and the time unit set in C+6.
- 2. Setting the 2-PID parameter (α) to 000 yields 0.65, the normal value.
- 3. The only CQM1 model that can use PID(—) is the CQM1-CPU4□-EV1.

Performance Specifications

Item			Specifications	
PID calculation	PID calculation method		Target value filter-type, two degrees of freedom (forward/reverse operation)	
Number of PID	control loops		No limit (1 loop per instruction)	
Sampling period		t	0.01 to 102.3 s (See note.)	
PID constants Proportional band P		Р	0.1 to 999.9%	
	Integral constant	Tik	1 to 8191, 9999 (No integral operation for sampling period multiple or 9999.)	
	Derivative constant	Tdk	0 to 8191 (No derivative operation for sampling period multiple.)	
Set value		SV	0 to 65,535 (Valid up to the maximum value of the input range.)	
Measured value P		PV	0 to 65,535 (Valid up to the maximum value of the input range.)	
Operation output amount MV		MV	0 to 65,535 (Valid up to the maximum value of the output range.)	

Note For the C200HS and the CQM1-CPU4□-EV1, the sampling period is 0.1 to 102.3 s.

Parameter Settings

Item	Contents	Setting range
Set value (SV)	This is the target value of the process being controlled.	Binary data (of the same number of bits as specified for the input range)
Proportional band	This is the parameter for P control expressing the proportional control range/total control range.	0001 to 9999 (4 digits BCD); (0.1% to 999.9%, in units of 0.1%)
Integral time (Tik)	This is a constant expressing the strength of the integral operation. As this value increases, the integral strength increases. The time unit parameter determines the setting method.	0001 to 8191 (4 digits BCD); (9999 = No integral operation) 1× to 8191× when time unit = 0 or 1 0.1 to 819.1 s when time unit = 8 0.1 to 81.9 s when time unit = 9 Set to between 1 and 8191 times the
		sampling period when a constant time is used.
Derivative time (Tdk)	This is a constant expressing the strength of the derivative operation. As this value increases, the derivative strength increases.	0001 to 8191 (4 digits BCD); (0000 = No derivative operation)
	The time unit parameter determines the setting method.	1x to 8191x when time unit = 0 or 1 0.1 to 819.1 s when time unit = 8 0.1 to 81.9 s when time unit = 9
		Set to between 1 and 8191 times the sampling period when a constant time is used.
Sampling period	This sets the period for executing the PID operation.	C200HX/HG/HE, CQM1-CPU4□-EV1: 0001 to 1023 (4 digits BCD); (0.1 to 102.3 s, in units of 0.1 s)
		C200HX/HG/HE only: 0001 to 9999 (4 digits BCD); (0.01 to 99.99 s, in units of 0.01 s)
PID forward/reverse designation	This is the parameter that determines the direction of the proportional operation.	0: Reverse operation 1: Forward operation (1 digit BCD)
2-PID parameter (α)	This is the input filter coefficient. Normally use 0.65 (i.e., a setting of 000). The filter efficiency decreases as the coefficient approaches 0.	000: α = 0.65 100 to 199: Rightmost two digits are α , i.e., 0.00 to 0.99. (3 digits BCD)
Input range	This is the number of input data bits.	0: 8 bits 5: 13 bits 1: 9 bits 6: 14 bits 2: 10 bits 7: 15 bits 3: 11 bits 8: 16 bits 4: 12 bits (1 digit BCD)
Time unit for	Specifies the time unit for the sampling period	0, 1, 8, or 9 (1 digit BCD)
sampling period and integral/derivative times	and the method for setting the integral/derivative parameters.	0: Constant time, Unit: 100 ms 1: Constant time, Unit: 10 ms 8: Relative time, Unit: 100 ms 9: Relative time, Unit: 10 ms
Output range	This is the number of output data bits.	Same as the setting range for the input range.

PID CONTROL Operation

Execution Condition OFF

All data that has been set is retained. Then the execution condition is OFF, the operation amount can be written to the output word (D) to achieve manual control.

Rising Edge of the Execution Condition

The work area is initialized based on the PID parameters that have been set and the PID control operation is begin. Sudden and radical changes in the operation output amount are not made when starting operation to avoid adverse affect on the controlled system (bumpless operation).

When PID parameters are changed, they first become valid when the execution condition changes from OFF to ON.

Execution Condition ON

The PID operation is executed at the intervals based on the sampling period, according to the PID parameters that have been set.


Sampling Period and PID Execution Timing

The sampling period is the time interval to retrieve the measurement data for carrying out a PID operation. PID(—), however, is executed according to the CPU Unit's sampling time, so there may be cases where the sampling period is exceeded. In such cases, the time interval until the next sampling is reduced.


PID Control Method

PID control operations are executed by means of PID control with feed-forward control (two degrees of freedom).

When overshooting is prevented with simple PID control, stabilization of disturbances is slowed (1). If stabilization of disturbances is speeded up, on the other hand, overshooting occurs and response toward the target value is slowed (2). With feed-forward PID control, there is no overshooting, and response toward the target value and stabilization of disturbances can both be speeded up (3).



Feed-forward PID control




Control Operations


Proportional Operation (P)

Proportional operation is an operation in which a proportional band is established with respect to the set value (SV), and within that band the operation amount (the control output amount) is made proportional to the deviation. If the present value (PV) is smaller than the proportional band, the operation amount will be 100%. If within the proportional band the operation amount is made proportional to the deviation and gradually decreased until the SV and PV match (i.e., until the deviation is 0), the operation amount will return to the previous value (forward operation).

The proportional band is expressed as a percentage with respect to the total input range. With proportional operation an offset (residual deviation) occurs, and the offset is reduced by making the proportional band smaller. If it is made too small, however, hunting will occur.




Adjusting the Proportional Band



Integral Operation (I)

Combining integral operation with proportional operation reduces the offset ac-


cording to the time that has passed. The strength of the integral operation is indicated by the integral time, which is the time required for the integral operation amount to reach the same level as the proportional operation amount with respect to the step deviation, as shown in the following illustration. The shorter the integral time, the stronger the correction by the integral operation will be. If the integral time is too short, the correction will be too strong and will cause hunting to occur.



Derivative Operation (D)

Proportional operation and integral operation both make corrections with respect to the control results, so there is inevitably a response delay. Derivative operation compensates for that drawback. In response to a sudden disturbance it delivers a large operation amount and rapidly restores the original status. A correction is executed with the operation amount made proportional to the incline (derivative coefficient) caused by the deviation.


The strength of the derivative operation is indicated by the derivative time, which is the time required for the derivative operation amount to reach the same level as the proportional operation amount with respect to the step deviation, as shown in the following illustration. The longer the derivative time, the stronger the correction by the derivative operation will be.



PID Operation

PID operation combines proportional operation (P), integral operation (I), and derivative operation (D). It produces superior control results even for control objects with dead time. It employs proportional operation to provide smooth control without hunting, integral operation to automatically correct any offset, and derivative operation to speed up the response to disturbances.

PID Operation Output Step Response




Direction of Operation

When using PID operation, select either of the following two control directions. In either direction, the operation amount increases as the difference between the SV and the PV increases.


• Forward operation: Control amount is increased when the SV is larger than the PV.

Forward Operation



 Reverse operation: Control amount is decreased when the SV is smaller than the PV.


Reverse Operation




Adjusting PID Parameters

The general relationship between PID parameters and control status is shown below.


 When it is not a problem if a certain amount of time is required for stabilization (settlement time), but it is important not to cause overshooting, then enlarge the proportional band.




When overshooting is not a problem but it is desirable to quickly stabilize control, then narrow the proportional band. If the proportional band is narrowed too much, however, then hunting may occur.



 When there is broad hunting, or when operation is tied up by overshooting and undershooting, it is probably because integral operation is too strong. The hunting will be reduced if the integral time is increased or the proportional band is enlarged.



 If the period is short and hunting occurs, it may be that the control system response is quick and the derivative operation is too strong. In that case, set the derivative operation lower.



Flags

ER: Content of *DM word is not BCD, or the DM area boundary has been exceeded.

A PID parameter SV is out of range.

The PID operation was executed but the cycle time was two times the sampling period. PID(—) will be executed for this error only even when ER (SR25503) is ON.


CY: The PID operation is being executed.

Example 1

At the rising edge of IR 00000 (OFF to ON), the work area in DM 0207 to DM 0232 is initialized according to the parameters (shown below) set in DM 0200 to DM 0206. After the work area has been initialized, PID control is executed and the manipulated variable is output to IR 020.

While IR 00000 is ON, PID control is executed at the sampling period intervals according to the parameters set in DM 0200 to DM 0206. The manipulated variable is output to IR 020.

The PID constants used in PID calculations will not be changed if the proportional band (P), integral constant (Tik), or derivative constant is changed after IR 00000 turns ON.




Input Values and Manipulated Variable Ranges The number of valid input data bits for the measured value is designated by the input range setting in C+6, bits 08 to 11, and the number of valid output data bits for the manipulated variable output is designated by the output range setting in C+6, bits 0 to 3. These ranges are shown in the following table.

C+6, bits 08 to 11 or C+6, bits 00 to 03	Number of valid bits	Range
0	8	0000 to 00FF Hex
1	9	0000 to 01FF Hex
2	10	0000 to 03FF Hex
3	11	0000 to 07FF Hex
4	12	0000 to 0FFF Hex
5	13	0000 to 1FFF Hex
6	14	0000 to 3FFF Hex
7	15	0000 to 7FFF Hex
8	16	0000 to FFFF Hex

If the range of data handled by an Analog Input Unit or Analog Output Unit cannot be set accurately by setting the number of valid bits, APR(069) (ARITH-METIC PROCESS) can be used to convert to the proper ranges before and after PID(190).


The following program section shows an example for a DRT1-AD04 Analog Input Unit and DRT1-DA02 Analog Output Unit operating as CompoBus/D slaves. The data ranges for these two Units is 0000 to 1770 Hex, which cannot be specified merely by setting the valid number of digits. APR(069) is thus used to convert the 0000 to 1770 Hex range of the Analog Input Unit to 0000 to FFFF Hex for input to PID(190) and then the manipulated variable output from PID(190) is

converted back to the range 0000 to 1770 Hex, again using APR(069), for output from the Analog Output Unit.



Example 2

This example shows a PID control program using PID(—).




Note Motors and heaters cannot be directly connected from an Analog Output Unit. An amplifier (i.e., a current amplification circuit) is required.

Creating the Program

Follow the procedure outlined below in creating the program.

- 1, 2, 3... 1. Set the target value (binary 0000 to 0FFF) in DM 0000.
 - 2. Input the PV of the temperature sensing element (binary 000 to 0FFF) in bits 0 to 11 of word 101.
 - 3. Output the operation amount of the heater to bits 0 to 11 of word 110 by means of the first PID(—) instruction in the following program.
 - 4. Output the operation amount of the fan to bits 0 to 11 of word 111 by means of the second PID(—) instruction in the following program.
 - 5. Convert the PV of the temperature sensing element (binary 000 to FFF) to temperature data (0000°C to 0200°C) by means of SCL(—), and output it to DM 0200.

Program



Note When using PID(—) or SCL(—), make the data settings in advance with a Peripheral Device such as the Programming Console or SSS.

	Heater	
HR 00	(DM0000)	Target
HR 01	0800	Propor
HR 02	0200	Integra
HR 03	0100	Deriva
HR 04	0001	Sampli
HR 05	0000	Forwar
HR 06	0404	PID pa I/O ran

Target value HR

Proportional band

Integral time/sampling period

Derivative time/sampling period

Sampling period

Forward/reverse designation/

PID parameters

I/O range and time unit settings

	SCL Parameters
DM 0100	0000
DM 0101	0000
DM 0102	0200
DM 0103	0FFF

	Fan
HR 40	(DM0000)
HR 41	0060
HR 42	0150
HR 43	0100
HR 44	0001
HR 45	0001
HR 46	0404


5-22 Logic Instructions

The logic instructions – COM(29), ANDW(34), ORW(35), XORW(36), and XNRW(37) – perform logic operations on word data.

5-22-1 COMPLEMENT – COM(29)

Ladder Symbols

Operand Data Areas




Wd: Complement word				
IR, SR, AR, DM, HR, LR				

Description

When the execution condition is OFF, COM(29) is not executed. When the execution condition is ON, COM(29) clears all ON bits and sets all OFF bits in Wd.

COM(29) will alternate between complements of Wd each cycle while the execution condition is ON; Use @COM(29) when necessary.

Example



Flags ER:

Indirectly addressed DM word is non-existent. (Content of *DM word is


not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

N: ON when bit 15 of Wd is set to 1.

5-22-2 LOGICAL AND – ANDW(34)

Ladder Symbols




Operand Data Areas

I1 : Input 1					
IR, SR, AR, DM, HR, TC, LR, #					
I2 : Input 2					
IR, SR, AR, DM, HR, TC, LR, #					
R: Result word					
IR, SR, AR, DM, HR, LR					

Description

When the execution condition is OFF, ANDW(34) is not executed. When the execution condition is ON, ANDW(34) logically AND's the contents of I1 and I2 bit-by-bit and places the result in R.

Example



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

N: ON when bit 15 of R is set to 1.

5-22-3 LOGICAL OR - ORW(35)

Ladder Symbols

ORW(35) 11 12 R R @ORW(35) 11 12 R


Operand Data Areas

I1 : Input 1				
IR, SR, AR, DM, HR, TC, LR, #				
I2 : Input 2				
IR, SR, AR, DM, HR, TC, LR, #				
R: Result word				
IR, SR, AR, DM, HR, LR				

Description

When the execution condition is OFF, ORW(35) is not executed. When the execution condition is ON, ORW(35) logically OR's the contents of I1 and I2 bit-by-bit and places the result in R.

Example



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

N: ON when bit 15 of R is set to 1.

5-22-4 EXCLUSIVE OR - XORW(36)

Ladder Symbols


Operand Data Areas

I1 : Input 1					
IR, SR, AR, DM, HR, TC, LR, #					
I2 : Input 2					
IR, SR, AR, DM, HR, TC, LR, #					
R: Result word					
IR, SR, AR, DM, HR, LR					

Description

When the execution condition is OFF, XORW(36) is not executed. When the execution condition is ON, XORW(36) exclusively OR's the contents of I1 and I2 bit-by-bit and places the result in R.

Example



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)


EQ: ON when the result is 0.

N: ON when bit 15 of R is set to 1.

5-22-5 EXCLUSIVE NOR - XNRW(37)

Operand Data Areas


Ladder Symbols



I1 : Input 1					
IR, SR, AR, DM, HR, TC, LR, #					
I2 : Input 2					
IR, SR, AR, DM, HR, TC, LR, #					
R: Result word					
IR, SR, AR, DM, HR, LR					

Description

When the execution condition is OFF, XNRW(37) is not executed. When the execution condition is ON, XNRW(37) exclusively NOR's the contents of I1 and I2 bit-by-bit and places the result in R.



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

EQ: ON when the result is 0.

N: ON when bit 15 of R is set to 1.

5-23 Subroutines and Interrupt Control

5-23-1 Subroutines

Subroutines break large control tasks into smaller ones and enable you to reuse a given set of instructions. When the main program calls a subroutine, control is transferred to the subroutine and the subroutine instructions are executed. The instructions within a subroutine are written in the same way as main program code. When all the subroutine instructions have been executed, control returns to the main program to the point just after the point from which the subroutine was entered (unless otherwise specified in the subroutine).

Subroutines may also be activated by interrupts or the MCRO(99) instruction.

Like subroutine calls, interrupts cause a break in the flow of the main program execution such that the flow can be resumed from that point after completion of the subroutine. An interrupt is caused either by an external source, such as an input signal from an Interrupt Input Unit, or a scheduled interrupt. In the case of the scheduled interrupt, the interrupt signal is repeated at regular intervals.

Whereas subroutine calls are controlled from within the main program, subroutines activated by interrupts are triggered when the interrupt signal is received. In the case of the scheduled interrupt, the time interval between interrupts is set by the user and is unrelated to the cycle timing of the PC. This capability is useful for periodic supervisory or executive program execution.

Interrupts

INT(89) is used to control the interrupt signals received from the Interrupt Input Unit, and also to control the scheduling of the scheduled interrupt. INT(89) provides such functions as masking of interrupts (so that they are recorded but ignored) and clearing of interrupts.

Refer to 5-23-2 Interrupts for more details on interrupts.

MCRO(99)

The MACRO instruction allows a single subroutine (programming pattern) to replace several subroutines that have identical structure but different operands. Since a number of similar program sections can be managed with just one subroutine, the number of program steps can be greatly reduced. Refer to 5-23-5 MACRO – MCRO(99) for more details on this instruction.

5-23-2 Interrupts

The C200HX/HG/HE PCs support both input interrupts and scheduled interrupts. Interrupts stop execution of the program to run a subroutine in must be executed immediately (input interrupts from an Interrupt Input Unit) or subroutines that must be executed periodically (scheduled interrupts).

There are two interrupt modes. In **normal mode** the CPU Unit waits until the current process is completed before stopping the main program. In **high-speed mode** the CPU Unit interrupts the current process. The normal mode is the default mode in C200HX/HG/HE PCs, but high-speed mode can be selected in the PC Setup.

Normal Interrupt Mode

The following setting is used for normal interrupt mode.

DM 6620 0 0 0

In normal interrupt mode, the following processing will be completed once started even if an interrupt occurs The interrupt will be processed as soon as the current process is completed.


- Host Link servicing
- Remote I/O servicing
- Special I/O Unit servicing
- Individual instruction execution

Use this mode whenever using C200H interrupt subroutines without modification or whenever possible considering the response time required for interrupts.

Note The C200HX/HG/HE is set to normal interrupt mode by default.

High-speed Interrupt Mode

The following setting is used for high-speed interrupt mode.



In high-speed interrupt mode, the following processing will be interrupted and the interrupt subroutine executed as soon as an interrupt is generated.

- Host Link servicing
- Remote I/O servicing
- Special I/O Unit servicing
- Individual instruction execution

Use this mode whenever interrupt response time must be accurate to 1.0 ms. Data will not necessarily be concurrent if the high-speed interrupt mode is used because Host Link servicing, remote I/O servicing, Special I/O Unit servicing, and individual instruction execution will not necessarily be completed when

started. The program must be designed to allow for this when required by the application. (See the section on data concurrence for further details.)

Input Interrupts


Input interrupts are executed when external inputs are received via an Interrupt Input Unit. Up to two Interrupt Input Units can be mounted to the CPU Rack and each Interrupt Input Unit provides 8 inputs numbered IN 0 through IN7.

Inputs IN0 through IN7 on the first Unit generate interrupts #00 to #07 and inputs IN0 through IN7 on the second Unit generate interrupts #08 to #15. Generally speaking, subroutines #00 to #15 are executed when interrupts #00 to #15 are generated.

Scheduled Interrupts

Scheduled interrupts can be executed at intervals set either in increments of 10 ms or in increments or 1 ms. Interrupt #99 is used and subroutine #99 is executed.

The unit used to set the scheduled interrupt interval is set in the PC Setup at DM 6622.



Interrupt Priority


The specified subroutine will be executed when an interrupt is generated. If further interrupts are generated during execution of an interrupt subroutine, they will not be processed until execution of the current interrupt subroutine has been completed. If more than one interrupt is generated or is awaiting execution at the same time, the corresponding subroutines will be executed in the following order of priority.

Input interrupt 1 > input interrupt 2 > ... > input interrupt 7 > scheduled interrupt

Special I/O in Interrupt Subroutines

I/O for Special I/O Units can be refreshed from within interrupt subroutines by using the I/O REFRESH (IORF) instruction. If the high-speed interrupt mode is used, refreshing in the normal cycle (END refreshing and IORF refreshing in the main program) must be disabled for the Special I/O Unit that is to be refreshed in the interrupt subroutine. An interrupt programming error (system FAL error 8B) will occur if the same special I/O is refreshed both within an interrupt program and within the normal cycle, and the special I/O will not be refreshed within the interrupt subroutine.

The PC Setup contains settings in DM 6620 that disable refreshing in the normal cycle for specific Special I/O Units. This settings are as shown below.



Note Disabling special I/O refreshing in the normal cycle to refresh special I/O in an interrupt subroutine is necessary only in the high-speed mode. Disabling normal cycle refreshing of special I/O during normal interrupt mode will be ignored and the special I/O will be refreshed both in the normal cycle and in the interrupt subroutine.

The execution time of interrupt subroutines must be kept to less than 10 ms if the high-speed interrupt mode is used and Special I/O Units, Host Link Units, or Remote I/O Units are programmed. An interrupt programming error (system FAL error 8B) will occur if the execution time is 10 ms or greater.

The execution time of interrupt subroutine with the longest execution time is output to SR 262 and the number of the subroutine with the longest execution time is output to SR 263.

Example: 12.3 ms for subroutine #80

SR 262	0	1	2	3	Maximum interrupt subroutine execution time (in 0.1 ms)
SR 263	8	0	*	*	No. of interrupt subroutine with maximum execution time


Note The above 10-ms limit does not apply when the normal interrupt mode is used or when the above Units are not mounted.

Data Concurrence

Although data concurrence is not a problem for execution of normal arithmetic instructions or comparison instructions, it can be a problem when executing longer instructions that handle multiple words, such as block transfer instructions, when the high-speed interrupt mode is used and the same data is handled both in the main program and in an interrupt subroutine.

Data may not be concurrent in two different situations: 1) if a data write operation in the main program is interrupted and the same data is read in an interrupt subroutine and 2) if a data read operation in the main program is interrupted and the same data is written in an interrupt subroutine.

If you must handle the same data both in the main program and in an interrupt subroutine, use programming such as that shown below to be sure that data concurrence is preserved, i.e., mask interrupts while read/writing data that is also handled in an interrupt subroutine.



Data concurrence can also be a problem if interrupts occur during data transfers occurring in servicing for Special I/O Units, remote I/O, or Host Link Systems. For any of these, data can be non-concurrent down to byte units.

Use one of the following methods to preserve data concurrence in the above situations. The second methods applies to Special I/O Units only.


 Mask interrupts in the main program while moving data transferred to/from Units to different words and use these alternate words in the interrupt subroutine. Use the I/O REFRESH instruction in interrupt subroutines to refresh required I/O from Special I/O Units and mask interrupts in the main program while reading/writing Special I/O Unit words.

5-23-3 SUBROUTINE ENTER - SBS(91)

Ladder Symbol

Definer Data Areas






Limitations

Description

Subroutine numbers 000 through 015 are used with input interrupts and subroutine number 099 is used for the scheduled interrupt.


A subroutine can be executed by placing SBS(91) in the main program at the point where the subroutine is desired. The subroutine number used in SBS(91) indicates the desired subroutine. When SBS(91) is executed (i.e., when the execution condition for it is ON), the instructions between the SBN(92) with the same subroutine number and the first RET(93) after it are executed before execution returns to the instruction following the SBS(91) that made the call.




SBS(91) may be used as many times as desired in the program, i.e., the same subroutine may be called from different places in the program).

SBS(91) may also be placed into a subroutine to shift program execution from one subroutine to another, i.e., subroutines may be nested. When the second subroutine has been completed (i.e., RET(93) has been reached), program execution returns to the original subroutine which is then completed before returning to the main program. There is no limit to the number of nesting levels, unlike the C200HS PCs in which nesting is limited to 16 levels.

A subroutine cannot call itself (e.g., SBS(91) 000 cannot be programmed within the subroutine defined with SBN(92) 000). The following diagram illustrates two levels of nesting.



The following diagram illustrates program execution flow for various execution conditions for two SBS(91).



Note A non-fatal error (error code 8B) will be generated if a subroutine's execution time exceeds 10 ms.

Flags

ER: A subroutine does not exist for the specified subroutine number.

A subroutine has called itself.

An active subroutine has been called.

(!\ Caution

SBS(91) will not be executed and the subroutine will not be called when ER is ON.

5-23-4 SUBROUTINE DEFINE and RETURN - SBN(92)/RET(93)

 Ladder Symbols
 Definer Data Areas

 N: Subroutine number

 000 to 255

Limitations

Each subroutine number can be used in SBN(92) once only.

Description

SBN(92) is used to mark the beginning of a subroutine program; RET(93) is used to mark the end. Each subroutine is identified with a subroutine number, N, that is programmed as a definer for SBN(92). This same subroutine number is used in any SBS(91) that calls the subroutine (see 5-23-3 SUBROUTINE ENTER – SBS(91)). No subroutine number is required with RET(93).

All subroutines must be programmed at the end of the main program. When one or more subroutines have been programmed, the main program will be executed up to the first SBN(92) before returning to address 00000 for the next cycle. Subroutines will not be executed unless called by SBS(91).

END(01) must be placed at the end of the last subroutine program, i.e., after the last RET(93). It is not required at any other point in the program.

Precautions

If SBN(92) is mistakenly placed in the main program, it will inhibit program execution past that point, i.e., program execution will return to the beginning when SBN(92) is encountered.

If either DIFU(13) or DIFU(14) is placed within a subroutine, the operand bit will not be turned OFF until the next time the subroutine is executed, i.e., the operand bit may stay ON longer than one cycle.

Flags

There are no flags directly affected by these instructions.

5-23-5 MACRO – MCRO(99)

Operand Data Areas

N: Subroutine number					
000 to 255					
I1: First input word					
IR, SR, AR, DM, HR, TC, LR					
O1: First output word					
IR, SR, AR, DM, HR, LR					

Limitations


Description

I1 through I1+3 must be in the same data area, as must O1 through O1+3.

The MACRO instruction allows a single subroutine to replace several subroutines that have identical structure but different operands. There are 4 input words, SR 290 to SR 293, and 4 output words, SR 294 to SR 297, allocated to MCRO(99). These 8 words are used in the subroutine and take their contents from I1 to I1+3 and O1 to O1+3 when the subroutine is executed.

When the execution condition is OFF, MCRO(99) is not executed. When the execution condition is ON, MCRO(99) copies the contents of I1 to I1+3 to SR 290 to SR 293, copies the contents of O1 to O1+3 to SR 294 to SR 297, and then calls and executes the subroutine specified in N. When the subroutine is completed, the contents of SR 294 through SR 297 are then transferred back to O1 to O1+3 before MCRO(99) is completed.

In the following example, the contents of DM 0010 through DM 0013 are copied to SR 290 through SR 293, the contents of DM 0020 through DM 0023 are copied to SR 294 through SR 297, and subroutine 010 is called and executed. When the subroutine is completed, the contents of SR 294 through SR 297 are copied back to DM 0020 to DM 0023.



Note

- 1. Subroutines for macros are programmed just like other subroutines, except that SR 290 to SR 297 contents are transferred in from the designated input and output words.
- 2. Not only external I/O words, but internal I/O words can be used for I1 and O1.
- SR 290 to SR 297 can be used as work bits when not used for macro programs.
- 4. MCRO(99) instructions can be nested, but be sure to preserve I/O data since the instructions use the same 8 I/O words (SR 290 to SR 297).

Precautions

MCRO(99) can be used only for program sections that can be written using four or fewer consecutive input words and/or four or fewer consecutive output words. It is thus generally necessary to consider system and program design together to take full advantage of macro programming.

Be careful that the input and output words properly correspond to the macro input and output words.

Flags

ER: A subroutine does not exist for the specified subroutine number.

An operand has exceeded a data area boundary.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

A subroutine has called itself.


An active subroutine has been called.

Example

The following examples shows the use of four MCRO(99) instructions that access the same subroutine. The program section on the left shows the same program without the use of MCRO(99).



5-23-6 INTERRUPT CONTROL – INT(89)



Operand Data Areas

C: Control code					
# (000, 001, 002, 100, or 200)					
N: Interrupt type					
# (000, 001, or 004)					
D: Control data					
IR, AR, DM, HR, TC, LR, #					

Limitations

D must be between #0000 and #00FF when N=000 and C=000 or 001.

D must be BCD between #0001 and #9999 when N=004 and C=000 or 001.

Description

INT(89) is used to control interrupts and performs one of 11 functions depending on the values of C and N. As shown in the following tables, six of the functions act on input interrupts, three act on the scheduled interrupt, and the other two mask or unmask all interrupts.

Interrupt	С	INT(89) Function	Comments
Input interrupts from	000	Mask/unmask input interrupts	Bits 00 to 07 of D indicate inputs 00 to 07.
Interrupt Input Unit 0 (N=000)	001	Clear input interrupts	
(14=000)	002	Read current mask status	Status written to D.
Input interrupts from	000	Mask/unmask input interrupts	Bits 00 to 07 of D indicate inputs 00 to 07.
Interrupt Input Unit 1 (N=001)	001	Clear input interrupts	
(11=001)	002	Read current mask status	Status written to D.
Scheduled (N=004)	000	Set interrupt interval	
	001	Set time to first interrupt	
	002	Read interrupt interval	

The following 2 functions depend on the value of C only.

Value of C	INT(89) Function
100	Mask all interrupts
200	Unmask all interrupts

Mask/unmask Input Interrupts (N=000 or 001, C=000) Set N=000 for Interrupt Input Unit 0 and N=001 for Interrupt Input Unit 1. This function is used to mask and unmask input interrupts 00 to 07. Masked inputs are recorded, but ignored. When an input is masked, the interrupt program for it will be run as soon as the bit is unmasked (unless it is cleared beforehand by executing INT(89) with C=001 and N=000).

Set the corresponding bit in D to 0 to unmask or to 1 to mask an I/O interrupt input. Bits 00 to 07 correspond to 00 to 07.

Clear Input Interrupts (N=000 or 001, C=001)

Set N=000 for Interrupt Input Unit 0 and N=001 for Interrupt Input Unit 1. This function is used to clear I/O interrupt inputs 00 to 07. Since interrupt inputs are recorded, masked interrupts will be serviced after the mask is removed unless they are cleared first.

Set the corresponding bit in D to 1 to clear an interrupt input. Bits 00 to 07 correspond to 00 to 07.

Read Current Mask Status (N=000 or 001, C=002)

Set N=000 for Interrupt Input Unit 0 and N=001 for Interrupt Input Unit 1. This function is used to write the current mask status for input interrupts 00 to 07 to word D. The corresponding bit will be ON if the input is masked. (Bits 00 to 07 correspond to 00 to 07.)

Set Interrupt Interval (N=004, C=000)

This function is used to set the interval between scheduled interrupts. The content of D (BCD: 0001 to 9999) is multiplied by the scheduled interrupt time unit (1 ms or 10 ms) to obtain the scheduled interrupt interval.

The scheduled interrupt time unit is set in DM 6622 of the PC Setup. Refer to 3-6-4 PC Setup for details on setting this time unit.

Set Time to First Interrupt (N=004, C=001)

This function is used to set the time to the first scheduled interrupt. The content of D (BCD: 0000 to 9999) is multiplied by the scheduled interrupt time unit (1 ms or 10 ms) to obtain the time to the first scheduled interrupt. The scheduled interrupt time unit is set in DM 6622 of the PC Setup. Refer to 3-6-4 PC Setup for details on setting this time unit.

Be sure to set the time to the first interrupt. If this setting is not made, the interval to the first interrupt (set with N=004, C=000) will be uncertain.

Use the First Cycle Flag (SR 25315) for the execution condition to INT(89) when setting the time to the first interrupt (C=001). The scheduled interrupt might never occur if the C=001 setting is made continuously.

Read Interrupt Interval (N=004, C=002)

This function is used to write the current setting for the scheduled interrupt interval to word D.

Mask/Unmasking All Interrupts (C=100/200)

This function is used to mask or unmask all interrupt processing. Masked inputs are recorded, but ignored. The masked inputs will be serviced as soon as they are unmasked. This function masks or unmask all interrupts at the same time and is independent of the masks created with other functions.

The control data, D, and interrupt type, N, are not used for this function. Set them to #0000.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)


C, and/or N are not within specified values.

All interrupts within the subroutine are masked or unmasked.

Example 1: Input Interrupt

This example shows how to unmask a particular interrupt input. Input interrupt subroutines will be executed when the CPU Unit receives the corresponding interrupt input, regardless of the location in the CPU Unit's cycle. These interrupts are useful when using program sections of uncertain length, such as event programs.

All input interrupts are masked at the start of operation, and the desired interrupt input is unmasked using INT(89) with N=000 and C=000. As shown in the following diagram, the subroutine would be executed if there were an input from input interrupt 00 of Interrupt Input Unit 0 when that interrupt input was unmasked.




Note Depending on the setting of DM 6621 in the PC Setup, Host Link servicing, Remote I/O servicing, Special I/O Unit servicing, and individual instruction execution will be completed before the subroutine is executed. Refer to page 282 for details.

Example 2: Scheduled Interrupt

This example shows how to set the interval between scheduled interrupts. Scheduled interrupt subroutines will be executed at fixed intervals, regardless of the location in the CPU Unit's cycle. This interrupt is useful for program sections such as regular monitoring programs.

The scheduled interrupt is disabled at the start of operation (the scheduled interrupt interval is 0), so the time to the first interrupt and scheduled interrupt interval must be set using INT(89) with N=004 and C=001/000. In the following diagram, the subroutine would be executed every 20 ms if the scheduled interrupt time unit is set to 10 ms in DM 6622 of the PC Setup.




Note Depending on the setting of DM 6621 in the PC Setup, Host Link servicing, Remote I/O servicing, Special I/O Unit servicing, and individual instruction execution will be completed before the subroutine is executed. Refer to page 282 for details.

5-24 Step Instructions

The step instructions STEP(08) and SNXT(09) are used in conjunction to set up breakpoints between sections in a large program so that the sections can be executed as units and reset upon completion. A section of program will usually be defined to correspond to an actual process in the application. (Refer to the application examples later in this section.) A step is like a normal programming code, except that certain instructions (e.g., IL(02)/ILC(03), JMP(04)/JME(05)) may not be included.

5-24-1 STEP DEFINE and STEP START-STEP(08)/SNXT(09)



Limitations

All control bits must be in the same word and must be consecutive.


IR 29800 to IR 29915 cannot be used for B.

Description

STEP(08) uses a control bit in the IR or HR areas to define the beginning of a section of the program called a step. STEP(08) does not require an execution condition, i.e., its execution is controlled through the control bit. To start execution of the step, SNXT(09) is used with the same control bit as used for STEP(08). If SNXT(09) is executed with an ON execution condition, the step with the same control bit is executed. If the execution condition is OFF, the step is not executed. The SNXT(09) instruction must be written into the program so that it is executed before the program reaches the step it starts. It can be used at different locations before the step to control the step according to two different execution conditions (see example 2, below). Any step in the program that has not been started with SNXT(09) will not be executed.

Once SNXT(09) is used in the program, step execution will continue until STEP(08) is executed without a control bit. STEP(08) without a control bit must be preceded by SNXT(09) with a dummy control bit. The dummy control bit may be any unused IR or HR bit. It cannot be a control bit used in a STEP(08).

Execution of a step is completed either by execution of the next SNXT(09) or by turning OFF the control bit for the step (see example 3 below). When the step is completed, all of the IR and HR bits in the step are turned OFF. All timers in the step except TTIM(—) are reset to their SVs. TTIM(—), counters, shift registers, bits set or reset with SET or RSET, and bits used in KEEP(11) maintain status. Two simple steps are shown below.



Steps can be programmed in consecutively. Each step must start with STEP(08) and generally ends with SNXT(09) (see example 3, below, for an exception). When steps are programmed in series, three types of execution are possible: sequential, branching, or parallel. The execution conditions for, and the positioning of, SNXT(09) determine how the steps are executed. The three examples given below demonstrate these three types of step execution.

Precautions


Interlocks, jumps, SBN(92), and END(01) cannot be used within step programs.

Bits used as control bits must not be used anywhere else in the program unless they are being used to control the operation of the step (see example 3, below). All control bits must be in the same word and must be consecutive.

If IR or LR bits are used for control bits, their status will be lost during any power interruption. If it is necessary to maintain status to resume execution at the same step, HR bits must be used.

Flags

25407: Step Start Flag; turns ON for one cycle when STEP(08) is executed and can be used to reset counters in steps as shown below if necessary.



Address	Instruction	Operands
00000	LD	00000
00001	SNXT(09)	01000
00002	STEP(08)	01000
00003	LD	00100


Address	Instruction	Operands
00004	LD	25407
00005	CNT	01
		# 0003

Examples


The following three examples demonstrate the three types of execution control possible with step programming. Example 1 demonstrates sequential execution; example 2, branching execution; and example 3, parallel execution.

Example 1: Sequential Execution


The following process requires that three processes, loading, part installation, and inspection/discharge, be executed in sequence with each process being reset before continuing on the the next process. Various sensors (SW1, SW2, SW3, and SW4) are positioned to signal when processes are to start and end.



The following diagram demonstrates the flow of processing and the switches that are used for execution control.




The program for this process, shown below, utilizes the most basic type of step programming: each step is completed by a unique SNXT(09) that starts the next step. Each step starts when the switch that indicates the previous step has been completed turns ON.




Address	Instruction	Operands		Address	Instruction	Operands
00000	LD	00001	ε	<u> </u>	Process B	J
00001	SNXT(09)	12800				
00002	STEP(08)	12800		00100	LD	00003
				00101	SNXT(09)	12802
<u> </u>	Process A	\exists	in the second	00102	STEP(08)	12802
00100	LD	00002	×	<u> </u>	Process C	
00101	SNXT(09)	12801				
00102	STEP(08)	12801		00200	LD	00004
	•		•	00201	SNXT(09)	12803
				00202	STEP(08)	

Example 2: Branching Execution


The following process requires that a product is processed in one of two ways, depending on its weight, before it is printed. The printing process is the same regardless of which of the first processes is used. Various sensors are positioned to signal when processes are to start and end.



The following diagram demonstrates the flow of processing and the switches that are used for execution control. Here, either process A or process B is used depending on the status of SW A1 and SW B1.




The program for this process, shown below, starts with two SNXT(09) instructions that start processes A and B. Because of the way 00001 (SW A1) and 00002 (SB B1) are programmed, only one of these will be executed to start either process A or process B. Both of the steps for these processes end with a SNXT(09) that starts the step for process C.




Address	Instruction	Ope	rands		Address	Instruction	Opera	ınds
00000	LD		00001					
00001	AND NOT		00002	=	<u></u>	Process B		
00002	SNXT(09)	HR	0000	1				
00003	LD NOT		00001	1	00100	LD		00004
00004	AND		00002	1	00101	SNXT(09)	HR	0002
00005	SNXT(09)	HR	0001	1	00102	STEP(08)	HR	0002
00006	STEP(08)	HR	0000	1				
				=	<u> </u>	Process C		
<u>~ </u>	Process A		E	þ				
					00200	LD		00005
00100	LD		00003	1	00201	SNXT(09)	HR	0003
00101	SNXT(09)	HR	0002	1	00202	STEP(08)		
00102	STEP(08)	HR	0001	1				

Example 3: Parallel Execution

The following process requires that two parts of a product pass simultaneously through two processes each before they are joined together in a fifth process. Various sensors are positioned to signal when processes are to start and end.




The following diagram demonstrates the flow of processing and the switches that are used for execution control. Here, process A and process C are started together. When process A finishes, process B starts; when process C finishes, process D starts. When both processes B and D have finished, process E starts.



The program for this operation, shown below, starts with two SNXT(09) instructions that start processes A and C. These instructions branch from the same instruction line and are always executed together, starting steps for both A and C. When the steps for both A and C have finished, the steps for process B and D begin immediately.

When both process B and process D have finished (i.e., when the status for both of them is "ON," but SW5 and SW6 have turned ON), processes B and D are reset together by the SNXT(09) at the end of the programming for process B. Although there is no SNXT(09) at the end of process D, the control bit for it is turned OFF by executing SNXT(09) LR 0004. This is because the OUT for LR 0003 is in the step reset by SNXT(09) LR 0004, i.e., LR 003 is turned OFF when SNXT(09) LR 0004 is executed Process B is thus reset directly and process D is reset indirectly before executing the step for process E.




	Address	Instruction	Оре	erands		Address	Instruction	Oper	ands	
	00000	LD		00001		00204	STEP(08)	LR	0002	
	00001	SNXT(09)	LR	0000						
	00002	SNXT(09)	LR	0002	=	$\overline{\overline{}}$	Process C		$\overline{\Rightarrow}$	>
	00003	STEP(08)	LR	0000						
						00300	LD		00003	
\succeq	<u> </u>	Process A		$\overline{}$	F	00301	SNXT(09)	LR	0003	
						00302	STEP(08)	LR	0003	
	00100	LD		00002						
	00101	SNXT(09)	LR	0001	≥	<u>-</u>	Process D		\Rightarrow	>
	00102	STEP(08)	LR	0001						
						00400	STEP(08)	LR	0004	
\succeq	(C	Process B		\mathbb{R}^{2}	F					
					=	<u> </u>	Process E		<u></u>	>
	00200	LD		LR 0003						
	00201	OUT		LR 0003		00500	LD		00005	
	00202	AND		00004		00501	SNXT(09)	LR	0005	
	00203	SNXT(09)	LR	0004		00502	STEP(08)			

5-25 Special Instructions

The instructions in this section are used for various operations, including programming user error codes and messages, counting ON bits, setting the watchdog timer, and refreshing I/O during program execution.

5-25-1 FAILURE ALARM – FAL(06) and SEVERE FAILURE ALARM – FALS(07)




Limitations

FAL(06) and FALS(07) share the same FAL numbers. Be sure to use a number in either FAL(06) or FALS(07), not both.

Description

FAL(06) and FALS(07) are provided so that the programmer can output error numbers for use in operation, maintenance, and debugging. When executed with an ON execution condition, either of these instructions will output a FAL number to bits 00 to 07 of SR 253. The FAL number that is output can be between 01 and 99 and is input as the definer for FAL(06) or FALS(07). FAL(06) with a definer of 00 is used to reset this area (see below).



FAL(06) produces a non-fatal error and FAL(07) produces a fatal error. When FAL(06) is executed with an ON execution condition, the ALARM/ERROR indicator on the front of the CPU Unit will flash, but PC operation will continue. When FALS(07) is executed with an ON execution condition, the ALARM/ERROR indicator will light and PC operation will stop.

The system also generates error codes to the FAL area.

Resetting Errors

All FAL error codes will be retained in memory, although only one of these is available in the FAL area. To access the other FAL codes, reset the FAL area by executing FAL(06) 00. Each time FAL(06) 00 is executed, another FAL error will be moved to the FAL area, clearing the one that is already there. FAL error codes are recorded and will be recalled in the following order: First code generated, lowest FAL number greater than the first code, lowest FAL number lower than the first code.


Clearing Messages

FAL(06) 00 is also used to clear message programmed with the instruction, MSG(46).

If the FAL area cannot be cleared, as is generally the case when FALS(07) is executed, first remove the cause of the error and then clear the FAL area through the Programming Console (see *4-6-5 Clearing Error Messages*).

5-25-2 CYCLE TIME – SCAN(18)

Ladder Symbols



Operand Data Areas

Mi: Multiplier (BCD)				
IR, SR, AR, DM, HR, TC, LR, #				
000 : Not used.				
000 : Not used.				

Limitations

Mi must be BCD. Only the rightmost three digits of Mi are used.

Description

SCAN(18) is used to set a minimum cycle time. Mi is the minimum cycle time that will be set in tenths of milliseconds, e.g., if Mi is 1200, the minimum cycle time will be 120.0 ms. The possible setting range is from 000.0 to 999.0 ms.

If the actual cycle time is less than the cycle time set with SCAN(18) the CPU Unit will wait until the designated time has elapsed before starting the next cycle. If the actual cycle time is greater than the set time, the set time will be ignored and the program will be executed to completion.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Mi is not BCD.

5-25-3 TRACE MEMORY SAMPLING – TRSM(45)

Data tracing can be used to facilitate debugging programs. To set up and use data tracing it is necessary to have a host computer running SSS; no data tracing is possible from a Programming Console. Data tracing is described in detail in the SSS Operation Manual. This section shows the ladder symbol for TRSM(45) and gives an example program.

Ladder Symbol



Description

TRSM(45) is used in the program to mark locations where specified data is to be stored in Trace Memory. Up to 12 bits and up to 3 words may be designated for tracing (refer to the SSS Operation Manual for details).

TRSM(45) is not controlled by an execution condition, but rather by two bits in the AR area: AR 2515 and AR 2514. AR 2515 is the Sampling Start bit. This bit is turned ON to start the sampling processes for tracing. The Sampling Start bit must not be turned ON from the program, i.e., it must be turned ON only from the peripheral device. AR 2514 is the Trace Start bit. When it is set, the specified data is recorded in Trace Memory. The Trace Start bit can be set either from the program or from the Programming Device. A positive or negative delay can also be set to alter the actual point from which tracing will begin.

Data can be recorded in any of three ways. TRSM(45) can be placed at one or more locations in the program to indicate where the specified data is to be traced. If TRSM(45) is not used, the specified data will be traced when END(01) is executed. The third method involves setting a timer interval from the peripheral devices so that the specified data will be tracing at a regular interval independent of the cycle time (refer to the SSS Operation Manual).

TRSM(45) can be incorporated anywhere in a program, any number of times. The data in the trace memory can then be monitored via a Programming Console, host computer, etc.

AR Control Bits and Flags

The following control bits and flags are used during data tracing. The Tracing Flag will be ON during tracing operations. The Trace Completed Flag will turn ON when enough data has been traced to fill Trace Memory.

Flag	Function
AR 2515	Sampling Start Bit
AR 2514	Trace Start Bit
AR 2513	Tracing Flag
AR 2512	Trace Completed Flag

Precautions


If TRSM(45) occurs TRSM(45) will not be executed within a JMP(08) – JME(09) block when the jump condition is OFF.

Example

The following example shows the basic program and operation for data tracing. Force set the Sampling Start Bit (AR 2515) to begin sampling. The Sampling Start Bit must not be turned ON from the program. The data is read and stored into trace memory.

When IR 00000 is ON, the Trace Start Bit (AR 2514) is also turned ON, and the CPU Unit looks at the delay and marks the trace memory accordingly. This can mean that some of the samples already made will be recorded as the trace memory (negative delay), or that more samples will be made before they are recorded (positive delay).

The sampled data is written to trace memory, jumping to the beginning of the memory area once the end has been reached and continuing up to the start marker. This might mean that previously recorded data (i.e., data from this sample that falls before the start marker) is overwritten (this is especially true if the delay is positive). The negative delay cannot be such that the required data was executed before sampling was started.




Address	Address Instruction		ands
00000	LD		0000
00001	OUT	AR	2514
00002	TRSM(45)		
00003	LD	AR	2513


Address	Address Instruction		nds
00004	OUT		00200
00005	LD	AR	2512
00006	OUT		00201

5-25-4 MESSAGE DISPLAY – MSG(46)



Operand Data Areas





Limitations

Description

FM and FM+7 must be in the same data area.

When executed with an ON execution condition, MSG(46) reads eight words of extended ASCII code from FM to FM+7 and displays the message on the Programming Console. The displayed message can be up to 16 characters long, i.e., each ASCII character code requires eight bits (two digits). Refer to *Appendix I* for the extended ASCII codes. Japanese katakana characters are included in this code.

If not all eight words are required for the message, it can be stopped at any point by inputting "0D." When 0D is encountered in a message, no more words will be read and the words that normally would be used for the message can be used for other purposes.

Message Buffering and Priority

Up to three messages can be buffered in memory. Once stored in the buffer, they are displayed on a first in, first out basis. Since it is possible that more than three MSG(46)s may be executed within a single cycle, there is a priority scheme, based on the area where the messages are stored, for the selection of those messages to be buffered.

The priority of the data areas is as follows for message display:

LR > IR > HR > AR > TC > DM > SR

In handling messages from the same area, those with the lowest address values have higher priority.

In handling indirectly addressed messages (i.e. DM), those with the lowest DM address values have higher priority.

Clearing Messages

To clear a message, execute FAL(06) 00 or clear it via a Programming Console using the procedure in *4-6-5 Clearing Error Messages*.

If the message data changes while the message is being displayed, the display will also change.


Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

Example

The following example shows the display that would be produced for the instruction and data given when 00000 was ON. If 00001 goes ON, a message will be cleared.




Address	Instruction	Operands	
00000	LD		00000
00001	MSG(46)		
		DM	0010
00002	LD		00001
00003	FAL(06)		00

	AS equiv	-				
DM 0010	4	1	4	2	Α	В
DM 0011	4	3	4	4	С	D
DM 0012	4	5	4	6	E	F
DM 0013	4	7	4	8	G	Н
DM 0014	4	9	4	Α	1	J
DM 0015	4	В	4	С	K	L
DM 0016	4	D	4	Е	М	N
DM 0017	4	F	5	0	0	Р

MSG ABCDEFGHIJKLMNOP

5-25-5 LONG MESSAGE – LMSG(47)

Ladder Symbols



Operand Data Areas

S: First source word (ASCII)
IR, SR, AR, DM, HR, TC, LR
: Not used.
Set to 000
: Not used.
Set to 000

Limitations

S through S+15 must be in the same data area and must be in ASCII. The message will be truncated if a null character (0D) is contained between S and S+15.

Description

LMSG(47) is used to output a 32-character message to a Programming Console. The message to be output must be in ASCII beginning in word S and ending in S+15, unless a shorter message is desired. A shorter message can be produced by placing a null character (0D) into the string; no characters from the null character on will be output.

To output to the Programming Console, it must be set in TERMINAL mode. Although LMSG(47) will be executed as normal, the message will not appear correctly on the Programming Console unless TERMINAL mode is set. Refer to 5-25-6 TERMINAL MODE – TERM(48) for details on switching to TERMINAL mode.

When pin 6 of the CPU Unit's DIP switch is OFF, the Programming Console can be switched to TERMINAL mode by pressing the CHG Key or by executing TERM(48) in the program. When pin 6 of the CPU Unit's DIP switch is ON, the Programming Console can be switched to Expansion TERMINAL mode by turning on bit AR 0709.

Flags

ER: S and S+15 are not in the same data area.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

Example

Although the display is longer and there is a choice of output devices, the coding for LMSG(47) is the same as that for MSG(46). Refer to *Example* under the previous section for an example using MSG(46).

5-25-6 TERMINAL MODE – TERM(48)

Ladder Symbols



Description

When the execution condition is OFF, TERM(48) is not executed. When the execution condition is ON, TERM(48) switches the Programming Console to TERMINAL mode. (Instructions MSG(46), LMSG(47), and the keyboard mapping function are executed in TERMINAL mode.)

The Programming Console will return to CONSOLE mode when the CHG key is pressed again. There is no instruction that returns the Programming Console to CONSOLE mode from the program.

The Programming Console can also be switched to TERMINAL mode by pressing the CHG key on the Programming Console before inputting the password or when the mode is being displayed provided that pin 6 of the CPU Unit's DIP switch is OFF. The Programming Console will return to CONSOLE mode when the CHG key is pressed again.

When pin 6 of the CPU Unit's DIP switch is ON, the Programming Console can be switched to Expansion TERMINAL mode by turning on bit AR 0709.

Example

In the following example, TERM(48) is used to switch the Programming Console to TERMINAL mode when 00000 is ON. Be sure that pin 6 of the CPU Unit's DIP switch is OFF.




Address	Instruction	Operands
00000	LD	00000
00001	TERM(48)	
		000
		000
		000

5-25-7 WATCHDOG TIMER REFRESH – WDT(94)

Ladder Symbols

Definer Data Areas



T: Watchdog timer value	
# (00 to 63)	

Description

When the execution condition is OFF, WDT(94) is not executed. When the execution condition is ON, WDT(94) extends the setting of the cycle monitor time (watchdog timer) set in DM 6618 of the PC Setup. The default setting is 120 ms.

Timer extension = 100 ms x T

Where, T = 00 to 63 (4-digit BCD)

Precautions

The cycle monitor time (watchdog timer setting) can be set to a maximum of 99 s with the PC Setup. The WDT(94) instruction can be used to extend the cycle monitor time to a maximum value of 6400 ms, but only the portion of the cycle used for instruction execution is extended.

WDT(94) can be executed more than once in a cycle, but the cycle time can't be extended by more than 6400 ms total. Any extension over 6400 ms will be ignored. Another WDT(94) instruction won't be executed if the cycle time has already been extended by 6400 ms.

Timers might not function properly when the cycle time exceeds 100 ms. When using WDT(94), the same timer should be repeated in the program at intervals that are less than 100 ms apart. TIMH(15) should be used only in a scheduled interrupt routine executed at intervals of 10 ms or less.

Flags

There are no flags affected by this instruction.

5-25-8 I/O REFRESH - IORF(97)

Ladder Symbol

St E

Operand Data Areas

St: Starting word

IR 000 to IR 049, IR 100 to IR 199,
SR 400 to SR 450

Limitations

IORF(97) can be used to refresh I/O words allocated to I/O Units, Special I/O Units, and Interrupt Input Units mounted to the CPU or Expansion I/O Racks.

It cannot be used for other I/O words, such as I/O Units on Slave Racks or Group-2 High-density I/O Units.

St must be less than or equal to E.

Description

To refresh I/O words allocated to CPU or Expansion I/O Racks (IR 000 to IR 029 or IR 300 to IR 309), simply specify the first (St) and last (E) I/O words to be refreshed. When the execution condition for IORF(97) is ON, all words between St and E will be refreshed. This will be in addition to the normal I/O refresh performed during the CPU Unit's cycle.

To refresh I/O words allocated to Special I/O Units 0 through 9 (IR 100 to IR 199), designate IR 040 to IR 049. These IR words are just used to identify the corresponding Special I/O Unit; execution of IORF(97) will have no effect on the content of IR 040 to IR 049.

For example, set St to IR 043 and E to IR 045 to refresh the I/O words allocated to Special I/O Units 3, 4, and 5. The I/O words allocated to those Units (IR 130 to IR 159) will be refreshed when IORF(97) is executed. This will be in addition to the normal I/O refresh performed during the CPU Unit's cycle.

To specify a particular 10-word Special I/O Unit Area (IR 100 to IR 190 or IR 400 to IR 450), input the first word of the 10-word area. (The last digit of the IR word must be 0.)

Refer to 5-25-9 GROUP-2 HIGH-DENSITY I/O REFRESH – MPRF(61) for details on refreshing words allocated to Group-2 High-density I/O Units.

Flags

ER: St and/or E aren't within the proper setting ranges.

(000 to 029, 040 to 040, 100 to 190, 300 to 309, or 400 to 450).

St and E aren't within the same setting range.

St is greater than E.

5-25-9 GROUP-2 HIGH-DENSITY I/O REFRESH – MPRF(61)

Ladder Symbols

MPRF(61) @MPRF(61) St St E E 000 000

Operand Data Areas

St: Starting unit number
#0000 to #000F
E: End unit number
#0000 to #000F
000 : Set to 000.

Limitations

MPRF(61) can be used to refresh I/O words allocated to Group-2 High-density I/O Units only. It cannot be used for other I/O words.

St and E must be between #0000 and #000F. St must be less than or equal to E.

Description

When the execution condition is OFF, MPRF(61) is not executed. When the execution condition is ON, the I/O words allocated to Group-2 High-density I/O Units with unit numbers St through E will be refreshed. This will be in addition to the normal I/O refresh performed during the CPU Unit's cycle.

It is not possible to specify the I/O words by address, only by the unit number of the Unit to which they are allocated.

Execution Time

The execution time for MPRF(61) is computed as follows:

 T_{MPRF} = Instruction execution time

+ Σ (Group-2 High-density I/O Unit I/O refresh times)

Refer to 6-1 Cycle Time for a table showing I/O refresh times for Group-2 High-density I/O Units.


Flags

ER: St or E is not BCD between #0000 and #000F.

St is greater than E.

5-25-10 BIT COUNTER - BCNT(67)

Ladder Symbols



Operand Data Areas

N: Number of words (BCD)
IR, SR, AR, DM, HR, TC, LR, #
SB: Source beginning word
IR, SR, AR, DM, HR, TC, LR
D: Destination word
IR, SR, AR, DM, HR, TC, LR

Limitations

N must be BCD between 0000 and 6656.

Description

When the execution condition is OFF, BCNT(67) is not executed. When the execution condition is ON, BCNT(67) counts the total number of bits that are ON in all words between SB and SB+(N-1) and places the BCD result in D.

Flags

ER: N is not BCD, or N is 0; SB and SB+(N-1) are not in the same area.

The resulting count value exceeds 9999.


Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)
ON when the count (N) exceeds the data area boundary.

EQ: ON when the result is 0.

5-25-11 FRAME CHECKSUM - FCS(---)

Ladder Symbols



Operand Data Areas


C: Control data
IR, SR, AR, DM, HR, LR, #
R ₁ : First word in range
IR, SR, AR, DM, HR, TC, LR
D: First destination word
IR, SR, AR, DM, HR, LR

Description

FCS(—) can be used to check for errors when transferring data through communications ports.

When the execution condition is OFF, FCS(—) is not executed. When the execution condition is ON, FCS(—) calculates the frame checksum of the specified range by exclusively ORing either the contents of words R_1 to R_1+N-1 or the bytes in words R_1 to R_1+N-1 . The frame checksum value (hexadecimal) is then converted to ASCII and output to the destination words (D and D+1).

The function of bits in C are shown in the following diagram and explained in more detail below.



Number of Items in Range

The number of items within the range (N) is contained in the 3 rightmost digits of C, which must be BCD between 001 and 999.

Calculation Units

The frame checksum of words will be calculated if bit 13 is OFF and the frame checksum of bytes will be calculated if bit 13 is ON.

If bytes are specified, the range can begin with the leftmost or rightmost byte of R_1 . The leftmost byte of R_1 will not be included if bit 12 is ON.

MSI	3 LSB
1	2
3	4
5	6
7	8
-:	-
	1

When bit 12 is OFF the bytes will be ORed in this order: 1, 2, 3, 4,

When bit 12 is ON the bytes will be ORed in this order: 2, 3, 4, 5,

Conversion to ASCII

The byte frame checksum calculation yields a 2-digit hexadecimal value which is converted to its 4-digit ASCII equivalent. The word frame checksum calculation yields a 4-digit hexadecimal value which is converted to its 8-digit ASCII equivalent, as shown below.

Byte frame checksum value

Word frame checksum value
F10B



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

D+1 4 6 3 1

The number of items is not 001 to 999 BCD.


The calculation range exceeds the data area.

Example

When IR 00000 is ON in the following example, the frame checksum (0008) is calculated for the 8 words from DM 0000 to DM 0007 and the ASCII equivalent (30 30 30 38) is written to DM 0011 and DM 0010.




Address	Instruction	Operands	
00000	LD		00000
00001	@FCS(—)		
		#	8000
		DM	0000
		DM	0010



5-25-12 FAILURE POINT DETECTION - FPD(--)

Ladder Symbols

Operand Data Areas



C: Control data
#
T: Monitoring time (BCD)
IR, SR, AR, DM, HR, TC. LR, #
D: First register word
IR, AR, DM, HR, LR


Limitations

D and D+8 must be in the same data area when bit 15 of C is ON. C must be input as a constant.

Description

FPD(—) can be used in the program as many times as desired, but each must use a different D. It is used to monitor the time between the execution of FPD(—) and the execution of a diagnostic output. If the time exceeds T, an FAL(06) non-fatal error will be generated with the FAL number specified in C.

The program sections marked by dashed lines in the following diagram can be written according to the needs of the particular program application. The processing programming section triggered by CY is optional and can used any instructions but LD and LD NOT. The logic diagnostic instructions and execution condition can consist of any combination of NC or NO conditions desired.




When the execution condition is OFF, FPD(—) is not executed. When the execution condition is ON, FPD(—) monitors the time until the logic diagnostics condition goes ON, turning ON the diagnostic output. If this time exceeds T, the following will occur:


- An FAL(06) error is generated with the FAL number specified in the first two digits of C. If 00 is specified, however, an error will not be generated.
 - The logic diagnostic instructions are searched for the first OFF input condition and this condition's bit address is output to the destination words beginning at D.
 - 3. The CY Flag (SR 25504) is turned ON. An error processing program section can be executed using the CY Flag if desired.
 - 4. If bit 15 of C is ON, a preset message with up to 8 ASCII characters will be displayed on the Peripheral Device along with the bit address mentioned in step 2.

Control Data

The function of the control data bits in C are shown in the following diagram.



Logic Diagnostic Instructions If the time until the logic diagnostics condition goes ON exceeds T, the logic diagnostic instructions are searched for the OFF input condition. If more than one input condition is OFF, the input condition on the highest instruction line and nearest the left bus bar is selected.




When IR 00000 to IR 00003 are ON, the normally closed condition IR 00002 would be found as the cause of the diagnostic output not turning ON.

Diagnostics Output

There are two ways to output the bit address of the OFF condition detected in the logic diagnostics condition.

1, 2, 3...
 Bit address output (used when bit 15 of C is OFF).
 Bit 15 of D indicates whether or not bit address information is stored in D+1.
 If there is, bit 14 of D indicates whether the input condition is normally open or closed.



D+1 contains the bit address code of the input condition, as shown below. The word addresses, bit numbers, and TC numbers are in binary.

Data		D+1 bit status														
area	15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
IR, SR (see	1	0	0	0	Woı	Word address			Bit number							
note c)	1	0	1	0	Woı	Word address Bit number										
HR	1	0	0	1	1	1 Word address			Bit r	numb	er					
LR	1	0	0	1	0	0 0 Word address Bit number										
TC*	1	0	0	1	0 1 * Timer or counter number											

Note a) *For the TC area, bit 09 of D+1 indicates whether the number is a timer or counter. A 0 indicates a timer, and a 1 indicates a counter.

- b) The status of the leftmost bit of the bit number (bit 03) is reversed.
- c) Although the same word address designations are used for both ranges, bit 13 is turned OFF to indicate IR 00000 through SR 25515 and turned ON to indicate SR 25600 through IR 51115

Example: If D + 1 contains 1000 0110 0100 1000, IR 10000 would be indicated as follows:

2. Bit address and message output (used when bit 15 of C is ON).

Bit 15 of D indicates whether or not there is bit address information stored in D+1 to D+3. If there is, bit 14 of D indicates whether the input condition is normally open or closed. Refer to the following table.

Words D+5 to D+8 contain information in ASCII that are displayed on a Peripheral Device along with the bit address when FPD(—) is executed. Words D+5 to D+8 contain the message preset by the user as shown in the following table.

Word	Bits 15 to 08	Bits 07 to 00
D+1	20 = space	First ASCII character of bit address
D+2	Second ASCII character of bit address	Third ASCII character of bit address
D+3	Fourth ASCII character of bit address	Fifth ASCII character of bit address
D+4	2D = "-"	"0"=normally open, "1"=normally closed
D+5	First ASCII character of message	Second ASCII character of message
D+6	Third ASCII character of message	Fourth ASCII character of message
D+7	Fifth ASCII character of message	Sixth ASCII character of message
D+8	Seventh ASCII character of message	Eighth ASCII character of message


Note If 8 characters are not needed in the message, input "0D" after the last character.

Determining Monitoring Time The procedure below can be used to automatically set the monitoring time, T, under actual operating conditions when specifying a word operand for T. This operation cannot be used if a constant is set for T.

- 1, 2, 3... 1. Switch the PC to MONITOR Mode operation.
 - 2. Connect a Peripheral Device, such as a Programming Console.
 - 3. Use the Peripheral Device to turn ON control bit AR 2508.
 - 4. Execute the program with AR 2508 turned ON. If the monitoring time currently in T is exceeded, 1.5 times the actual monitoring time will be stored in T. FAL(06) errors will not occur while AR 2508 is ON.
 - 5. Turn OFF AR 2508 when an acceptable value has been stored in T.


Example

In the following example, the FPD(—) is set to display the bit address and message ("ABC") when a monitoring time of 123.4 s is exceeded.



Address	Instruction	Oper	ands
00000	LD		25315
00001	MOV(21)		
		#	4142
		HR	15
00002	LD		25315
00003	MOV(21)		
		#	430D
		HR	16
00004	LD	LR	0000
00005	FPD(—)		
		#	8010
		#	1234
		HR	10
00006	AND		25504
00007	INC(38)		
		DM	0100
80000	LD		10000
00009	OR		10001
00010	LD NOT		10002
00011	OR NOT		10003
00012	AND LD		
00013	OUT	LR	0015

FPD(—) is executed and begins monitoring when LR 0000 goes ON. If LR 0015 does not turn ON within 123.4 s and IR 10000 through IR 10003 are all ON, IR 10002 will be selected as the cause of the error, an FAL(06) error will be generated with an FAL number of 10, and the bit address and preset message ("10002–1ABC") will be displayed on the Peripheral Device.



Flags ER: T is not BCD.

C is not a constant or the rightmost two digits of C are not BCD 00 to 99.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

CY: ON when the time between the execution of FPD(—) and the execution of a diagnostic output exceeds T.

5-25-13 DATA SEARCH - SRCH(---)

Ladder Symbols

Operand Data Areas

N: Number of words
IR, SR, AR, DM, HR, TC, LR, #
R ₁ : First word in range
IR, SR, AR, DM, HR, TC, LR
C: Comparison data, result word
IR, SR, AR, DM, HR, LR

Limitations

N must be BCD between 0001 to 6656.

 R_1 and R_1+N-1 must be in the same data area.

Description

When the execution condition is OFF, SRCH(—) is not executed. When the execution condition is ON, SRCH(—) searches the range of memory from R_1 to R_1+N-1 for addresses that contain the comparison data in C. If one or more addresses contain the comparison data, the EQ Flag (SR 25506) is turned ON and the lowest address containing the comparison data is identified in C+1. The address is identified differently for the DM area:

- For an address in the DM area, the word address is written to C+1. For example, if the lowest address containing the comparison data is DM 0114, then #0114 is written in C+1.
 - 2. For an address in another data area, the number of addresses from the beginning of the search is written to C+1. For example, if the lowest address containing the comparison data is IR 114 and the first word in the search range is IR 014, then #0100 is written in C+1.

If none of addresses in the range contain the comparison data, the EQ Flag (SR 25506) is turned OFF and C+1 is left unchanged.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

N is not BCD between 0001 and 6655.

EQ: ON when the comparison data has been matched in the search range.


Example

In the following example, the 10 word range from DM 0010 to DM 0019 is searched for addresses that contain the same data as DM 0000 (#FFFF). Since DM 0012 contains the same data, the EQ Flag (SR 25506) is turned ON and #0012 is written to DM 0001.



Address	Instruction	Opera	ands
00000	LD		00001
00001	@SRCH()		
		#	0010
		DM	0010
		DM	0000

DM 0010	0000
DM 0011	9898
DM 0012	FFFF
DM 0013	9797
DM 0014	AAAA
DM 0015	9595
DM 0016	1414
DM 0017	0000
DM 0018	0000
DM 0019	FFFF



5-25-14 EXPANSION DM READ – XDMR(—)

Ladder Symbols

Operand Data Areas

N: Number of words
IR, SR, AR, DM, HR, TC, LR, #
S: First expansion DM word
IR, SR, AR, DM, HR, TC, LR, #
D: First destination word
IR, SR, AR, DM, HR, LR

Limitations N must be BCD between 0001 and 3000.

S must be BCD between 7000 and 9999.

S and S+N-1 must be in the same data area, as must D and D+N-1.

Description

When the execution condition is OFF, XDMR(—) is not executed. When the execution condition is ON, XDMR(—) copies the contents of expansion DM words S through S+N-1 to the destination words D through D+N-1.

Precautions

The Expansion DM area must be set in the PC Setup before it can be used in programming. Do not exceed the set range of the Expansion DM area.

Execution of XDMR(—) is given priority whenever a power interruption occurs.

Flags

ER: The specified expansion DM words are non-existent. Make sure that the specified words have been allocated to expansion DM. Refer to 7-2-15 UM Area Allocation for details.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

N is not BCD between 0001 and 3000.


S is not BCD between 7000 and 9999.

Example

In the following example, the 100 word range from DM 7000 through DM 7099 is copied to DM 0010 through DM 0109 when IR 00001 is ON.




Address	Instruction	Oper	ands
00000	LD		00001
00001	@XDMR()		
		#	0100
		#	7000
		DM	0010




5-25-15 INDIRECT EM ADDRESSING – IEMS(—)

Ladder Symbols

Operand Data Areas





Limitations Description

C must be 000, #E000, #E0B0, #E0B1, or #E0B2.

When executed with an ON execution condition, IEMS(—) changes the destination of indirect DM addressing (*DM) to DM or the specified EM bank. The current EM bank number can also be changed when indirect addressing is changed to EM.

The destination for *DM is switched to the DM area at the start of an interrupt subroutine. It is also returned to the DM area at the beginning of each scan.

The following table shows the allowed values for C and their functions:

С	IEMS(—) Operation					
000	Switches the destination of ⋆DM to the DM area.					
#E000	Switches the destination of *DM to the current bank in the EM area.					
#E0B0	Switches the destination of *DM to the bank 0 in the EM area.					
#E0B1	1 Switches the destination of *DM to the bank 1 in the EM area.					
#E0B2	Switches the destination of *DM to the bank 2 in the EM area.					

The content of DM 6031 indicates the current *DM destination and the current EM bank number as shown in the following table. Use DM 6031 in the ladder-diagram program to determine if the contents of indirect DM addressing is the DM or EM area. (Programming Devices cannot be used here because bits 08 to 15 will always indicate the DM area when read from the Programming Device.)

Word	Bits 00 to 07	Bits 08 to 15
DM 6031	Current EM bank number (00 to 02)	*DM destination (00: DM; 80: EM)


Note Input 000 for the second and third operands when using replacement instructions.

Flags

ER: C is not one of the allowed values.

Example


In the following example, IEMS(—) changes the destination for *DM to EM bank 1 and uses indirect addressing to move #1234 into EM 0001 in EM bank 1.



5-25-16 SELECT EM BANK - EMBC(---)



Operand Data Areas



N : Bank number
IR, SR, AR, DM, HR, LR, #

Limitations

N must be 0000, 0001, or 0002 and the bank number specified by N must exist in the CPU Unit.

Description

When executed with an ON execution condition, EMBC(—) changes the current EM bank to the specified bank number. The CPU Unit can access only the current bank, which is indicated in bits 00 through 07 of DM 6031.

An error will occur and EMBC(—) won't be executed if the specified bank number doesn't exist in the CPU Unit.


Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

The specified bank number, N, doesn't exist in the CPU Unit.

Example

In the following example, EMBC(—) changes the current bank to bank number 2 when IR 00000 is ON.



5-26 Network Instructions

The network instructions are used for communicating with other PCs, BASIC Units, or host computers linked through the SYSMAC NET Link System, SYSMAC LINK System, Ethernet System, or Controller Link System.

5-26-1 NETWORK SEND – SEND(90)

Ladder Symbols

Operand Data Areas

S: Source beginning word
IR, SR, AR, DM, HR, TC, LR
D: Destination beginning word
IR, SR, AR, DM, HR, TC, LR
C: First control data word
IR, SR, AR, DM, HR, TC, LR

Limitations

Description

C through C+2 must be within the same data area and must be within the values specified below. To be able to use SEND(90), the system must have a SYSMAC NET Link, SYSMAC LINK Unit, PC Card Unit, or Controller Link Unit mounted.

When the execution condition is OFF, SEND(90) is not executed. When the execution condition is ON, SEND(90) transfers data beginning at word S, to addresses specified by D in the designated node on the SYSMAC NET Link, SYSMAC LINK System, Ethernet System, or Controller Link System. The control words, beginning with C, specify the number of words to be sent, the destination node, and other parameters. The contents of the control data depends on whether a transmission is being sent in a SYSMAC NET Link System, a SYSMAC LINK System, an Ethernet System, or a Controller Link System.

The status of bit 15 of C+1 determines whether the instruction is for a SYSMAC NET Link System or a SYSMAC LINK/Ethernet/Controller Link System.

Control Data

Ethernet Systems

Set the destination node number to 0 to send the data to all nodes. Refer to the *PC Card Unit Operation Manual* for details.

Word	Bits 00 to 07	Bits 08 to 15
С	Number of words (0 to 1000 in 4-digit	t hexadecimal, i.e., 0000 _{hex} to 03E8 _{hex)}
C+1	Response time limit (0.1 and 25.4 seconds in 0.1 s increments in 2-digit hexadecimal without decimal point, i.e., 01 _{hex} to FF _{hex})	Bits 08 to 11: No. of retries (0 to 15 in hexadecimal, i.e., 0 _{hex} to F _{hex})
	Default is 00_{hex} (2 seconds)	Bit 12 ON: Direct destination beginning word designation OFF: Indirect designation
		Bit 13 ON: Response not returned. OFF: Response returned.
		Bit 14 ON: Operating level 0 OFF: Operating level 1
		Bit 15: Set to 1.
C+2	Destination node (0 to 127 in 2-digit hexadecimal, i.e., 00_{hex} to $7E_{hex}$)*	Bits 08 to 12: Unit address of destination node. Set to 00 _{hex} .
		Bits 13 to 15: Set to 0.

SYSMAC NET Link Systems

The destination port number is always set to 0. Set the destination node number to 0 to send the data to all nodes. Set the network number to 0 to send data to a node on the same Subsystem (i.e., network). Refer to the SYSMAC NET Link System Manual for details.

Word	Bits 00 to 07	Bits 08 to 15
С	Number of words (0 to 1000 in 4-digit	hexadecimal, i.e., 0000 _{hex} to 03E8 _{hex})
C+1	Network number (0 to 127 in 2-digit hexadecimal, i.e., 00_{hex} to $7F_{hex}$)	Bit 12 ON: Direct destination beginning word designation OFF: Indirect designation
		Bit 14 ON: Operating level 0 OFF: Operating level 1 Bits 08 to 11, 13 and 15: Set to 0.
C+2	Destination node (0 to 126 in 2-digit hexadecimal, i.e., 00_{hex} to $7E_{hex}$)*	Destination port NSB: 00 NSU: 01/02

^{*}The node number of the PC executing the send may be set.

SYSMAC LINK Systems


Set the destination node number to 0 to send the data to all nodes. Refer to the SYSMAC LINK System Manual for details.

Word	Bits 00 to 07		Bits 08 to 15
С	Number of words (0 to 1000 in 4-digit	hexadeci	mal, i.e., 0000 _{hex} to 03E8 _{hex)}
C+1	Response time limit (0.1 and 25.4 seconds in 2-digit hexadecimal without decimal point, i.e., 00_{hex} to FF _{hex})	Bits 08 t	to 11: No. of retries (0 to 15 in hexadecimal, i.e., 0 _{hex} to F _{hex})
	Note: The response time will be 2 seconds if the limit is set to 0_{hex} . There will be no time limit if the time limit is set to FF_{hex} .	Bit 12	ON: Direct destination beginning word designation OFF: Indirect designation
		Bit 13	ON: Response not returned. OFF: Response returned.
		Bit 14	ON: Operating level 0 OFF: Operating level 1
		Bit 15:	Set to 1.
C+2	Destination node (0 to 62 in 2-digit hexadecimal, i.e., 00_{hex} to $3E_{hex}$)*	Set to 0	

^{*}The node number of the PC executing the send cannot be set.

Controller Link Systems

SEND(90) transmits "n" words beginning with S (the beginning source word for data transmission at the source node) to the "n" words beginning with D (the beginning destination word for data reception at destination node N).



This setting is enabled only when "Destination network address specified" is set in word C. When specifying a destination network address, set all the nodes in the routing tables. For details on routing tables, refer to refer to the section on network interconnections in the *Controller Link Unit Operation Manual (W309)*.

Note

- When communicating in the same network with CV-series PCs manufactured prior to April 1996, the local network address cannot be set to "00." Set a number other than "00" as the local network address in the routing tables, and then specify that number.
- 2. With the message service, there is no guarantee that a message to a destination node will reach its destination. It is always possible that the message may be lost in transit due to noise or some other condition. When using the message service, it is advisable to prevent this situation from occurring by performing resend processing at the node where instructions are issued. With the SEND, RECV, and CMND(194) instructions, resend processing is performed automatically once the number of retries has been set, so be sure to specify a number other than "0" for the number of retries.

Indirect Destination Beginning Word Designations

D is used to specify the destination beginning word as follows when indirect specification is designated:

	12 to 15	08 to 11	04 to 07	00 to 03
D	Area type		0	Word no. (5th digit)
D+1	Word no. (4th digit)	Word no. (3rd digit)	Word no. (2nd digit)	Word no. (1st digit)

SYSMAC NET Link Systems

Indirect designations depend on the series of the destination PC.

CV-series PCs

Addresses in parentheses are for the CV500.

Designation			Corresponding	g CV-series PC words		
Area Area code		Word number	Area	Word number		
IR area	00	0 to 999	CIO Area	0 to 999		
LR area	06	0 to 63		1000 to 1063		
HR area	07	0 to 99		1064 to 1163		
SR area	08	0 to 27		1164 to 1191		
Timer area (PV)	03	0 to 1023	Timer Area (PV)	0 to 1023 (0 to 511)		
DM area	05	0 to 24575	DM Area	0 to 24575 (0 to 8191)		

C-series PCs

	Designation				
Area	Area Area code Word numbe				
IR area	00	0 to 511			
LR area	06	0 to 63			
HR area	07	0 to 99			
SR area	08	0 to 27			
Timer area (PV)	03	0 to 511			
DM area	05	0 to 6655			
EM area	10 to 17 (Bank 0 to 7)	0 to 6143			
	28 to 2F (Bank 8 to 15)				
	18 (Current bank)				

SYSMAC LINK/Ethernet Systems

Indirect designations depend on the series of the destination PC.

CV-series PCs

	Designation				
Area	Area code	Word number			
CIO Area	00	0 to 2555			
CPU Bus Link Area	01	0 to 255			
Auxiliary Area	02	0 to 511			
Timer Area	03	0 to 1023			
Counter Area	04	0 to 1023			
DM Area	05	0 to 24575			
EM Area	10 to 17: Bank 0 to 7	0 to 32765			
	18: Current bank				

C-s	~=:			_
C-S	eri	es	г,	U.S


Designation				
Area	Area code	Word number		
IR area	00	0 to 511		
LR area	06	0 to 63		
HR area	07	0 to 99		
SR area	08	0 to 27		
Timer area (PV)	03	0 to 511		
DM area	05	0 to 6655		

Controller Link Systems

CV-series PCs have a larger area than C200HX/HG/HE PCs, so the beginning words for sending and receiving at destination nodes cannot always be directly specified by means of SEND(192) and RECV(193) operands. Moreover, depending on circumstances, it may be desirable to change the beginning word at destination nodes.

In such cases, set the "Direct/Indirect" control data designation to "1" (Indirect), and specify the beginning words for sending as described below.

The beginning receive word is determined by the contents of the destination node's D and D+1 words.




Note Specify the area code according to the following table.


Destination node: C200HX/HG/HE PC			Destinatio	n node: CV-series F	oc.
Area Code			Are	ea	Code
IR (Internal Relay)		00	CIO		00
LR (Link Relay)		06	CPU Bus Link		01
HR (Holding Relay)		07	Auxiliary		02
AR (Auxiliary Relay)		08	Timer		03
TC (Timer/Counter)		03	Counter		04
DM (Data Memory)		05	DM (Data Memory)		05
EM (Expansion DM)	Banks 0 to 7 Banks 8 to 15 Current bank	10 to 17 28 to 2F 18	EM (Expansion DM)	Banks 0 to 7 Current bank	10 to 17 18

Examples

This example is for a SYSMAC NET Link System. When 00000 is ON, the following program transfers the content of IR 001 through IR 005 to LR 20 through LR 24 on node 10.



Address	Instruction	Opera	nds
00000	LD		00000
00001	SEND(90)		
			001
		LR	20
		DM	0010



Flags


ER: The specified node number is greater than 126 in a SYSMAC NET Link System, greater than 62 in a SYSMAC LINK System, or greater than 127 in an Ethernet or Controller Link System.

The sent data overruns the data area boundaries.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

There is no SYSMAC NET Link/SYSMAC LINK/PC Card/Controller Link Unit.

5-26-2 NETWORK RECEIVE – RECV(98)



RECV(98) S D C C

Operand Data Areas

S: Source beginning word
IR, SR, AR, DM, HR, TC, LR
D : Destination beginning word
IR, SR, AR, DM, HR, TC, LR
C: First control data word

IR, SR, AR, DM, HR, TC, LR

Limitations

C through C+2 must be within the same data area and must be within the values specified below. To be able to use RECV(98), the system must have a SYSMAC NET Link, SYSMAC LINK Unit, or PC Card Unit mounted.

Description

When the execution condition is OFF, RECV(98) is not executed. When the execution condition is ON, RECV(98) transfers data beginning at S from a node on the SYSMAC NET Link, SYSMAC LINK, Ethernet System to words beginning at D. The control words, beginning with C, provide the number of words to be received, the source node, and other transfer parameters.

The status of bit 15 of C+1 determines whether the instruction is for a SYSMAC NET Link System or a SYSMAC LINK/Ethernet System.

Control Data

Ethernet Systems

Refer to the PC Card Unit Operation Manual for details.

Word	Bits 00 to 07	Bits 08 to 15	
С	Number of words (0 to 1000 in 4-digit	hexadeo	cimal, i.e., 0000 _{hex} to 03E8 _{hex)}
C+1	Response time limit (0.1 and 25.4 seconds in 0.1 s increments in 2-digit hexadecimal without decimal point, i.e., 01 _{hex} to FF _{hex})	Bits 08	to 11: No. of retries (0 to 15 in hexadecimal, i.e., 0 _{hex} to F _{hex})
	Default is 00_{hex} (2 seconds)	Bit 12	ON: Direct source beginning word designation OFF: Indirect designation
		Bit 13	ON: Response not returned. OFF: Response returned.
		Bit 14	ON: Operating level 0 OFF: Operating level 1
		Bit 15:	Set to 1.
C+2	Source node (0 to 127 in 2-digit hexadecimal, i.e., 00_{hex} to $7F_{hex}$)*	Bits 08	to 12: Unit address of source node. Set to 00 _{hex} . to 15: Set to 0.

SYSMAC NET Link Systems

The source port number is always set to 0. Set the network number to 0 to receive data to a node on the same Subsystem (i.e., network). Refer to the SYS-MAC NET Link System Manual for details.

Word	Bits 00 to 07	Bits 08 to 15	
С	Number of words (0 to 1000 in 4-digit	hexadecimal, i.e., 0000 _{hex} to 03E8 _{hex})	
C+1	Network number (0 to 127 in 2-digit hexadecimal, i.e., 00_{hex} to $7F_{hex}$)	Bit 12 ON: Direct source beginning word designation OFF: Indirect designation	
		Bit 14 ON: Operating level 0 OFF: Operating level 1 Bits 08 to 11, 13 and 15: Set to 0.	
C+2	Source node (1 to 126 in 2-digit hexadecimal, i.e., 01 _{hex} to 7E _{hex})	Source port NSB: 00 NSU: 01/02	


SYSMAC LINK Systems

Refer to the SYSMAC LINK System Manual for details.

Word	Bits 00 to 07	Bits 08 to 15
С	Number of words (0 to 256 in 4-digit	hexadecimal, i.e., 0000 _{hex} to 0100 _{hex})
C+1	Response time limit (0.1 and 25.4 seconds in 2-digit hexadecimal without decimal point, i.e., 00_{hex} to FF_{hex}) Note: The response time will be 2 seconds if the limit is set to 0_{hex} . There will be no time limit if the time limit is set to FF_{hex} .	Bits 08 to 11: No. of retries (0 to 15 in hexadecimal, i.e., 0hex to Fhex) Bit 12 ON: Direct source beginning word designation OFF: Indirect designation Bit 13: Set to 0. Bit 14 ON: Operating level 0 OFF: Operating level 1 Bit 15: Set to 1.
C+2	Source node (0 to 62 in 2-digit hexadecimal, i.e., 00_{hex} to $3E_{hex}$)	Set to 0.


Controller Link Systems

RECV(98) receives "m" words beginning with S (the beginning word for data transmission at the destination node, M) to the words from D (the beginning word for data reception at the source node) onwards.





- S: Destination node beginning send word
- D: Source node beginning receive word
- C: Source node first control data word



This setting is enabled only when "Destination network address specified" is set in word C. When specifying the destination network address, set all the nodes in the routing tables. For details on the routing tables, refer to the section on network interconnections in the *Controller Link Unit Operation Manual (W309)*.

Note 1. When communicating in the same network with CV-series PCs manufactured prior to April 1996, the local network address cannot be set to "00." Set a number other than "00" as the local network address in the routing tables, and then specify that number.

2. With the message service, there is no guarantee that a message to a destination node will reach its destination. It is always possible that the message may be lost in transit due to noise or some other condition. When using the message service, it is advisable to prevent this situation from occurring by performing resend processing at the node where instructions are issued. With the SEND, RECV, and CMND(194) instructions, resend processing is performed automatically once the number of retries has been set, so be sure to specify a number other than "0" for the number of retries.

Indirect Destination Beginning Word Designations


D is used to specify the sourced beginning word when indirect specification is designated using the same designations as those used for the destination beginning word for SEND(90).


Examples

This example is for a SYSMAC NET Link System. When 00000 is ON, the following program transfers the content of IR 001 through IR 005 to LR 20 through LR 24 on node 10.



Address	Instruction	Operands	
00000	LD		00000
00001	RECV(98)		
			001
		LR	20
		DM	0010





Flags

ER: The specified node number is greater than 126 in a SYSMAC NET Link System, greater than 62 in a SYSMAC LINK System, or greater than 127 in an Ethernet or Controller Link System.

The received data overflows the data area boundaries.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

There is no SYSMAC NET Link/SYSMAC LINK/PC Card/Controller Link Unit.


5-26-3 About Network Communications

SEND(90) and RECV(98) are based on command/response processing. That is, the transmission is not complete until the sending node receives and acknowledges a response from the destination node. Note that the SEND(90)/RECV(98) Enable Flag is not turned ON until the first END(01) after the transmission is completed. Refer to the SYSMAC NET Link System Manual or SYSMAC LINK System Manual for details about command/response operations.

If multiple SEND(90)/RECV(98) operations are used, the following flags must be used to ensure that any previous operation has completed before attempting further send/receive SEND(90)/RECV(98) operations

SR Flag	Functions
SEND(90)/RECV(98) Enable Flags (SR 25201, SR 25204)	OFF during SEND(90)/RECV(98) execution (including command response processing). Do not start a SEND(90)/RECV(98) operation unless this flag is ON.
SEND(90)/RECV(98) Error Flags	OFF following normal completion of SEND/RECV (i.e., after reception of response signal)
(SR 25200, SR 25203)	ON after an unsuccessful SEND(90)/RECV(98) attempt. Error status is maintained until the next SEND(90)/RECV(98) operation.
	Error types: Time-out error (command/response time greater than 1 second) Transmission data errors

Timing




Data Processing for SEND(90)/RECV(98)

Data is transmitted for SEND(90) and RECV(98) for all PCs when SEND(90)/RECV(98) is executed. Final processing for transmissions/receptions is performed during servicing of peripheral devices and Link Units.

Programming Example: Multiple SEND(90)/RECV(98)

To ensure successful SEND(90)/RECV(98) operations, your program must use the SEND(90)/RECV(98) Enable Flags and SEND(90)/RECV(98) Error Flags to confirm that execution is possible. The following program shows one example of how to do this for a SYSMAC NET Link System.




Address	Instruction	Operands	
00000	LD	00000	
00001	AND		25204
00002	AND NOT		12802
00003	LD		12801
00004	KEEP(11)		12800
00005	LD		12800
00006	@MOV(21)		
		#	000A
		DM	0000
00007	@MOV(21)		
		#	0000
		DM	0001
80000	@MOV(21)		
		#	0003
		DM	00002
00009	@XFER(70)		
		#	0010
			000
		DM	0002
00010	@SEND(90)		
		DM	0010
		DM	0020
		DM	0000
00011	LD		12800
00012	AND		25203
00013	OUT		00200
00014	LD		12800
00015	AND		25204
00016	DIFU(13)		12801
00017	LD		00001
00018	AND		25204

	1	
Address	Instruction	Operands
00019	AND NOT	12800
00020	LD	12803
00021	KEEP(11)	12802
00022	LD	12802
00023	AND	25204
00024	AND NOT	25203
00025	XFER(70)	
		# 0016
		000
		DM 0030
00026	LD	12802
00027	@MOV(21)	
		# 0010
		DM 0003
00028	@MOV(21)	
		# 0000
		DM 0004
00029	@MOV(21)	
		# 007E
		DM 0005
00030	@RECV(98)	
		HR 10
		LR 10
		DM 0003
00031	LD	12802
00032	AND	25203
00033	OUT	00201
00034	LD	12802
00035	AND	25204
00036	DIFU(13)	12803

5-27 Serial Communications Instructions

5-27-1 RECEIVE - RXD(---)

Ladder Symbols



Operand Data Areas

D: First destination word	
IR, SR, AR, DM, HR, TC, LR	
C: Control word	
IR, SR, AR, DM, HR, TC, LR, #	
N: Number of bytes	
IR, SR, AR, DM, HR, TC, LR, #	

Limitations

D and D+(N \div 2)–1 must be in the same data area.

N must be BCD from #0000 to #0256.

Description

When the execution condition is OFF, RXD(—) is not executed. When the execution condition is ON, RXD(—) reads N bytes of data received at the peripheral port, and then writes that data in words D to D+(N+2)-1. Up to 256 bytes of data can be read at one time.

If fewer than N bytes are received, the amount received will be read.


Note RXD(—) is required to receive data via the peripheral port or RS-232C port only. Transmission sent from a host computer to a Host Link Unit are processed automatically and do not need to be programmed.




The PC will be incapable of receiving more data once 256 bytes have been received if received data is not read using RXD(—). Read data as soon as possible after the Reception Completed Flag is turned ON (SR 26414 for the peripheral port, SR26406 for the RS-232C port).


Control Word

The value of the control word determines the port from which data will be read and the order in which data will be written to memory.



The order in which data is written to memory depends on the value of digit 0 of C. Eight bytes of data 12345678... will be written in the following manner:





Flags

ER: The CPU Unit is not equipped with an RS-232C port.

Another device is not connected to the specified port.

There is an error in the communications settings (PC Setup) or the operand settings.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

The destination words (D to D+(N+2)-1) exceed the data area.

Peripheral Port

26414: SR 26414 will be turned ON when data has been received normally at the peripheral port and will be reset when the data is read using RXD(—) is executed.

266: SR 266 contains the number of bytes received at the peripheral port and is reset to 0000 when RXD(—) is executed.

RS-232C Port

26406: SR 26406 will be turned ON when data has been received normally at the peripheral port and will be reset when the data is read using RXD(—) is executed.

265: SR 265 contains the number of bytes received at the RS-232C port and is reset to 0000 when RXD(—) is executed.

Note Communications flags and counters can be cleared either by specifying 0000 for N or using the Port Reset Bit (SR 25208 for peripheral port and SR 25209 for RS-232C port).

5-27-2 TRANSMIT – TXD(—)

Ladder Symbols

TXD(—) S C N N

Operand Data Areas

S: First source word	
IR, SR, AR, DM, HR, TC, LR	
C: Control word	
IR, SR, AR, DM, HR, TC, LR, #	
N: Number of bytes	
IR, SR, AR, DM, HR, TC, LR, #	

Limitations

S and S+(N+2)-1 must be in the same data area.

N must be BCD from #0000 to #0256. (#0000 to #0061 in host link mode)

Description


When the execution condition is OFF, TXD(—) is not executed. When the execution condition is ON, TXD(—) reads N bytes of data from words S to S+(N+2)-1, converts it to ASCII, and outputs the data from the specified port. TXD(—) operates differently in host link mode and RS-232C mode, so these modes are described separately.

Note The following flags will be ON to indicate that communications are possible through the various ports. Be sure the corresponding flag is ON before executing TXD(—).

SR 26405: RS-232C port
SR 26413: Peripheral port
SR 26705: Host Link Unit #0
SR 26713: Host Link Unit #1

Host Link Mode

N must be BCD from #0000 to #0061 (i.e., up to 122 bytes of ASCII). The value of the control word determines the port from which data will be output, as shown below.




Note Data is not output when the CTS and DSR signals are monitored.

The specified number of bytes will be read from S through S+(N/2)–1, converted to ASCII, and transmitted through the specified port. The bytes of source data shown below will be transmitted in this order: 12345678...

	MSI	3 LSB
S	1	2
S+1	3	4
S+2	5	6
S+3	7	8
!		

The following diagram shows the format for host link command (TXD) sent from the PC. Depending on their settings, the C200 HX/HG/HE and C200HS automatically attach the prefixes and suffixes, such as the node number, header, and FCS.




RS-232C Mode

N must be BCD from #0000 to #0256. The value of the control word determines the port from which data will be output and the order in which data will be written to memory.

Control Word

The value of the control word determines the port from which data will be read and the order in which data will be written to memory.



Note Data is not output when the CTS and DSR signals are monitored.

The specified number of bytes will be read from S through S+(NP2)–1 and transmitted through the specified port.

	MSI	B LSB
S	1	2
S+1	3	4
S+2	5	6
S+3	7	8
:	:	-:

When digit 0 of C is 0, the bytes of source data shown above will be transmitted in this order: 12345678...

When digit 0 of C is 1, the bytes of source data shown above will be transmitted in this order: 21436587...

Note When start and end codes are specified the total data length should be 256 bytes max., including the start and end codes.

Flags

ER: Another device is not connected to the peripheral port.

There is an error in the communications settings (PC Setup) or the operand settings.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

The source words (S to S+(N+2)-1) exceed the data area.

26405: RS-232C Port Communications Enabled Flag
26413: Peripheral Port Communications Enabled Flag
26705: Host Link Unit #0 Communications Enabled Flag
26713: Host Link Unit #1 Communications Enabled Flag

5-27-3 CHANGE RS-232C SETUP – STUP(—)

Ladder Symbols

STUP(—) N S S ---

Operand Data Areas

N: RS-232C port specifier
IR 000, IR 001, or IR 002
S: First source word
IR, SR, AR, DM, HR, TC, LR, #

The 3rd operand is ignored.

Limitations

N must be IR 000, IR 001, or IR 002.

S and S+4 must be in the same data area.

(S can be set to #0000 to change the RS-232C settings to their defaults.)

STUP(—) can't be executed for the internal RS-232C port if pin 2 of the DIP switch is ON.

STUP(—) can't be executed within an interrupt subroutine.

Description

When the execution condition is OFF, STUP(—) is not executed. When the execution condition is ON, STUP(—) changes the PC Setup settings for the port specified by N.

N determines which part of the RS-232C Setup is changed.

N	Specified Port		
IR 000	Built-in RS-232C port (PC Setup: DM 6645 to DM 6649)		
IR 001	Communications Board port A (PC Setup: DM 6555 to DM 6559)		
IR 002	Communications Board port B (PC Setup: DM 6550 to DM 6554)		


If S is a word address, the contents of S through S+4 are copied to the 5 words in the PC Setup that contain the settings for the port specified by N.

If S is input as the constant #0000, the settings for the specified port are returned to their default values.

S	Function
Word address	The contents of S through S+4 are copied to the part of the PC Setup that contains the settings for the port specified by N.
Constant (#0000)	The settings for the port specified by N are returned to their default values.


Application Example

This example shows a program that transfers the contents of DM 0100 through DM 0104 to the PC Setup area for Communications Board port A (DM 6555 through DM 6569).



Address	Instruction	Operands
00000	LD	00000
00001	@STUP(—)	
		001
		DM 0100
		000

The settings are transferred as shown below. The Changing RS-232C Setup Flag (SR 27504) will be turned OFF when the transfer has been completed.



(Refer to 3-6-4 PC Setup for details.)

The following table shows the function of the transferred setup data.

Word	Content (see note)	Function
DM 0100	1001	Enables the communications settings in DM 0101 and sets the communications mode to RS-232C.
DM 0101	0803	Sets the following communications settings: 9,600 bps, 1 start bit, 8-bit data, 1 stop bit, no parity
DM 0102	0000	No transmission delay (0 ms)
DM 0103	2000	Enables the end code CR, LF.
DM 0104	0000	

Note For details on the contents of setup data, refer to 3-6-4 PC Setup.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

The port specifier (N) isn't IR 000, IR 001, or IR 002.

Port A has been specified, but pin 2 of the DIP switch is ON.

The PC Setup is write-protected. (Pin 1 of the DIP switch is ON.)

The specified source words exceed the data area.

The instruction was executed from an interrupt program.

5-27-4 PROTOCOL MACRO – PMCR(—)

Ladder Symbols

@PMCR(-PMCR(---) С С S S D D

Operand Data Areas

C: Control word
IR, SR, AR, DM, HR, TC, LR, #
S: First output word
IR, SR, AR, DM, HR, TC, LR, #
D: First input word
IR, SR, AR, DM, HR, TC, LR

Limitations

C must be BCD from #1000 to #2999.

DM 6144 through DM 6655 cannot be used for D.

Description

When the execution condition is OFF, PMCR(—) is not executed. When the execution condition is ON, PMCR(—) calls and executes the specified communications sequence (protocol data) that has been registered in the Communications Board installed in the PC.

The send/receive message for the communications sequence registered in the Communications Board must be set to read or write word data when DM isn't specified for S and D. Use a constant when it isn't necessary to set a word for the first output word.


When the communications sequence doesn't require an input word, specify a word address anyway. Data won't be stored in the specified word and the contents of the word will be retained. When the communications sequence does require input words, specify words that aren't used for any other purpose in the program.

The input and output words (S and D) can also be set in the communications sequence registered in the Communications Board.

Note Refer to the Communications Board Operation Manual for details on the Communications Boards and the Protocol Software Operation Manual for details on communications sequences.

Control Word

The first digit of the control word (1 or 2) specifies the Communications Board port and the last three digits specify the communications sequence (000 to 999), as shown in the following diagram.



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

D is not BCD or DM 6144 through DM 6655 has been used for D.


Another PMCR(—) instruction was already in progress when the instruction was executed.

The port specifier was not 1 or 2.

Example

When IR 00000 is ON and SR 28908 (the Communications Board Port A Instruction Execution Flag) is OFF, communications sequence 100 is called in the Communications Board and data is transferred through Communications Board port A.

Send data is read from the range of words beginning at DM 0000 (the first output word) and reception data is stored in the range of words beginning at DM 0010 (the first input word).



Address	Instruction	Operands	
00200	LD		00000
00201	AND NOT	28908	
00202	PMCR()		
		#	1100
		DM	0000
		DM	0010

5-28 Advanced I/O Instructions

Advanced I/O instructions enable control, with a single instruction, of previously complex operations involving external I/O devices (digital switches, 7-segment displays, etc.).

There are five advanced I/O instructions, as shown in the following table. All of these are expansion instructions and must be assigned to function codes before they can be used.

Name	Mnemonic	Function
7-SEGMENT DISPLAY OUTPUT	7SEG(—)	BCD output to 7-segment display
DIGITAL SWITCH INPUT	DSW(—)	Data input from a digital switch
HEXADECIMAL KEY INPUT	HKY(—)	Hexadecimal input from 16-key keypad
TEN-KEY INPUT	TKY(—)	BCD input from 10-key keypad
MATRIX INPUT	MTR()	Data input from an 8 x 8 matrix

Although TKY(—) is used only to simplify programming, the other advanced I/O instructions can be used to shorten cycle time, reduce the need for Special I/O Units, and reduce system cost. With the exception of TKY(—), however, the advanced I/O instructions can only be used once each in the program and cannot be used for I/O Units mounted to Slave Racks, where Special I/O Units must be used.

5-28-1 7-SEGMENT DISPLAY OUTPUT – 7SEG(—)

Ladder Symbols

7SEG(—) S O C

Operand Data Areas

S: First source word
IR, SR, AR, DM, HR, TC, LR
O: Output word
IR, SR, AR, DM, HR, LR
C: Control data
000 to 007

Limitations

S and S+1 must be in the same data area. DM 0000 to DM6143 can be used for O.

Do not set C to values other than 000 to 007.

Overview

When the execution condition is OFF, 7SEG(—) is not executed. When the execution condition is ON, 7SEG(—) reads the source data (either 4 or 8-digit), converts it to 7-segment display data, and outputs that data to the 7-segment display connected to the output indicated by O.

The value of C indicates the number of digits of source data and the logic for the Input and Output Units, as shown in the following table.

Source data	Display's data input logic	Display's latch input logic	С
4 digits (S)	Same as Output Unit Same as Output Unit		000
		Different from Output Unit	001
	Different from Output Unit	Same as Output Unit	002
		Different from Output Unit	003
8 digits	Same as Output Unit	Same as Output Unit	004
(S, S+1)		Different from Output Unit	005
	Different from Output Unit	Same as Output Unit	006
		Different from Output Unit	007

If there are 8 digits of source data, they are placed in S and S+1, with the most significant digits placed in S+1. If there are 4 digits of source data, they are placed in S.

7SEG(—) displays the 4 or 8-digit data in 12 cycles, and then starts over and continues displaying the data.

The 7-segment display must provide four data lines and one latch signal line for each display digit.

Note

- 1. Consider the cycle time and the characteristics of the 7-segment display when designing the system.
- 2. Output bits not used here can be used as ordinary output bits.

Precautions

I/O refreshing must be performed for all I/O points used by 7SEG(—) each time it is executed to ensure effective operation. The I/O REFRESH instruction must thus be used with 7SEG(—) whenever 7SEG(—) is used in a subroutine to ensure that the I/O points are refreshed each execution. Refer to page 352 for an example of this type of programming.


7SEG(—) will be executed from the first cycle whenever program execution is started, including restarts made after power interruptions.

Do not use 7SEG(—) more than twice in the program.

7SEG(—) cannot be used for I/O Units mounted to Slave Racks.

Hardware

This instruction outputs word data to a 7-segment display. It utilizes either 8 output bits for 4 digits or 12 output bits for 8 digits. The 7-segment display is connected to an Output Unit as shown in the diagram below. For 4-digit display, the data outputs (D0 to D3) are connected to output points 0 through 3 (allocated word O), and latch outputs (CS0 to CS3) are connected to output points 4 through 7. Output point 12 (for 8-digit display) or output point 8 (for 4-digit display)



play) will be turned ON when one round of data is displayed, but there is no need to connect them unless required by the application.

The outputs must be connected from an Output Unit with 8 or more output points for four digits or 16 or more output points for eight digits. Basic Output, Special I/O, or High-density Output Units can be used.

Note

- 1. Output Unit outputs normally employ negative logic. (Only the PNP output type employs positive logic.)
- 2. The 7-segment display may require either positive or negative logic, depending on the model.
- 3. The 7-segment display must have 4 data signal lines and 1 latch signal line for each digit.

Using the Instruction

If the first word holding the data to be displayed is specified at S, and the output word is specified at O, and the SV taken from the table below is specified at C, then operation will proceed as shown below when the program is executed. If only four digits are displayed, then only word S will be used.

Data Storage Format

Leftmost 4 digits	Rightmost 4 digits	
S+1	S	

Timing

The timing of data output is shown in the following table. "O" is the first word holding display data and "C" is the output word.

Function	Bit(s)	in O	Output status (Data and latch logic depends on C)
	(4 digits, 1 block)	(4 digits, 2 blocks)	
Data output	00 to 03	00 to 03 04 to 07	Note 0 to 3: Data output for word S 4 to 7: Data output for word S+1
Latch output 0	04	08	
Latch output 1	05	09	
Latch output 2	06	10	
Latch output 3	07	11	
One Round Flag	08	12	0 1 2 3 4 5 6 7 8 9 10 11 12
			12 cycles required to complete one round

Application Example

This example shows a program for displaying 8-digit BCD numbers at a 7-segment LED display. Assume that the 7-segment display is connected to output word IR 100. Also assume that the Output Unit is using negative logic, and that the 7-segment display logic is also negative for data signals and latch signals.



The 8-digit BCD data in DM 0120 (rightmost 4 digits) and DM 0121 (leftmost 4 digits) are always displayed by means of 7SEG(—). When the contents of DM 0120 and DM 0121 change, the display will also change.

Flags

ER: S and S+1 are not in the same data area. (When set to display 8-digit data)

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

There is an error in operand settings.

25409: SR 25409 will be ON while 7SEG(—) is being executed.

5-28-2 DIGITAL SWITCH INPUT – DSW(—)

DSW(—) IW OW R

Ladder Symbols

IW: Input word IR, SR, AR, DM, HR, LR OW: Output word IR, SR, AR, DM, HR, LR R: First result word IR, SR, AR, DM, HR, LR

Operand Data Areas

Overview

DSW(—) is used to read the value set on a digital switch connected to I/O Units. When the execution condition is OFF, DSW(—) is not executed. When the execution condition is ON, DSW(—) reads the 8-digit value set on the digital switch from IW and places the result in R.

The 8-digit value it is placed in R and R+1, with the most significant digits placed in R+1.

DSW(—) reads the 8-digit value in 20 executions, and then starts over and continues reading the data.

The digital switch must provide four data lines and one latch signal line and read signal line for each digit being input.

Precautions

I/O refreshing must be performed for all I/O points used by DSW(—) each time it is executed to ensure effective operation. The I/O REFRESH instruction must thus be used with DSW(—) whenever DSW(—) is used in a subroutine to ensure that the I/O points are refreshed each execution. Refer to page 352 for an example of this type of programming.

DSW(—) will be executed from the first cycle whenever program execution is started, including restarts made after power interruptions.


Do not use DSW(—) more than twice in the program.

DSW(—) cannot be used for I/O Units mounted to Slave Racks.


Note Input and output bits not used here can be used as ordinary input and output bits.

Hardware

With this instruction, 8-digit BCD set values are read from a digital switch. DSW(—) utilizes 5 output bits and 8 input bits. Connect the digital switch and the Input and Output Units as shown in the diagram below. Output point 5 will be turned ON when one round of data is read, but there is no need to connect output point 5 unless required for the application.




The following example illustrates connections for an A7B Thumbwheel Switch.



The inputs must be connected to a DC Input Unit with 8 or more input points and the outputs must be connected from a Transistor Output Unit with 8 or more output points.

Using the Instruction


If the input word for connecting the digital switch is specified at for word A, and the output word is specified for word B, then operation will proceed as shown below when the program is executed.



16 cycles to complete one round of execution

Application Example

This example shows a program for reading 8 digits in BCD from the digital switch. Assume that the digital switch is connected to IR 000 (input) and IR 100 (output).



When IR 00015 turns ON, the IR 05000 will hold itself ON until the One Round Flag (IR 10005) turns ON upon completion of one round of reading by DSW(—).

The data set from the digital switch by DSW(—) is stored in HR 51.

When the One Round Flag (10005) turns ON after reading has been completed, the number stored in HR 51 is transferred to DM 0000.

Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

R and R+1 are not in the same data area.

25410: ON while DSW(---) is being executed.

5-28-3 HEXADECIMAL KEY INPUT – HKY(—)

Ladder Symbols

HKY(—) IW OW D

Operand Data Areas

IW: Input word
IR, SR, AR, DM, HR, LR
OW: Control signal output word
IR, SR, AR, DM, HR, LR
D: First register word
IR, SR, AR, DM, HR, LR

Limitations

D and D+2 must be in the same data area.

Overview

When the execution condition is OFF, HKY(—) is not executed. When the execution condition is ON, HKY(—) inputs data from a hexadecimal keypad connected to the input indicated by IW. The data is input in two ways:

- An 8-digit shift register is created in D and D+1. When a key is pressed on the hexadecimal keypad, the corresponding hexadecimal digit is shifted into the least significant digit of D. The other digits of D, D+1 are shifted left and the most significant digit of D+1 is lost.
 - 2. The bits of D+2 and bit 4 of OW indicate key input. When one of the keys on the keypad (0 to F) is being pressed, the corresponding bit in D+2 (00 to 15) and bit 4 of OW are turned ON.

Note

- When one of the keypad keys is being pressed, input from the other keys is disabled.
- 2. Input and output bits not used here can be used as ordinary input and output bits.

With this instruction, one key input is read in 4 to 13 cycles. More than one cycle is required because the ON keys can only be determined as the outputs are turned ON to test them.

The hexadecimal key input device must be connectable in a 4 x 4 matrix.

Precautions

I/O refreshing must be performed for all I/O points used by HKY(—) each time it is executed to ensure effective operation. The I/O REFRESH instruction must thus be used with HKY(—) whenever HKY(—) is used in a subroutine to ensure that the I/O points are refreshed each execution. Refer to page 352 for an example of this type of programming.


HKY(—) will be executed from the first cycle whenever program execution is started, including restarts made after power interruptions.

Do not use HKY(—) more than twice in the program.

HKY(—) cannot be used for I/O Units mounted to Slave Racks.

Hardware


This instruction inputs 8 digits in hexadecimal from a hexadecimal keyboard. It utilizes 5 output bits and 4 input bits. Prepare the hexadecimal keyboard, and connect the 0 to F numeric key switches, as shown below, to input points 0 through 3 and output points 0 through 3. Output point 4 will be turned ON while any key is being pressed, but there is no need to connect it unless required by the application.



The inputs connected to the input terminals must be on a DC Input Unit with 8 or more input points and the outputs connected to the output terminals must be from a Transistor Output Unit with 8 points or more.

Using the Instruction

If the input word for connecting the hexadecimal keyboard is specified at word A, and the output word is specified at word B, then operation will proceed as shown below when the program is executed.



Flags


ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

D and D+2 are not in the same data area.

SR 25408: ON while HKY(—) is being executed.

Example

This example shows a program for inputting numbers from a hexadecimal keyboard. Assume that the hexadecimal keyboard is connected to IR 000 (input) and IR 100 (output).



The hexadecimal key information that is input to IR 000 by HKY(—) is converted to hexadecimal and stored in words DM1000 and DM1001.

IR 00015 is used as an "ENTER key," and when IR 00015 turns ON, the numbers stored in DM 1000 and DM 1001 are transferred to DM 0000 and DM 0001.

5-28-4 TEN KEY INPUT – TKY(—)

Ladder Symbols

TKY(—) IW D₁ D₂

Operand Data Areas

IW: Input word
IR, SR, AR, DM, HR, LR
D ₁ : First register word
IR, SR, AR, DM, HR, LR
D ₂ : Key input word
IR, SR, AR, DM, HR, LR

Limitations

Overview

 D_1 and D_1+1 must be in the same data area.

When the execution condition is OFF, TKY(—) is not executed. When the execution condition is ON, TKY(—) inputs data from a ten-key keypad connected to the input indicated by IW. The data is input in two ways:

TKY(—) can be used in several locations in the program by changing the input word, IW.


- An 8-digit shift register is created in D₁ and D₁+1. When a key is pressed on the ten-key keypad, the corresponding BCD digit is shifted into the least significant digit of D₁. The other digits of D₁, D₁+1 are shifted left and the most significant digit of D₁+1 is lost.
 - 2. The first ten bits of D_2 indicate key input. When one of the keys on the keypad (0 to 9) is being pressed, the corresponding bit of D_2 (00 to 09) is turned ON.

Note

- 1. While one key is being pressed, input from other keys will not be accepted.
- 2. If more than eight digits are input, digits will be deleted beginning with the leftmost digit.
- 3. Input bits not used here can be used as ordinary input bits.

Hardware


This instruction inputs 8 digits in BCD from a 10-key keypad and uses 10 input points. Prepare a 10-key keypad, and connect it so that the switches for numeric keys 0 through 9 are input to points 0 through 9 as shown in the following diagram. The inputs on a DC Input Unit with 16 or more input points can be used.



DC Input Unit

Using the Instruction

If the input word for connecting the 10-key keypad is specified for IW, then operation will proceed as shown below when the program is executed.




Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

 D_1 and D_1+1 are not in the same data area.

Example

In this example, a program for inputting numbers from the 10-key is shown. Assume that the 10-key is connected to IR 000.



The 10-key information input to IR 000 using TKY(—) is converted to BCD and stored in DM 1000 and DM 1001. Key information is stored in DM 1002.

IR 00015 is used as an "ENTER key," and when IR 00015 turns ON, the data stored in DM 1000 and DM 1001 will be transferred to DM 0000 and DM 0001.

5-28-5 **MATRIX INPUT – MTR(—)**

Ladder Symbols

MTR(—) IW OW

D

Operand Data Areas


IW: Input word
IR, SR, AR, DM, HR, LR
OW : Output word
IR, SR, AR, DM, HR, LR
D: First destination word
IR, SR, AR, DM, HR, LR

Limitations

D and D+3 must be in the same data area.

Overview

When the execution condition is OFF, MTR(—) is not executed. When the execution condition is ON, MTR(—) inputs data from an 8×8 matrix and records that data in D to D+3. Data for all 64 points in the matrix will be recorded even when fewer than 64 keys are connected.



A selection signal is output to OW bits 00 to 07 consecutively for 3 cycles. Only one output bit will be turned on at a time. Bit 08 of OW is turned ON for 3 cycles after 07 to indicate when each round of reading the matrix has been completed.

When one of the 64 keys is pressed, an input will be received at one of the input bits. The key that was pressed is identified by comparing the output bit to which the signal was output and input bit at which it was received.


When an key input is detected, the corresponding bit in D through D+3 is turned ON. The following table shows the correspondence between keys and bits in D through D+3.

Word	Bits	Corresponding Keys
D	00 to 15	0 to 15
D+1	00 to15	16 to 31
D+2	00 to 15	32 to 47
D+3	00 to 15	48 to 63


Hardware

This instruction inputs up to 64 signals from an 8 x 8 matrix using 8 input points and 8 output points. Any 8 x 8 matrix can be used. The inputs must be connected through a DC Input Unit with 8 or more points and the outputs must be connected through a Transistor Output Unit with 8 or more points. The basic wiring and timing diagrams for MTR(—) are shown below.

Wiring



Timing Diagram



Precautions

The 64 keys can be divided into 8 rows (including a row for OW bit 08) which are scanned consecutively. Since each row is scanned for 3 cycles, a delay of up to 25 cycles can occur before a given row of keys is scanned for inputs.

I/O refreshing must be performed for all I/O points used by MTR(—) each time it is executed to ensure effective operation. The I/O REFRESH instruction must thus be used with MTR(—) whenever MTR(—) is used in a subroutine to ensure that the I/O points are refreshed each execution.

MTR(—) will be executed from the first cycle whenever program execution is started, including restarts made after power interruptions.


SR 25403, which is turned on while MTR(—) is being executed, is reset in an interlocked program section and MTR(—) is not executed in an interlocked program section.

Do not use MTR(—) more than twice in the program.

MTR(—) cannot be used for I/O Units mounted to Slave Racks.

Example

The following examples shows programming MTR(—) in a scheduled subroutine, where IORF(97) is programmed to ensure that the I/O words used by MTR(—) are refreshed each time MTR(—) is executed.



Flags

ER: Indirectly addressed DM word is non-existent. (Content of *DM word is

not BCD, or the DM area boundary has been exceeded.)

25403: SR 25403 is ON while MTR(—) is being executed.

5-29 Special I/O Unit Instructions

The Special I/O Unit instructions are used to transfer data to and from the memory of the specified Special I/O Unit.

5-29-1 SPECIAL I/O UNIT READ - IORD(---)

Ladder Symbols

Operand Data Areas

C: Control code
IR, SR, AR, DM, HR, TC, LR, #
S: Source information
IR, SR, AR, DM, HR, TC, LR, #
D: First destination word
IR, SR, AR, DM, HR, TC, LR


Limitations

Only Special I/O Units mounted to the PC's CPU Rack or Expansion I/O Racks can be specified.

The last three digits of S must be BCD (from 001 to 128).

Description


When the execution condition is OFF, IORD(—) is not executed. When the execution condition is ON, IORD(—) transfers data from the specified Special I/O Unit's memory to words beginning at D. The source information provides the node number of the Special I/O Unit and the number of words to be read, as shown in the following diagram.



The control code (C) depends on the Special I/O Unit being specified. Refer to the Unit's Operating Manual for details.

Example

When IR 00000 goes from OFF to ON, the following instruction transfers 100 words from the memory area of Special I/O Unit number 3 to DM 0100 through DM 0199.



Address	Instruction	Oper	ands
00200	LD	·	00000
00201	@IORD(—)		
			С
			#3100
		DM	0100

Flags

ER: The last three digits of S (number of words specifier) isn't BCD or isn't within the range of 001 through 128.


Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

The source Unit's unit number isn't 0 to F or it is mounted on a Slave Rack.

The received data overflows a data area boundary.

EQ: ON when the data was read successfully, otherwise OFF.

5-29-2 SPECIAL I/O UNIT WRITE – IOWR(—)



Operand Data Areas

C: Control code
IR, SR, AR, DM, HR, TC, LR, #
S: First source word
IR, SR, AR, DM, HR, TC, LR
D: Destination information
IR, SR, AR, DM, HR, TC, LR, #


Limitations

Only Special I/O Units mounted to the PC's CPU Rack or Expansion I/O Racks can be specified.

The last three digits of D must be BCD (from 001 to 128).

Description


When the execution condition is OFF, IOWR(—) is not executed. When the execution condition is ON, IOWR(—) transfers data from the words beginning at D to the specified Special I/O Unit's memory. The destination information provides the node number of the Special I/O Unit and the number of words to be written, as shown in the following diagram.



The control code (C) depends on the Special I/O Unit being specified. Refer to the Unit's Operating Manual for details.

Example

When IR 00000 goes from OFF to ON, the following instruction writes the contents of the 10 words from DM 0100 through DM 0109 to the memory area of Special I/O Unit number 2.



Address	Instruction	Operands
00200	LD	00000
00201	@IOWR()	
		С
		DM 0100
		#2010

Flags

ER: The last three digits of D (number of words specifier) isn't BCD or isn't within the range of 001 through 128.

Indirectly addressed DM word is non-existent. (Content of *DM word is not BCD, or the DM area boundary has been exceeded.)

The destination Unit's unit number isn't 0 to F or it is mounted on a Slave Rack.

The instruction wasn't completed normally.

EQ: ON when the data was read successfully, otherwise OFF.

5-29-3 PCMCIA CARD MACRO – CMCR(—)

Ladder Symbols

CMCR(—) C S D @CMCR(—)

Operand Data Areas

C: First control word
IR, SR, AR, DM, HR, TC, LR, #
S: First command word
IR, SR, AR, DM, HR, TC, LR, #
D: Response word
IR. SR. AR. DM. HR. TC. LR

Limitations

DM 6144 through DM 6655 cannot be used for D.

Description

When the execution condition is OFF, CMCR(—) is not executed. When the execution condition is ON, CMCR(—) executes a macro process that writes, reads, compares, or searches the memory of the Card in the PCMCIA Card Interface Unit.

When CMCR(—) writes data in a comma-delimited file, that file can be written entirely in one line. Comma-delimited files that were created in a personal computer are assumed to be written in one of the following formats. (It doesn't matter if the comma is in a separate byte.)

4 bytes, comma, 4 bytes, comma, 4 bytes, comma


8 bytes, comma, 8 bytes, comma, 8 bytes, comma

A file can be appended only if there is free space in the Card and data can be overwritten only when an acceptable offset has been specified.

The fields in the comma-delimited file must not be enclosed by definers such as quotation marks.

Control Words

Write the control data in the first control word using the format shown in the following diagram.



Process Number

The process number (1 through 4) determines what function CMCR(—) will perform.

Process number	Process name	Function	
1	Write file Writes data from the PC's memory to the specifi in the Card in the PC Card Unit.		
2	Read file	Reads data from the specified file in the Card in the PC Card Unit to the PC's memory.	
3	Compare file with memory	Compares the specified file in the Card in the PC Card Unit to data in the PC's memory.	
4	Search file	Searches the specified file in the Card in the PC Card Unit.	


Port Settings

The port settings (bits 8, 9, and 10) specify details about CMCR(—) operations and the format of the PC Card files.

Process	Port settings			
number	Bit 8	Bit 9	Bit 10	
1	OFF: Overwrite existing file. ON: Create new file.	OFF: Create a comma-delimited file. ON: Create a binary file.	OFF: One-word comma delimiter. ON: Two-word comma delimiter.	
2	OFF: Read the specified file. ON: Read the number of elements in the specified file.	OFF: Read as a comma-delimited file. ON: Read as a binary file.	OFF: One-word comma delimiter. ON: Two-word comma delimiter.	
3		OFF: Compare as a comma-delimited file. ON: Compare as a binary file.	OFF: One-word comma delimiter. ON: Two-word comma delimiter.	
4		OFF: Search as a comma-delimited file. ON: Search as a binary file.	OFF: One-word comma delimiter. ON: Two-word comma delimiter.	

Command Words

The command words are made up of the data length, and command data. For the data length, specify the length of the command data +1. The maximum length of the command data is 1,000 words.



The data length, offset, and command data settings depend on the process number that is specified, as shown in the following table.

Process	Data length	Command data		
number		Offset	Data	
1	Number of words of data (BCD: 1 to 1001)	Number of elements of write data (0 to FFFF) Specify number of words for one-word comma delimiter and binary. Specify number of elements for two-word comma delimiter.	Data to be written to the file 999 words max. for one-word comma delimiter and binary. 998 words max. (449 elements) for two-word comma delimiter.	
2	Always set to 0003.	Number of elements of read data (0 to FFFF)	Specify the number of words to read (in hexadecimal, 1 to 3E7).	
		Specify number of words for one-word comma delimiter and binary. Specify number of elements for two-word comma delimiter.	999 (\$3E7) words max. for one-word comma delimiter and binary. 449 (\$1F3) elements max. for two-word comma delimiter.	
3	Number of words of data (BCD: 1 to 1001)	Number of elements of compare data (0 to FFFF) Specify number of words for one-word comma delimiter and binary. Specify number of elements for two-word comma delimiter.	Data to be compared. 999 words max. for one-word comma delimiter and binary. 998 words max. (449 elements) for two-word comma delimiter.	
4	Specify 3 for one-word comma delimiter and binary. Specify 4 for two-word comma delimiter.	Number of elements of search data (0 to FFFF) Specify number of words for one-word comma delimiter and binary. Specify number of elements for two-word comma delimiter.	Search data Specify one word of search data for one-word comma delimiter and binary. Specify two words of search data for two-word comma delimiter.	

Note

- 1. When an offset of 0 is specified for process number 1 and a file with the same name already exists, the existing file will be deleted and a new file will be created. If the data length has been set to 1 (no write data), the instruction just deletes the existing file. If the offset has been set to 1, data will be appended to the end of the existing file.
- 2. A comma-delimited file is a file in which a 1-byte character such as a comma is inserted after every 4 bytes or 8 bytes of data. An error (termination code 2) will occur if there are any 2-byte delimiters such as CR+LF. Replace these 2-byte delimiters with 1-byte delimiters in advance.

Response Data

The response data depends on the process number that was specified, as shown in the following table.

Process number	Response data		
1	None		
2	Contains the data read from the specified file. When the number of elements is read, it is contained in 2-word hexadecimal.		
3	None (The result of the comparison is returned in the termination code.)		
4	When the search data is found in the file, its location is returned as the number of words or data elements (0 to FFFF) from the offset location.		
	Beginning of the file: 0000 Second word (element): 0001 Third word (element): 0002		

SR Bits and the Termination Code

The instruction's termination code is output to SR 237 after CMCR(—) is executed. Also, SR 252 contains flags that indicate the instruction's completion status (normal/error) and the execution status for operating levels 0 and 1. The following table shows the function of these bits.

Word	Bit(s)	Function	
SR 237	00 to 07	Termination code output area for operating level 0 after execution of CMCR(—).	
	08 to 15	Termination code output area for operating level 1 after execution of CMCR(—).	
SR 252	00	Error Flag for operating level 0 after execution of CMCR(—)	
	01	ON when CMCR(—) can be executed for operating level 0	
	03	Error Flag for operating level 1 after execution of CMCR(—)	
	04	ON when CMCR(—) can be executed for operating level 1	

The following table shows the meaning of the termination codes.

Code	Meaning
00	Normal completion
01	Parameter error such as offset, file size, or number of words to read
02	Disk full, file I/O error, or file type error
03	Non-existent file specified
04	Comparison or search failed
05 to FE	Undefined
FF	Process number error

Flags

ER: The content of a word containing an indirect DM/EM address is not BCD or the DM/EM area boundary has been exceeded.


DM 6144 through DM 6655 has been used for D.

The execution enabled flag for the specified operating level (SR 25201 or SR 25204) was OFF.

The operating level specified was not 0 or 1.

Example

By turning IR 00000 OFF \rightarrow ON \rightarrow OFF, 100 words of DM data starting from DM 0100 are written to the file G:\DMSAVE.DAT (Memory Card, slot 1). The DM area settings are shown after the ladder diagram.



 $\,$ DM 0000 to DM 0007 contain the control data and DM 0098 to DM 0199 contain the command data, as shown below.

Word	Content	Function
DM 0000		Control data
DM 0001	47 3A	ASCII: "G:"
DM 0002	5C 44	ASCII: "\ D"
DM 0003	4D 53	ASCII: "M S"
DM 0004	41 56	ASCII: "A V"
DM 0005	45 2E	ASCII: "E ."
DM 0006	44 41	ASCII: "D A"
DM 0007	54	ASCII: "T"

Word	Content	Function
DM 0098	0102	Write data length: 102 (hexadecimal)
DM 0099	0000	Offset: 0
DM 0100		Data to be written
:	:	:
:	:	:
DM 0199		Data to be written

SECTION 6 Program Execution Timing

The timing of various operations must be considered both when writing and debugging a program. The time required to execute the program and perform other CPU Unit operations is important, as is the timing of each signal coming into and leaving the PC in order to achieve the desired control action at the right time. This section explains the cycle and shows how to calculate the cycle time and I/O response times.

6-1	Cycle 7	Cime	362
6-2	Calcula	ating Cycle Time	366
	6-2-1	PC with I/O Units Only	367
	6-2-2	PC with Host Link and Remote I/O Master Units	367
6-3	Instruc	tion Execution Times	369
6-4	I/O Res	sponse Time	378
	6-4-1	Basic Systems	378
	6-4-2	Remote I/O Systems	379
	6-4-3	Host Link Systems	382
	6-4-4	PC Link Systems	382
	6-4-5	One-to-one Link I/O Response Time	385
	6-4-6	Interrupt Response Times	387


6-1 Cycle Time

To aid in PC operation, the average, maximum, and minimum cycle times can be displayed on the Programming Console or any other Programming Device and the maximum cycle time and current cycle time values are held in AR 26 and AR 27. Understanding the operations that occur during the cycle and the elements that affect cycle time is, however, essential to effective programming and PC operations.

The major factors in determining program timing are the cycle time and the I/O response time. One run through all required CPU Unit operations is called a cycle; the time required for each cycle is called the cycle time.

The overall flow of the CPU Unit operation is as shown in the following flowchart.

Flowchart of CPU Unit Operation



The first three operations immediately after power application are performed only once each time the PC is turned on. The rest of the operations are performed in cyclic fashion.

The cycle time is the time that is required for the CPU Unit to complete one of these cycles. This cycle includes basically 9 types of operation: Overseeing, Program execution, Cycle time calculation, I/O refreshing, Host Link Unit servicing, RS-232C port servicing, Peripheral Device servicing, Communications Board servicing, and SYSMAC NET/SYSMAC LINK servicing.

The cycle time is the total time required for the PC to perform all 9 of these operations. The time required for operation 3, cycle time calculation, is negligible and can be ignored in actual calculations.

Operation		Time required	Function	
1.	Overseeing	0.7 ms (2.1 ms in the C200HE-CPU11-E)	Watchdog timer reset. I/O Bus, Program Memory checked. Clock refreshed.	
2.	Program execution	Total execution time for all instructions varies with program size, the instructions used, and execution conditions. Refer to 6-3 Instruction Execution Times for details.	Program executed.	
3.	Cycle time calculation	Negligible, but a wait can be generated to bring the cycle time up to the minimum setting if one has been made.	Cycle time calculated. When the CYCLE TIME instruction (SCAN(18)) is executed, waits until the set time has elapsed and then resets the watchdog timer.	
4.	I/O refreshing	Total of following times: 20 μs per input byte (8 points). 20 μs per output byte (8 points). (12-point Output Units calculated as 16 points.) PC Link Unit I/O refresh time.	Input bits set according to status of input signals. Output signals sent according to status of output bits in memory. Inputs and Outputs in Remote I/O Systems refreshed.	
		Special I/O Unit refresh time.	Special I/O Units serviced.	
		1.1 ms per Remote I/O Master Unit + 0.17 ms per I/O word used on Slave Racks.	Group-2 High-density I/O Units serviced.	
		Group-2 (High-density) I/O Unit refresh time.		
		Refer to the tables below for details on PC Link, Special I/O Unit, and Group-2 Highdensity I/O Unit refresh times.		
5.	Host Link Unit servicing	6 ms per Unit max.	Commands from computers connected through Rack-mounting Host Link Units processed.	
6.	RS-232C port servicing	0 ms when no device is connected. 0.26 ms minimum or $T \times 0.05$, where T is the cycle time calculated in operation 3	Communications with devices connected to RS-232C port processed.	
7.	Peripheral device	0 ms when no device is connected.	Commands from Programming Devices	
	servicing	0.26 ms minimum or T \times 0.05, where T is the cycle time calculated in operation 3	(computers, Programming Consoles, etc.) processed.	
8.	Communications Board servicing	0.5 ms + processing time per port. The processing time per port is as follows: 0.26 ms minimum or T \times 0.05, where T is the cycle time calculated in operation 3	Commands from the Communications Board (RS-232C, RS-422, or RS-485) are processed.	
9.	SYSMAC NET Link/ SYSMAC LINK servicing PC card servicing	0 ms when no Communications Unit is mounted. For C200HS-SLK□□ or C200HS-SNT□□: 0.8 ms + 15 ms max. per Unit. For C200HW-SLK□□: 3.5 ms max. per Unit. For C200HW-PCU01/PCS01: 6 ms max.	Commands from computers and other devices connected to SYSMAC NET Link/SYSMAC LINK/PC Card Units processed.	

PC Link Unit I/O Refresh

I/O pts to refresh	Time required (ms)
512	7.4
256	4.1
128	2.7
64	1.7

Special I/O Unit Refresh

Unit	Time required per Unit
C200H-ID501/215	0.6 ms
C200H-OD501/215	0.6 ms when set for 32 I/O pts.
C200H-MD501/215	1.6 ms when set for dynamic I/O
C200H-CT001-V1/CT002	2.0 ms
C200H-CT021	0.7 ms
C200H-NC111/NC112	2.1 ms
C200HW-NC113	2.6 ms
C200H-NC211	5.0 ms
C200HW-NC213	2.9 ms
C200HW-NC413	4.5 ms
C200H-MC221	2 ms for normal operation 3 ms for refreshing expansion data area
C200H-AD001	1.1 ms
C200H-DA001	0.9 ms
C200H-TS001/TS101	1.2 ms
C200H-ASC02	1.9 ms normally, 5.0 ms for @ format
C200H-IDS01-V1/IDS21	2.0 ms normally, 5.5 ms for command transfer
C200H-OV001	3.3 ms
C200H-FZ001	2.0 ms
C200H-TC□□□	2.7 ms
C200H-CP114	2.0 ms
C200H-AD002	1.4 ms
C200H-PID□□□	2.7 ms
C200H-DA002	1.0 ms
C200HW-SRM21	0.44 ms when the max. number of Slaves is 16. 0.88 ms when the max. number of Slaves is 32.
C200HW-DRM21-V1 C200HW-DRT21	1.72 ms + 0.022 × the number of words

Group-2 High-density I/O Unit Refresh

Unit	Time required per Unit
C200H-ID216	0.18 ms
C200H-OD218	0.14 ms
C200H-ID217	0.31 ms
C200H-OD219	0.23 ms

NT Links

If the PC is connected to a Programmable Terminal (PT) via a C200HX/HG/HE Interface Unit, the times shown in the following table will be required to refresh I/O for the PT.

Number of table entries for PT	I/O refresh time
Minimum setting: Character string table: 0 Numeral table: 0	2.5 ms
Maximum setting: Character string table: 32 Numeral table: 128	5.4 ms

Watchdog Timer and Long Cycle Times

Within the PC, the watchdog timer measures the cycle time and compares it to a set value. If the cycle time exceeds the set value of the watchdog timer, a FALS 9F error is generated and the CPU Unit stops. WDT(94) can be used to extend the set value for the watchdog timer.

Even if the cycle time does not exceed the set value of the watchdog timer, a long cycle time can adversely affect the accuracy of system operations as shown in the following table.

Cycle time (ms)	Possible adverse affects		
10 or greater	TIMH(15) inaccurate when TC 016 through TC 511 are used. (Accuracy when using TC 000 through TC 0015 not affected.)		
20 or greater	0.02-second clock pulse (SR 25401) not accurately readable.		
100 or greater	0.1-second clock pulse (SR 25500) not accurately readable and Cycle Time Error Flag (SR 25309) turns ON.		
200 or greater	0.2-second clock pulse (SR 25501) not accurately readable.		
6,500 or greater	FALS code 9F generated regardless of watchdog timer setting and the system stops.		

Online Editing

When online editing is executed from a Programming Device, operation will be interrupted for a maximum of 80 ms and interrupts will be masked to rewrite the user program. No warnings will be given for long cycle times during this interval. Check the effects on I/O response time before editing the program online.

When bits 00 to 07 of AR 25 contain the password code of "5A," online editing will be disabled and the CPU Unit will be in standby status while the Online Edit Disable Bit (AR 2509) is ON. The Online Edit Standby Flag (AR 2510) will be ON while the CPU Unit is in standby status. Processing will be executed when AR 2509 is turned OFF. (AR 2510 will be turned OFF, too.)




Editing the program online can cause delays in I/O responses with no warnings being given from the system for the long cycle time produced by editing online. Before editing online, make sure that delays in I/O responses will not create a dangerous situation in the controlled system.

6-2 Calculating Cycle Time

The PC configuration, the program, and program execution conditions must be taken into consideration when calculating the cycle time. This means taking into account such things as the number of I/O points, the programming instructions used, and whether or not peripheral devices are employed. This section shows some basic cycle time calculation examples. To simplify the examples, the instructions used in the programs have been assumed to be all either LD or OUT. The average execution time for the instructions is thus 0.156 µs. (Execution times are given in the table in 6-3 Instruction Execution Times.)

6-2-1 PC with I/O Units Only

Here, we'll compute the cycle time for a simple PC. The CPU Unit controls only I/O Units, eight on the CPU Rack and five on a 5-slot Expansion I/O Rack. The PC configuration for this would be as shown below. It is assumed that the program contains 5,000 instructions requiring an average of 0.156 μ s each to execute.



Calculations

The equation for the cycle time from above is as follows:

Cycle time = Overseeing time + Program execution time + I/O refresh time + Peripheral device servicing time

Process	Calculation	With Peripheral Device	Without Peripheral Device
Overseeing	Fixed	0.7 ms	0.7 ms
Program execution	$0.156 \mu s$ /instruction $\times 5,000$ instructions	0.78 ms	0.78 ms
I/O refresh	See below.	0.34 ms	0.34 ms
Peripheral device servicing	Minimum time	0.26 ms	0.0 ms
Cycle time	Total of above	2.08 ms	1.82 ms

The I/O refresh time would be as follows for two16-point Input Units, four 8-point Input Units, two 12-point Output Units (12-point Units are treated as 16-point Units), and five 8-point Output Units controlled by the PC:


$$\frac{(16 \text{ pts} \times 2) + (8 \text{ pts} \times 4)}{8 \text{ pts}} \times 20 \text{ } \mu\text{s} + \frac{(16 \text{ pts} \times 2) + (8 \text{ pts} \times 5)}{8 \text{ pts}} \times 20 \text{ } \mu\text{s} = 0.34 \text{ ms}$$

6-2-2 PC with Host Link and Remote I/O Master Units

Here, the cycle time is computed for a PC with a Host Link Unit and Remote I/O Master Unit installed. The PC configuration for this could be as shown below.

The CPU Unit controls three 8-point Input Units, three 8-point Output Units, a Host Link Unit, and a Remote I/O Master Unit connected to a Remote I/O Slave Rack containing four 16-point Input Units and four 12-point Output Units.

It is assumed that the program contains 5,000 instructions requiring an average of 0.156 μ s each to execute, and that nothing is connected to the RS-232C port and no SYSMAC NET/SYSMAC LINK Unit is mounted.



Calculations

The equation for the cycle time is as follows:

Cycle time = Overseeing time + Program execution time

+ I/O refreshing time + Host Link Unit servicing time

+ Peripheral device servicing time

Process	Calculation	With Peripheral Device	Without Peripheral Device
Overseeing	Fixed	0.7 ms	0.7 ms
Program execution	$0.156 \mu s$ /instruction $\times 5,000$ instructions	0.78 ms	0.78 ms
I/O refresh	See below.	2.58 ms	2.58 ms
Host Link servicing	Fixed	6.0 ms	6.0 ms
Peripheral device servicing	0.7 + 0.78 + 2.58 + 6 = 10.06	0.50 ms	0.0 ms
	$10.06 \times 0.05 = 0.50$		
Cycle time	Total of above	10.56 ms	10.06 ms

The I/O refreshing time would be as follows for three 8-point Input Units and three 8-point Output Units mounted in the CPU Rack, and eight Units mounted in a Slave Rack.

$$\frac{(8 \text{ pts} \times 3) + (8 \text{ pts} \times 3)}{8 \text{ pts}} \times 20 \text{ } \mu\text{s} + 1.1 \text{ ms} + 8 \text{ Units} \times 0.17 \text{ ms} = 2.58 \text{ ms}$$

6-3 Instruction Execution Times

The following table lists the execution times for all instructions that are available for the C200HX/HG/HE. The maximum and minimum execution times and the conditions which cause them are given where relevant. When "word" is referred to in the Conditions column, it implies the content of any word except for indirectly addressed DM words. Indirectly addressed DM words, which create longer execution times when used, are indicated by "*DM."

Execution times for most instructions depend on whether they are executed with an ON or an OFF execution condition. Exceptions are the ladder diagram instructions OUT and OUT NOT, which require the same time regardless of the execution condition. The OFF execution time for an instruction can also vary depending on the circumstances, i.e., whether it is in an interlocked program section and the execution condition for IL is OFF, whether it is between JMP(04) 00 and JME(05) 00 and the execution condition for JMP(04) 00 is OFF, or whether it is reset by an OFF execution condition. "R," "IL," and "JMP" are used to indicate these three times.

All execution times are given in microseconds unless otherwise noted.

Instruction	Conditions	ON execu	ution time	(μ s)	OFF exec	cution time	(μs)
		C200HX	C200HG	C200HE	C200HX	C200HG	C200HE
LD	For IR and SR 23600 to SR 25515	0.104	0.156	0.312	0.104	0.156	0.313
	For SR 25600 to SR 51115	0.208	0.313	0.626	0.104	0.156	0.313
LD NOT	For IR and SR 23600 to SR 25515	0.104	0.156	0.313	0.104	0.156	0.313
	For SR 25600 to SR 51115	0.208	0.313	0.626	0.104	0.156	0.313
AND	For IR and SR 23600 to SR 25515	0.104	0.156	0.312	0.104	0.156	0.313
	For SR 25600 to SR 51115	0.208	0.313	0.626	0.104	0.156	0.313
AND NOT	For IR and SR 23600 to SR 25515	0.104	0.156	0.313	0.104	0.156	0.313
	For SR 25600 to SR 51115	0.208	0.313	0.626	0.104	0.156	0.313
OR	For IR and SR 23600 to SR 25515	0.104	0.156	0.313	0.104	0.156	0.313
	For SR 25600 to SR 51115	0.208	0.313	0.626	0.104	0.156	0.313
OR NOT	For IR and SR 23600 to SR 25515	0.104	0.156	0.313	0.104	0.156	0.313
	For SR 25600 to SR 51115	0.208	0.313	0.626	0.104	0.156	0.313
AND LD		0.104	0.156	0.313	0.104	0.156	0.313
OR LD		0.104	0.156	0.313	0.104	0.156	0.313
OUT	For IR and SR 23600 to SR 25515	0.208	0.313	0.626	0.208	0.313	0.626
	For SR 25600 to SR 51115	0.313	0.468	0.936	0.208	0.313	0.626
OUT NOT	For IR and SR 23600 to SR 25515	0.208	0.313	0.626	0.208	0.313	0.626
	For SR 25600 to SR 51115	0.313	0.468	0.936	0.208	0.313	0.626
TIM	Constant for SV	0.417	0.625	1.25	0.417	0.625	1.25
	*DM for SV				22.45	22.45	37.15
	For designated words 256 to 511				0.417	0.625	1.25
CNT	Constant for SV	0.417	0.625	1.25	0.417	0.625	1.25
	*DM for SV	0.417	0.625	1.25	22.55	22.55	37.25
	For designated words 256 to 511	0.417	0.625	1.25	0.417	0.625	1.25
SET	For IR and SR 23600 to SR 25515	0.208	0.313	0.626	0.208	0.313	0.626
	For SR 25600 to SR 51115	0.313	0.468	0.936	0.208	0.313	0.626
RSET	For IR and SR 23600 to SR 25515	0.208	0.313	0.626	0.208	0.313	0.626
	For SR 25600 to SR 51115	0.313	0.468	0.936	0.208	0.313	0.626
NOP(00)		0.104	0.156	0.312	0.313	0.469	0.938
END(01)		24.75		39.45	0.313	0.469	0.938
IL(02)		7.55		22.25	0.313	0.469	0.938
ILC(03)		9.25		23.95	0.313	0.469	0.938

Instruction	Conditions	ON execu	ution time	(μs)	OFF exec	ution time	(μs)
		C200HX	C200HG	C200HE	C200HX	C200HG	C200HE
JMP(04)		7.65		22.35	0.313	0.469	0.938
JME(05)		7.95		22.65	0.313	0.469	0.938
FAL(06)	FAL numbers 01 to 99	88.6		88.6	0.313	0.469	0.938
, ,	FAL number 00	86.6		86.6	0.313	0.469	0.938
FALS(07)			(see note 1)	(see note 2)	0.313	0.469	0.938
STEP(08)		33.1		47.8	0.313	0.469	0.938
		15.3		30			
SNXT(09)		9.25		23.95	0.313	0.469	0.938
SFT(10)	With 1-word shift register	21.05		35.75	R: 8.05	IL: 8.05	JMP: 8.05
	With 100-word shift register	117.8		132.5	R: 8.05	IL: 8.05	JMP: 8.05
	With 250-word shift register	262.5		277.2	R: 8.05	IL: 8.05	JMP: 8.05
KEEP(11)	For IR and SR 23600 to SR 25515	0.208	0.313	0.625	0.208	0.319	0.625
	For SR 25600 to SR 51115	0.318	0.469	0.938			
CNTR(12)	Constant for SV	19.15		33.85	R: 16.95	IL: 11.65	JMP: 11.65
	*DM for SV	31.45		46.15	R: 16.95	IL: 11.65	JMP: 11.65
DIFU(13)		13.75		28.45	Normal: 13.75	IL: 13.65	JMP: 11.95
DIFD(14)		13.65		28.35	Normal: 13.65	IL: 13.55	JMP: 11.85
TIMH(15)	Interrupt Constant for SV	18.35		33.05	R: 25.05	IL: 24.05	JMP: 14.45
	Normal cycle	16.55		31.25	R: 21.95	IL:21.05	JMP: 11.25
	Interrupt *DM for SV	18.35		33.05	R: 37.1	IL: 36.5	JMP: 14.45
	Normal cycle	16.55		31.25	R: 34.1	IL: 33.3	JMP: 11.25
WSFT(16)	When shifting 1 word	16.45		31.15	0.313	0.469	0.938
	When shifting 6,144 words using *DM	6.45 ms		(see note 2)			
CMP(20)	When comparing a constant to a word	0.417	0.625	1.25	0.313	0.469	0.938
	When comparing two words	0.521	0.781	1.56			
	When comparing two *DM	35.2		49.9			
MOV(21)	When transferring a constant to a word	0.417	0.625	1.25	0.313	0.469	0.938
	When comparing two words	0.625	0.937	1.87			
	When transferring *DM to *DM	33.7		48.4			
MVN(22)	When transferring a constant to a word	0.417	0.625	1.25	0.313	0.469	0.938
	When comparing two words	0.625	0.937	1.87			
	When transferring *DM to *DM	34.3		49			
BIN(23)	When converting a word to a word	19.65		34.35	0.313	0.469	0.938
	When converting *DM to *DM	40.5		55.2	1		
BCD(24)	When converting a word to a word	18.25		32.95	0.313	0.469	0.938
	When converting *DM to *DM	39.1		53.8	1		
ASL(25)	When shifting a word	12.25		26.95	0.313	0.469	0.938
	When shifting ∗DM	23.35		38.05	1		

Instruction	Conditions	ON execution time	(μ s)	OFF exec	cution time	(μs)
		C200HX C200HG		C200HX		C200HE
ASR(26)	When shifting a word	11.95	26.65	0.313	0.469	0.938
	When shifting *DM	22.95	37.65			
ROL(27)	When rotating a word	13.15	27.85	0.313	0.469	0.938
	When rotating *DM	24.25	38.95			
ROR(28)	When rotating a word	13.15	27.85	0.313	0.469	0.938
	When rotating *DM	24.25	38.95	1		
COM(29)	When inverting a word	11.45	26.15	0.313	0.469	0.938
	When inverting *DM	22.65	37.35			
ADD(30)	Constant + word → word	16.65	31.35	0.313	0.469	0.938
	Word + word→ word	18.45	33.15			
	$*DM + *DM \rightarrow *DM$	50.1	64.8			
SUB(31)	Constant – word → word	16.65	31.35	0.313	0.469	0.938
	Word – word→ word	18.45	33.15			
	$*DM - *DM \rightarrow *DM$	50.1	64.8			
MUL(32)	Constant \times word \rightarrow word	31.15	45.85	0.313	0.469	0.938
	$Word \times word \rightarrow word$	32.95	47.65			
	$\star DM \times \star DM \rightarrow \star DM$	64.7	79.4			
DIV(33)	Word ÷ constant → word	30.15	44.85	0.313	0.469	0.938
	Word ÷ word→ word	32.35	47.05			
	*DM ÷ *DM → *DM	64.1	78.8	1		
ANDW(34)	Constant AND word → word	14.35	29.05	0.313	0.469	0.938
	Word AND word→ word	15.25	29.95	1		
	*DM AND *DM → *DM	46.7	61.4	=		
ORW(35)	Constant OR word → word	14.35	29.05	0.313	0.469	0.938
0.111(00)	Word OR word→ word	15.25	29.95	-	01.00	0.000
	*DM OR *DM → *DM	46.7	61.4	=		
XORW(36)	Constant XOR word → word	14.35	29.05	0.313	0.469	0.938
- ()	Word XOR word→ word	15.25	29.95			
	$*DM XOR *DM \rightarrow *DM$	46.7	61.4			
XNRW(37)	Constant XNOR word → word	14.55	29.25	0.313	0.469	0.938
,	Word XNOR word→ word	15.45	30.15	1		
	*DM XNOR *DM → *DM	46.9	61.6	1		
INC(38)	When incrementing a word	11.55	26.25	0.313	0.469	0.938
	When incrementing *DM	22.45	37.15			
DEC(39)	When decrementing a word	11.45	26.15	0.313	0.469	0.938
	When decrementing ∗DM	22.35	37.05			
STC(40)		7.22	21.92	0.313	0.469	0.938
CLC(41)		7.22	21.92	0.313	0.469	0.938
TRSM(45)		18.65	33.35	0.313	0.469	0.938
MSG(46)	Designated as DM	12.05	26.75	0.313	0.469	0.938
	Designated as *DM	21.95	36.65	7		
ADB(50)	Constant + word → word	19.15	33.85	0.313	0.469	0.938
	Word + word \rightarrow word	20.05	34.75	7		
	$*DM + *DM \rightarrow *DM$	51.7	66.4	7		
SBB(51)	Constant – word → word	18.95	33.65	0.313	0.469	0.938
	$Word - word \rightarrow word$	19.85	34.55	7		
	$*DM - *DM \rightarrow *DM$	51.7	66.4			

Instruction	Conditions	ON execu	ution time	(μs)	OFF exec	ution time	(μs)
		C200HX	C200HG	C200HE	C200HX	C200HG	C200HE
MLB(52)	$Constant \times word \to word$	16.95		31.65	0.313	0.469	0.938
	$Word \times word \rightarrow word$	17.85		32.55			
	$*DM \times *DM \rightarrow *DM$	49.3		64	1		
DVB(53)	Word ÷ constant → word	17.15		31.85	0.313	.313 0.469	0.938
	$Word \div word \to word$	18.05		32.75			
	$*DM \div *DM \rightarrow *DM$	49.7		64.4	1		
ADDL(54)	Word + word \rightarrow word	22.45		37.15	0.313 0.469	0.938	
,	$*DM + *DM \rightarrow *DM$	53.9		68.6	1		
SUBL(55)	$Word - word \rightarrow word$	22.45		37.15	0.313	0.313 0.469	0.938
	$*DM - *DM \rightarrow *DM$	53.9		68.6			
MULL(56)	$Word \times word \rightarrow word$	110.6		125.3	0.313	0.469	0.938
	$*DM \times *DM \rightarrow *DM$	142.6		157.3	1		
DIVL(57)	$Word \div word \to word$	105.8		120.5	0.313	0.469	0.938
	$*DM \div *DM \rightarrow *DM$	135.8		150.5			
BINL(58)	When converting words to words	35.15		49.85	0.313	0.469	0.938
	When converting *DM to *DM	55.9		70.6	1		
BCDL(59)	When converting words to words	25.75		40.45	0.313	0.469	0.938
	When converting *DM to *DM	46.5		61.2			
XFER(70)	When transferring 1 word	45.3	45.3		0.313	0.469	0.938
	When transferring 1,024 words using *DM	655		653.9			
	When transferring 6,143 words using *DM	3.66 ms		(see note 3)			
BSET(71)	When setting a constant to 1 word	19.75		34.45	0.313	0.469	0.938
	When setting *DM ms to 1,024 words using *DM	40.9		55.6			
	When setting *DM ms to 6,144 words using *DM	52.3		67			
ROOT(72)	When taking root of word and placing in a word	41.7		56.4	0.313	0.469	0.938
	When taking root of 99,999,999 in *DM and placing in *DM	85.5		100.2			
XCHG(73)	Between words	14.45		29.15	0.313	0.469	0.938
	Between *DM	36.45		51.15			
SLD(74)	When shifting 1 word	15.65		30.35	0.313	0.469	0.938
	When shifting 1,024 DM words using *DM	2.72 ms		(see note 2)			
	When shifting 6,144 DM words using *DM	16.2 ms		(see note 2)			
SRD(75)	When shifting 1 word	15.65		30.35	0.313	0.469	0.938
	When shifting 1,024 DM words using *DM	2.72 ms 16.2 ms		(see note 2)			
	When shifting 6,144 DM words using *DM			(see note 2)			
MLPX(76)	When decoding word to word	47.3		62	0.313	0.469	0.938
	When decoding *DM to *DM	103.8		118.5			
DMPX(77)	When encoding a word to a word	28.45		43.15	0.313	0.469	0.938
	When encoding ∗DM to ∗DM	111.8		126.5			

Instruction	Conditions	ON execu	tion time	(u s)	OFF exec	cution time	e (և Տ)
	2000	C200HX	C200HG	C200HE	C200HX		C200HE
SDEC(78)	When decoding a word to a word	26.95	0_0000	41.65	0.313	0.469	0.938
(- /	When decoding 2 digits *DM to *DM	63.3		78			
	When decoding 4 digits *DM to *DM	71.7		86.4	-		
FDIV(79)	Word ÷ word → word (equals 0)			77	0.313	0.313 0.469	0.938
(-)	Word ÷ word → word (doesn't equal 0)	499		513.7	1		
	*DM ÷ *DM → *DM	843		857.7	-		
DIST(80)	$\begin{array}{c} *DW + *DW \rightarrow *DW \\ \hline \text{Constant} \rightarrow (\text{word} + (\text{word})) \end{array}$	27.65		42.35	0.313	0.469	0.938
DIST(00)	$*DM \rightarrow (*DM + (*DM))$	61.5		76.2	0.515	0.409	0.930
COLL(81)	$(\text{Word} + (\text{word})) \rightarrow \text{word}$	28.75		43.45	0.313	0.469	0.938
COLL(61)	$(*DM + (*DM)) \rightarrow *DM$	64.3		79	0.313	0.409	0.936
MOVB(82)	When transferring a constant to a word	17.35		32.05	0.313	0.469	0.938
WO V D (02)	When transferring word to a word	19.45		34.15	0.313	0.409	0.936
	When transferring *DM to *DM	52.9		67.6	1		
MOVD(83)	When transferring a constant to a word	16.95		31.65	0.313	0.469	0.938
WO V D (00)	When transferring word to a word	18.25		32.95	0.515	0.403	0.330
	When transferring *DM to *DM	54.3		69	_		
SFTR(84)	When shifting 1 word	20.05		34.75	0.313	0.469	0.938
01 111(01)	When shifting 1,024 *DM using *DM	1.1 ms		(see	0.010	0.100	0.000
	,g :,e_: ,			note 2)			
	When shifting 6,144 *DM using *DM	6.37 ms		(see note 2)			
TCMP(85)	Comparing to words in a designated table	37.25		51.95	0.313	0.469	0.938
	Comparing to words in a designated table	38.1		52.8			
	Comparing *DM → *DM-designated table	69.1		83.8			
ASC(86)	Between words	30.1		44.8	0.313	0.469	0.938
	Between ∗DM	78.3		93			
SEND(90)	1-word transmit	60.9		75.6	0.313	0.469	0.938
	1000-word transmit	99.2		113.9			
SBS(91)		22.1		36.8	0.313	0.469	0.938
SBN(92)					0.313	0.469	0.938
RET(93)		20.9		35.6	0.313	0.469	0.938
WDT(94)		10.55		25.25	0.313	0.469	0.938
IORF(97)	1-word refresh	110 (IN), (OUT)	170	110 (IN), 170 (OUT)	0.313	0.469	0.938
	30-word refresh	2002		2000.9	1		
RECV(98)	1-word refresh	67.1		67.1	0.313	0.469	0.938
	1000-word refresh	105.8		105.8			
MCRO(99)	Designating a word parameter	38.5		53.2	0.313	0.469	0.938
• •	Designating a ∗DM parameter	58.2		72.9	1		
ASFT(—)	When resetting 1 word	24.95		39.65	0.313	0.469	0.938
Default: (17)	When shifting 1 word using ∗DM	29.05		43.75	1		
` '	When shifting 10 word using ∗DM	39.9		54.6	1		
SCAN(—)	Constant for SV	18.65		33.35	0.313	0.469	0.938
Default: (18)	*DM for SV	30.45		45.15	1		
MCMP(—)	Comparing 2 words, result word	60.3		75	0.313	0.469	0.938
Default: (19)	Comparing 2 *DM, result *DM	93		107.7	1		
		•					

Instruction	Conditions	ON execution time ((μ s)	OFF exec	ution time	ne (μs)	
		C200HX	C200HG	C200HE	C200HX	C200HG	C200HE	
LMSG()	Word for SV	17.95		32.65	0.313	0.469	0.938	
Default: (47)	∗DM for SV	27.65		42.35	1			
TERM(—) Default: (48)		8.55	8.55		0.313	0.469	0.938	
CMPL(—)	When comparing words to words	16.55		31.25	0.313	0.469	0.938	
Default: (60)	When comparing ∗DM to ∗DM	38.5		53.2				
MPRF()	1 Unit	2.00		16.7	0.313	0.469	0.938	
Default: (61)	10 Units	13.00		27.7				
XFRB(—)	Sending 1 bit from word to word	22.45		37.15	0.313	0.469	0.938	
Default: (62)	Sending FF bits from ∗DM to ∗DM	142.6		157.3				
LINE(—) Default: (63)	When transferring from words to a constant	59.7		74.4	0.313	0.469	0.938	
	When transferring from words to a word	62.1		76.8				
	When transferring *DM to *DM	182.5		197.2				
COLM(—) Default: (64)	When transferring from a constant to words	72.7		87.4	0.313	0.469	0.938	
	When transferring from a word to words	74.9		89.6				
	When transferring *DM to *DM	190.5		205.2				
SEC(—)	DM to DM	35.35		50.05	0.313	0.469	0.938	
Default: (65)	*DM to *DM	56.3		71				
HMS(—)	DM to DM	36.5		51.2	0.313	0.469	0.938	
Default: (66)	*DM to *DM	57.7		72.4				
BCNT(—)	Constant for SV	39.1		53.8	0.313	0.469	0.938	
Default: (67)	*DM for SV	26.5 ms		(see note 2)				
BCMP(—) Default: (68)	Comparing constant to word-designated table	62.1		76.8	0.313	0.469	0.938	
	To a word after comparing with a word	63.1		77.8				
	Comparing $*DM \rightarrow *DM$ -designated table	98.2		112.9				
APR(—)	SIN designation	24.25		38.95	0.313	0.469	0.938	
Default: (69)	*DM for SV	473		487.7				
TTIM(—) Default: (87)	Setting to a constant	27.55		42.25	Constant input OFF: 23.15	R: 24.15 IL: 20.55	JPM: 19.55	
	Setting to *DM	35.5		50.2	Constant input OFF: 35.30	R: 36.3 IL: 32.7	JPM: 31.9	
ZCP(—)	Comparing a constant to a word	16.75		31.45	0.313	0.469	0.938	
Default: (88)	Comparing a word to a word	17.65		32.35				
	Comparing *DM to a *DM	49.7		64.4				
INT(—) Default: (89)	Word for SV	19.90 to 198.50		(see note 3)	0.313	0.469	0.938	
(00)	*DM for SV	19.90 to 213.5		(see note 3)				
TKY(—)	Input to DM	25.65		40.35	0.313	0.469	0.938	
	Input to *DM	46.7		61.4				
RXD(—)	When designating a word	31.5		30.4	0.313	0.469	0.938	
	When designating ∗DM	73.5		72.4				

Instruction	Conditions	ON execution time	(μ s)	OFF exec	cution time	e (μ s)	
		C200HX C200HG	C200HE	C200HX		C200HE	
TXD(—)	When designating a word	56.1	70.8	0.313	0.469	0.938	
, ,	When designating *DM	99.4	114.1	-			
7SEG(—)	Word-designated 4 digits	19 to 22	(see note 2)	0.313	0.469	0.938	
	*DM-designated 4 digits	30 to 34	(see note 2)	_			
	Word-designated 8 digits	19 to 22	(see note 2)				
	*DM-designated 8 digits	30 to 34	(see note 2)				
FPD(—)	Word designation, code output	74.60 to 89.40	(see note 2)	0.313	0.469	0.938	
	*DM designation, message output	105.0 to 142.2	(see note 2)				
SRCH()	Constant for SV	39.7	54.4	0.313	0.469	0.938	
	Word for SV	1.35 ms	(see note 2)				
	*DM for SV	7.73 ms	(see note 2)				
MAX(—)	DM search	31.75	46.45	0.313	0.313	0.469	0.938
	*DM search	1.31 ms	(see note 2)				
MIN(—)	DM search	31.75	46.45	0.313	0.469	0.938	
	*DM search	1.31 ms	(see note 2)				
SUM()	DM add	26.55	41.25	0.313	0.469	0.938	
	*DM add	1.30 ms	(see note 2)				
FCS(—)	Add a word → word	26.75	41.45	0.313	0.469	0.938	
	Add 999 words → *DM	1.05 ms	(see note 2)				
HEX(—)	DM conversion	36.95	51.65	0.313	0.469	0.938	
	*DM conversion	102.6	117.3				
AVG(—)	Average of an operation	33.05	47.75	0.313	0.469	0.938	
	Average of 64 operations	133.8	148.5				
PID(—)	When designating a word	48.1	62.8	0.313	0.469	0.938	
	When designating *DM	89.4	104.1				
XDMR(—)	Constant for SV	39.9	54.6	0.313	0.469	0.938	
	Word for SV	1.44 ms	(see note 2)				
	*DM for SV	4.19 ms	(see note 2)				
MTR(—)	Input to DM	29 to 34	(see note 2)	0.313	0.469	0.938	
	Input to *DM	45 to 51	(see note 2)				
ADBL(—)	$DM + DM \rightarrow DM$	27.35	42.05	0.313	0.469	0.938	
	$*DM + *DM \rightarrow *DM$	60.1	74.8	1			
SBBL()	$DM - DM \rightarrow DM$	26.95	41.65	0.313	0.469	0.938	
	$*DM - *DM \rightarrow *DM$	59.7	74.4	1_			
	•						

Instruction	Conditions	ON execu	tion time	(µ s)	OFF exec	cution time	(μs)
		C200HX		C200HE	C200HX		C200HE
MBS(—)	Constant \times word \rightarrow word	20.85	0_0000	35.55	0.313	0.469	0.938
- ()	$DM \times DM \to DM$	_	21.65 53.5				
	$*DM \times *DM \rightarrow *DM$						
DBS(—)	Constant ÷ word → word	21.55			0.313	3 0.469	0.938
226()	DM ÷ DM → DM	22.45		36.25 37.15	- 0.010	0.100	0.000
	*DM ÷ *DM → *DM	54.9		69.6			
MBSL(—)	DM × DM → DM	45.3		60	0.313	0.469	0.938
WIDOL()	$*DM \times *DM \rightarrow *DM$	77.1		91.8	0.313 0.469	0.330	
DBSL(—)	DM ÷ DM → DM	86.6		101.3	0.313	0.469	0.938
DBSL(—)	*DM ÷ *DM → *DM	118.6		133.3	0.313	0.409	0.936
CPS(—)	When comparing two constants	13.95		28.65	0.313	0.469	0.938
CF3(—)	When comparing DM to DM	15.65		30.35	0.313	0.409	0.936
	When comparing DM to *DM	36.9		51.6			
CPSL(—)	When comparing two DM	18.65		33.35	0.313	0.460	0.938
01 01()	When comparing two ±DM	40.7		55.4	0.515	0.469	0.930
NEG(—)	When converting a constant to a word	15.05		29.75	0.313		0.938
1420()	When converting a word to a word	16.85		31.55	0.515	0.403	0.330
	When converting #DM to #DM	37.1		51.8			
NEGL()	When converting a word to a word	18.15		32.85	0.313	0.469	0.938
NEOE()	When converting #DM to #DM	39.7		54.4	0.010	0.400	0.550
ZCPL(—)	When comparing two words	19.95		34.65	0.313	0.469	0.938
2012()	When comparing two *DM	53.3		68	0.010	0.400	0.550
SCL(—)	Word for SV	58.3		73	0.313	0.469	0.938
002()	*DM for SV	89.4		104.1	- 0.010	0.100	0.000
HKY(—)	When designating a word	23.55		38.25	0.313	0.469	0.938
, ,	When designating *DM	44.3		59	0.010	0.100	0.000
DSW(—)	DM CS output	35		49.7	0.313	0.469	0.938
20()	DM RD output	35		49.7	0.010	0.100	0.000
	DM data retrieval	45		59.7			
	*DM CS output	44		58.7			
	*DM RD output	44		58.7			
	*DM data retrieval	53		67.7			
BXFR(—)	Word designation (1 word)	71.5		70.4	0.313	0.469	0.938
	*DM designation (1,024 words)	3.68 ms		(see note 3)			
	*DM designation (6,144 words)	8.75 ms		(see note 3)			
EMBC()	Constant designation	18.45		33.15	0.313	0.469	0.938
	Word designation	19.95		34.65			
	*DM designation	33.45		48.15			
XFR2(—)	Word designation (1 word)	46.4		45.3	0.313	0.469	0.938
	*DM designation (1,024 words)	656.2		655.1			
	*DM designation (6,144 words)	3.66 ms		(see note 3)			
BXF2()	Word designation (1 word)	72.8		71.7	0.313	0.469	0.938
	*DM designation (1,024 words)	3.68 ms		(see note 3)			
	*DM designation (6,144 words)	8.75 ms		(see note 3)			

Instruction	Conditions	ON execu	ON execution time (μs)			ution time	(μs)
		C200HX	C200HG	C200HE	C200HX	C200HG	C200HE
IEMS(—)	Constant designation (Switch to DM.)	19.25	•	18.15	0.313	0.469	0.938
	Word designation (Switch to EM bank.)	24.95		23.85			
IORD(—)			(see note 1)	(see note 2)	0.313	0.469	0.938
IOWR(—)			(see note 1)	(see note 2)	0.313	0.469	0.938
STUP(—)	Default RS-232C designation	30.9		29.8	0.313 0.4	0.469	0.938
	Communications Board Port A *DM designation	61		59.9			
PMCR(—)	Constant for port & Sequence number, DM for input and output words	41		39.9	0.313	0.469	0.938
	Constant for port & Sequence number, *DM for input and output words	56		54.9			
	*DM for port & Sequence number, *DM for input and output words	74.2		73.1			
CMCR()	Word designation	74		72.9	0.313	0.469	0.938
	DM designation	80		78.9			
	⋆DM designation	103		101.9			

Note

- 1. Same as the C200HX's instruction execution time.
- 2. Add 14.7 μs to the C200HX's instruction execution time.
- 3. Add 1.1 μs to the C200HX's instruction execution time.

6-4 I/O Response Time

The I/O response time is the time it takes for the PC to output a control signal after it has received an input signal. The time it takes to respond depends on the cycle time and when the CPU Unit receives the input signal relative to the input refresh period.


The minimum and maximum I/O response time calculations described below are for where IR 00000 is the input bit that receives the signal and IR 00200 is the output bit corresponding to the desired output point.



6-4-1 Basic Systems

Minimum I/O Response Time


The PC responds most quickly when it receives an input signal just prior to the I/O refresh period in the cycle. Once the input bit corresponding to the signal has been turned ON, the program will have to be executed once to turn ON the output bit for the desired output signal and then the I/O refresh operation would have to be repeated to refresh the output bit. The I/O response time in this case is thus found by adding the input ON-delay time, the cycle time, and the output ON-delay time. This situation is illustrated below.



Minimum I/O response time =
Input ON delay + Cycle time + Output ON delay

Maximum I/O Response Time

The PC takes longest to respond when it receives the input signal just after the I/O refresh phase of the cycle. In this case the CPU Unit does not recognize the input signal until the end of the next cycle. The maximum response time is thus one cycle longer than the minimum I/O response time, except that the I/O refresh time would not need to be added in because the input comes just after it rather than before it.



Maximum I/O response time =

Input ON delay + (Cycle time \times 2) + Output ON delay

Calculation Example

The data in the following table would produce the minimum and maximum cycle times shown calculated below.

Item	Time
Input ON-delay	1.5 ms
Output ON-delay	15 ms
Cycle time	20 ms

Minimum I/O response time = 1.5 + 20 + 15 = 36.5 ms

Maximum I/O response time = $1.5 + (20 \times 2) + 15 = 56.5 \text{ ms}$

Note In this example the I/O refresh time is negligible has not been included in the minimum I/O response time.

6-4-2 Remote I/O Systems

With Remote I/O Systems, only the cycle time of the PC needs to be considered in computing the I/O response times as long as the remote I/O transmission time is negligible and smaller than the cycle time. The cycle time, however, is increased by the presence of the Remote I/O System.

The processing that determines and the methods for calculating maximum and minimum response times from input to output are provided in this section. Calculations assume that both the input and the output are located on Slave Racks in a Remote I/O System, but the calculations are the same for I/O points on Optical I/O Units, I/O Link Units, I/O Terminals, etc.



Although more precise equations are possible if required, equations used for the following calculations do not consider fractions of a scan.

In looking at the following timing charts, it is important to remember the sequence in which processing occurs during the PC scan, particular that inputs will not produce programmed actions until the program has been executed.

When calculating the response times involving inputs and outputs from another CPU Unit connected by an I/O Link Unit, the cycle time of the controlling CPU Unit and the cycle time of the PC to which the I/O Link Unit is mounted must both be considered.

/ Caution

Noise may increase I/O delays.

Remote I/O Transmission Times

The remote I/O transmission time is computed as follows:

T_{RM} = Total Slave transmission time for one Master

= $\Sigma T_{RT} + \Sigma T_{TT}$

 T_{RT} = Transmission time for each Slave

 $= 1.4 \text{ ms} + (0.2 \text{ ms} \times \text{n})$

Where n = number of I/O words on the Slave Rack

 T_{TT} = Optical I/O Unit/I/O Terminal transmission time

= 2 ms \times m


Where m = number of Optical I/O Units/I/O Terminals

Minimum I/O Response Time

The minimum response time occurs when all signals are processed as soon as they are received. Here, three scans are required so that the program is executed, as shown in the following diagram.

Time = Input ON delay + cycle time \times 3 + output ON delay

Cycle time > Remote I/O transmission times




Maximum I/O Response Time

The maximum response time occurs when the input just misses the program execution portion of the scan, meaning that processing must wait for the next transmission and then the next (i.e., the fourth) scan.

Time = Input ON delay + cycle time \times 4 + output ON delay

Cycle time > Remote I/O transmission times

Note Use the maximum cycle time output to AR 26 in computing the maximum I/O response time.



Example Calculations

Calculations would be as shown below for an input ON delay of 1.5 ms, an output ON delay of 15 ms, and a cycle time of 20 ms.

Minimum I/O Response Time

Time = $1.5 \text{ ms} + (20 \text{ ms} \times 3) + 15 \text{ ms} = 76.5 \text{ ms}$

Maximum I/O Response Time

Time = $1.5 \text{ ms} + (20 \text{ ms} \times 4) + 15 \text{ ms} = 96.5 \text{ ms}$


Note

- 1. The cycle time may be less than or equal to the remote I/O transmission time when there are Special I/O Units on Slave Racks. If this is the case, there may be cycles when I/O is not refreshed between the Master and the C200HX/HG/HE CPU Unit.
- 2. Refreshing is performed for Masters only once per cycle, and then only after confirming completion of the remote cycle.
- 3. The short duration of ON/OFF status produced by differentiated instructions can cause inaccurate signals when dealing with Remote I/O Systems unless appropriate programming steps are taken.

6-4-3 Host Link Systems

The following diagram illustrates the processing that takes place when an input on one PC is transferred through the Host Link System to turn ON an output on another PC. Refer to Host Link System documentation for further details.





The equations used to calculate the minimum and maximum cycle times are given below. The number of cycles required for each PC depends on the amount of data being read/written.

Minimum response time =

Input ON delay + Command transmission time + (Cycle time of PC for Unit #0 \times 3) + Response transmission time + Host computer processing time + Command transmission time + (Cycle time of PC for Unit #31 \times 3) + Output ON delay


Maximum response time =

Input ON delay + Command transmission time + (Cycle time of PC for Unit #0 \times 10) + Response transmission time + Host computer processing time + Command transmission time + (Cycle time of PC for Unit #31 \times 10) + Output ON delay

6-4-4 PC Link Systems

The processing that determines and the methods for calculating maximum and minimum response times from input to output are provided in this subsection. The following System and I/O program steps will be used in all examples below. This System contains eight PC Link Units.

In looking at the following timing charts, it is important to remember the sequence processing occurs during the PC scan, particular that inputs will not produce programmed-actions until the program has been execution.



Note Noise may increase I/O delays.

PC Link Conditions

The PC Link System used in this example consists of the following:


No. of PCs linked: 8

• No. of LR points linked: 128 per PC

Maximum PC: 8LR points used: 1,024

Minimum Response Time

The following illustrates the data flow that will produce the minimum response time, i.e., the time that results when all signals and data transmissions are processed as soon as they occur.



The equation for minimum I/O response time is thus as follows:

Response time = Input ON delay + Cycle time of PC of Unit 0 + Minimum transmission time + (Cycle time of PC of Unit 7×2) + Output ON delay

Inserting the following values into this equation produces a minimum I/O response time of 149.3 ms.

Input ON delay: 1.5 ms


Output ON delay: 15 ms
Cycle time for PC of Unit 0: 20 ms
Cycle time for PC of Unit 7: 50 ms

Minimum transmission time: 2.8 ms+10 ms=12.8 ms

Maximum Response Time

The following diagram illustrates the data flow that will produce the maximum response time. Delays occur because signals or data is received just after they would be processed or because data is sent during processing. In either case, processing must wait until the next scan/polling cycle.

First output to the buffer in the polling unit is delayed by the setting of the number of LR bits to be refreshed each scan. A similar delay is present when the LR data reaches Unit 7. The polling delay is the result of the LR data in its PC being updated immediately after the previous was sent to the buffer in the PC Link Unit, cause a delay until the next polling cycle. One more polling cycle is then required before the data reaches the buffer in PC Link Unit 7.



The equation for maximum I/O response time is thus as follows:

Response time = Input ON delay + [Cycle time of PC of Unit $0 \times$ (Number of LR transfer bits \div I/O refresh bits)] + α + (PC Link polling time + Induction sequence processing time) + {Cycle time of PC of Unit $7 \times$ [(Number of LR transfer bits \div I/O refresh bits) \times 2 + 1]} + β + Output ON delay

If cycle time of PC of Unit 0 > PC Link polling time, $\alpha =$ cycle time of PC of Unit 0. If cycle time of PC of Unit 0 < PC Link polling time, $\alpha = PC$ Link polling time.

If cycle time of PC of Unit 7 > PC Link polling time, β = cycle time of PC of Unit 7. If cycle time of PC of Unit 7 < PC Link polling time, β = PC Link polling time.

Inserting the following values into this equation produces a maximum I/O response time of 661.3 ms.

Input ON delay: 1.5 ms
Output ON delay: 15 ms
Cycle time for PC of Unit 0: 20 ms
Cycle time for PC of Unit 7: 50 ms

PC Link polling time: $2.8 \text{ ms} \times 8 \text{ PCs} + 10 \text{ ms} = 32.4 \text{ ms}$ Induction sequence processing: $15 \text{ ms} \times (8 \text{ PCs} - 8 \text{ PCs}) = 0 \text{ ms}$

I/O refresh bits for Unit 0 256
I/O refresh bits for Unit 7 256

Reducing Response Time

IORF(97) can be used in programming to shorten the I/O response time greater than is possible by setting a high number of refresh bits. (Remember, increasing the number of refresh bits set on the back-panel LED shortens response time, but increases the cycle time of the PC.)

In programming the PCs for PC Link Units #0 and #7, IORF(97) is executed during every PC scan for the PC Link Units. The basic equation for the maximum I/O response time is as follows:

Response time = Input ON delay + [Cycle time of PC of Unit $0 \times$ (Number of LR transfer bits \div Number of I/O refresh bits \div 2)] + α + PC Link polling time + Induction sequence processing time + {Cycle time of PC of Unit $7 \times$ [(Number of LR transfer bits \div Number of I/O refresh bits \div 2) \times 2 + 1]} + β + Output ON delay

If cycle time of PC of Unit 0 > PC Link polling time, $\alpha =$ cycle time of PC of Unit 0. If cycle time of PC of Unit 0 < PC Link polling time, $\alpha = PC$ Link polling time.

If cycle time of PC of Unit 7 > PC Link polling time, β = cycle time of PC of Unit 7. If cycle time of PC of Unit 7 < PC Link polling time, β = PC Link polling time.

The required data from the example System configuration is as follows:

Input ON delay 1.5 ms
Output ON delay 15 ms

Cycle time of PC of Unit 0 20 ms + 5.7 ms = 25.7

(5.7 ms required for IORF execution)

Cycle time of PC of Unit 7 50 ms + 5.7 ms = 55.7

(5.7 ms required for IORF execution)

Number of PC Link Units 8

Number of LR bits 1,024

Number of refresh bits for Unit 0 256

Number of refresh bits for Unit 7 256

PC Link polling time $2.8 \text{ ms} \times 8 \text{ PCs} + 10 \text{ ms} = 32.4 \text{ ms}$ Induction sequence processing time $15 \text{ ms} \times (8 \text{ PCs} - 8 \text{ PCs}) = 0 \text{ ms}$

Placing these values into the equation produces a maximum I/O response time of 466.9 ms, approximately 200 ms shorter than when IORF is not used.

6-4-5 One-to-one Link I/O Response Time

When two C200HX/HG/HEs are linked one-to-one, the I/O response time is the time required for an input executed at one of the C200HX/HG/HEs to be output to the other C200HX/HG/HE by means of one-to-one link communications.

One-to-one link communications are carried out reciprocally between the master and the slave. The respective transmission times are as shown below, depending on the number of LR words used.

Number of words used	Transmission time
64 words (LR 00 to LR 63)	39 ms
32 words (LR 00 to LR 31)	20 ms
16 words (LR 00 to LR 15)	10 ms

The minimum and maximum I/O response times are shown here, using as an example the following instructions executed at the master and the slave. In this example, communications proceed from the master to the slave.




The following conditions are taken as examples for calculating the I/O response times.

Input ON delay: 8 ms
Master cycle time: 10 ms
Slave cycle time: 14 ms
Output ON delay: 10 ms
Number of LR words: 64 words

Minimum I/O Response Time The C200HX/HG/HE responds most quickly under the following circumstances:

- **1, 2, 3...** 1. The C200HX/HG/HE receives an input signal just prior to the input refresh phase of the cycle.
 - 2. The master to slave transmission begins immediately.
 - 3. The slave executes communications servicing immediately after completion of communications.




The minimum I/O response time is as follows:

Input ON delay: 8 ms
Master cycle time: 10 ms
Transmission time: 39 ms
Slave cycle time: 15 ms
Output ON delay: 10 ms
Minimum I/O response time: 82 ms

Maximum I/O Response Time The C200HX/HG/HE takes the longest to respond under the following circumstances:

- 1, 2, 3... 1. The C200HX/HG/HE receives an input signal just after the input refresh phase of the cycle.
 - 2. The master to slave transmission does not begin immediately.

3. Communications are completed just after the slave executes communications servicing.




The maximum I/O response time is as follows:

Input ON delay:8 msMaster cycle time: $10 \text{ ms} \times 2$ Transmission time: $39 \text{ ms} \times 3$ Slave cycle time: $15 \text{ ms} \times 2$ Output ON delay:10 msMaximum I/O response time:185 ms

6-4-6 Interrupt Response Times

The response time from the time an interrupt input is received until the interrupt subroutine execution has been completed is described next.

Input Interrupts



t1 = ON delay of Interrupt Input Unit

t2 = Software interrupt response time


Total interrupt response time = t1 + t2

The ON delay of Interrupt Input Unit is 0.2 ms or less.

The software interrupt response time depends on the interrupt response parameter setting in DM 6620 of the PC Setup. If the DM 6620 is set for the C200H-compatible mode (0000), the software interrupt response time is less than 10 ms. If the DM 6620 is set for the C200HX/HG/HE mode (1xxx), the software interrupt response time is less than 1 ms. The total interrupt response time is thus as shown in the following table.

Interrupt response setting	Total interrupt response time
C200H-compatible mode (Normal response)	0.2 ms + (Total of following: Special I/O processing time, Remote I/O processing time, Host Link servicing time, instruction execution)
C200HS mode (High-speed response)	1.2 ms or less

Scheduled Interrupts



t3 = Software interrupt response time

Total interrupt response time = t3 (software interrupt response time)

The software interrupt response time depends on the interrupt response parameter setting in DM 6620 of the PC Setup. If the DM 6620 is set for the C200H-compatible mode (0000), the software interrupt response time is less than 10 ms. If the DM 6620 is set for the C200HS mode (1xxx), the software interrupt response time is less than 1 ms. The total interrupt response time is thus as shown in the following table.

Interrupt response setting	Total interrupt response time
C200H-compatible mode (Normal response)	Total of following: Special I/O processing time, Remote I/O processing time, Host Link servicing time, instruction execution
C200HS mode (High-speed response)	1.0 ms or less

Note

- 1. If there is any instruction in the program that requires longer than 10 ms to execute when using the C200H-compatible mode, the total interrupt response time will be equal to the execution time of the instruction requiring longer than 10 ms.
- The above calculations assume that only one interrupt requires executed at any one time. If multiple interrupts are generated at the same time, execution of all but the first interrupt will go on standby, increasing the response times given above.
- 3. If an interrupt occurs while a C200HS-SLK□□ or C200HS-SNT□□ is being serviced, the interrupt will not be processed until SYSMAC NET/SYS-MAC LINK Unit servicing has been completed. The response times in this case will be as shown in the following table and will not be affected by the interrupt response setting.

Interrupt	Total interrupt response time
Input interrupt	10.2 ms max.
Scheduled interrupt	10 ms max.

This restriction does not apply when a C200HW-SLK□□ is being used with a C200HX/HG/HE PC.

Interrupt Processing Time

The processing time from receiving an interrupt input, through program execution, and until a return is made to the original program location is described next.

The limit of the count frequency resulting from using the scheduled interrupt period or input interrupts as the count input is determined by the interrupt processing time.

Interrupt processing time =

Total interrupt response time + Interrupt program execution time + Interrupt return time

The interrupt program execution time is determined by the content of the interrupt subroutine. This time is negligible f only SBN(92) and RET(93) are executed.


The interrupt return time is 0.04 ms.

Note

- If there are several elements that can cause interrupts or if the interrupt period is shorted than the average interrupt processing time, the interrupt subroutine will be executed and the main program will not be executed. This will cause the cycle monitoring time to be exceeded and an FALS 9F error will be generated, stopping PC operation.
- 2. The maximum interrupt program execution time is contained in SR 262 and SR 263.

Interrupt Input Pulse Width

The pulse width input to Interrupt Input Units must be set to within the conditions shown in the following diagram.



ON time: 0.2 ms min. OFF time: 0.5 ms min.

SECTION 7

Program Monitoring and Execution

This section provides the procedures for monitoring and controlling the PC through a Programming Console. Refer to the SYSMAC Support Software Operation Manual for SSS procedures if you are using a computer running SSS.

7-1	Monitor	ring Operation and Modifying Data	392
7-2	Progran	nming Console Operations	392
	7-2-1	Bit/Word Monitor	392
	7-2-2	Forced Set/Reset	395
	7-2-3	Forced Set/Reset Cancel	397
	7-2-4	Hexadecimal/BCD Data Modification	398
	7-2-5	Hex/ASCII Display Change	400
	7-2-6	4-digit Hex/Decimal Display Change	401
	7-2-7	8-digit Hex/Decimal Display Change	402
	7-2-8	Differentiation Monitor	403
	7-2-9	3-word Monitor	404
	7-2-10	3-word Data Modification	404
	7-2-11	Binary Monitor	405
	7-2-12	Binary Data Modification	407
	7-2-13	Changing Timer/Counter SV	408
	7-2-14	Expansion Instruction Function Code Assignments	411
	7-2-15	UM Area Allocation	412
	7-2-16	Reading and Setting the Clock	413
	7-2-17	Expansion Keyboard Mapping	413
	7-2-18	Keyboard Mapping	414

7-1 Monitoring Operation and Modifying Data

The simplest form of operation monitoring is to display the address whose operand bit status is to be monitored using the Program Read or one of the search operations. As long as the operation is performed in RUN or MONITOR mode, the status of any bit displayed will be indicated.

This section provides other procedures for monitoring data as well as procedures for modifying data that already exists in a data area. Data that can be modified includes the PV (present value) and SV (set value) for any timer or counter. All monitor operations in this section can be performed in RUN, MONITOR, or PROGRAM mode and can be cancelled by pressing CLR.

All data modification operations except for timer/counter SV changes are performed after first performing one of the monitor operations. Data modification is possible in either MONITOR or PROGRAM mode, but cannot be performed in RUN mode.

7-2 Programming Console Operations

7-2-1 Bit/Word Monitor

The status of any bit or word in any data area can be monitored using the following operation. Although the operation is possible in any mode, ON/OFF status displays will be provided for bits in MONITOR or RUN mode only.

The Bit/Digit Monitor operation can be entered either from a cleared display by designating the first bit or word to be monitored or it can be entered from any address in the program by displaying the bit or word address whose status is to be monitored and pressing MONTR.

When a bit is monitored, it's ON/OFF status will be displayed (in MONITOR or RUN mode); when a word address is designated other than a timer or counter, the digit contents of the word will be displayed; and when a timer or counter number is designated, the PV of the timer will be displayed and a small box will appear if the completion flag of a timer or counter is ON. When multiple words are monitored, a caret will appear under the leftmost digit of the address designation to help distinguish between different addresses. The status of TR bits and SR flags (e.g., the arithmetic flags), cleared when END(01) is executed, cannot be monitored.


Up to six memory addresses, either bits, words, or a combination of both, can be monitored at once, although only three of these are displayed at any one time. To monitor more than one address, return to the start of the procedure and continue designating addresses. Monitoring of all designated addresses will be maintained unless more than six addresses are designated. If more than six addresses are designated, the leftmost address of those being monitored will be cancelled.

To display addresses that are being monitored but are not presently on the Programming Console display, press MONTR without designating another address. The addresses being monitored will be shifted to the right. As MONTR is pressed, the addresses being monitored will continue shifting to the right until the rightmost address is shifted back onto the display from the left.

During a monitor operation the up and down keys can be pressed to increment and decrement the leftmost address on the display and CLR can be pressed to cancel monitoring the leftmost address on the display. If the last address is cancelled, the monitor operation will be cancelled. The monitor operation can also be cancelled regardless of the number of addresses being monitored by pressing SHIFT and then CLR.

LD and OUT can be used only to designate the first address to be displayed; they cannot be used when an address is already being monitored.


Key Sequence




Examples

The following examples show various applications of this monitor operation.

Program Read then Monitor




Bit Monitor




Note The status of TR bits SR flags SR 25503 to 25507 (e.g., the arithmetic flags), cleared when END(01) is executed, cannot be monitored.


Word Monitor



EM Area Word Monitor



Multiple Address Monitoring



7-2-2 Forced Set/Reset

When the Bit/Digit Monitor operation is being performed and a bit, timer, or counter address is leftmost on the display, PLAY/SET can be pressed to turn ON the bit, start the timer, or increment the counter and REC/RESET can be pressed to turn OFF the bit or reset the timer or counter. Timers will not operate in PRO-GRAM mode. SR bits cannot be turned ON and OFF with this operation.

Bit status will remain ON or OFF only as long as the key is held down; the original status will return as soon as the key is released. If a timer is started, the completion flag for it will be turned ON when SV has been reached.


SHIFT and PLAY/SET or SHIFT and REC/RESET can be pressed to maintain the status of the bit after the key is released. The bit will not return to its original status until the NOT key is pressed, or one of the following conditions is met.

- 1, 2, 3... 1. The Force Status Clear operation is performed.
 - 2. The PC mode is changed. (See note.)
 - 3. Operation stops due to a fatal error or power interruption.
 - 4. The I/O Table Registration operation is performed.

This operation can be used in MONITOR mode to check wiring of outputs from the PC prior to actual program execution. This operation cannot be used in RUN mode.


Note The forced set/reset bit status will be maintained when switching from PRO-GRAM to MONITOR mode if the Force Status Hold Bit is ON and DM 6601 of the PC Setup has been set maintain the bit's status. Refer to 3-6-4 PC Setup for details.

Key Sequence



Example

The following example shows how either bits or timers can be controlled with the Force Set/Reset operation. The displays shown below are for the following program section.



Address	Instruction	Da	ata
00200	LD		00100
00201	TIM		000
		#	0123
00202	LD	TIM	000
00203	OUT		00500

The following displays show what happens when TIM 000 is set with 00100 OFF (i.e., 00500 is turned ON) and what happens when TIM 000 is reset with 00100 ON (i.e., timer starts operation, turning OFF 00500, which is turned back ON when the timer has finished counting down the SV).

ON

ON

Force setting TIM 000 turns ON 00500.

Monitoring TIM 000.

TIM 000 returns to its original status when PLAY/SET is released.

Display with 0010 originally ON.

10123 ON OFF Timer starts timing, turning 00500 OFF.*

 T0000010000500
 When the time is up, 00500

 00000^ ON^ ON
 goes ON again.

Indicates that the time is up.

T0000010000500

T0000010000500

0123^ OFF^ OFF

T0000010000500

T0000010000500

0123^ OFF^ OFF

T0000010000500

T0000010000500

ON^

m00000^ OFF^

00000^

^ OFF^ OFF

7-2-3 Forced Set/Reset Cancel

тім

MONTR

PLAY

SET


MONTR

REC RESET

TIM

This operation restores the status of all bits in the I/O, IR, TIM, CNT, HR, AR, or LR areas which have been force set or reset. It can be performed in PROGRAM or MONITOR mode.

Key Sequence




When the PLAY/SET and REC/RESET keys are pressed, a beeper will sound. If you mistakenly press the wrong key, then press CLR and start again from the beginning.

^{*}Timing not done in PROGRAM mode.

Example

The following example shows the displays that appear when Restore Status is carried out normally.




7-2-4 Hexadecimal/BCD Data Modification

When the Bit/Digit Monitor operation is being performed and a BCD or hexadecimal value is leftmost on the display, CHG can be input to change the value. SR words cannot be changed.

If a timer or counter is leftmost on the display, the PV will be displayed and will be the value changed. See 7-2-13 Changing Timer/Counter SV for the procedure to change SV. PV can be changed in MONITOR mode only when the timer or counter is operating.

To change contents of the leftmost word address, press CHG, input the desired value, and press WRITE

Key Sequence



Example

The following example shows the effects of changing the PV of a timer.

timer/counter is operating.


Timing


This example is in MONITOR mode 00000 CLR 00000 Monitor status of timer PV TIM TIM 000 that will be changed. T000 MONTR 0122 Timing PRES UAL? CHG PV decrementing T000 0119 ???? **Timing** PRES UAL? O ^A 0 T000 0100 0200 **Timing** PV changed. Timer/counter PVs T000 WRITE can be changed even when the 0199

7-2-5 Hex/ASCII Display Change

This operation converts DM data displays from 4-digit hexadecimal data to ASCII and vice versa.

Key Sequence







7-2-6 4-digit Hex/Decimal Display Change

This operation converts data displays from normal or signed 4-digit hexadecimal data to decimal and vice versa.

Decimal values from 0 to 65,535 are valid when inputting normal 4-digit hexadecimal data, and decimal values from –32,768 to +32,767 are valid when inputting signed 4-digit hexadecimal data.

Key Sequence







7-2-7 8-digit Hex/Decimal Display Change

This operation converts data displays from normal or signed, 4 or 8-digit hexadecimal data to decimal and vice versa.

Decimal values from 0 to 4,294,967,295 are valid when inputting normal 8-digit hexadecimal data, and decimal values from –2,147,483,648 to +2,147,483,647 are valid when inputting signed 8-digit hexadecimal data.

Key Sequence







7-2-8 Differentiation Monitor

This operation can be used to monitor the up or down differentiation status of bits in the IR, SR, AR, LR, HR, and TC areas. To monitor up or down differentiation status, display the desired bit leftmost on the bit monitor display, and then press SHIFT and the Up or Down Arrow Key.

A CLR entry changes the Differentiation Monitor operation back to a normal bit monitor display.

Key Sequence






7-2-9 3-word Monitor


To monitor three consecutive words together, specify the lowest numbered word, press MONTR, and then press EXT to display the data contents of the specified word and the two words that follow it.

A CLR entry changes the Three-word Monitor operation to a single-word display.

Key Sequence



Example




7-2-10 3-word Data Modification


This operation changes the contents of a word during the 3-Word Monitor operation. The blinking square indicates where the data can be changed. After the new data value is keyed in, pressing WRITE causes the original data to be overwritten with the new data. If CLR is pressed before WRITE, the change operation will be cancelled and the previous 3-word Monitor operation will resume.

This operation cannot be used to change SR 253 through SR 255. Only those words displayed on the 3-word Monitor display can be changed.

Key Sequence




Example





7-2-11 Binary Monitor

You can specify that the contents of a monitored word be displayed in binary by pressing SHIFT and MONTR after the word address has been input. Words can be successively monitored by using the up and down keys to increment and decrement the displayed word address. To clear the binary display, press CLR.

Key Sequence








7-2-12 Binary Data Modification


This operation assigns a new 16-digit binary value to an IR, HR, AR, DM, EM, or LR word.

The cursor, which can be shifted to the left with the up key and to the right with the down key, indicates the position of the bit that can be changed. After positioning to the desired bit, a 0 or a 1 can then be entered as the new bit value. The bit can also be Force Set or Force Reset by pressing SHIFT and either PLAY/SET or REC/RESET. An S or R will then appear at that bit position. Pressing the NOT key will clear the force status, S will change to 1, and R to 0. After a bit value has been changed, the blinking square will appear at the next position to the right of the changed bit.

Key Sequence



Example




7-2-13 Changing Timer/Counter SV

There are two ways to change the SV of a timer or counter. It can be done either by inputting a new value; or by incrementing or decrementing the current SV. Either method can be used only in MONITOR or PROGRAM mode. In MONITOR mode, the SV can be changed while the program is being executed. Incrementing and decrementing the SV is possible only when the SV has been entered as a constant.

To use either method, first display the address of the timer or counter whose SV is to be changed, presses the down key, and then press CHG. The new value can then be input numerically and WRITE pressed to change the SV or EXT can be pressed followed by the up and down keys to increment and decrement the current SV. When the SV is incremented and/or decremented, CLR can be pressed once to change the SV to the incremented or decremented value but remaining in the display that appeared when EXT was pressed or CLR can be pressed twice to return to the original display with the new SV.

This operation can be used to change a SV from designation as a constant to a word address designation and visa verse.


Key Sequence




Example

Inputting New SV and Changing to Word Designation

The following examples show inputting a new constant, changing from a constant to an address, and incrementing to a new constant.



Incrementing and Decrementing




7-2-14 Expansion Instruction Function Code Assignments


This operation is used to read or change the function codes assigned to expansion instructions. There are 18 function codes that can be assigned to expansion instructions: 17, 18, 19, 47, 48, 60 to 69, and 87 to 89. More than one function code can be assigned to an expansion instruction.

Note Function Code Assignments can be read in any mode, but can be changed in PROGRAM mode only.

The function code assignments become possible only when the DIP switch pin 1 is OFF and pin 4 is ON.

Key Sequence






7-2-15 UM Area Allocation


This operation is used to allocate part of the UM Area for use as expansion DM. It can be performed in PROGRAM mode only. Memory allocated to expansion DM is deducted from the ladder program area.

The amount of memory available for the ladder program depends on the amount of RAM in the CPU Unit. About 15.2 KW of memory is available with the16-KW RAM and about 31.2 KW is available with the 32-KW RAM.

This operation cannot be used to allocate UM to the I/O comment area. UM can be allocated to the I/O comment area only with a host computer equipped with SYSMAC Support Software.

Key Sequence






7-2-16 Reading and Setting the Clock

This operation is used to read or set the CPU Unit's clock. The clock can be read in any mode, but it can be set in MONITOR or PROGRAM mode only.

The CPU Unit will reject entries outside of the acceptable range, i.e., 01 to 12 for the month, 01 to 31 for the day of the month, 00 to 06 for the day of the week, or 00 to 60 for the seconds, but it will not recognize non-existent dates, such as 2/31.

Example



7-2-17 Expansion Keyboard Mapping


This operation is used to control the ON/OFF status of bits SR 27700 through SR 27909 by pressing keys on the Programming Console's keyboard. The C200HX/HG/HE also supports the Keyboard Mapping operation, which controls the status of bits in AR 22. These operations can be performed in any PC mode, but the Programming Console must be in TERMINAL or expansion TERMINAL mode.

To enable expansion keyboard mapping, pin 6 of the CPU Unit's DIP switch and AR 0709 must be ON and AR 0708 must be OFF.


Bits turned ON with this operation can be turned OFF by toggling AR 0708. Turn AR 0709 OFF to stop expansion keyboard mapping and switch the Programming Console from Expansion TERMINAL mode to CONSOLE mode.

TERMINAL Mode

The Programming Console can be put into TERMINAL mode by pressing CHG or executing TERM(48) in the program. Pin 6 of the CPU Unit's DIP switch must be OFF.




Expansion TERMINAL Mode The Programming Console can be put into Expansion TERMINAL mode by turning ON AR 0709. Pin 6 of the CPU Unit's DIP switch must be ON.



7-2-18 **Keyboard Mapping**

The C200HX/HG/HE supports the expansion keyboard mapping as well as normal keyboard mapping. Expansion keyboard mapping controls the status of the 41 bits SR 27700 through SR 27909, while normal keyboard mapping controls only the 16 bits in AR 22. The status of these bits can be controlled by pressing the corresponding Programming Console keys when the Programming Console is in TERMINAL mode or expansion TERMINAL mode.

The following diagram shows how to switch the Programming Console between CONSOLE mode (normal operating mode) and TERMINAL or expansion TER-MINAL mode.



TERMINAL Mode

The Programming Console can be put into TERMINAL mode by pressing CHG or executing TERM(48) in the program. Pin 6 of the CPU Unit's DIP switch must be OFF.

Press the CHG key again to return to CONSOLE mode.

When the Programming Console is in TERMINAL mode it can perform normal keyboard mapping and display messages output by MSG(46) or LMSG(47).

With keyboard mapping, bits 00 to 15 of AR 22 will be turned ON when keys 0 to F are pressed on the Programming Console's keyboard. A bit will remain ON after the Programming Console's key is released.

All bits in AR 22 will be turned OFF when AR 0708 is turned ON. Keyboard mapping inputs are disabled when AR 0708 is ON.

In addition to the keyboard mapping function, TERMINAL mode allows messages output by MSG(46) and LMSG(47) to be displayed on the Programming Console. These messages will be erased if the Programming Console is switch back to CONSOLE mode.

Expansion TERMINAL Mode

The Programming Console can be put into Expansion TERMINAL mode by turning ON AR 0709. Pin 6 of the CPU Unit's DIP switch must be ON.

Turn off AR 0709 or pin 6 of the CPU Unit's DIP switch to return to CONSOLE mode.

When the Programming Console is in TERMINAL mode it can perform expansion keyboard mapping and display messages output by MSG(46) or LMSG(47). With expansion keyboard mapping, bits SR 27700 through SR 27909 will be turned ON when the corresponding key is pressed on the Programming Console's keyboard. A bit will remain ON after the Programming Console's key is released.

All bits from SR 27700 through SR 27909 will be turned OFF when AR 0708 is turned ON. Expansion keyboard mapping inputs are disabled when AR 0708 is ON.

In addition to the keyboard mapping function, expansion TERMINAL mode allows messages output by MSG(46) and LMSG(47) to be displayed on the Programming Console. These messages will be erased if the Programming Console is switch back to CONSOLE mode.

The following diagram shows the correspondence between the position of Programming Console keys and bits in the SR Area. Each key corresponds 1 to 1 with a bit. Shifted inputs are not recognized. Keys 0 to 15 correspond to bits SR 27700 to SR 27715, keys 16 to 31 correspond to bits SR 27800 to SR 27815, and keys 32 to 41 correspond to bits SR 27900 to SR 27909.

FUN key>	0	1	2	3	4	5
	6	7	8	9	10	11
	12	13	14	15	16	17
	18	19	20	21	22	23
	24	25	26	27	28	29
	30	31	32	33	34	35
	36	37	38	39	40	41

The following table shows the correspondence between the actual Programming Console keys and bits SR 27700 to SR 27909.

SR word	Bit	Corresponding key(s)
277	00	FUN
	01	SET
	02	NOT

SR word	Bit	Corresponding key(s)
277	03	*1
	04	*2
	05	
		SHIFT
	06	AND
		AND H-
	07	OR
		OR H
	08	CNT
		CNI
	09	TR
	10	LR
	11	HR
	12	LD H-
		HF
	13	OUT
		OUT -O+
	14	TIM
		lim lim
	15	DM
		DM
278	00	СН
		*
	01	CONT
		#
	02	7
		·
	03	8
		Ů
	04	9
	05	EXT
	06	СНС
	07	SRCH
	08	E 4
	09	F 5
	10	6
		Ů

SR word	Bit	Corresponding key(s)
278	11	PLAY SET
	12	DEL
	13	MONTR
	14	B 1
	15	© 2
279	00	D 3
	01	REC RESET
	02	INS
	03	•
	04	A 0
	05	*3
	06	CLR
	07	VER
	08	WRITE
	09	•

SECTION 8 Serial Communications

This section provides an overview of the serial communications (Host Link, RS-232C, one-to-one links, NT links, and protocol macros) that operate through the RS-232C, RS-422/485, and Peripheral Ports.

8-1	Introdu	ction	420
8-2	Host L	ink Communications	421
	8-2-1	Host Link Command Summary	421
	8-2-2	Host Link Communications	424
	8-2-3	Example Programs	427
8-3	RS-232	2C Communications	428
	8-3-1	Communications Frame Structure	429
	8-3-2	Communications Procedure	429
	8-3-3	Application Example	431
8-4	One-to-	-one PC Links	432
8-5	NT Lin	ks	434
8-6	The Pro	otocol Macro Function	435
	8-6-1	Introduction	435
	8-6-2	Communications Board Settings	438
	8-6-3	Communications Procedure	439
	8-6-4	Application Example	442

Introduction Section 8-1

8-1 Introduction

The RS-232C port and peripheral port built into the C200HX/HG/HE PC's CPU Unit support the following communications functions:

- Communications with Programming Devices (e.g., Programming Console or SSS.)
- Host Link communications with personal computers and other external devices.
- RS-232C (no-protocol) communications with personal computers and other external devices.
- One-to-one link communications with another PC.
- NT link communications (one-to-one or one-to-N) with Programmable Terminals (PTs) equipped with an NT link interface.

In addition to these communications functions, optional Communications Boards that support Protocol Macros can be installed in most C200HX/HG/HE PCs.

The following table summarizes the communications functions.


Function	Connected device	Connection	Summary	Related instructions
Host Link	Host computer or PT	One-to-one or One-to-N	Provides communications between a host computer and PC.	Host Link commands, TXD(—)
			The PC's operating status and the contents of data areas can be monitored from the host computer.	
			TXD(—) can be used to transmit data from the PC's data areas to the host computer.	
RS-232C (no protocol)	Host computer or other RS-232C device	One-to-one	TXD(—) and RXD(—) can be used to manage simple data transfer sequences such as inputs from bar code readers or outputs to printers.	TXD(—), RXD(—)
			Control signals RS, CS, ER, and DR can be controlled by the instructions.	
One-to-one Link	PC	One-to-one	Makes a one-to-one connection be- tween two PCs using the LR areas of the PCs.	
NT Link	PT	One-to-one or One-to-N	Provides data transfers between the PC and one or more PTs.	
Protocol Macro	Other serial device	One-to-one or One-to-N	The Protocol Macro function allows the user to define separate data transfer sequences and transfer messages.	PMCR(—)
			Up to 1,000 communications sequences can be registered.	
			A support program is provided that simplifies creation of communications sequences.	

8-2 Host Link Communications

8-2-1 Host Link Command Summary


Host Link communications are used to transfer data between the PC and a host computer (a personal computer or PT). It is possible to monitor the PC's operating status and the contents of PC data areas from the host computer using Host Link commands. It is also possible to transfer data from the PC's IOM data areas (IR area, SR area, LR area, HR area, AR area, timer and counter PVs, DM 0000 through DM 6143, and EM 0000 through EM 6143) to a host computer using the TXD(—) instruction in the ladder program.

RS-232C Connections (1-to-1) Only one PC can be connected with the host computer (one-to-one connection) when the Host Link is made with RS-232C connections.



RS-422/485 Connections (1-to-N)


Up to 32 PCs can be connected with the host computer (one-to-N connection) when the Host Link is made with RS-422/485 connections.



Wiring Ports

Use the wiring diagram shown below as a guide in wiring the port to the external device. Refer to documentation provided with the computer or other external device for wire details for it.

The connections between the C200HX/HG/HE and a personal computer are illustrated below as an example.



Applicable Connectors

The following connectors are applicable. One plug and one hood are included with the CPU Unit.

Plug: XM2D-0901 (female) for IBM PC/AT or compatible (OMRON)

or equivalent

Hood: XM2S-0911 (OMRON) or equivalent

Note Ground the FG terminal on the PC and at the computer to 100 Ω or less. Refer to the C200HX/HG/HE Installation Manual and to the documentation for your computer for details.

Host Link Parameters

The following parameters in the PC Setup must be set in advance to enable Host Link communications.

Communications Mode

Set the communications mode to Host Link mode. (This is the default setting.)

RS-232C port: Set bits 12 through 15 of DM 6645 to 0. Peripheral port: Set bits 12 through 15 of DM 6650 to 0.

Node Number Setting

When 1:N connections are being used, set a unique node number from 00 to 31. When a 1:1 connection is being used, set the PC's node number to 00.

RS-232C port: Set bits 00 through 07 of DM 6648 (00 to 31). Peripheral port: Set bits 00 through 07 of DM 6653 (00 to 31).

Standard Port Settings

Standard settings or custom settings can be used for the RS-232C and peripheral ports. The standard settings are used when the following bits are set to 0. (The custom settings are explained below.)

RS-232C port: Bits 00 through 03 of DM 6645 (0: standard; 1: custom). Peripheral port: Bits 00 through 03 of DM 6650 (0: standard; 1: custom).

The standard settings are shown in the following table.

ltem	Setting
Start bits	1
Data length	7
Stop bits	2
Parity	Even
Baud rate	9,600 bps


Custom Port Settings

Standard settings or custom settings can be used for the RS-232C and peripheral ports. The custom settings are used when the following bits are set to 1.

RS-232C port: Bits 00 through 03 of DM 6645 (0: standard; 1: custom). Peripheral port: Bits 00 through 03 of DM 6650 (0: standard; 1: custom).

The custom settings for the RS-232C port are defined in DM 6646 and the custom settings for the peripheral port are defined in DM 6651.

The following settings are valid only when pin 5 on the CPU Unit's DIP switch is turned OFF. Be sure to set the communications parameters to the same settings for both ends of the communications.



Parameter	Setting	Start bits	Data length	Stop bits	Parity
Transmission Frame Format	00	1	7	1	Even
	01	1	7	1	Odd
	02	1	7	1	None
	03	1	7	2	Even
	04	1	7	2	Odd
	05	1	7	2	None
	06	1	8	1	Even
	07	1	8	1	Odd
	08	1	8	1	None
	09	1	8	2	Even
	10	1	8	2	Odd
	11	1	8	2	None

Parameter	Setting	Baud rate
Baud rate	00	1,200 bps
	01	2,400 bps
	02	4,800 bps
	03	9,600 bps
	04	19,200 bps

Transmission Delay Time

Depending on the devices connected to the RS-232C port, it may be necessary to allow time for transmission. When that is the case, set the transmission delay to regulate the amount of time allowed. The transmission delay time is set in units of 10 ms.

RS-232C port: Set DM 6647 from 0000 to 9999 (0 to 99.99 s delay). Peripheral port: Set DM 6652 from 0000 to 9999 (0 to 99.99 s delay).

Note If pin 5 of the CPU Unit's DIP switch is ON, the standard communications settings will be used regardless of the settings in the PC Setup. The standard settings are as follows:

Item	Setting
Node number	00
Start bits	1
Data length	7
Stop bits	2
Parity	Even
Baud rate	9,600 bps
Transmission delay time	None


8-2-2 Host Link Communications

Host link communications are executed by means an exchange of commands and responses between the host computer and the PC. The command or response data that is transferred in one exchange is known as a frame and one frame can contain up to 131 characters of data.

The frame formats for Host Link commands transmitted from the host computer and responses returned from the PC are described below. The PC automatically returns an ASCII-code response when it receives an ASCII-code command from the host computer. The host computer must have a program that controls the transmission and reception of the commands and responses.

Command Frame Format

When transmitting a command from the host computer, prepare the command data in the format shown below.



The header code and text depend on the Host Link command being transmitted. When a composite command is transmitted, there will be a second sub-header code.

The FCS (Frame Check Sequence) code is calculated at the host computer and set in the command frame. The FCS calculation is described later in this section.

The command frame may be up to 131 characters long. A command of 132 characters or more must be divided into more than one frame. To split the command, use a carriage return delimiter (\downarrow , CHR\$(13)) instead of a terminator. A terminator must be used at the end of the last frame.

When dividing commands such as WR, WL, WC, or WD that execute write operations, be careful not to divide into separate frames data that is to be written into a single word. Be sure to divide frames so that they coincide with the divisions between words.

Item	Function	
@	An "@" symbol must be placed at the beginning of every command.	
Node no.	Identify the PC by the node number set in DM 6648 of the PC Setup.	
Header code	Set the 2-character command code.	
Text	Set the command parameters.	
FCS	Set a 2-character Frame Check Sequence code.	
Terminator	Set two characters, "*" and the carriage return (CHR\$(13)) to indicate the end of the command.	

Response Frame Format

The response from the PC is returned in the format shown below. Prepare a program so that the response data can be interpreted and processed.




The header code and text depend on the Host Link command that was received. The end code indicates the completion status of the command (e.g., whether or not an error has occurred).

When the response is longer than 131 characters, it will be divided into more than one frame. A carriage return delimiter (,I, CHR\$(13)) instead of a terminator will automatically be set at the end of the frame. A terminator will be set at the end of the last frame.

Item	Function
@	An "@" symbol is placed at the beginning of every response.
Node no.	The PC's node number set in DM 6648 of the PC Setup.
Header code	The 2-character command code is returned.
Text	The results of the command are returned.
FCS	The 2-character Frame Check Sequence code is returned.
Terminator	Two characters, "*" and the carriage return (CHR\$(13)) indicate the end of the response.

FCS (Frame Check Sequence) When a frame is transmitted, an FCS code is placed just before the delimiter or terminator in order to check whether an error has occurred in the transmission. The FCS is 8-bit data converted into two ASCII characters. The 8-bit data is the result of an EXCLUSIVE OR performed on the data from the beginning of the frame until the end of the text in that frame (i.e., just before the FCS). Calculating the FCS each time a frame is received and checking the result against the FCS that is included in the frame makes it possible to check for data errors in the frame.




	ASCII code			
@	40	0100 EOR	0000	
1	31	0011 EOR	0001	
0	30	0011 EOR	0000	
R	52	0101	0010	
		1		
<u>1</u>	31	0011	0001	
Calculation		0100	0010	
result		i	i	Converted to hexadecimal.
		4	2	Handled as ASCII characters.


Communications Sequence

The right to send a frame is called the "transmission right." The Unit that has the transmission right is the one that can send a frame at any given time. The transmission right is traded back and forth between the host computer and the PC each time a frame is transmitted. An example communications sequence between the host computer and PC is described below.

- The host computer sets a delimiter at the end of the first command frame and transmits the frame.
- When the PC receives the delimiter, it returns the same delimiter to the host computer.
- After receiving the delimiter from the PC, the host computer transmits the next frame.
- The PC sets a delimiter at the end of the first response frame and transmits the frame.
- When the host computer receives the delimiter, it returns the same delimiter to the PC
- After receiving the delimiter from the host computer, the PC transmits the next frame.
- Long transmissions are managed by exchanging delimiters in this way. The last frame ends with a terminator.



Using the TXD(—) Instruction The TXD(—) instruction can be used to transmit data from the PC's data area to the host computer. There is no response from the host computer. The TXD(—) instruction will be executed after the response has been transmitted if TXD(—) is executed while a response to a Host Link command is being returned to the host computer.



8-2-3 Example Programs

Command Transmission

The following type of program must be prepared in the host computer to receive the data. This program allows the computer to read and display the data received from the PC while a host link read command is being executed to read data from the PC.

```
10 'C200HX/HG/HE SAMPLE PROGRAM FOR EXCEPTION
20 CLOSE
30 CLS
40 OPEN "COM:E73" AS #1
50 ★KEYIN
60 INPUT "DATA ----",S$
70 IF S$=" " THEN GOTO 190
80 PRINT "SEND DATA = ";S$
90 ST$=S$
100 INPUT "SEND OK? Y or N?=",B$
110 IF B$="Y" THEN GOTO 130 ELSE GOTO ★KEYIN
120 S$=ST$
                                         'Sends command to PC
130 PRINT #1,S$
140 INPUT #1,R$
                                         'Receives response from PC
150 PRINT "RECV DATA = ";R$
160 IF MID$(R$,4,2)="EX" THEN GOTO 210 'Identifies command from PC
170 IF RIGHT$(R$,1)<>"*" THEN S$=" ":GOTO 130
180 GOTO ★KEYIN
190 CLOSE 1
200 END
210 PRINT "EXCEPTION!! DATA"
220 GOTO 140
```

Example Program for FCS

This example shows a BASIC subroutine program for executing an FCS check on a frame received by the host computer.


```
400 *FCSCHECK
410 L=LEN(RESPONSE$) ' . . . . . Data transmitted and received
420 Q=0:FCSCK$=" "
430 A$=RIGHT$(RESPONSE$,1)
440 PRINT RESPONSE$, AS, L
450 IF A$="*" THEN LENGS=LEN(RESPONSE$)-3
              ELSE LENGS=LEN(RESPONSE$)-2
460 FCSP$=MID$(RESPONSE$, LENGS+1, 2) ' . ... FCS data received
470 FOR I=1 TO LENGS ' . . . . . Number of characters in FCS
480 Q=ASC(MID$(RESPONSE$, I, 1)) XOR Q
490 NEXT I
500 FCSD$=HEX$(Q)
510 IF LEN(FCSD$)=1 THEN FCSD$="0"+FCSD$ 'FCS result
520 IF FCSD$<>FCSP$ THEN FCSCK$="ERR"
530 PRINT"FCSD$=";FCSD$,"FCSP$=";FCSP$,"FCSCK$=";FCSCK$
540 RETURN
```

Note

- 1. Normal reception data includes the FCS, delimiter or terminator, and so on. When an error occurs in transmission, however the FCS or some other data may not be included. Be sure to program the system to cover this possibility.
- 2. In this program example, the CR code (CHR\$(13)) is not entered for RE-SPONSE\$. When including the CR code, make the changes in lines 430 and 450.

TXD(—) Application Example This example shows a program for using the RS-232C port in the Host Link mode to transmit 10 bytes of data (DM 0000 to DM 0004) to a computer. From DM 0000 to DM 0004, "1234" is stored in every word.

The default values are assumed for all of the PC Setup (i.e., the RS-232C port is used in Host Link mode, the node number is 00, and the standard communications parameters are used.)




If SR 26405 (the Transmit Ready Flag) is ON when IR 00100 turns ON, the ten bytes of data (DM 0000 to DM 0004) will be transmitted.

8-3 RS-232C Communications

This section explains RS-232C communications. The TXD(—) and RXD(—) instructions can be used with RS-232C communications to output data to a printer, input data from a bar code reader or transmit Host Link commands to other devices equipped with an RS-232C port.

RS-232C Connection

The following diagram shows the RS-232C connection when the RS-232C port is used in RS-232C mode (no protocol).



PC Setup Parameters

The following parameters in the PC Setup must be set in advance to enable RS-232C mode communications through the RS-232C or peripheral ports.

Communications Mode

Set the communications mode to RS-232C mode.

RS-232C port: Set bits 12 through 15 of DM 6645 to 1. Peripheral port: Set bits 12 through 15 of DM 6650 to 1.


Standard Port Settings

Standard settings or custom settings can be used for the RS-232C and peripheral ports. Refer to page 422 for details on the standard communications settings.

Custom Port Settings

Standard settings or custom settings can be used for the RS-232C and peripheral ports. Refer to page 423 for details on custom communications settings.


Enabling Start and End Codes



Defaults: No start code; data reception complete at 256 bytes.

Specify whether or not a start code is to be set at the beginning of the data, and whether or not an end code is to be set at the end. Instead of setting the end code, it is possible to specify the number of bytes to be received before the reception operation is completed. Both the codes and the number of bytes of data to be received are set in DM 6649 or DM 6654.

Setting the Start Code, End Code, and Amount of Reception Data



Defaults: No start code; data reception complete at 256 bytes.

8-3-1 Communications Frame Structure

Up to 259 bytes of data (including the start and end codes) can be transferred with the execution of one TXD(—) or RXD(—) instruction. When there are two or more start codes, the first start code will be used. Likewise, when there are two or more end codes, the first end code will be used.

Avoid using commonly occurring characters for the end code. Use CR and LF for the end code if data transmissions are being cut short because the end code is occurring within the body of the transmission data.

• No start code and end code

	Data (specified number of bytes)	
Start code only		
ST	Data (specified number of bytes)	
• End code only		
	Data (256 bytes or less)	ED

• Both start code and end code

ı			
	ST	Data (257 bytes or less)	I FD
	٠.	Data (201 by 100 of 1000)	

• CR, LF specified for the end code

-			
	Data (258 bytes or less)	CR	LF

Both start code (00 to FF) and end code (CR, LF)

ST Data (259 bytes or less) CR LF

8-3-2 Communications Procedure

Brief descriptions of the TXD(—) and RXD(—) are provided below.

Transmission (TXD(—))

Refer to 5-27-2 TRANSMIT – TXD(—) for more details. Always include the specified port's Transmit Ready Flag as an execution condition for TXD(—) to ensure that this Flag is ON before the transmission can be executed.

Check to see that SR 26405 (RS-232C Port Transmit Ready Flag), SR 26413 (Peripheral Port Transmit Ready Flag), SR 28305 (Communications Board Port A Transmit Ready Flag), or SR 28313 (Communications Board Port B Transmit Ready Flag) is ON.

2. Use the TXD(—) instruction to transmit the data. (Bits 08 to 11 are valid only when bits 12 to 15 are set to 0.)

(@)TXD
S
C

- S: Address of first word of data to be transmitted
- C: Control data

Bits 00 to 03

0: Leftmost bytes first

1: Rightmost bytes first

Bits 04 to 07

0: Normal data transmission operation

1: Status of bit 15 for the leftmost word of the transmission data is reflected on the RTS of the corresponding port.

2: Status of bit 15 for the leftmost word of the transmission data is reflected on the

the transmission data is reflected on the DTR of the corresponding port.

3: Statuses of bits 14 and 15 for the leftmost word of the transmission data are

reflected on the RTS and DTR of the corresponding port.

Bits 08 to 11

0: Built-in RS-232C port

1: Communications Board port A

2: Communications Board port B

Bits 12 to 15

0: RS-232C port

1: Peripheral port

2: Host Link Unit #1

3: Host Link Unit #2

N: Number of bytes to be transmitted (4 digits BCD), 0000 to 0256 (start and end bits)

From the time this instruction is executed until the data transmission is complete, the Transmit Ready Flag (SR 26405, SR 26413, SR 28305, or SR 28313) will remain OFF. It will turn ON again upon completion of the data transmission.

Reception (RXD(--))

Refer to 5-27-1 RECEIVE - RXD(-) for more details.

- Check to see that SR 26406 (RS-232C Port Reception Completed Flag) or SR 26414 (Peripheral Port Reception Completed Flag) is ON.
 - 2. Use the RXD(—) instruction to receive the data. (Bits 08 to 11 are valid only when bits 12 to 15 are set to 0.)



- D: Leading word no. for storing reception data
- C: Control data

Bits 00 to 03

0: Leftmost bytes first

1: Rightmost bytes first

Bits 04 to 07

0: Normal data reception operation

1: Reads the status of CTS of the corresponding port into bit 15 for the leftmost word of the reception data write.

2: Reads the status of DSR of the corresponding port into bit 15 for the leftmost word of the reception data write.

3: Reads the statuses of CTS and DSR of the corresponding port into bits 14 and 15 for the leftmost word of the reception data

write.

Bits 08 to 11

0: Built-in RS-232C port

1: Communications Board port A

2: Communications Board port B

Bits 12 to 15

0: RS-232C port

1: Peripheral port

N: Number of bytes stored (4 digits BCD), 0000 to 0256 (start and end bits)

3. When RXD(—) is executed, the received data is transferred to the specified words (without the start and end codes) and the Reception Completed Flag is turned OFF. The start and end of reception are as follows:

Start: Continuous reception status if the start code is not enabled.

Reception starts when the start code is received if it is enabled.

End: Reception ends when the end code is received or 259 bytes of data

have been received.

4. The status resulting from reading the data received will be stored in the SR Area. Check to see that the operation was successfully completed. The contents of these bits will be reset each time RXD(—) is executed.

RS-232C	Peripheral	Error
SR 26400 to SR 26403	SR 26408 to SR 26411	Communications port error code (1 digit BCD) 0: Normal completion 1: Parity error 2: Framing error 3: Overrun error
SR 26404	SR 26412	Communications Error Flag
SR 26407	SR 26415	Reception Overrun Flag (After reception was completed, the subsequent data was received before the data was read by means of the RXD instruction.)
SR 265	SR 266	Number of bytes received (not including start and end bits)

Note To reset the RS-232C port (i.e., to restore the initial status), turn ON SR 25209. To reset the Communications Board port A, turn ON SR 28900. To reset the Communications Board port B, turn ON SR 28901. These bits will turn OFF automatically after the reset.

8-3-3 Application Example


This example shows a program for using the RS-232C port in the RS-232C mode to transmit 10 bytes of data (DM 0100 to DM 0104) to the computer, and to store the data received from the computer in the DM area beginning with DM 0200. Before executing the program, the following PC Setup settings must be made.

DM 6645: 1000 (RS-232C port in RS-232C mode; standard settings)

DM 6648: 2000 (No start code; end code CR/LF)

The default values are assumed for all other PC Setup settings. The host computer must have the same communications settings and a program to receive the data transmitted from the PC.

The data 3454 is stored in each word from DM 0100 to DM 0104.



If SR 26405 (the Transmit Ready Flag) is ON when IR 00100 turns ON, the ten bytes of data (DM 0100 to DM 0104) will be transmitted, leftmost bytes first.

When SR 26406 (Reception Completed Flag) goes ON, the number of bytes of data specified in SR 265 will be read from the PC's reception buffer and stored in memory starting at DM 0200, leftmost bytes first.

The data will be as follows:


"3454345434543454<u>CR LF"</u>

One-to-one PC Links Section 8-4

8-4 One-to-one PC Links

If two PCs are linked one-to-one by connecting them together through their RS-232C ports, they can share common LR areas. When two PCs are linked one-to-one, one of them will serve as the master and the other as the slave.

As shown in the diagram below, when data is written into a word the LR area of one of the linked Units, it will automatically be written identically into the same word of the other Unit. Each PC has specified words to which it can write and specified words that are written to by the other PC. Each can read, but cannot write, the words written by the other PC.




Wiring

Wire the cable as shown in the diagram below using the connector listed.

Applicable Connectors

The following connectors are applicable. One plug and one hood are included with the CPU Unit. The same connectors can be used for both ends of the cable.

Plug: XM2A-0901 (OMRON) or equivalent Hood: XM2S-0911 (OMRON) or equivalent




Note Ground the FG terminal of the PC to a resistance of 100 Ω or less.

One-to-one PC Links Section 8-4

PC Setup

To use a 1:1 link, the only settings necessary are the communications mode and the link words.

Set the communications mode for one of the PCs to one-to-one link master and the other PC to one-to-one link slave, and then set the link words in the PC designated as the master. Bits 08 to 11 are valid only for the master for link one-to-one.



The word used by each PC will be as shown in the following table, according to the settings for the master, slave, and link words.

DM 6645 setting	LR 00 to LR 63	LR 00 to LR 31	LR 00 to LR 15
Master words	LR00 to LR31	LR00 to LR15	LR00 to LR07
Slave words	LR32 to LR63	LR16 to LR31	LR08 to LR15

Communications Procedure

If the settings for the master and the slave are made correctly, then the one-toone link will start up automatically when the PCs are turned on.

Application Example


This example shows a program for verifying the conditions for executing a one-to-one link using the RS-232C ports. Before executing the program, set the following PC Setup parameters.

Master: DM 6645: 3200 (one-to-one link master; link words: LR 00 to LR 15)


Slave: DM 6645: 2000 (one-to-one link slave)

When the following programs are executed in the master and the slave, the status of IR 001 of each Unit will be reflected in IR 100 of the other Unit. IR 001 is an input word and IR 100 is an output word.

In the Master



In the Slave



NT Links Section 8-5


8-5 NT Links

A one-to-one NT link that uses NT link commands can be established by connecting the RS-232C port of the PC to the RS-232C port of a Programmable Terminal (PT).

A one-to-N NT link that uses NT link commands can be established by connecting the PC and Programmable Terminal (PT) with RS-422/485 cable.


One-to-one NT Links

The following diagram shows the connections for a one-to-one NT link.



One-to-N NT Links

The following diagram shows the connections for a one-to-N NT link. Up to 8 Programmable Terminals can be connected unless the PC is a C200HE-CPU__-E. With a C200HE-CPU__-E, up to 4 Programmable Terminals can be connected (including connections through a Communications Board).



The following table shows the maximum number of PTs that can be connected to each port.

PC	RS-232C port	Communications port A	Communications port B
C200HE	4	4	4
C200HX/HG	8	8	8

PC Setup

Make the following settings when establishing an NT link.

Link	Port	Setting
One-to-one	Built-in RS-232C port	Set bits 12 to 15 of DM 6645 to 4.
	Communications Board port B	Set bits 12 to 15 of DM 6550 to 4.
	Communications Board port A	Set bits 12 to 15 of DM 6555 to 4.
One-to-N	Built-in RS-232C port	Set bits 12 to 15 of DM 6645 to 5.
		Set the max. node number (1 to 7) in bits 08 to 11 of DM 6545 (1 to 3 for the C200HE).
	Communications Board port B	Set bits 12 to 15 of DM 6550 to 5.
		Set the max. node number (1 to 7) in bits 08 to 11 of DM 6550 (1 to 3 for the C200HE).
	Communications Board port A	Set bits 12 to 15 of DM 6555 to 5.
		Set the max. node number (1 to 7) in bits 08 to 11 of DM 6555 (1 to 3 for the C200HE).

Restrictions on Use

If the C200H-OV001 Voice Unit is being used, the 1:N mode cannot be used with the RS-232 port. In that case, either use the NT Link in 1:1 mode or use the 1:N mode with the port on the communications board.

Applications

Refer to the documentation provided for the NT Link Interface Unit for details on actual NT link applications.

8-6 The Protocol Macro Function

This section explains how to use the Protocol Macro function.

8-6-1 Introduction


The Protocol Macro function is a communications protocol that controls half duplex (see below) data transfers with various communications devices and general-purpose components equipped with RS-232C or RS-422/485 ports. The user can easily modify the data transfer procedures (communications sequences) with OMRON's Protocol Support Software and execute the communications sequences from the ladder program with PMCR(—).

The Communications Boards come equipped with seven communications procedures. These standard sequences can be used as is or modified to meet the requirements of a particular application.

Note Refer to the *Communications Board Operation Manual* for details on Communications Boards and the *Protocol Support Software Operation Manual* for details on the Protocol Support Software.


Half Duplex Communications

With half duplex communications, data is received and sent consecutively, i.e., not at the same time. (The C200HX/C200HG/C200HE Protocol Macro function supports half duplex communications only.)




Full Duplex Communications

With full duplex communications, data can be received and sent simultaneously. (The C200HX/C200HG/C200HE Protocol Macro function does not support full duplex communications.)




RS-232C Connection (One-to-one)

Only one device can be connected with an RS-232C connection. The RS-232C cable can be up to 15 m long.



RS-422/485 Connection (One-to-N)


An RS-422/485 connection allows 2 or more devices to be connected (one-to-N connection) with a maximum cable length of 500 m. The RS-422/485 connection is also useful for distant one-to-one connections.




Connection Cable Wiring

The following diagrams show the cable wiring used with Protocol Macro function communications.


RS-422/485 Adapter Connection (NT-AL001)



General Device/Computer Connections (RS/CS Flow, Cross Connection)



Modem Connection (Straight Connection)



Note Ground the FG terminals on the PC and at the other device to 100 Ω or less. Refer to the *C200HX/HG/HE Installation Manual* and the documentation included with the other device for details.

8-6-2 Communications Board Settings

The following parameters must be set in advance in order to use the Protocol Macro function through a Communications Board.

Communications Mode

Set the communications mode to Protocol Macro mode.

Port B: Set bits 12 through 15 of DM 6550 to 6. Port A: Set bits 12 through 15 of DM 6555 to 6.

Standard Port Settings

Standard settings or custom settings can be used for ports A and B. The standard settings are used when the following bits are set to 0.

Port B: Bits 00 through 03 of DM 6550 (0: standard; 1: custom). Port A: Bits 00 through 03 of DM 6555 (0: standard; 1: custom).

The standard settings are shown in the following table.


Item	Setting
Start bits	1
Data length	7
Stop bits	2
Parity	Even
Baud rate	9,600 bps

Custom Port Settings

Standard settings or custom settings can be used for ports A and B. The custom settings are used when the following bits are set to 1.

Port B: Bits 00 through 03 of DM 6550 (0: standard; 1: custom). Port A: Bits 00 through 03 of DM 6555 (0: standard; 1: custom).

The custom settings for Port B are defined in DM 6551 and the custom settings for the Port A are defined in DM 6556.



Parameter	Setting	Start bits	Data length	Stop bits	Parity
Transmission Frame	00	1	7	1	Even
Format	01	1	7	1	Odd
	02	1	7	1	None
	03	1	7	2	Even
	04	1	7	2	Odd
	05	1	7	2	None
	06	1	8	1	Even
	07	1	8	1	Odd
	08	1	8	1	None
	09	1	8	2	Even
	10	1	8	2	Odd
	11	1	8	2	None

Parameter	Setting	Baud rate
Baud rate	00	1,200 bps
	01	2,400 bps
	02	4,800 bps
	03	9,600 bps
	04	19,200 bps

8-6-3 Communications Procedure

The Protocol Macro's communications sequences must be created with the Protocol Support Software and transferred to the Communications Board in advance. In the PC, the PMCR(—) instruction is executed to execute a communications sequence stored in the Communications Board.

Communications Sequence Structure

Up to 1,000 communications sequences with sequence numbers 000 to 999 can be created with the Protocol Support Software. Each communications sequence is composed of a maximum of 16 steps. The following table shows the communications sequence settings.

	Item	Function	Parameter settings
settings such as X-on/X-off flow CS flow control.		Sets the transmission control method, such as X-on/X-off flow control or RS/CS flow control.	X-on/X-off, RS/CS, modem control, de- limiter control, or contention control
	Link words	Sets the link words for the data link between the PC and Communications Board.	IR/SR, LR, HR, AR, DM, and EM areas
	Monitor time	Sets the monitor time (watchdog timer) for communications processing.	Reception standby, reception completed, transmission completed 0.01 s, 0.1 s, 1 s, and 1 minute units
	Response notification	Sets the timing for writing the received data.	Scan notification or interrupt notification
Step settings	Repeat counter	Sets the number of times to repeat the step.	Constant 0 to 255 IR/SR, LR, HR, AR, DM, and EM areas
	Command	Sets the communications command.	Send, Recv, or Send&Recv
	Number of retries	Sets the number of retries when errors occur for the Send&Recv command.	0 to 9
	Transmission wait time	Sets the time to wait before sending the data when transmitting	0.01 s, 0.1 s, 1 s, and 1 minute units
	Transmission message	Sets the transmission data for the Send or Send&Recv commands.	Header, address, length, data, error check code, and terminator
	Reception message	Sets the expected reception data for the Recv or Send&Recv commands.	Header, address, length, data, error check code, and terminator
	Reception matrix	Sets the expected reception data (up to 15 types) for the Recv or Send&Recv commands and adjusts processing depending on the data type.	Header, address, length, data, error check code, terminator, and next process
	Response notification	Sets whether or not to write the received data.	Yes/No
	Next process	Sets the next step to go to when the current step has been completed successfully.	End, Goto, Next, or Abort
	Error processing	Sets the next step to go to when an error has occurred in the current step.	End, Goto, Next, or Abort

Transmission/Reception Message Structure

The transmission message and reception message have the following structure.

111	A -I -I	1	D-4-	Fanca a state at a	T
Header	Address	Length	Data	Error check	Terminator

Item	Function
Header	Set the data that indicates the beginning of the message.
Address	Set the node number or other identifier that indicates the destination for the message.
Length	The data length (number of bytes) is added automatically.
Data	Set the message contents.
Error check code	Set SUM, LRC, or CRC as the error check code. The specified error check code will be added automatically when transmitting. When receiving, error control will be performed automatically based on the error check code specified in the message and the specified amount (length) of data will be received.
Terminator	Set the data that indicates the end of the message.

The following attributes can be set for each item in the transmission or reception message. The abbreviation "R M" stands for reception message and "T M" stands for transmission message.

Da	ata attribute	Hea	ader	Add	ress	Ler	ngth	Da	ata	Error	ror check Termi		inator
		ТМ	R M	ТМ	R M	ТМ	R M	ТМ	R M	ТМ	R M	ТМ	R M
Constant	ASCII " HEX [Yes	Yes	Yes	Yes			Yes	Yes			Yes	Yes
	Special characters CR, STX, etc.	Yes	Yes					Yes	Yes			Yes	Yes
No variable conversion	First-order equation using variable (N)			Yes	Yes			Yes	Yes				
	Wild card (*)				Yes				Yes				
	Read word (R)			Yes	Yes			Yes	Yes				
	Write word (W)				Yes				Yes				
	Automatic variable: LNG					Yes	Yes						
	Automatic variable: SUM, LRC, and CRC									Yes	Yes		
Variable ASC	First-order equation using variable (N)			Yes	Yes			Yes	Yes				
conversion	Wild card (*)				Yes				Yes				
	Read word (R)			Yes	Yes			Yes	Yes				
	Write word (W)				Yes				Yes				
	Automatic variable: LNG					Yes							
	Automatic variable: SUM, LRC, and CRC									Yes			
Variable HEX	First-order equation using variable (N)			Yes	Yes			Yes	Yes				
conversion	Wild card (*)				Yes				Yes				
	Read word (R)			Yes	Yes			Yes	Yes				
	Write word (W)				Yes				Yes				
	Automatic variable: LNG						Yes						
	Automatic variable: SUM, LRC, and CRC										Yes		

Read Word (R)

Word data can be read by setting the desired attributes for the "address" or "data" in the transmission and reception messages. When the attribute is set, the address or data is read from the specified word. There are three ways to specify the word:

1, 2, 3... 1. The second operand of the PMCR(—) instruction (S, the first output word) can be used.

Example: R(1)

When the command is "Send," data is read from the first word following the word specified for PMCR(—) instruction's second operand.

2. Input and output words in the communications sequence's link area can be used.

Example: R(I1+5)

Specifies the fifth word from the beginning of the receive words in the link area.

Example: R(O2+1)

Specifies the first word from the second send word in the link area.

3. A data area word address can be specified directly.

Example: R(DM 0000 + 2)

Specifies the second word after DM 0000.

Wild Cards (*) and Write Word (W)

When receiving data, wild cards (*) and Write Words can be set for the "address" or "data." Their functions are explained below:


- **1, 2, 3...** 1. The address of the word is specified as the PMCR(—) instruction's third operand (first input word).
 - A wild card can be set in the reception message's address to receive any message regardless of the destination. The result is a broadcast communication.
 - 3. The wild card can be set in the reception message's data to receive all messages.
 - 4. The Write Word attribute can be set in the reception message's address to receive any message regardless of the destination and write the message in the data area specified by the reception message's address.
 - The Write Word attribute can be set in the reception message's data to receive all messages and write the message in the data area specified by the reception message's address.

First-order Equation Using Variable N

First-order equations that include the variable N can be used for the address and data entries. Variable N is incremented by 1 each time that a step is repeated by the repeat counter specified in the communication sequence's step. Using an equation with N for the address or data allows the kind of dynamic specifications shown in the following example:

Example: R(2N+6)

Specifies the sixth word following the PMCR(—) instruction's second operand for the "address" or "data" and adds two words to the specification each time that the step is repeated.



Error Check Code and Length


A SUM, LRC, or CRC error check code and the data length are automatically added to the message when it is transmitted. When the message is received, the data is checked for transmission errors using the error check code and the number of bytes of data specified by the data length are received.

Reception Matrix

If a reception matrix is set in the reception message, up to 15 types of reception messages can be set and different processes and error processing can be assigned to each type of message.

8-6-4 Application Example

Communications sequences can be called and executed by the PMCR(—) instruction. The following example shows a communications sequence that transmits five words of data are transmitted one after the other beginning with the first word after the PMCR(—) instruction's second operand and then stores received data in the word specified in the third operand.



- 1, 2, 3...
 When IR 00000 is ON and SR 28908 (Communications Board Port A Instruction Execution Flag) is OFF, data communications are carried out through port A of the Communications Board.
 - 2. DM 0000 is the first word of the transmission data, which is transmitted consecutively (5 times) based on the communications sequence's repeat counter.
 - 3. The received data is written to the DM area beginning at word DM 0010.

The Send command must be set in the transmission step and the repeat counter must be set to 5. The Read Word attribute must be used for the data in the transmission message with the PMCR(—) instruction's second operand, and the first-order equation R(N+1) must be set.

In order to write the reception message to the data area address specified by the PMCR(—) instruction's second operand, the timing for writing the received data must be set in the response notification parameter of the sequence settings. The Recv command must be set in each reception step and "Yes" must be set for the response notification parameter of the step settings.

Set the wild card (*) in the reception message so that all data will be received. In the next process, set "End" in both the transmission step and the reception step. In error processing, set "Abort" in both the transmission step and the reception step.

SECTION 9 Troubleshooting

The C200HX/HG/HE provides self-diagnostic functions to identify many types of abnormal system conditions. These functions minimize downtime and enable quick, smooth error correction.

This section provides information on hardware and software errors that occur during PC operation. Program input errors are described in 4-7 *Inputting, Modifying, and Checking the Program*. Although described in *Section 3 Memory Areas*, flags and other error information provided in SR and AR areas are listed in 9-5 *Error Flags*.

9-1	Alarm Indicators	446
9-2	Programmed Alarms and Error Messages	446
9-3	Reading and Clearing Errors and Messages	446
9-4	Error Messages	447
9-5	Error Flags	451
9-6	Host Link Errors	452

9-1 Alarm Indicators

The ALM/ERR indicator on the front of the CPU Unit provides visual indication of an abnormality in the PC. When the indicator is ON (ERROR), a fatal error (i.e., ones that will stop PC operation) has occurred; when the indicator is flashing (ALARM), a nonfatal error has occurred. This indicator is shown in 2-1-1 CPU Unit Indicators.

/! WARNING The PC will turn ON the ALM/ERR indicator, stop program execution, and turn OFF all outputs from the PC for most hardware errors, for certain fatal software errors, or when FALS(07) is executed in the program (see tables on following pages). PC operation will continue for all other errors. It is the user's responsibility to take adequate measures to ensure that a hazardous situation will not result from automatic system shutdown for fatal errors and to ensure that proper actions are taken for errors for which the system is not automatically shut down. System flags and other system and/or user-programmed error indications can be used to program proper actions.

9-2 **Programmed Alarms and Error Messages**

FAL(06), FALS(07), and MSG(46) can be used in the program to provide userprogrammed information on error conditions. With these three instructions, the user can tailor error diagnosis to aid in troubleshooting.

FAL(06) is used with a FAL number other than 00, which is output to the SR area when FAL(06) is executed. Executing FAL(06) will not stop PC operation or directly affect any outputs from the PC.

FALS(07) is also used with a FAL number, which is output to the same location in the SR area when FALS(07) is executed. Executing FALS(07) will stop PC operation and will cause all outputs from the PC to be turned OFF.

When FAL(06) is executed with a function number of 00, the current FAL number contained in the SR area is cleared and replaced by another, if more have been stored in memory by the system.

When MSG(46) is used a message containing specified data area words is displayed onto the Programming Console or another Programming Device.

The use of these instructions is described in detail in Section 5 Instruction Set.

Reading and Clearing Errors and Messages 9-3

System error messages can be displayed onto the Programming Console or other Programming Device.

On the Programming Console, press the CLR, FUN, and MONTR keys. If there are multiple error messages stored by the system, the MONTR key can be pressed again to access the next message. If the system is in PROGRAM mode, pressing the MONTR key will clear the error message, so be sure to write down all message errors as you read them. (It is not possible to clear an error or a message while in RUN or MONITOR mode; the PC must be in PROGRAM mode.) When all messages have been cleared, "ERR CHK OK" will be displayed.

Details on accessing error messages from the Programming Console are provided in 7-1 Monitoring Operation and Modifying Data. Procedures for the SSS are provided in the SSS Operation Manual: C Series respectively.

9-4 Error Messages

There are basically three types of errors for which messages are displayed: initialization errors, non-fatal operating errors, and fatal operating errors. Most of these are also indicated by FAL number being transferred to the FAL area of the SR area.

The type of error can be quickly determined from the indicators on the CPU Unit, as described below for the three types of errors. If the status of an indicator is not mentioned in the description, it makes no difference whether it is lit or not.

After eliminating the cause of an error, clear the error message from memory before resuming operation.

Asterisks in the error messages in the following tables indicate variable numeric data. An actual number would appear on the display.

The following is a simplified CPU Unit troubleshooting procedure:

- **1, 2, 3...** 1. If the POWER indicator is lit and the RUN indicator is not lit, check the initialization errors.
 - 2. Connect the Programming Console to the PC and check if the mode is displayed. If the mode is not displayed, turn off and restart the power supply.
 - 3. If the ALM/ERR indicator is flashing, check the non-fatal operating errors.
 - 4. Change to the RUN or MONITOR mode and check if the RUN indicator is lit. If the RUN indicator is not lit and all previous steps fail, replace the CPU Unit.

Initialization Errors

The following error messages appear before program execution has been started. The POWER indicator will be lit and the RUN indicator will not be lit for either of these.

Error and message	FAL no.	Probable cause	Possible correction
Waiting for Special I/O or Interrupt Input Units	None	A Special I/O Unit or Interrupt Input Unit has not initialized.	Perform the I/O Table Read operation to check unit numbers. Replace Unit if it is indicated by "\$" only in the I/O table.
			(High-density I/O Units will not appear on I/O Table Read display for all peripheral devices.)
Waiting for Remote I/O	None	Power to Remote I/O Unit is off or terminator cannot be found.	Check power supply to Remote I/O Units, connections between Remote I/O Units, and terminator setting.

Non-fatal Operating Errors

The following error messages appear for errors that occur after program execution has been started. PC operation and program execution will continue after one or more of these errors have occurred. For each of these errors, the POW-ER and RUN indicators will be lit and the ALM/ERR indicator will be flashing.

Error and message	FAL no.	Probable cause	Possible correction
FAL error SYS FAIL FAL**	01 to 99	FAL(06) has been executed in program. Check the FAL number to determine conditions that would cause execution (set by user).	Correct according to cause indicated by FAL number (set by user).
Interrupt Input Unit error SYS FAIL FALSA	8A	An error occurred in data transfer between the Interrupt Input Unit and the CPU Unit.	Replace the Interrupt Input Unit.

Error and message	FAL no.	Probable cause	Possible correction
Interrupt subroutine error SYS FAIL FALSE	8B	An interrupt subroutine longer than 10 ms was executed during I/O refreshing of a Remote I/O Unit or during Host Link servicing.	Check the contents of SR 262 and SR 263 and verify that the interrupt subroutine's processing time is less than 10 ms.
		An attempt was made to execute a different type of I/O refresh from the type set for the Special I/O Unit cycle refresh.	Change the program or the Special I/O Unit cycle refresh setting so that the same refresh method is used.
High-density I/O Unit error	9A	An error occurred in data transfer between a High-density I/O Unit and the CPU Unit.	Check AR 0205 to AR 0214 to identify the Unit with a problem, replace the Unit, and restart the PC.
PC Setup error SYS FAIL FAL9B	9B	An error has been detected in the PC Setup. This error will be generated when the setting is read or used for the first time.	Check and correct the PC Setup settings. (SR 27500 to SR 27502 indicate which part of the PC Setup is incorrect.)
Communications Board error SYS FAIL FAL90	9C	An error has occurred with a Communications Board.	Refer to the Communications Board's Operation Manual for details.
Memory Cassette Transfer error	9D	An error has occurred during data transmission between UM and a Memory Cassette because: Not in PROGRAM Mode. UM or Memory Cassette is read-only.	Make sure that the PC is in PROGRAM mode. Make sure that the Memory Cassette is not write-protected. Make sure that the UM and Memory Cassette capacity
		Insufficient capacity in UM or Memory Cassette. A checksum error occurred in the Memory Cassette	is sufficient. Make sure that SYSMAC NET data links are not active during the transfer. Transfer the data again.
Cycle time overrun CYCLE TIME OVER	F8	Watchdog timer has exceeded 100 ms.	Program cycle time is longer than recommended. Reduce cycle time if possible.
I/O table verification error I/O VER ERR	E7	Unit has been removed or replaced by a different kind of Unit, making I/O table incorrect.	Use I/O Table Verify Operation to check I/O table and either connect dummy Units or register the I/O table again.
Remote I/O error FEMOTE EFE Remote I/O Master Unit number	B0 or B1	Error occurred in transmissions between Remote I/O Units.	Check transmission line between PC and Master and between Remote I/O Units.

Error and message	FAL no.	Probable cause	Possible correction
Special I/O Unit error	D0	Error has occurred in PC Link Unit, Remote I/O Master Unit, between a Host Link, SYSMAC LINK, or SYSMAC NET Link Unit and the CPU Unit, or in refresh between Special I/O Unit and the CPU Unit.	Determine the unit number of the Unit which caused the error (AR 00 or SR 282), correct the error, and toggle the appropriate Restart Bit in AR 01, SR 250, or SR 252. If the Unit does not restart, replace it.
Battery error	F7	Backup battery is missing or its voltage has dropped.	Check battery, and replace if necessary.

Fatal Operating Errors

The following error messages appear for errors that occur after program execution has been started. PC operation and program execution will stop and all outputs from the PC will be turned OFF when any of the following errors occur. No CPU Unit indicators will be lit for the power interruption error. For all other fatal operating errors, the POWER and ALM/ERR indicators will be lit. The RUN output will be OFF.

Error and message	FAL no.	Probable cause	Possible correction
Power interruption No message.	None	Power has been interrupted for at least 10 ms.	Check power supply voltage and power lines. Try to power-up again.
Memory error	F1	SR 27211 ON:	Check the PC Setup.
MEMORY ERR		A checksum error has occurred in the PC Setup (DM 6600 to DM 6655).	
		SR 27212 ON:	Check the program.
		A checksum error has occurred in the program, indicating an incorrect instruction.	
		SR 27213 ON	
		A checksum error has occurred in an expansion instruction change.	
		SR 27214 ON:	Install the Memory Cassette
		Memory Cassette was installed or removed with the power on.	correctly.
		SR 27215 ON:	Check whether the CPU Unit
		Autoboot error.	memory is protected or a checksum error occurred in the Memory Cassette.
No END(01) instruction NO END INST	F0	END(01) is not written anywhere in program.	Write END(01) at the final address of the program.
I/O bus error I/O BUS ERR * Rack no.	C0 to C3	Error has occurred in the bus line between the CPU Unit and I/O Units.	The rightmost digit of the FAL number indicates the number of the Rack where the error was detected. Check the cable connections between Racks.

Error and message	FAL no.	Probable cause	Possible correction
Too many Units I/O UNIT OVER	E1	Two or more Special I/O Units or Group-2 High-density I/O Units are set to the same unit number.	Perform the I/O Table Read operation to check unit numbers, and eliminate duplications.
		The unit number of a Special I/O Unit that requires two words is set to the last unit number (9 or F).	Unit numbers of Units that require two words cannot be set to the last unit number. Change the unit number to an allowed setting.
		The I/O number of a 64-pt Group-2 High-density I/O Unit is set to the last unit number (9 or F).	Unit numbers of 64-pt Group-2 High-density I/O Units cannot be set to the last unit number. Change the unit number to a valid setting.
		Two SYSMAC NET Link or SYSMAC LINK Units share the same operating level.	Check the SYSMAC NET Link and SYSMAC LINK Unit operating levels and eliminate duplications.
		Three or more Interrupt Input Units are mounted.	Up to two Interrupt Input Units can be mounted.
		The unit number of a Special I/O Unit or High-density I/O Unit isn't within the allowed setting range.	Set the unit number within the allowed setting range.
		A third Expansion Rack has been connected to a PC which can accommodate only two.	Disconnect the third Rack unless the PC can accommodate three Racks.
Input-output I/O table error I/O SET ERROR	E0	Input and output word designations registered in I/O table do no agree with input/output words required by Units actually mounted.	Check the I/O table with I/O Table Verification operation and check all Units to see that they are in correct configuration. When the system has been confirmed, register the I/O table again.
FALS error SYS FAIL FALS**	01 to 99 or 9F	FALS has been executed by the program. Check the FAL number to determine conditions that would cause execution (Set by user or by system).	Correct according to cause indicated by FAL number. If FAL number is 9F, check watchdog timer and cycle time, which may be too long.
		There is an error in the CPU.	Turn ON the power again in PROGRAM mode.
(Or the previous message may be displayed.)			Check the program.

Communications Errors

If errors occur in communications, the indicator the peripheral port and RS-232C port (COMM) will not light. Check the connection, programming on both ends (C200HX/HG/HE and peripheral), and then reset the port using the reset bit (RS-232C port: SR 25209).

Other Error Messages

A number of other error messages are detailed within this manual. Errors in program input and debugging can be examined in *Section 4 Writing and Inputting the Program*.

Error Flags Section 9-5

9-5 Error Flags

The following table lists the flags and other information provided in the SR and AR areas that can be used in troubleshooting. Details are provided in 3-4 SR Area and 3-5 AR Area.

SR Area

Address(es)	Function			
23600 to 23615	Node loop status for SYSMAC NET Link system			
23700 to 23715	Completion/error code output area for SEND(90)/RECV(98) in SYSMAC LINK/SYSMAC NET Link			
24700 to 25015	PC Link Unit Run and Error Flags			
25100 to 25115	Remote I/O Error Flags			
25200	SYSMAC LINK/SYSMAC NET Link Level 0 SEND(90)/RECV(98) Error Flag			
25203	SYSMAC LINK/SYSMAC NET Link Level 1 SEND(90)/RECV(98) Error Flag			
25206	Rack-mounting Host Link Unit Level 1 Error Flag			
25208	RS-232C Port Error Flag			
25300 to 25307	FAL number output area.			
25308	Low Battery Flag			
25309	Cycle Time Error Flag			
25310	I/O Verification Error Flag			
25311	Rack-mounting Host Link Unit Level 0 Error Flag			
25312	Remote I/O Error Flag			
25411	Interrupt Input Unit Error Flag			
25413	Interrupt Programming Error Flag			
25414	Group-2 High-density I/O Unit Error Flag			
25415	Special Unit Error Flag (Special I/O, PC Link, Host Link, Remote I/O Master, SYSMAC NET Link, or SYSMAC Link Unit Error Flag)			
25503	Instruction Execution Error (ER) Flag			
26400 to 26403	RS-232C Port Error Code			
26404	RS-232C Port Communications Error			
26408 to 26411	Peripheral Port Error Code (except Peripheral Mode)			
26412	Peripheral Port Communications Error Flag (except Peripheral Mode)			
26800 to 26815	Communications Board Error Information			
27011	UM Transfer Error Flag: SYSMAC NET data link active during data link table transfer.			
27012	UM Transfer Error Flag: Not PROGRAM mode			
27013	UM Transfer Error Flag: Read Only			
27014	UM Transfer Error Flag: Insufficient capacity or no UM			
27015	UM Transfer Error Flag: Board Checksum Error			
27211	Memory Error Flag: PC Setup Checksum Error			
27212	Memory Error Flag: UM or Ladder Checksum Error			
27213	Memory Error Flag: Expansion Instruction Code Change Area Checksum Error			
27214	Memory Error Flag: Memory Cassette Online Disconnection			
27215	Memory Error Flag: Autoboot Error			
27312	IOM Transfer Error Flag: Not PROGRAM mode			
27313	IOM Transfer Error Flag: Read Only			
27314	IOM Transfer Error Flag: Insufficient capacity			
27500	PC Setup Error (DM 6600 to DM 6605)			
27501	PC Setup Error (DM 6613 to DM 6623)			
27502	PC Setup Error (DM 6635 to DM 6655)			

Host Link Errors Section 9-6

Address(es)	Function			
28000 to 28015	Group-2 High-density I/O Unit Error Flags for Units 0 to F			
28200 to 28215	Special I/O Unit Error Flags for Units 0 to F			
28300 to 28303	Communications Board Port A Error Code			
28308 to 28311	Communications Board Port B Error Code			

AR Area

Address(es)	Function
0000 to 0009	Special I/O or PC Link Unit Error Flags
0010	SYSMAC LINK/SYSMAC NET Link Level 1 System Error Flags
0011	SYSMAC LINK/SYSMAC NET Link Level 0 System Error Flags
0012	Rack-mounting Host Link Unit Level 1 Error Flag
0013	Rack-mounting Host Link Unit Level 0 Error Flag
0014	Remote I/O Master Unit 1 Error Flag
0015	Remote I/O Master Unit 0 Error Flag
0200 to 0204	Error Flags for Slave Racks 0 to 4
0205 to 0214	Group-2 High-density I/O Unit Error Flags (AR 0205 to AR 0214 correspond to I/O numbers 0 to 9.)
0215	Group-2 High-density I/O Unit Error Flag
0300 to 0315	Optical I/O Units (0 to 7) Error Flags
0400 to 0415	Optical I/O Units (8 to 15) Error Flags
0500 to 0515	Optical I/O Units (16 to 23) Error Flags
0600 to 0615	Optical I/O Units (24 to 31) Error Flags
0713 to 0715	Error History Bits
1114	Communications Controller Error Flag Level 0
1115	EEPROM Error Flag for operating level 0
1514	Communications Controller Error Flag Level 1
1515	EEPROM Error Flag for operating level 1

9-6 Host Link Errors

These are the response codes (end codes) that may be returned in the response frame. When two or more errors occur, the end code for the first error will be returned.

End code	Contents	Probable cause	Corrective measures
00	Normal completion		
01	Not executable in RUN mode	The command that was sent cannot be executed when the PC is in RUN mode.	Check the relation between the command and the PC mode.
02	Not executable in MONITOR mode	The command that was sent cannot be executed when the PC is in MONITOR mode.	
03	UM write-protected	The PC's UM is write-protected.	Turn OFF pin 1 of the CPU Unit's DIP switch.
04	Address over	The program address setting in an SV Read or SV Change command exceeds the 65,535 maximum.	Correct the program address setting and transfer the command again.
13	FCS error	The FCS is wrong. Either the FCS calculation is mistaken or there is adverse influence from noise.	Check the FCS calculation method. If there was influence from noise, transfer the command again.
14	Format error	The command format is wrong or a command that can't be divided has been divided.	Check the format and transfer the command again.
15	Entry number data error	The data is outside of the specified range or too long.	Correct the data and transfer the command again.

Host Link Errors Section 9-6

End code	Contents	Probable cause	Corrective measures
16	Command not supported	The operand specified in an SV Read or SV Change command does not exist in the program.	Check the command and program.
18	Frame length error	The maximum frame length of 132 bytes was exceeded. (If the frame exceeds 280 bytes, the Reception Overflow Flag will be turned ON and there won't be a response.)	Check the command and divide it into multiple frames if necessary.
19	Not executable	Items to read not registered for composite command (QQ).	Execute QQ to register items to read before attempting batch read.
23	User memory write-protected	Pin 1 on C200HX/HG/HE DIP switch is ON.	Turn OFF pin 1 of the CPU Unit's DIP switch.
A3	Aborted due to FCS error in trans- mit data	An FCS error occurred in the second or later frame.	Check the FCS calculation method. If there was influence from noise, transfer the command again.
A4	Aborted due to format error in transmit data	The command format did not match the number of bytes in the second or later frame.	Check the format and transfer the command again.
A5	Aborted due to entry number data error in transmit data	There was a data error in the second or later frame.	Correct the data and transfer the command again.
A8	Aborted due to frame length error in transmit data	The length of the second or later frame exceeded the 132-byte max.	Keep frames to 132 bytes or fewer.

Errors without Responses A response won't be received with some errors, regardless of the command. These errors are listed in the following table.

Error	PC operation
Parity overrun or framing error during command reception	The Communications Error Flag will be turned ON, an error code will be registered, and receptions will be reset. (The error will be cleared automatically if communications restart normally.)
A carriage return (CR) isn't received within 280 bytes.	SR 26407 (RS-232C Port Reception Overflow Flag) will be turned ON. Communications will return to normal when a normal command is transmitted.
A command is received that doesn't have the @ character at the beginning of the first frame.	Receptions are reset.
Incorrect node number (Not the local node, hexadecimal, or over 31)	The command is discarded and receptions are reset.
A Write command is divided, but an intermediate frame or the last frame has only one or two bytes of data.	FCS error

SECTION 10 Host Link Commands

This section describes the host link commands which can be used for host link communications via the C200HX/HG/HE ports. Refer to 8-2 *Host Link Communications* for information on the procedures for using host link commands and errors associated with host link commands.

10-1	Host Li	nk Command Summary	56
10-2	Host Li	nk End Codes	57
	10-2-1	End Code Summary	57
	10-2-2	Command/End Code Table	59
10-3	Host Li	nk Commands	50
	10-3-1	IR/SR AREA READ — RR	50
	10-3-2	LR AREA READ — RL	51
	10-3-3	HR AREA READ — RH	52
	10-3-4	PV READ — RC	53
	10-3-5	TC STATUS READ — RG	54
	10-3-6	DM AREA READ — RD	55
	10-3-7	AR AREA READ — RJ	56
	10-3-8	EM AREA READ — RE	56
	10-3-9	IR/SR AREA WRITE — WR	57
	10-3-10	LR AREA WRITE — WL	58
	10-3-11	HR AREA WRITE — WH	59
	10-3-12	PV WRITE — WC	70
	10-3-13	TC STATUS WRITE — WG	71
	10-3-14	DM AREA WRITE — WD	72
	10-3-15	AR AREA WRITE — WJ	73
	10-3-16	EM AREA WRITE — WE	74
	10-3-17	SV READ 1 — R#	75
	10-3-18	SV READ 2 — R\$	76
		SV READ 3 — R%	78
	10-3-20	SV CHANGE 1 — W#	79
	10-3-21	SV CHANGE 2 — W\$	30
	10-3-22	SV CHANGE 3 — W%	32
	10-3-23	STATUS READ — MS	33
	10-3-24	STATUS WRITE — SC	35
	10-3-25	ERROR READ — MF	36
	10-3-26	FORCED SET — KS	37
	10-3-27	FORCED RESET — KR	38
	10-3-28	MULTIPLE FORCED SET/RESET — FK	€0
	10-3-29	FORCED SET/RESET CANCEL — KC	€1
	10-3-30	PC MODEL READ — MM	€
	10-3-31	TEST— TS	€
	10-3-32	PROGRAM READ — RP) 4
	10-3-33	PROGRAM WRITE — WP	€
	10-3-34	I/O TABLE GENERATE — MI) 6
	10-3-35	COMPOUND COMMAND — QQMR	€7
	10-3-36	COMPOUND COMMAND DATA READ — QQIR	98
	10-3-37	ABORT — XZ) 9
	10-3-38	INITIALIZE — **)()
		TXD RESPONSE — EX)()
	10-3-40	Undefined Command — IC)1

10-1 Host Link Command Summary

Command Chart

The commands listed in the chart below can be used for host link communications with the C200HX/HG/HE.

Header code	PC mode			Name	Page
	RUN	MON	PRG		
RR	Valid	Valid	Valid	IR/SR AREA READ	460
RL	Valid	Valid	Valid	LR AREA READ	461
RH	Valid	Valid	Valid	HR AREA READ	462
RC	Valid	Valid	Valid	PV READ	463
RG	Valid	Valid	Valid	TC STATUS READ	464
RD	Valid	Valid	Valid	DM AREA READ	465
RJ	Valid	Valid	Valid	AR AREA READ	466
RE	Valid	Valid	Valid	EM AREA READ	466
WR	Not valid	Valid	Valid	IR/SR AREA WRITE	467
WL	Not valid	Valid	Valid	LR AREA WRITE	468
WH	Not valid	Valid	Valid	HR AREA WRITE	469
WC	Not valid	Valid	Valid	PV WRITE	470
WG	Not valid	Valid	Valid	TC STATUS WRITE	471
WD	Not valid	Valid	Valid	DM AREA WRITE	472
WJ	Not valid	Valid	Valid	AR AREA WRITE	473
WE	Not valid	Valid	Valid	EM AREA WRITE	474
R#	Valid	Valid	Valid	SV READ 1	475
R\$	Valid	Valid	Valid	SV READ 2	476
R%	Valid	Valid	Valid	SV READ 3	478
W#	Not valid	Valid	Valid	SV CHANGE 1	479
W\$	Not valid	Valid	Valid	SV CHANGE 2	480
W%	Not valid	Valid	Valid	SV CHANGE 3	482
MS	Valid	Valid	Valid	STATUS READ	483
SC	Valid	Valid	Valid	STATUS WRITE	485
MF	Valid	Valid	Valid	ERROR READ	486
KS	Not valid	Valid	Valid	FORCED SET	487
KR	Not valid	Valid	Valid	FORCED RESET	488
FK	Not valid	Valid	Valid	MULTIPLE FORCED SET/RESET	490
KC	Not valid	Valid	Valid	FORCED SET/RESET CANCEL	491
MM	Valid	Valid	Valid	PC MODEL READ	492
TS	Valid	Valid	Valid	TEST	493
RP	Valid	Valid	Valid	PROGRAM READ	494
WP	Not valid	Not valid	Valid	PROGRAM WRITE	495
MI	Not valid	Not valid	Valid	I/O TABLE GENERATE	496
QQ	Valid	Valid	Valid	COMPOUND COMMAND	497
XZ	Valid	Valid	Valid	ABORT (command only)	499
**	Valid	Valid	Valid	INITIALIZE (command only)	500
EX	Valid	Valid	Not valid	TXD RESPONSE (response only)	500
IC				Undefined command (response only)	501

Host Link End Codes Section 10-2

10-2 Host Link End Codes

10-2-1 End Code Summary

These are the response (end) codes that are returned in the response frame. When two or more errors occur, the end code for the first error will be returned.

End code	Contents	Probable cause	Corrective measures
00	Normal completion		
01	Not executable in RUN mode	The command that was sent cannot be executed when the PC is in RUN mode.	Check the relation between the command and the PC mode.
02	Not executable in MONITOR mode	The command that was sent cannot be executed when the PC is in MONITOR mode.	
03	UM write-protected	The PC's UM is write-protected.	Turn OFF pin 1 of the CPU Unit's DIP switch.
04	Address over	The program address setting in an SV Read or SV Change command is above the highest program address but less than 65,536.	Correct the program address setting and transfer the command again.
13	FCS error	The FCS is wrong. Either the FCS calculation is mistaken or there is adverse influence from noise.	Check the FCS calculation method. If there was influence from noise, transfer the command again.
14	Format error	The command format is wrong or a command that can't be divided has been divided.	Check the format and transfer the command again.
15	Entry number data error	The data is outside of the specified range or too long.	Correct the data and transfer the command again.
16	Command not supported	The operand specified in an SV Read or SV Change command does not exist in the program.	Check the command and program.
18	Frame length error	The maximum frame length of 132 bytes was exceeded. (If the frame exceeds 280 bytes, the Reception Overflow Flag will be turned ON and there won't be a response.)	Check the command and divide it into multiple frames if necessary.
19	Not executable	Items to read not registered for composite command (QQ).	Execute QQ to register items to read before attempting batch read.
20	Couldn't create I/O table	Unrecognized Remote I/O Unit, too many I/O words, or node number duplication for Remote Optical I/O Units.	Check the Remote I/O System and the number of I/O words.
23	User memory protected	Pin 1 on C200HX/HG/HE DIP switch is ON.	Turn OFF pin 1 of the CPU Unit's DIP switch.
A3	Aborted due to FCS error in transmit data	An FCS error occurred in the second or later frame.	Check the FCS calculation method. If there was influence from noise, transfer the command again.
A4	Aborted due to format error in transmit data	The command format did not match the number of bytes in the second or later frame.	Check the format and transfer the command again.
A5	Aborted due to entry number data error in transmit data	There was a entry number data error in the second or later frame.	Correct the data and transfer the command again.
A8	Aborted due to frame length error in transmit data	The length of the second or later frame exceeded the 132-byte max.	Keep frames to 132 bytes or fewer.

Host Link End Codes Section 10-2

Errors without Responses

A response won't be received with some errors, regardless of the command. These errors are listed in the following table.

Error	PC operation
Parity overrun or framing error during command reception	The Communications Error Flag will be turned ON, an error code will be registered, and receptions will be reset. (The error will be cleared automatically if communications restart normally.)
A carriage return (CR) isn't received within 280 bytes.	SR 26407 (RS-232C Port Reception Overflow Flag) will be turned ON. Communications return to normal when a normal command is transmitted.
A command is received that doesn't have the @ character at the beginning of the first frame.	Receptions are reset.
Incorrect node number (Not the local node, hexadecimal, or over 31)	The command is discarded and receptions are reset.
A Write command's intermediate frame or last frame has only one or two bytes of data.	FCS error

Host Link End Codes Section 10-2

10-2-2 Command/End Code Table

The following table shows which end codes can be returned for each command.

Header							Po	ossib	le En	d Cod	les							Comments
RR	00					13	14	15		18				А3			A8	
RL	00					13	14	15		18				А3			A8	
RH	00					13	14	15		18				А3			A8	
RC	00					13	14	15		18				А3			A8	
RG	00					13	14	15		18				А3			A8	
RD	00					13	14	15		18				А3			A8	
RJ	00					13	14	15		18								
RE	00					13	14	15		18				А3			A8	
WR	00	01				13	14	15		18				А3	A4	A5	A8	
WL	00	01				13	14	15		18				А3	A4	A5	A8	
WH	00	01				13	14	15		18				А3	A4	A5	A8	
WC	00	01				13	14	15		18				А3	A4	A5	A8	
WG	00	01				13	14	15		18				А3	A4	A5	A8	
WD	00	01				13	14	15		18			23	А3	A4	A5	A8	
WJ	00	01				13	14	15		18				А3	A4	A5	A8	
WE	00	01				13	14	15		18				А3	A4	A5	A8	
R#	00					13	14	15	16	18			23					
R\$	00				04	13	14	15	16	18			23					
R%	00				04	13	14	15	16	18			23					
W#	00	01				13	14	15	16	18			23					
W\$	00	01			04	13	14	15	16	18			23					
W%	00	01			04	13	14	15	16	18			23					
MS	00					13	14			18								
SC	00					13	14	15		18	19							
MF	00					13	14	15		18								
KS	00	01				13	14	15		18								
KR	00	01				13	14	15		18								
FK	00	01				13	14	15		18								
KC	00	01				13	14			18								
MM	00					13	14			18								
TS						13	14			18								
RP	00					13	14			18			23	А3			A8	
WP	00	01	02			13	14	15		18	19		23	А3	A4	A5	A8	
MI	00	01	02	03		13	14			18		20						
QQ	00					13	14	15		18	19			А3	A4	A5	A8	
XZ																		No response
**																		No response
EX																		No end code
IC																		No end code

Host Link Commands Section 10-3


10-3 Host Link Commands

This section explains the various Host Link commands that can be issued from the host computer to the PC. Refer to 8-2 Host Link Communications for information on the procedures for using host link commands and errors associated with host link commands.


10-3-1 IR/SR AREA READ — RR

Reads the contents of the specified number of IR and SR words, starting from the specified word.

Command Format



Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words. If more than 30 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 31 words.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

	PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected	
OK	OK	OK	OK	OK	

Execution Conditions

Comn	nands	Responses		
Single	Multiple	Single	Multiple	
OK		OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect and an end code of 15 (entry number data error) will be returned if the specified words exceed the data area boundaries or aren't specified in BCD.


End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data

Host Link Commands Section 10-3


10-3-2 LR AREA READ --- RL

Reads the contents of the specified number of LR words, starting from the specified word.

Command Format



Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words. If more than 30 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 31 words.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

	PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected	
OK	OK	OK	OK	OK	

Execution Conditions

Comn	nands	Responses		
Single	Multiple	Single	Multiple	
OK		OK	OK	

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect and an end code of 15 (entry number data error) will be returned if the specified words exceed the data area boundaries or aren't specified in BCD.

End code	Contents					
00	Normal completion					
13	FCS error					
14	Format error					
15	Entry number data error					
18	Frame length error					
A3	Aborted due to FCS error in transmit data					
A8	Aborted due to frame length error in transmit data					


10-3-3 HR AREA READ — RH

Reads the contents of the specified number of HR words, starting from the specified word.

Command Format



Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words. If more than 30 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 31 words.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

PC Mode		UM Area		
RUN MONITOR PROGRAM		Write-protected	Read-protected	
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	OK


End Codes

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-4 PV READ — RC

Reads the contents of the specified number of timer/counter PVs (present values), starting from the specified timer/counter.

Command Format



Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words. If more than 30 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 31 words.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

PC Mode		UM Area		
RUN MONITOR PROGRAM		Write-protected	Read-protected	
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	OK


End Codes

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-5 TC STATUS READ — RG

Reads the status of the Completion Flags of the specified number of timers/counters, starting from the specified timer/counter. A "1" indicates that the Completion Flag is ON.

Command Format



Response Format



Limitations

The text portion of the response's first frame can contain up to 121 words. If more than 121 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 124 words.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

PC Mode		UM Area		
RUN MONITOR PROGRAM		Write-protected	Read-protected	
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	OK


End Codes

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data

10-3-6 DM AREA READ --- RD


Reads the contents of the specified number of DM words, starting from the specified word.

Command Format



Note To specify 10,000 words, input 0000 for the number of words to be read.

Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words. If more than 30 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 31 words.

DM 6656 to DM 6999 do not exist, but an error will not occur if you try to read these words. Instead, "0000" will be returned as a response. Likewise, "0000" will be returned for extension DM words (DM 7000 to DM 9999) if extension DM hasn't been allocated in the UM area.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	OK


End Codes

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-7 AR AREA READ — RJ

Reads the contents of the specified number of AR words, starting from the specified word.

Command Format



Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect and an end code of 15 (entry number data error) will be returned if the specified words exceed the data area boundaries or aren't specified in BCD.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error

10-3-8 EM AREA READ --- RE


Reads the contents of the specified number of EM words, starting from the specified word in the specified EM bank.

Command Format



Note Input 00, 01, or 02 to specify bank number 0, 1, or 2. Input two spaces to specify the current bank.

Response Format



Limitations

The text portion of the response's first frame can contain up to 30 words. If more than 30 words are read, the data will be returned in multiple frames.

In the second and later frames, the text portion of the response can contain up to 31 words.

If a valid bank number is specified but the PC isn't equipped with that EM bank, "0000" will be returned as the read data.

This command can't be used to change the current bank number.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	OK

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect and an end code of 15 (entry number data error) will be returned if the specified words exceed the data area boundaries, the specified words aren't specified in BCD, or an invalid bank number is specified.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-9 IR/SR AREA WRITE — WR

Writes data to the IR and SR areas, starting from the specified word. Writing is done word by word.

Command Format



Response Format



Limitations

Data cannot be written to words 253 to 255. If there is an attempt to write to these words, no error will result, but nothing will be written to these words.

Except for the first word of the write data, the write data can be divided into multiple frames.

PC Settings

PC Mode		UM Area		
RUN MONITOR PROGRAM		Write-protected	Read-protected	
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundaries, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-10 LR AREA WRITE --- WL

Writes data to the LR area, starting from the specified word. Writing is done word by word.

Command Format



Response Format



Limitations

Except for the first word of the write data, the write data can be divided into multiple frames.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-11 HR AREA WRITE --- WH

Writes data to the HR area, starting from the specified word. Writing is done word by word.

Command Format



Response Format



Limitations

Except for the first word of the write data, the write data can be divided into multiple frames.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-12 PV WRITE — WC

Writes the PVs (present values) of timers/counters starting from the specified timer/counter.

Command Format



Response Format



Limitations

Except for the first word of the write data, the write data can be divided into multiple frames.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.

An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)


With Host Link Units, an end code of 15 (entry number data error) will be returned if the write data isn't BCD.

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-13 TC STATUS WRITE --- WG

Writes the status of the Completion Flags for timers and counters in the TC area, starting from the specified timer/counter (number). Writing is done number by number. When a Completion Flag is ON, it indicates that the time or count is up.

Command Format



Response Format



PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the digits of write data aren't 0 or 1, the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-14 DM AREA WRITE --- WD

Writes data to the DM area, starting from the specified word. Writing is done word by word.

Command Format



Response Format



Limitations

Except for the first word of the write data, the write data can be divided into multiple frames.

DM 6656 to DM 6999 do not exist, but an error won't occur if the command attempts to write to these words. Likewise, an error won't occur if the command attempts to write to extension DM words (DM 7000 to DM 9999) which haven't been allocated in the UM area.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK		OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
23	User memory protected
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-15 AR AREA WRITE — WJ

Writes data to the AR area, starting from the specified word. Writing is done word by word.

Command Format



Response Format



Limitations

Except for the first word of the write data, the write data can be divided into multiple frames.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Comn	nands	Resp	onses
Single	Multiple	Single Multiple	
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data

10-3-16 EM AREA WRITE --- WE


Writes data to the specified EM area bank, starting from the specified word. Writing is done word by word.

Command Format



Note Input 00, 01, or 02 to specify bank number 0, 1, or 2. Input two spaces to specify the current bank.

Response Format



Limitations

Except for the first word of the write data, the write data can be divided into multiple frames.

If a valid bank number is specified but the PC isn't equipped with that EM bank, the command will be completed normally without writing any data.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Comn	nands	Respo	onses
Single	Multiple	Single Multiple	
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the first word of write data isn't in the first frame.


An end code of 15 (entry number data error) will be returned if the specified write data exceeds the data area boundary, the beginning word isn't specified in BCD, or the write data isn't hexadecimal. (An end code of A5 will be returned instead of 15 for non-hexadecimal write data in multiple command frames.)

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data

10-3-17 SV READ 1 — R#

Searches for the first instance of a TIM, TIMH(15), CNT, CNTR(12), or TTIM(87) instruction with the specified TC number in the user's program and reads the PV, which assumed to be set as a constant. The SV that is read is a 4-digit decimal number (BCD).


Command Format



Use all four characters to specify the timer or counter instruction's mnemonic. Add a space to the end of a TIM or CNT mnemonic to make it 4 characters long.

Instruction name	Mnemonic			TC number	
	OP1	OP2	OP3	OP4	range
TIMER	Т	I	М	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	I	M	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	Т	Т	I	М	

Response Format



Limitations

The second word of the instruction must be a BCD constant from 0000 to 0511. If the same instruction is used more than once in a program, the SV of the first one will be read.

The command can't be executed if the UM area is read-protected.

PC Settings

PC Mode			UM A	Area
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	

Execution Conditions

Comn	nands	Responses	
Single	Multiple	Single Multiple	
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.

An end code of 15 (entry number data error) will be returned if an incorrect instruction mnemonic or TC number is used.


An end code of 16 (command not supported) will be returned if the specified instruction doesn't exist in the program.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
16	Command not supported
18	Frame length error
23	User memory protected

10-3-18 SV READ 2 — R\$

Reads the constant SV or the word address where the SV is stored. The SV that is read is a 4-digit decimal number (BCD) written as the second operand for the TIM, TIMH(15), CNT, CNTR(12), or TTIM(87) instruction at the specified program address in the user's program.


Command Format



Use all four characters to specify the timer or counter instruction's mnemonic. Add a space to the end of a TIM or CNT mnemonic to make it 4 characters long.

Instruction name	Mnemonic			TC number	
	OP1	OP2	OP3	OP4	range
TIMER	Т	I	М	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	1	М	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	Т	Т	I	M	

Response Format



The "Operand" parameter indicates the data area where the SV is stored or a constant. The "SV" parameter indicates the word address or the SV itself if it is a constant.

	Operand			Classification	Constant or
OP1	OP2	OP3	OP4		word address
С	I	0	(Space)	IR or SR	0000 to 0511
L	R	(Space)	(Space)	LR	0000 to 0063
Н	R	(Space)	(Space)	HR	0000 to 0099
Α	R	(Space)	(Space)	AR	0000 to 0027
D	M	(Space)	(Space)	DM	0000 to 6655
D	M	*	(Space)	DM (indirect)	0000 to 6655
С	0	N	(Space)	Constant	0000 to 9999
E	M	(Space)	(Space)	EM	0000 to 6143
Е	М	*	(Space)	EM (indirect)	0000 to 6143

Limitations

The command is valid only when the UM setting is ladder only.

The command can't be executed if the UM area is read-protected.

PC Settings

PC Mode			UM A	Area
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK		OK	

End Codes

An end code of 04 (address over) will be returned if the program address is above the highest program address but less than 65,536 (32,767 in the C200HS).

An end code of 14 (format error) will be returned if the length of the command is incorrect.

An end code of 15 (entry number data error) will be returned if the program address isn't specified in BCD or the operand/SV parameters are incorrect.


An end code of 16 (command not supported) will be returned if the specified instruction doesn't exist in the program.

End code	Contents
00	Normal completion
04	Address over
13	FCS error
14	Format error
15	Entry number data error
16	Command not supported
18	Frame length error
23	User memory protected

10-3-19 SV READ 3 — R%

Reads the constant SV or the word address where the SV is stored. The SV that is read is a 4-digit decimal number (BCD) written in the second word of the TIM, TIMH(15), CNT, CNTR(12), or TTIM(87) instruction at the specified program address in the user's program.


Command Format



Use all four characters to specify the timer or counter instruction's mnemonic. Add a space to the end of a TIM or CNT mnemonic to make it 4 characters long.

Instruction name		Mner	nonic		TC number
	OP1	OP2	OP3	OP4	range
TIMER	Т	I	M	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	1	M	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	Т	Т	I	М	

Response Format



The "Operand" parameter indicates the data area where the SV is stored or a constant. The "SV" parameter indicates the word address or the SV itself if it is a constant.

Operand				Classification	Constant or
OP1	OP2	OP3	OP4		word address
С	1	0	(Space)	IR or SR	0000 to 0511
L	R	(Space)	(Space)	LR	0000 to 0063
Н	R	(Space)	(Space)	HR	0000 to 0099
А	R	(Space)	(Space)	AR	0000 to 0027
D	М	(Space)	(Space)	DM	0000 to 6655
D	М	*	(Space)	DM (indirect)	0000 to 6655
С	0	N	(Space)	Constant	0000 to 9999
Е	М	(Space)	(Space)	EM	0000 to 6143
Е	М	*	(Space)	EM (indirect)	0000 to 6143

Limitations

The command is valid only when the UM setting is ladder only.

The command can't be executed if the UM area is read-protected.

SR 253 through SR 255 can't be specified.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK		OK	

End Codes

An end code of 04 (address over) will be returned if the program address is above the highest program address but less than 65,536 (32,768 in the C200HS).

An end code of 14 (format error) will be returned if the length of the command is incorrect.

An end code of 15 (entry number data error) will be returned if the program address exceeds the 65,535 maximum (32,767 in the C200HS), the program address isn't specified in BCD, or the mnemonic/SV operands are incorrect.


An end code of 16 (command not supported) will be returned if the specified instruction doesn't exist in the program.

End code	Contents
00	Normal completion
04	Address over
13	FCS error
14	Format error
15	Entry number data error
16	Command not supported
18	Frame length error
23	User memory protected

10-3-20 SV CHANGE 1 — W#

Searches for the first instance of the specified TIM, TIMH(15), CNT, CNTR(12), or TTIM(87) instruction in the user's program and changes the SV to new constant SV specified in the second word of the instruction.


Command Format



Use all four characters to specify the timer or counter instruction's mnemonic. Add a space to the end of a TIM or CNT mnemonic to make it 4 characters long.

Instruction name		Mnemonic			TC number
	OP1	OP2	OP3	OP4	range
TIMER	Т	I	M	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	1	M	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	Т	T	I	М	

Response Format



Limitations

The command can't be executed unless the SV is BCD from 0000 to 9999.

The command can't be executed if the UM area is write-protected.

If the same instruction is used more than once in a program, the SV of the first one will be changed.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK		OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.

An end code of 15 (entry number data error) will be returned if the SV isn't BCD or the mnemonic/TC number is incorrect.


An end code of 16 (command not supported) will be returned if the specified instruction doesn't exist in the program.

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
16	Command not supported
18	Frame length error
23	User memory protected

10-3-21 SV CHANGE 2 — W\$

Changes the contents of the second word of the TIM, TIMH(15), CNT, CNTR(12), or TTIM(87) at the specified program address in the user's program. This can only be done with a program of less than 10K.

Command Format




Use all four characters to specify the timer or counter instruction's mnemonic. Add a space to the end of a TIM or CNT mnemonic to make it 4 characters long.

Instruction name		TC number			
	OP1	OP2	OP3	OP4	range
TIMER	Т	I	М	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	1	М	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	T	Т	I	M	

The "Operand" parameter indicates the data area where the SV is stored or a constant. The "SV" parameter indicates the word address or the SV itself if it is a constant.

Operand				Classification	Constant or
OP1	OP2	OP3	OP4		word address
С	I	0	(Space)	IR or SR	0000 to 0511
L	R	(Space)	(Space)	LR	0000 to 0063
Н	R	(Space)	(Space)	HR	0000 to 0099
Α	R	(Space)	(Space)	AR	0000 to 0027
D	M	(Space)	(Space)	DM	0000 to 6655
D	M	*	(Space)	DM (indirect)	0000 to 6655
С	0	N	(Space)	Constant	0000 to 9999
E	M	(Space)	(Space)	EM	0000 to 6143
E	M	*	(Space)	EM (indirect)	0000 to 6143

Response Format



Limitations

The command is valid only when the UM setting is ladder only. SR 253 through SR 255 can't be specified.

The command can't be executed if the UM area is write-protected.

PC Settings

ſ	PC Mode			UM A	Area
	RUN	MONITOR	PROGRAM	Write-protected	Read-protected
		OK	OK		OK

Execution Conditions

Comn	nands	Resp	onses
Single Multiple		Single	Multiple
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.

An end code of 15 (entry number data error) will be returned if the program address isn't BCD, the program address exceeds the maximum address in the program, the mnemonic/TC number is incorrect, or the SV is incorrect.

An end code of 16 (command not supported) will be returned if the specified instruction doesn't exist in the program.


End code	Contents			
00	Normal completion			
01	Not executable in RUN mode			

End code	Contents			
04	Address over			
13	FCS error			
14	Format error			
15	Entry number data error			
16	Command not supported			
18	Frame length error			
23	User memory protected			

10-3-22 SV CHANGE 3 — W%

Changes the contents of the second word of the TIM, TIMH(15), CNT, CNTR(12), or TTIM(87) at the specified program address in the user's program.

Command Format




Use all four characters to specify the timer or counter instruction's mnemonic. Add a space to the end of a TIM or CNT mnemonic to make it 4 characters long.

Instruction name		Mner	TC number		
	OP1	OP2	OP3	OP4	range
TIMER	T	I	М	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	1	М	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	Т	Т	I	М	

The "Operand" parameter indicates the data area where the SV is stored or a constant. The "SV" parameter indicates the word address or the SV itself if it is a constant.

Operand				Classification	Constant or
OP1	OP2	OP3	OP4		word address
С	1	0	(Space)	IR or SR	0000 to 0511
L	R	(Space)	(Space)	LR	0000 to 0063
Н	R	(Space)	(Space)	HR	0000 to 0099
Α	R	(Space)	(Space)	AR	0000 to 0027
D	М	(Space)	(Space)	DM	0000 to 6655
D	М	*	(Space)	DM (indirect)	0000 to 6655
С	0	N	(Space)	Constant	0000 to 9999
Е	М	(Space)	(Space)	EM	0000 to 6143
Е	М	*	(Space)	EM (indirect)	0000 to 6143

Response Format



Limitations

The command is valid only when the UM setting is ladder only.

SR 253 through SR 255 can't be specified.

The command can't be executed if the UM area is write-protected.

PC Settings

	PC Mode			UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected		
	OK	OK		OK		

Execution Conditions

Comn	nands	Respo	onses
Single Multiple		Single	Multiple
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.

An end code of 15 (entry number data error) will be returned if the program address isn't BCD, the program address exceeds the maximum address in the program, the mnemonic/TC number is incorrect, or the SV is incorrect.


An end code of 16 (command not supported) will be returned if the specified instruction doesn't exist in the program.

End code	Contents	
00	Normal completion	
01	Not executable in RUN mode	
04	Address over	
13	FCS error	
14	Format error	
15	Entry number data error	
16	Command not supported	
18	Frame length error	
23	User memory protected	


10-3-23 STATUS READ - MS

Reads the PC operating conditions.


Command Format




Response Format



"Status data" consists of four digits (two bytes) hexadecimal. The leftmost byte indicates CPU Unit operation mode, and the rightmost byte indicates the size of the program area.





PC Settings

PC Mode			UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected	
OK	OK	OK	OK	OK	

Execution Conditions

Commands		Responses	
Single	Single Multiple		Multiple
OK		OK	

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
18	Frame length error


10-3-24 STATUS WRITE — SC

Changes the PC operating mode.


Command Format



Response Format



"Mode data" consists of two digits (one byte) hexadecimal. With the leftmost two bits, specify the PC operating mode. Set all of the remaining bits to "0."



PC Settings

PC Mode		UM Area		
RUN MONITOR PROGRAM		Write-protected	Read-protected	
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single Multiple	
OK		OK	

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
19	Not executable

10-3-25 ERROR READ — MF


Reads and clears errors in the PC. Also checks whether previous errors have been cleared.

Command Format




For the "error clear" parameter, specify 01 to clear errors and 00 to not clear errors (BCD). Fatal errors can be cleared only when the PC is in PROGRAM mode.


Response Format



1st word



2nd word



Limitations

When errors are being cleared (error clear = 01), the errors are read after the error clear function is executed.

PC Settings

PC Mode		UM Area		
RUN MONITOR PROGRAM		Write-protected	Read-protected	
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single Multiple	
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.


An end code of 15 (entry number data error) will be returned if the error clear parameter isn't set to 00 or 01.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error

10-3-26 FORCED SET — KS

Force sets an IR, SR, LR, HR, or AR bit or the Completion Flag of a timer or counter. Once a bit has been forced set or reset, that status will be retained until FORCED SET/RESET CANCEL (KC) is transmitted.

Command Format




For data areas IR, SR, LR, HR, and AR, the "Operand" parameter indicates the data area where the bit will be force-set and the "Word address" parameter indicates the word address.

For the TC area, "Operand" parameter indicates the mnemonic of the timer or counter instruction and the "Word address" parameter indicates the TC number.

Data area/		Operand			Word	Bit
instruction	OP1	OP2	OP3	OP4	address	
IR or SR	С	I	0	(Space)	0000 to 0511	00 to 15
LR	L	R	(Space)	(Space)	0000 to 0063	
HR	Н	R	(Space)	(Space)	0000 to 0099	
AR	Α	R	(Space)	(Space)	0000 to 0027	
TIMER	Т	I	М	(Space)	0000 to 0511	Always
HIGH-SPEED TIMER	Т	I	М	Н		00
COUNTER	С	N	Т	(Space)		
REVERS. COUNTER	С	N	T	R		
TOTALIZING TIMER	Т	Т	1	М		
TRANSITION FLAGS	Т	N	(Space)	(Space)	0000 to 1023	

Response Format



Limitations

Bits in SR 253 through SR 255 can't be specified.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.


An end code of 15 (entry number data error) will be returned if the operand, word address, or bit parameter setting is incorrect.

End code	Contents
00	Normal completion
01	Not executable in RUN mode
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error

10-3-27 FORCED RESET — KR

Force resets an IR, SR, LR, HR, or AR bit or the Completion Flag of a timer or counter. Once a bit has been forced set or reset, that status will be retained until FORCED SET/RESET CANCEL (KC) is transmitted.

Command Format




For data areas IR, SR, LR, HR, and AR, the "Operand" parameter indicates the data area where the bit will be force-set and the "Word address" parameter indicates the word address.

For the TC area, "Operand" parameter indicates the mnemonic of the timer or counter instruction and the "Word address" parameter indicates the TC number.

Data area/		0	perand		Word	Bit
instruction	OP1	OP2	OP3	OP4	address	
IR or SR	С	I	0	(Space)	0000 to 0511	00 to 15
LR	L	R	(Space)	(Space)	0000 to 0063	
HR	Н	R	(Space)	(Space)	0000 to 0099	
AR	Α	R	(Space)	(Space)	0000 to 0027	
TIMER	Т	I	M	(Space)	0000 to 0511	Always
HIGH-SPEED TIMER	Т	I	M	Н		00
COUNTER	С	N	Т	(Space)		
REVERS. COUNTER	С	N	Т	R		
TOTALIZING TIMER	Т	Т	I	М		
TRANSITION FLAGS	Т	N	(Space)	(Space)	0000 to 1023	

Response Format



Limitations

Bits in SR 253 through SR 255 can't be specified.

PC Settings

PC Mode			UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected	
	OK	OK	OK	OK	

Execution Conditions

Commands		Responses	
Single	Single Multiple		Multiple
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.


An end code of 15 (entry number data error) will be returned if the operand, word address, or bit parameter setting is incorrect.

End code	Contents		
00	Normal completion		
01	Not executable in RUN mode		
13	FCS error		
14	Format error		
15	Entry number data error		
18	Frame length error		

10-3-28 MULTIPLE FORCED SET/RESET — FK

Force sets, force resets, or cancels the forced status of the bits in one word in the IR, SR, LR, HR, or AR, or a timer/counter Completion Flag.

Command Format



For data areas IR, SR, LR, HR, and AR, the "Operand" parameter indicates the data area where the bit will be force-set and the "Word address" parameter indicates the word address.


For the TC area, "Operand" parameter indicates the mnemonic of the timer or counter instruction and the "Word address" parameter indicates the TC number.

Data area/		0	perand		Word	Bit
instruction	OP1	OP2	OP3	OP4	address	
IR or SR	С	I	0	(Space)	0000 to 0511	00 to 15
LR	L	R	(Space)	(Space)	0000 to 0063	
HR	Н	R	(Space)	(Space)	0000 to 0099	
AR	Α	R	(Space)	(Space)	0000 to 0027	
TIMER	T	I	М	(Space)	0000 to 0511	Always
HIGH-SPEED TIMER	Т	I	M	Н		00
COUNTER	С	N	Т	(Space)		
REVERS. COUNTER	С	N	Т	R		
TOTALIZING TIMER	T	T	I	М		
TRANSITION FLAGS	T	N	(Space)	(Space)	0000 to 1023	

The 16 bytes of forced set/reset/cancel data specifies what operation will be performed on the specified data area word or Completion Flag. If a timer or counter is specified, the status of the Completion Flag is force-set or force-reset using the setting for bit 15, and the settings for bits 00 through 14 will be ignored. Only force-setting and force-resetting are possible for timers/counters.

Forced set/reset/cancel data	Operation
0000	Bit status not changed
0010	Reset to 0.
0011	Set to 1.
0100	Forced-reset
0101	Forced-set
1000	Cancel forced set/reset status

Response Format



Limitations

Bits in SR 253 through SR 255 can't be specified.

Only 15 timers/counters or 15 Transition Flags can be set/reset.

The UM settings are not checked when Transition Flags are specified, i.e., as long as the Transition Flag address does not exceed 1023, the command will be executed normally even if the specified Flag does not actually exist in the remote PC.

PC Settings

PC Mode			UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected	
	OK	OK	OK	OK	

Execution Conditions

Comn	nands	Responses	
Single Multiple		Single Multiple	
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect. (The forced set/reset/cancel data is 16 bytes long.)

Note With Host Link Units, an error code of 14 (format error) won't be returned if data is specified for bit 15 for a timer/counter or Transition Flag. (The forced set/reset/cancel data can be one byte long or 16 bytes long.)

An end code of 15 (entry number data error) will be returned if the operand, word address, or bit parameter setting is incorrect. An end code of 15 will also be returned if the a data specification of 0 or 1 is used for a timer or counter Completion Flag or for a Transition Flag.


An error code of 15 (entry number data error) will be returned if [\$C, \$D] is specified for the forced data when set to TC.

End code	Contents			
00	Normal completion			
01	Not executable in RUN mode			
13	FCS error			
14	Format error			
15	Entry number data error			
18	Frame length error			


10-3-29 FORCED SET/RESET CANCEL — KC

Cancels all forced set and forced reset bits (including those set by FORCED SET, FORCED RESET, and MULTIPLE FORCED SET/RESET). If multiple bits are set, the forced status will be cancelled for all of them.

Command Format



Response Format



PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple Sin		Single	Multiple
OK		OK	

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
18	Frame length error


10-3-30 PC MODEL READ - MM

Reads the model type of the PC. The codes returned for this command are different from the NT Link codes.

Command Format



Response Format



"Model code" indicates the PC model in two digits hexadecimal.

Model code	Model
01	C250
02	C500
03	C120
0E	C2000
10	C1000H
11	C2000H/CQM1
12	C20H/C28H/C40H, C200H, C200HS, C200HX/HG/HE
20	CV500
21	CV1000
22	CV2000
40	CVM1-CPU01-E
41	CVM1-CPU11-E
42	CVM1-CPU21-E

PC Settings

Ī	PC Mode			UM A	Area
	RUN	MONITOR	PROGRAM	Write-protected	Read-protected
	OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.


End code	Contents	
00	Normal completion	
13	FCS error	
14	Format error	
18	Frame length error	

10-3-31 TEST-TS

Returns, unaltered, one block of data transmitted from the host computer.


Command Format

Specify any characters other than the carriage return (CHR\$(13)).



Response Format

The same characters specified in the command will be returned unaltered if the test is successful.



PC Settings

PC Mode			UM A	Area
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK		OK	

End Codes


An end code of 14 (format error) will be returned if a terminator isn't received in the first frame.

End code	Contents	
13	FCS error	
14	Format error	
18	Frame length error	


10-3-32 PROGRAM READ — RP

Reads the contents of the PC user's program area in machine language (object code). The contents are read as a block, from the beginning to the end.

Command Format



Response Format



Limitations

The command is valid only when the UM setting is ladder only.

The command can't be executed if the UM area is read-protected.

Data is read from the beginning of the ladder area to the maximum limit of the program area. (For example, \$A06C0 through \$A7FBF when the UM size is 16K words and none of the UM area is allocated to expansion DM or I/O comments.) The beginning read address and the length of the response depend on the UM area settings (such as the amount of memory allocated to expansion DM).

The response's first frame can contain up to 30 words of program data. The second and later frames can contain up to 31 words each.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

	PC Mode			Area
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK		OK	OK

End Codes


An end code of 14 (format error) will be returned if the length of the command is incorrect.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
18	Frame length error
23	User memory protected
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-33 PROGRAM WRITE — WP

Writes to the PC user's program area the machine language (object code) program transmitted from the host computer. The contents are written as a block, from the beginning.

Command Format



Response Format



Limitations

The command is valid only when the UM setting is ladder only.

The command can't be executed if the UM area is write-protected.

Data is written from the beginning of the ladder area to the maximum limit of the program area. Here are two examples:

- 1, 2, 3...
- 1. \$A06C0 through \$A7FBF when the UM size is 16K words and none of the UM area is allocated to expansion DM or I/O comments.
- 2. \$A06E0 through \$A7FBF when the UM size is 16K words, 1000 words are allocated to the expansion DM, and none is allocated to I/O comments.

The beginning write address and maximum size of the program depend on the UM area settings (such as the amount of memory allocated to expansion DM).

An error won't occur if the command attempts to write program data beyond the maximum size of the program area.

The program data can be divided into multiple frames.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
		OK		OK

Execution Conditions

Commands		Responses	
Single Multiple		Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect (the total size of the program is an odd number of bytes) or the first frame contains no program data.

An end code of 15 (entry number data error) will be returned if the specified write data isn't hexadecimal.


End code	Contents		
00	Normal completion		
01	Not executable in RUN mode		
02	Not executable in MONITOR mode		
13	FCS error		

End code	Contents			
14	Format error			
15	Entry number data error			
18	Frame length error			
19	Not executable			
23	User memory protected			
A3	Aborted due to FCS error in transmit data			
A4	Aborted due to format error in transmit data			
A5	Aborted due to entry number data error in transmit data			
A8	Aborted due to frame length error in transmit data			


10-3-34 I/O TABLE GENERATE --- MI

Corrects the registered I/O table to match the actual I/O table.

Command Format



Response Format



PC Settings

PC Mode			UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected	
		OK		OK	

Execution Conditions

Comn	nands	Responses		
Single	Multiple	Single	Multiple	
OK		OK		

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.


End code	Contents		
00	Normal completion		
01	Not executable in RUN mode		
02	Not executable in MONITOR mode		
03	UM write-protected		
13	FCS error		
14	Format error		
18	Frame length error		
20	Couldn't create I/O table		

Note The write-protected error code for this command is different from the other commands.

10-3-35 COMPOUND COMMAND — QQMR

Registers at the PC all of the bits, words, and timers/counters that are to be read, and reads the status of all of them as a batch. The registered information is retained in the PC until it is overwritten by the COMPOUND COMMAND or the PC's power is turned off.

Command Format




The "Read area" indicates the data area, the "Read word address" indicates the word address, and the "Data format" indicates the bit number (00 to 15) or entire word (CH).

Data area/instruction	Operand				Constant or
	OP1	OP2	OP3	OP4	word address
IR or SR	С	I	0	(Space)	0000 to 0511
LR	L	R	(Space)	(Space)	0000 to 0063
HR	Н	R	(Space)	(Space)	0000 to 0099
AR	Α	R	(Space)	(Space)	0000 to 0027
TIMER	Т	I	М	(Space)	0000 to 0511
HIGH-SPEED TIMER	Т	I	М	Н	
COUNTER	С	N	Т	(Space)	
REVERSIBLE COUNTER	С	N	Т	R	
TOTALIZING TIMER	Т	Т	I	M	
DM	D	М	(Space)	(Space)	0000 to 6655
EM (current bank)	Е	M	(Space)	(Space)	0000 to 6143
EM (bank 0)	Е	М	0	0	0000 to 6143
EM (bank 1)	E	М	0	1	0000 to 6143
EM (bank 2)	Е	М	0	2	0000 to 6143

Each word or bit address is specified one item at a time separated by a break code (,). The maximum number of items that can be specified is 128 unless an address in the EM area is specified, in which case the maximum is 100. (When the PV of a timer/counter is specified, the status of the Completion Flag is also returned, and must therefore be counted as two items.)

Response Format



Limitations

The registered data is checked from the beginning and the data will be registered up to any errors. For example, if a command attempts to register 129 items, a frame length error (end code 18) will occur but the first 128 items will be registered.

DM 6656 to DM 6999 do not exist, but an error will not occur if you try to register these words.

Bits and words can be specified in any order and they will be registered in the order that they were specified.

The data can be divided into multiple frames.

PC Settings

PC Mode		UM Area		
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK	OK	OK	

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect or the "," data break between two items is omitted.


An end code of 15 (entry number data error) will be returned if the "Read area," "Read word address," or "Data format" setting is incorrect.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
15	Entry number data error
18	Frame length error
19	Not executable
A3	Aborted due to FCS error in transmit data
A4	Aborted due to format error in transmit data
A5	Aborted due to entry number data error in transmit data
A8	Aborted due to frame length error in transmit data


10-3-36 COMPOUND COMMAND DATA READ — QQIR


The bit, word, and timer/counter status is read as a batch according to the read information that was registered with QQMR.

Command Format



Response Format





Limitations

The data is read in the same order in which it was registered with QQMR.

A response of "0000" will be returned for non-existent words such as DM 6656 to DM 6999, unallocated expansion DM, or non-existent EM banks.

The INITIALIZE and ABORT commands can be sent instead of the delimiter for multiple responses for this command. If other commands are sent, they will be treated the same as delimiters.

PC Settings

PC Mode			UM A	Area
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Comn	nands	Responses	
Single	Multiple	Single	Multiple
OK		OK	OK

End Codes

An end code of 14 (format error) will be returned if the length of the command is incorrect.


An end code of 19 (not executable) will be returned if there is no registered data.

End code	Contents
00	Normal completion
13	FCS error
14	Format error
18	Frame length error
19	Not executable
A3	Aborted due to FCS error in transmit data
A8	Aborted due to frame length error in transmit data

10-3-37 ABORT — XZ

Aborts the Host Link command that is currently being processed, allowing the next command to be received. The ABORT command does not receive a response.

Command Format



Limitations

Multiple responses to a command can be cancelled with this command. This command is valid even without the FCS code and terminator.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Comn	nands	Responses	
Single	Multiple	Single	Multiple
OK			


End Codes

There are no end codes with this command.

10-3-38 INITIALIZE — **

Initializes the transmission control procedure of all the PCs connected to the host computer. The INITIALIZE command does not use node numbers or FCS, and does not receive a response.

Command Format



Limitations

Multiple responses to a command can be cancelled with this command.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
OK			


End Codes

There are no end codes with this command.

10-3-39 TXD RESPONSE — EX

This is the response format used when the PC's TXD(—) instruction is executed in Host Link mode. (TXD(—) converts the specified data into ASCII code and transmits it to the host computer with this format.)

Response Format



Limitations

The frame can contain up to 122 characters. (TXD(—) doesn't support multiple frames.)

There is no command associated with EX.

PC Settings

PC Mode			UM Area	
RUN	MONITOR	PROGRAM	Write-protected	Read-protected
OK	OK		OK	OK

Execution Conditions

Commands		Responses	
Single	Multiple	Single	Multiple
		OK	


End Codes

There are no end codes with this command.

10-3-40 Undefined Command — IC

This response is returned if the header code of a command cannot be decoded. Check the header code.

Response Format



Limitations

This error response will be returned if there are fewer than 6 bytes of data between a command's "@" character and the terminator, an incorrect header code is used, or a frame is corrupted.

There is no command associated with IC.

PC Settings

	PC Mode		UM A	Area
RUN MONITOR PROGRAM			Write-protected	Read-protected
OK	OK	OK	OK	OK

Execution Conditions

Comn	nands	Responses		
Single	Multiple	Single	Multiple	
		OK		

End Codes

There are no end codes with this command.

Appendix A Standard Models

CPU Rack

Name		Speci	fications		Model number
CPU Units (All models are pro-	UM	DM	I/O points	RS-232C	
vided with clock function and slots for communications except CPU11-E.)	3.2K words	4K words	640	No	C200HE-CPU11-E
	7.2K words	6K words	880	No	C200HE-CPU32-E
				Yes	C200HE-CPU42-E
	15.2K words	12K words	880	No	C200HG-CPU33-E
				Yes	C200HG-CPU43-E
			1,184	No	C200HG-CPU53-E
				Yes	C200HG-CPU63-E
	31.2K words	24K words	880	No	C200HX-CPU34-E
				Yes	C200HX-CPU44-E
			1,184	No	C200HX-CPU54-E
				Yes	C200HX-CPU64-E
Power Supply Units	100 to 120/20	0 to 240 VAC	·		C200HW-PA204
	100 to 120/20	C200HW-PA204S			
	24 VDC	C200HW-PD024			
CPU I/O Backplanes	3 slots	C200HW-BC031			
	5 slots	C200HW-BC051			
美国国际联系统	8 slots	C200HW-BC081			
ACTION AND DESCRIPTION OF THE PERSON OF THE	10 slots	C200HW-BC101			
Communication Boards	Communication	C200HW-COM01			
	RS-232C port	C200HW-COM02			
	RS-422/485 p	C200HW-COM03			
- J.P.	Communication MAC NET Lin	C200HW-COM04-E			
	Two RS-232C	C200HW-COM05-E			
	RS-422/485 p function	C200HW-COM06-E			
Memory Cassettes	EEPROM	4K words			C200HW-ME04K
Normal Samuel		8K words			C200HW-ME08K
		16K words			C200HW-ME16K (see note)
		32K words			C200HW-ME32K
	EPROM	16K words/3	2K words		C200HS-MP16K
		Equivalent to	27256, 150 ns	s, 12.5 V	ROM-JD-B
		Equivalent to	27512, 150 ns	s, 12.5 V	ROM-KD-B

Note: The C200HW-ME16K will be released soon. The EEPROM Memory Cassette can be also used with the C200HS-ME16K.

Expansion I/O Racks

Name		Specifications	Model number
Power Supply Units	100 to 120/200	C200HW-PA204	
	100 to 120/200	C200HW-PA204S	
	24 VDC	C200HW-PD024	
Expansion I/O Backplanes	3 slots		C200HW-BI031
THE WELL OF	5 slots	C200HW-BI051	
	8 slots	C200HW-BI081	
	10 slots	C200HW-BI101	
I/O Connecting Cables	30 cm	The total length of the I/O Connecting Cables	C200H-CN311
AND	70 cm	used in a network must be 12 m maximum.	C200H-CN711
	200 cm		C200H-CN221
	500 cm		C200H-CN521
	1,000 cm		C200H-CN131

Slave Racks

	Name		Specifications		Model number	
Slave Racks	Remote I/O Slave	100 to 12	20/200 to 240 VAC (switchable)	APF/PCF	C200H-RT001-P	
	73.1	24 VDC			C200H-RT002-P	
		100 to 12	20/200 to 240 VAC (switchable)	Wired	C200H-RT201	
	# # T	24 VDC			C200H-RT202	
Backplanes		3 slots			C200H-BC031-V2	
		5 slots	5 slots			
	<u> </u>	8 slots			C200H-BC081-V2	
	6 (2)	10 slots			C200H-BC101-V2	
I/O Blocks		Input	Input Specify either 12 or 24 VDC.		G71-IC16	
		Output			G71-OD16	
I/O	AC input	Specify either 100 or 200 VAC.			G7TC-IA16	
Terminals	DC input	Specify e	either 12 or 24 VDC.		G7TC-ID16	
	Output	Specify e	either 12 or 24 VDC.	_	G7TC-OC16	

I/O Units

Name		ne		Specifications	Model number
Input Units AC Input Units		nput Units	8 pts	100 to 120 VAC	C200H-IA121
			16 pts	100 to 120 VAC	C200H-IA122/IA122V
3			8 pts	200 to 240 VAC	C200H-IA221
*			16 pts	200 to 240 VAC	C200H-IA222/IA222V
3 1	DC I	nput Units	8 pts	12 to 24 VDC	C200H-ID211
	DC I	nput Units	16 pts	24 VDC	C200H-ID212
47.	AC/E	OC Input Units	8 pts	12 to 24 VAC/DC	C200H-IM211
			16 pts	24 VAC/DC	C200H-IM212
		rupt Input Unit note)	8 pts	12 to 24 VDC	C200HS-INT01
Output	Rela	y Output Units	8 pts	2 A, 250 VAC/24 VDC (for resistive load)	C200H-OC221
Units			12 pts	2 A, 250 VAC/24 VDC (for resistive load)	C200H-OC222
			5 pts	2 A, 250 VAC/24 VDC (for resistive load) Independent commons	C200H-OC223
			8 pts	2 A, 250 VAC/24 VDC (for resistive load) Independent commons	C200H-OC224
			16 pts	2 A, 250 VAC/24 VDC (for resistive load) (see note)	C200H-OC225
	Triac	Triac Output Units	8 pts	1 A, 120 VAC	C200H-OA121-E
			8 pts	1.2 A, 250 VAC	C200H-OA223
			12 pts	0.3 A, 250 VAC	C200H-OA222V
2		sistor Output	8 pts	1 A, 12 to 48 VDC	C200H-OD411
	Units	5	12 pts	0.3 A, 24 VDC	C200H-OD211
			16 pts	0.3 A, 24 VDC (see note)	C200H-OD212
			8 pts	2.1 A, 24 VDC	C200H-OD213
			8 pts	0.8 A, 24 VDC; source type (PNP); w/load short protection	C200H-OD214
			8 pts	0.3 A, 5 to 24 VDC; source type (PNP)	C200H-OD216
			12 pts	0.3 A, 5 to 24 VDC; source type (PNP)	C200H-OD217
			16 pts	1.0 A, 24 VDC; source type (PNP); with load short protection	C200H-OD21A
Analog Time	r Unit		4 timers	0.1 to 1 s/1 to 10 s/10 to 60 s/1 min to 10 min (switchable)	C200H-TM001
#.21 #.21	Variable Resistor Connector		Connecto	r w/lead wire (2 m) for 1 external resistor	C4K-CN223

Name		Specifications		Model number
B7A Interface Units		15 or 16 input pts	Connects to B7A Link Terminals. Standard transmission delay.	C200H-B7AI1
		16 output pts	Connects to B7A Link Terminals. Standard transmission delay.	C200H-B7AO1 (see note)

Note: If the Interrupt Input Unit is mounted on an Expansion I/O Rack, the interrupt function cannot be used and the Interrupt Input Unit will be treated as an ordinary 8-point Input Unit. Moreover, Interrupt Input Units cannot be used on Slave Racks. In addition, Interrupt Input Units require that a version 2 (i.e., model numbers with a "-V2" suffix) Backplane be used at the CPU Rack. If an earlier version Backplane is mounted, the interrupt function cannot be used. When mounting the C200H-OC225, C200H-OD212, or C200H-B7AO1 to a Backplane, make sure that the model number of the Backplane includes the suffix "-V1" or "-V." The C200H-OC225, C200H-OD212, or C200H-B7AO1 cannot be mounted to any Backplane the model number of which does not include the suffix "-V1" or "-V."

Group-2 I/O Units

	Name		Specifications	Model number
100 mm	DC Input Units	64 pts	12 VDC	C200H-ID111
		32 pts	24 VDC	C200H-ID216
		64 pts		C200H-ID217
Transistor Output		32 pts	16 mA at 4.5 V to 100 mA at 26.4 V	C200H-OD218
Units	64 pts		C200H-OD219	
		32 pts	24 VDC 0.5 A (5 A/unit)	C200H-OD21B
B7A Interfac	e Units	32 input pts	Connects to B7A Link Terminals.	C200H-B7A12
100 mg 27		32 output pts	Standard or high-speed transmission delay.	C200H-B7A02
		16 input and 16 output points	– delay.	C200H-B7A21
		32 input and 32 output points		C200H-B7A22

Special I/O Units

	Name		Specifications	Model number
High-density	DC Input Units	32 pts	5 VDC (TTL inputs); w/high-speed input	C200H-ID501
I/O Units		32 pts	24 VDC; w/high-speed input	C200H-ID215
(see note)	Transistor Output Units	32 pts	0.1 A, 24 VDC (useable as 128-point dynamic output unit)	C200H-OD215
		32 pts	35 mA, 5 VDC (TTL outputs) (useable as 128-point dynamic output unit)	C200H-OD501
	DC Input/Transistor Output Units	16 input and 16 output pts	24-VDC inputs; w/high-speed input; 0.1-A, 24-VDC outputs (useable as 128-point dynamic input unit)	C200H-MD215
		16 input and 16 output pts	5-VDC TTL inputs; w/high speed input; 35-mA, 5-VDC TTL outputs (useable as 128-point dynamic input unit)	C200H-MD501
		16 input and 16 output pts	12-VDC TTL inputs; w/high speed input; 12-VDC TTL outputs (useable as 128-point dynamic input unit)	C200H-MD115

Name			Specifications	Model number
Analog I/O	Analog Input Units	4 to 20 mA, 1 to	5/0 to 10 V (switchable); 4 inputs; 12 bits	C200H-AD001
Units		4 to 20 mA, 1 to inputs; 12 bits or	C200H-AD002	
	Analog Output Unit	4 to 20 mA, 1 to	5/0 to 10 V (switchable); 2 outputs	C200H-DA001
Fuzzy Logic l	Jnit	Programmed us inputs and 4 out	ing the Fuzzy Support Software. Up to 8 puts.	C200H-FZ001
	Fuzzy Support Software	Available on eith	er 3.5" or 5.25" floppy disks.	C500-SU981-E
Temperature	Sensor Units	Thermocouple	K(CA) or J(IC), switchable; 4 inputs	C200H-TS001
			K(CA) or L(Fe-CuNi) DIN standards; 4 inputs	C200H-TS002
\$ 1.0 1.0		Pt resistance thermometer	Pt 100 Ω; 4 inputs	C200H-TS101
A80 11			Pt 100 Ω ; 4 inputs; DIN and 1989 JIS standards	C200H-TS102
Temperature	Control Units	Thermocouple	Transistor output	C200H-TC001
All Control			Voltage output	C200H-TC002
			Current output	C200H-TC003
			Transistor output	C200H-TC101
		thermometer	Voltage output	C200H-TC102
			Current output	C200H-TC103
Heat/Cool		Thermocouple	Transistor output	C200H-TV001
Temperature	Control Units		Voltage output	C200H-TV002
A			Current output	C200H-TV003
åni		Pt resistance	Transistor output	C200H-TV101
		thermometer	Voltage output	C200H-TV102
u ,/			Current output	C200H-TV103
Cam Position	Cam Positioner Unit		of rotation by means of a resolver and down of Protation by means of a resolver and down of Protation of Prot	C200H-CP114
Data Setting	Data Setting Console		Used to set and monitor data in Temperature Control Units, Cam Positioner Units, PID Control Units, and Heat/Cool Temperature Control Units.	
	Connecting Cables	2 m		C200H-CN225
**************************************	French Street			C200H-CN425
PID Control L	PID Control Units		t; 4 to 20 mA/1 to 5 V/0 to 5V/0 to 10 V e)	C200H-PID01
		Voltage output; 4 (selectable)	4 to 20 mA/1 to 5 V/0 to 5V/0 to 10 V inputs	C200H-PID02
			4 to 20 mA/1 to 5 V/0 to 5V/0 to 10 V inputs	C200H-PID03

	Name		Specifications	Model number
Position Con	trol Units	1 axis	Pulse output; speeds: 1 to 100,000 pps	C200H-NC111
			Pulse output; directly connects to servomotor driver; compatible with line driver; speeds: 1 to 250,000 pps	C200H-NC112
魔./		1 axis	1 axis Pulse output; directly connects to servodriver	
		2 axes	Pulse output; speeds: 1 to 250,000 pps, 53 pts per axis	C200H-NC211
		2 axes	Pulse output; directly connects to servodriver	C200HW-NC213
			Pulse output; directly connects to servodriver	C200HW-NC413
High-speed (High-speed Counter Units		Pulse input; counting speed: 50 kcps; 5 VDC/12 VDC/24 VDC	C200H-CT001-V1
			Pulse input; counting speed: 75 kcps; RS-422 line driver	C200H-CT002
.		2 axes	Pulse input; counting speed: 75 kcps; RS-422 line driver; 7-digit BCD	C200H-CT021
ASCII Unit	ASCII Unit		24K-byte RAM and 24K-byte EEPROM are built-in.	
ID Sensor Ur	nits	Local application	n, electromagnetic coupling	C200H-IDS01-V1
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		Remote applicat	tion; microwave transmissions	C200H-IDS21
₩ 1	Read/Write Heads	Electromagnetic	type:	V600-H series
<u>}</u> - },		Microwave type		V620-H series
	<u> </u>		/600-H series.	V600-D□□R□□
			EEPROM type for V600-H series.	
Voice Unit		60 messages m (switchable)	ax.; message length: 32, 48, or 64 s	C200H-OV001
***	Connecting Cable	RS-232C		C200H-CN224

Note: When mounting a High-density I/O Unit as a Special I/O Unit to a Slave Rack, the Remote I/O Master must be the C200H-RM001-PV1 or C200H-RM201.

Communication Units

	Name	Specifications	Specifications			
SYSMAC LINK Unit (coaxial cable)		A Bus Connection Unit must be ordered separately.	Data link table: 918 words	C200HW-SLK23		
*			Data link table: 2,966 words	C200HW-SLK24		
1	Terminator	One required for each node at ends of Sy	One required for each node at ends of System.			
	Attachment Stirrup	Provided with SYSMAC LINK Unit.	Provided with SYSMAC LINK Unit.			
	F Adapter	To connect network	C1000H-CE001			
l	F Adapter Cover	To connect network		C1000H-COV01		

Name		Spe	ecifications		Model number	
	LINK Unit ber cable)	Connection Unit must be order	Connect with H-PCF cable. A Bus Connection Unit must be ordered Data lin 918 wor			C200HW-SLK13
- #9°°¢ ∰		separately.		Data lin 2,966 w		C200HW-SLK14
	Power Supply Adapter	Required when supplying back	ckup power		For 1 or 2 Units	C200H-APS03
	Power Cable	Connects Power Supply Ada	pter and SY	SMAC	For 1 Unit	C200H-CN111
		NET Link Unit.			For 2 Units	C200H-CN211
	LINK Support paxial cable)	To connect IBM PC/AT or con system	mpatible as r	node in S	YSMAC LINK	3G8F5-SLK21-E
SYSMAC	NET Link Unit	A Bus Connection Unit must	be ordered s	separatel	y.	C200HS-SNT32
e a de la constante	Power Supply	Required when supplying bad	ckup power		For 1 Unit	C200H-APS01
*	Adapter				For 2 Units	C200H-APS02
3.0	Power Cable Connects Power Supply Adapter and SYSMAC NET C200H-APS01		For 1 Unit	C200H-CN001		
			Included w C200H-AP		For 2 Units	C200H-CN002
Bus Conr	nection Units		Connects SYSMAC LINK Unit or SYSMAC NET Link Unit to C200HW-COM01/COM04-E		For 1 Unit	C200HW-CE001
**) <i>(20</i>) -	Communications Board			For 2 Units	C200HW-CE002
Host Link	Units	Rack-mounting	C200H, C2 C200HE,	200HS,	APF/PCF	C200H-LK101-PV1
	E.		C200HG, 0	C200HX	RS-422	C200H-LK202-V1
				RS-2		C200H-LK201-V1
PC Link Unit		Single level: 32 Units Multilevel: 16 Units			RS-485	C200H-LK401
Remote I/O Master Units		Up to two per PC; connectab per PC total	le to up to 5	Slaves	APF/PCF	C200H-RM001-PV1
					Wired	C200H-RM201
Remote I	O Slave Units	See Racks at beginning of pr	oduct lists.			

SYSMAC NET/SYSMAC LINK Hardware

Name	Specifications	Model number
SYSMAC NET Network Support Board	For IBM PC/AT or compatible	S3200-NSB11-E
SYSMAC LINK Network Support Board	For IBM PC/AT or compatible, coaxial cable connector	3G8F5-SLK21-E

Link Adapters

Name	Specifications	Model number
Link Adapters	3 RS-422 connectors	3G2A9-AL001
	3 optical connectors (APF/PCF)	3G2A9-AL002-PE
A STATE OF THE PARTY OF THE PAR	3 optical connectors (PCF)	3G2A9-AL002-E
The state of the s	1 connector for RS-232C; 2 for RS-422	3G2A9-AL003
	1 connector each for APF/PCF, RS-422, and RS-232C	3G2A9-AL004-PE
	1 connector each for PCF, RS-422, and RS-232C	3G2A9-AL004-E
	1 connector each for APF/PCF and AGF	3G2A9-AL005-PE
	1 connector each for PCF and AGF	3G2A9-AL005-E
	1 connector for APF/PCF; 2 for AGF	3G2A9-AL006-PE
	1 connector for PCF; 2 for AGF	3G2A9-AL006-E
	O/E converter; 1 connector for RS-485, 1 connector each for APF/PCF	B500-AL007-P
	Used for on-line removal of SYSMAC NET Link Units from the SYSMAC NET Link System, SYSMAC NET Optical Link Adapter 3 connectors for APF/PCF.	B700-AL001

Optical Fiber Products

Optical Fiber Cable for SYSMAC NET and SYSMAC LINK H-PCF Optical Fiber Cable with Connectors

System	Appearance	Model number
SYSMAC NET SYSMAC LINK		S3200-CN□□-20-20
		S3200-CN□□-20-25
		S3200-CN□□-20-62
		\$3200-CN□□-25-25
		S3200-CN□□-25-62
		S3200-CN□□□-62-62

Model Numbers

The above cable model numbers specify the type of cable, the length, and the type of connectors attached.

- 1. **\$3200-CN** specifies H-PCF optical fiber cable.
- 2. The boxes ($\square\square\square$) are replaced by codes indicating the standard model lengths, as shown below.

Consult with your OMRON representative for longer cables. When ordering longer cables, omit the portion represented by the boxes and specify the length in meters separately, e.g., S3200-CN-20-20, 30 m.

Code	Length	Code	Length
201	2 m	152	15 m
501	5 m	202	20 m
102	10 m	Omitted	Over 20 m

3. The last two portions of the model numbers (e.g., 20-25) specify the connectors, as shown below.

Code	Connector
20	S3200-COCF2011
25	S3200-COCF2511
62	S3200-COCH62M

Applicable Optical Fiber Connectors

Model number/Appearance	A	oplicable Units
	SYSMAC NET	SYSMAC LINK
S3200-COCF2011	CV500-SNT31	CV500-SLK11 C1000H-SLK11
S3200-COCF2511	C200HS-SNT32	C200HW-SLK13/14
S3200-COCH62M	\$3200-LSU03-01E \$3200-NSUA1-00E \$3200-NSUG4-00E \$3200-NSB11-E C500-SNT31-V4 B700-AL001	

All Plastic Optical Fiber Cable for SYSMAC BUS

Name	Specifications	Model number	Standards
All Plastic Optical Fiber Cable	Cable only; order desired length in 5 m increments between 5 and 100 m, or in increments of 200 m or 500 m.	3G5A2-PF002	
Optical Connectors A	Two optical connectors (brown) for APF (10 m max.)	3G5A2-CO001	
Optical Connectors B	Two optical connectors (black) for APF (8 to 20 m)	3G5A2-CO002	
All Plastic Optical Fiber Cable Set	1-m cable with an Optical Connector A connected to each end	3G5A2-PF101	
Optical Fiber Processing Kit	Accessory: 125-mm nipper (Muromoto Tekko's 550M) for APF	3G2A9-TL101	

Plastic Clad Optical Fiber Cable for SYSMAC BUS

Name	Specifications		Model number	Standards
Plastic Clad Optical Fiber	0.1 m, w/connectors	_10° to 70°C	3G5A2-OF011	
Cables (indoor)	1 m, w/connectors		3G5A2-OF101	
	2 m, w/connectors		3G5A2-OF201	
	3 m, w/connectors		3G5A2-OF301	
	5 m, w/connectors		3G5A2-OF501	
	10 m, w/connectors		3G5A2-OF111	
	20 m, w/connectors		3G5A2-OF211	
	30 m, w/connectors		3G5A2-OF311	
	40 m, w/connectors		3G5A2-OF411	
	50 m, w/connectors	1	3G5A2-OF511	
	Cable only; order desired length between 1 and 500 m in increments of 1 m.		3G5A2-OF002	
	Cable only; order desired length between 501 and 800 m in increments of 1 m.	Ambient temp: 0° to 55°C (do not expose to di- rect sunlight)		

H-PCF Optical Fiber Cables (For SYSMAC NET, SYSMAC LINK, and SYSMAC BUS)

Name	Specifications		Model number	Stan- dards
Optical Fiber Cables SYSMAC NET, SYSMAC LINK	10 m, black	Composite cable including two-core cable and two-core	S3200-HCLB101	
	50 m, black		S3200-HCLB501	
	100 m, black		S3200-HCLB102	
	500 m, black	power supply cable	S3200-HCLB502	
	1,000 m, black	Cable	S3200-HCLB103	
	10 m, orange		S3200-HCLO101	
	50 m, orange		S3200-HCLO501	
	100 m, orange		S3200-HCLO102	
	500 m, orange		S3200-HCLO502	
	1,000 m, orange		S3200-HCLO103	1
Optical Fiber Cables SYSMAC NET, SYSMAC LINK, SYSMAC BUS, SYSMAC WAY	10 m, black	Two-core cable	S3200-HCLB101	
	50 m, black		S3200-HCCB501	
	100 m, black		S3200-HCCB102	
	500 m, black		S3200-HCCB502	
	1000 m, black		S3200-HCCB103	
	10 m, orange		S3200-HCCO101	
	50 m, orange		S3200-HCCO501	
	100 m, orange		S3200-HCCO102	
	500 m, orange		S3200-HCCO502	
	1,000 m, orange		S3200-HCCO103	
	10 m, black	Two-core cord	S3200-HBCB101	
	50 m, black	1	S3200-HBCB501	
	100 m, black	1	S3200-HBCB102	1
	500 m, black	1	S3200-HBCB502	1
	1,000 m, black		S3200-HBCB103	

Name	Specifications		Model number	Stan- dards
Optical Fiber Cable Connector	SYSMAC NET: S3200-LSU03-01E B700-AL001 C500-SNT31-V4	Full-lock con- nector for NSU, NSB, and C500 SYSMAC NET Link Unit	S3200-COCH62M	
	SYSMAC BUS: C200H-RM001-PV1 C200H-RT001/RT002-P C500-RM001-(P)V1 C500-RT001/RT002-(P)V1 3G2A9-□□□(-P)	Half-lock con- nector for Re- mote I/O Mas- ter, Remote I/O Slave, Host Link Unit, and Link Adapter	S3200-COCH82	
()	SYSMAC NET/SYSMAC LINK C200HS-SNT32 C200HW-SLK13/14	Half-lock con- nector	S3200-COCF2511	
	SYSMAC NET/SYSMAC LINK CV500-SNT31 CV500-SLK11 CV1000H-SLK11	Full-lock con- nector	S3200-COCF2011	
	To relay at all SYSMAC NET nodes.	COCF62M and COCF62F are	S3200-COCF62M	
		used as a pair.	S3200-COCF62F	

Note: 1. Optical fiber cables must be prepared and connected by specialists.

- 2. If the user prepares and connects optical fiber cables, the user must take a seminar held under the auspices of Sumitomo Electric Industries, Ltd. and obtain a proper certificate.
- 3. The Optical Power Tester, Head Unit, Master Fiber Set, and Optical Fiber Assembling Tool are required to connect optical fiber cables.
- 4. You may want to use the Plastic Clad Optical Fiber Cable/All Plastic Optical Fiber Cable with connectors listed on the previous two pages.

Optical Fiber Assembling Tool

Name	Specifications	Model number	Stan- dards
	Used to connect H-PCF and crimp-cut connectors for optical transmission systems such as the SYS-MAC C- and CV-series SYSMAC BUS, SYSMAC LINK and SYSMAC NET.	S3200-CAK1062	

Note: 1. Optical fiber cables must be prepared and connected by specialists.

2. The Optical Power Tester, Head Unit, Master Fiber set, and Optical Fiber Assembling Tool are required to connect optical fiber cables.

Optical Power Tester

Name	Name Specifications		Model number	Stan- dards
Optical Power Tester (see note) (provided with a connector adapter, light source unit, small single-head plug, hard case, and AC adapter)	SYSMAC NET: CV500-SNT31 C200HS-SNT32	S3200-CAT200 2 (provided with the Tester)	S3200-CAT2000	
	SYSMAC LINK: CV500-SLK11 C200HW-SLK13/14 CV1000H-SLK11	S3200-CAT270 2 (provided with the Tester)	S3200-CAT2700	
	SYSMAC BUS: C200H-RM001-PV1 C200H-RT001/RT002-P C500-RM001-(P)V1 C500-RT001/RT002-(P)V1	S3200-CAT282 2 (provided with the Tester)	S3200-CAT2820	
	SYSMAC NET: S3200-LSU03-01E C500-SNT31-V4	S3200-CAT320 2 (provided with the Tester)	S3200-CAT3200	

Note: There is no difference between the light source unit and connector adapter for the Head Unit and those for the Optical Power Tester.

Head Unit

Name	Specifications	Model number	Stan- dards
Head Units (a set consisting of light source unit and connector adapter)	SYSMAC NET: CV500-SNT31 C200HS-SNT32	S3200-CAT2002	
(see note)	SYSMAC LINK: CV500-SLK11 C200HW-SLK13/14 CV1000H-SLK11	S3200-CAT2702	
	SYSMAC BUS: C500-RM001-(P)V1 C500-RT001/RT002-(P)V1 C200H-RM001-PV1 C200H-RT001/RT002-PV1	S3200-CAT2822	
	SYSMAC NET: S3200-LSU03-01E C500-SNT31-V4	S3200-CAT3202	

Note: Use a proper Head Unit model for the optical module to be used. If two types of optical modules (unit type and board type) are used, order an Optical Power Tester plus a proper Head Unit model.

Master Fiber Set

Name	Specifications	Model number	Stan- dards
Master Fiber Sets (1 m)	S3200-CAT3202 (SYSMAC NET, NSB, NSU, Bridge)	S3200-CAT3201	
	S3200-CAT2002/CAT2702 (SYSMAC NET, SYSMAC LINK)	S3200-CAT2001H	1
	S3200-CAT2822 (SYSMAC BUS)	S3200-CAT2821	

Note: 1. The Master Fiber Set is used in combination with the Optical Power Tester to check the optical levels of optical fiber cables connected to optical fiber cable connectors.

- 2. Optical fiber cables must be prepared and connected by specialists.
- 3. The Optical Power Tester, Head Unit, Master Fiber set, and Optical Fiber Assembling Tool are required to connect optical fiber cables.

Programming Devices

Name	Specifications		Model number	Stan- dards
Programming Consoles	Hand-Held, w/backlight		C200H-PRO27-E	U, C
	2-m Connecting Cable included		CQM1-PRO01-E	U, C
Programming Console Mounting Bracket	Used to attach Hand-held Programmii panel.	Used to attach Hand-held Programming Console to a panel.		
Programming Console Connecting Cables	For Hand-held Programming Console	2 m	C200H-CN222	
		4 m	C200H-CN422	
Data Setting Console	Used for data input and process value display for the C200H-TC□□□, C200H-TV□□□, C200H-CP114, and C200H-PID0□.		C200H-DSC01	
Data Setting Console Connecting Cables	For C200H-DSC01	2 m	C200H-CN225	
Confidentify Cables		4 m	C200H-CN425	1
Connecting Cable	Used to connect an IBM PC/AT or compatible to the C200HX/HG/HE.	3.3 m	CQM1-CIF02	

Optional Products

Name	Specifications	Model number	Standards
I/O Unit Cover	[]]		
Terminal Block Covers	Short protection for 10-pin terminal block (package of 10 covers); 8 pts	C200H-COV02	
-	Short protection for 19-pin terminal block (package of 10 covers); 12 pts	C200H-COV03	
Connector Cover	Protective cover for unused I/O Connecting Cable connectors	C500-COV02	
Space Unit	Used for vacant slots	C200H-SP001	N, L
Battery Set	For C200H or C200HS RAM Memory Unit only	C200H-BAT09	

Name	Specifications	Model number	Standards
Relay	24 VDC	G6B-1174P-FD-US	
Backplane Insula-	For C200HW-BC031 (3-slot CPU Backplane)	C200H-ATT31	
tion Plates	For C200HW-BC051 (5-slot CPU Backplane)	C200H-ATT51	
	For C200HW-BC081 (8-slot CPU Backplane)	C200H-ATT81	
	For C200HW-BC101 (10-slot CPU Backplane)	C200H-ATTA1	
	For C200HW-BI031 (3-slot I/O Backplane)	C200HW-ATT32	
	For C200HW-BI051 (5-slot I/O Backplane)	C200HW-ATT52	
	For C200HW-BI081 (8-slot I/O Backplane)	C200HW-ATT82	
	For C200HW-BI101 (10-slot I/O Backplane)	C200HW-ATTA2	
I/O Brackets	For 3-slot Backplane	C200H-ATT33	N
"O Blackets	For 5-slot Backplane	C200H-ATT53	
	For 8-slot Backplane	C200H-ATT83	
	For 10-slot Backplane	C200H-ATTA3	
External Connectors	Solder terminal; 40p and a Connector Cover	C500-CE401	
 	Solderless terminal; 40p and a Connector Cover (Crimp-type)	C500-CE402	
	Pressure welded terminal; 40p	C500-CE403	
	Solder terminal; 40p and a Connector Cover (Horizontal-type)	C500-CE404	
, 1° 1° 1	Crimp-style terminal; 40p and a Connector Cover (Horizontal-type)	C500-CE405	

Mounting Rails and Accessories

Name	Specifications	Model number	Standards
DIN Track Mounting Bracket	1 set (2 included)	C200H-DIN01	
DIN Tracks	Length: 50 cm; height: 7.3 cm	PFP-50N	
	Length: 1 m; height: 7.3 cm	PFP-100N	
	Length: 1 m; height: 16 mm	PFP-100N2	
End Plate		PFP-M	
Spacer		PFP-S	

Note: Order DIN Tracks, End Plates, and Spacers in units of 10 each.

SYSMAC Support Software (SSS)

Name	Specifications	Model number	Stan- dards
SYSMAC Support Software (for C20, C□□P, C□□K, C120, C□□H, C200H, C200HE, C200HE, C200HG, C200HX, C500, C1000H, C2000H, CQM1, and CVM1)	3.5", 2HD for IBM PC/AT compatible Note: Version 1.0 doesn't support the additional functions of the C200HX/HG/HE.	C500-ZL3AT1-E	

Protocol Support Software

Name	Specifications	Model number	Stan- dards
Protocol Support Software	3.5", 2HD for IBM PC/AT compatible	C200HW-ZW3AT1-E	

Training Materials

Name	Specifications	Model number	Stan- dards
SYSMAC Training System	Includes text book, cassette tape, and input switch board.	C200H-ETL01-E	
Fuzzy Training System	Includes a Fuzzy Training System Manual, a Main Unit, a C200H-MR831 Memory Unit, a C200H-PRO27-E Programming Console, a C200H-CN222 Cable for the Programming Console, C500-SU981-E Fuzzy Training Software, an RS-232C Cable, and a carrying belt.	C200H-ETL13-E	

Appendix B Programming Instructions

A PC instruction is input either by pressing the corresponding Programming Console key(s) (e.g., LD, AND, OR, NOT) or by using function codes. To input an instruction with its function code, press FUN, the function code, and then WRITE. Refer to the pages listed programming and instruction details.

Code	Mnemonic	Name	Function	Page
_	AND	AND	Logically ANDs status of designated bit with execution condition.	149
_	AND LD	AND LOAD	Logically ANDs results of preceding blocks.	150
_	AND NOT	AND NOT	Logically ANDs inverse of designated bit with execution condition.	149
_	CNT	COUNTER	A decrementing counter.	166
_	LD	LOAD	Used to start instruction line with the status of the designated bit or to define a logic block for use with AND LD and OR LD.	149
_	LD NOT	LOAD NOT	Used to start instruction line with inverse of designated bit.	149
_	OR	OR	Logically ORs status of designated bit with execution condition.	149
	OR LD	OR LOAD	Logically ORs results of preceding blocks.	150
	OR NOT	OR NOT	Logically ORs inverse of designated bit with execution condition.	149
	OUT	OUTPUT	Turns ON operand bit for ON execution condition; turns OFF operand bit for OFF execution condition.	150
_	OUT NOT	OUTPUT NOT	Turns operand bit OFF for ON execution condition; turns operand bit ON for OFF execution condition (i.e., inverts operation).	150
_	RSET	RESET	Turns the operand bit OFF when the execution condition is ON, and does not affect the status of the operand bit when the execution condition is OFF.	153
_	SET	SET	Turns the operand bit ON when the execution condition is ON, and does not affect the status of the operand bit when the execution condition is OFF.	153
_	TIM	TIMER	ON-delay (decrementing) timer operation.	159
00	NOP	NO OPERATION	Nothing is executed and program moves to next instruction.	158
01	END	END	Required at the end of the program.	158
02	IL	INTERLOCK	If interlock condition is OFF, all outputs are turned OFF and all timer PVs reset between this IL(02) and the next	155
03	ILC	INTERLOCK CLEAR	ILC(03). Other instructions are treated as NOP; counter PVs are maintained.	155
04	JMP	JUMP	If jump condition is OFF, all instructions between JMP(04)	157
05	JME	JUMP END	and the corresponding JME(05) are ignored.	157
(@)06	FAL	FAILURE ALARM AND RESET	Generates a non-fatal error and outputs the designated FAL number to the Programming Console.	302
07	FALS	SEVERE FAILURE ALARM	Generates a fatal error and outputs the designated FALS number to the Programming Console.	302
08	STEP	STEP DEFINE	When used with a control bit, defines the start of a new step and resets the previous step. When used without N, defines the end of step execution.	293
09	SNXT	STEP START	Used with a control bit to indicate the end of the step, reset the step, and start the next step.	293
10	SFT	SHIFT REGISTER	Creates a bit shift register.	171
11	KEEP	KEEP	Defines a bit as a latch controlled by set and reset inputs.	154
12	CNTR	REVERSIBLE COUNTER	Increases or decreases PV by one whenever the increment input or decrement input signals, respectively, go from OFF to ON.	169

Code	Mnemonic	Name	Function	Page
13	DIFU	DIFFERENTIATE UP	Turns ON the designated bit for one cycle on the rising edge of the input signal.	151
14	DIFD	DIFFERENTIATE DOWN	Turns ON the bit for one cycle on the trailing edge.	151
15	TIMH	HIGH-SPEED TIMER	A high-speed, ON-delay (decrementing) timer.	164
(@)16	WSFT	WORD SHIFT	Shifts data between starting and ending words in word units, writing zeros into starting word.	178
17 to 19	For expansi	on instructions.		
20	CMP	COMPARE	Compares the contents of two words and outputs result to GR, EQ, and LE Flags.	193
(@)21	MOV	MOVE	Copies source data (word or constant) to destination word.	180
(@)22	MVN	MOVE NOT	Inverts source data (word or constant) and then copies it to destination word.	180
(@)23	BIN	BCD TO BINARY	Converts four-digit, BCD data in source word into 16-bit binary data, and outputs converted data to result word.	204
(@)24	BCD	BINARY TO BCD	Converts binary data in source word into BCD, and outputs converted data to result word.	205
(@)25	ASL	ARITHMETIC SHIFT LEFT	Shifts each bit in single word of data one bit to left, with CY.	175
(@)26	ASR	ARITHMETIC SHIFT RIGHT	Shifts each bit in single word of data one bit to right, with CY.	175
(@)27	ROL	ROTATE LEFT	Rotates bits in single word of data one bit to left, with CY.	176
(@)28	ROR	ROTATE RIGHT	Rotates bits in single word of data one bit to right, with CY.	176
(@)29	COM	COMPLEMENT	Inverts bit status of one word of data.	277
(@)30	ADD	BCD ADD	Adds two four-digit BCD values and content of CY, and outputs result to specified result word.	229
(@)31	SUB	BCD SUBTRACT	Subtracts a four-digit BCD value and CY from another four-digit BCD value and outputs result to the result word.	231
(@)32	MUL	BCD MULTIPLY	Multiplies two four-digit BCD values and outputs result to specified result words.	235
(@)33	DIV	BCD DIVIDE	Divides four-digit BCD dividend by four-digit BCD divisor and outputs result to specified result words.	236
(@)34	ANDW	LOGICAL AND	Logically ANDs two 16-bit input words and sets corresponding bit in result word if corresponding bits in input words are both ON.	278
(@)35	ORW	LOGICAL OR	Logically ORs two 16-bit input words and sets corresponding bit in result word if one or both of corresponding bits in input data are ON.	279
(@)36	XORW	EXCLUSIVE OR	Exclusively ORs two 16-bit input words and sets bit in result word when corresponding bits in input words differ in status.	280
(@)37	XNRW	EXCLUSIVE NOR	Exclusively NORs two 16-bit input words and sets bit in result word when corresponding bits in input words are same in status.	281
(@)38	INC	BCD INCREMENT	Increments four-digit BCD word by one.	228
(@)39	DEC	BCD DECREMENT	Decrements four-digit BCD word by one.	228
(@)40	STC	SET CARRY	Sets carry flag (i.e., turns CY ON).	229
(@)41	CLC	CLEAR CARRY	Clears carry flag (i.e., turns CY OFF).	229
45	TRSM	TRACE MEMORY SAMPLE	Initiates data tracing.	304
(@)46	MSG	MESSAGE	Displays a 16-character message on the Programming Console display.	305
47 & 48	For expansi	on instructions.		
(@)50	ADB	BINARY ADD	Adds two four-digit hexadecimal values and content of CY, and outputs result to specified result word.	243
(@)51	SBB	BINARY SUBTRACT	Subtracts a four-digit hexadecimal value and CY from another four-digit hexadecimal value and outputs result to the result word.	245

Code	Mnemonic	Name	Function	Page
(@)52	MLB	BINARY MULTIPLY	Multiplies two four-digit hexadecimal values and outputs result to specified result words.	248
(@)53	DVB	BINARY DIVIDE	Divides four-digit hexadecimal dividend by four-digit hexadecimal divisor and outputs result to specified result words.	248
(@)54	ADDL	DOUBLE BCD ADD	Adds two eight-digit values (2 words each) and content of CY, and outputs result to specified result words.	230
(@)55	SUBL	DOUBLE BCD SUBTRACT	Subtracts an eight-digit BCD value and CY from another eight-digit BCD value and outputs result to the result words.	233
(@)56	MULL	DOUBLE BCD MULTIPLY	Multiplies two eight-digit BCD values and outputs result to specified result words.	236
(@)57	DIVL	DOUBLE BCD DIVIDE	Divides eight-digit BCD dividend by eight-digit BCD divisor and outputs result to specified result words.	237
(@)58	BINL	DOUBLE BCD TO DOUBLE BINARY	Converts BCD value in two consecutive source words into binary and outputs converted data to two consecutive result words.	205
(@)59	BCDL	DOUBLE BINARY TO DOUBLE BCD	Converts binary value in two consecutive source words into BCD and outputs converted data to two consecutive result words.	206
60 to 69	For expansion	on instructions.		
(@)70	XFER	BLOCK TRANSFER	Moves content of several consecutive source words to consecutive destination words.	182
(@)71	BSET	BLOCK SET	Copies content of one word or constant to several consecutive words.	181
(@)72	ROOT	SQUARE ROOT	Computes square root of eight-digit BCD value and outputs truncated four-digit integer result to specified result word.	241
(@)73	XCHG	DATA EXCHANGE	Exchanges contents of two different words.	183
(@)74	SLD	ONE DIGIT SHIFT LEFT	Left shifts data between starting and ending words by one digit (four bits).	177
(@)75	SRD	ONE DIGIT SHIFT RIGHT	Right shifts data between starting and ending words by one digit (four bits).	177
(@)76	MLPX	4-TO-16/8-TO-256 DECODER	Converts up to four hexadecimal digits in source word into decimal values from 0 to 15 and turns ON, in result word(s), bit(s) whose position corresponds to converted value. Can also convert up to eight hexadecimal digits and turn ON corresponding bits in result words R to R+15.	209
(@)77	DMPX	16-TO-4/256-TO-8 ENCODER	Determines position of highest ON bit in source word(s) and writes the ON bit's position (0 to F) to digit(s) in R. Can also determine the position of the highest ON bit in one or two groups of 16 words (S to S+15, S+16 to S+31) and writes the ON bit's position (00 to FF) to byte(s) in R.	212
(@)78	SDEC	7-SEGMENT DECODER	Converts hexadecimal values from source word to data for seven-segment display.	215
(@)79	FDIV	FLOATING POINT DIVIDE	Divides one floating point value (Dd+1, Dd) by another (Dr+1, Dr) and outputs the result to R+1 and R.	238
(@)80	DIST	SINGLE WORD DISTRIBUTE	Moves one word of source data to destination word whose address is given by destination base word plus offset.	183
(@)81	COLL	DATA COLLECT	Extracts data from source word and writes it to destination word.	185
(@)82	MOVB	MOVE BIT	Transfers designated bit of source word or constant to designated bit of destination word.	187
(@)83	MOVD	MOVE DIGIT	Moves hexadecimal content of specified four-bit source digit(s) to specified destination digit(s) for up to four digits.	188
(@)84	SFTR	REVERSIBLE SHIFT REGISTER	Shifts data in specified word or series of words to either left or right.	173
(@)85	TCMP	TABLE COMPARE	Compares four-digit hexadecimal value with values in table consisting of 16 words.	199

Code	Mnemonic	Name	Function	Page		
(@)86	ASC	ASCII CONVERT	Converts hexadecimal values from the source word to eight-bit ASCII code starting at leftmost or rightmost half of starting destination word.	218		
87 to 89	For expansion instructions.					
(@)90	SEND	NETWORK SEND	Used for communications with other PCs linked through the SYSMAC NET Link System or SYSMAC LINK System.	320		
(@)91	SBS	SUBROUTINE ENTRY	Calls and executes subroutine N.	285		
92	SBN	SUBROUTINE DEFINE	Marks start of subroutine N.	286		
93	RET	RETURN	Marks the end of a subroutine and returns control to main program.	286		
(@)94	WDT	WATCHDOG TIMER REFRESH	Increases the watchdog timer PV by 0 to 6300 ms.	308		
(@)97	IORF	I/O REFRESH	Refreshes all I/O words between the start and end words.	308		
(@)98	RECV	NETWORK RECEIVE	Used for communications with other PCs linked through the SYSMAC NET Link System or SYSMAC LINK System.	325		
(@)99	MCRO	MACRO	Calls and executes a subroutine replacing I/O words.	287		

Expansion Instructions

The following table shows the instructions that can be treated as expansion instructions. The default function codes are given for instructions that have codes assigned by default.

Code	Mnemonic	Name	Function	Page
17	(@)ASFT	ASYNCHRONOUS SHIFT REGISTER	Creates a shift register that exchanges the contents of adjacent words when one of the words is zero and the other is not.	178
18	(@)SCAN	CYCLE TIME	Sets the minimum cycle time (0 to 999.0 s).	303
19	(@)MCMP	MULTI-WORD COMPARE	Compares a block of 16 consecutive words to another block of 16 consecutive words.	192
47	(@)LMSG	32-CHARACTER MESSAGE	Outputs a 32-character message to the Programming Console.	306
48	(@)TERM	TERMINAL MODE	Switches the Programming Console to TERMINAL mode for the normal keyboard mapping operation.	307
60	CMPL	DOUBLE COMPARE	Compares two eight-digit hexadecimal values.	196
61	(@)MPRF	GROUP-2 HIGH-DENSITY I/O REFRESH	Refreshes I/O words allocated to Group-2 High-density I/O Units.	309
62	(@)XFRB	TRANSFER BITS	Copies the status of up to 255 specified source bits to the specified destination bits.	189
63	(@)LINE	COLUMN TO LINE	Copies a bit column from 16 consecutive words to the specified word.	224
64	(@)COLM	LINE TO COLUMN	Copies the 16 bits from the specified word to a bit column of 16 consecutive words.	225
65	(@)SEC	HOURS TO SECONDS	Converts hour and minute data to second data.	207
66	(@)HMS	SECONDS TO HOURS	Converts second data to hour and minute data.	208
67	(@)BCNT	BIT COUNTER	Counts the total number of bits that are ON in the specified block of words.	310
68	(@)BCMP	BLOCK COMPARE	Judges whether the value of a word is within 16 ranges (defined by lower and upper limits).	197
69	(@)APR	ARITHMETIC PROCESS	Performs sine, cosine, or linear approximation calculations.	263
87	TTIM	TOTALIZING TIMER	Creates a totalizing timer.	165
88	ZCP	AREA RANGE COMPARE	Compares a word to a range defined by lower and upper limits and outputs the result to the GR, EQ, and LE flags.	200
89	(@)INT	INTERRUPT CONTROL	Performs interrupt control, such as masking and unmasking the interrupt bits for I/O interrupts.	289

Code	Mnemonic	Name	Function	Page
	7SEG	7-SEGMENT DISPLAY OUTPUT	Converts 4- or 8-digit BCD data to 7-segment display format and then outputs the converted data.	338
	(@)ADBL	DOUBLE BINARY ADD	Adds two 8-digit binary values (normal or signed data) and outputs the result to R and R+1.	249
	AVG	AVERAGE VALUE	Adds the specified number of hexadecimal words and computes the mean value. Rounds off to 4 digits past the decimal point.	259
	(@)BXF2	EM BANK TRANSFER	Moves content of several consecutive source words to consecutive destination words. Words in the current EM bank can be specified for the source or destination.	191
	CMCR	PCMCIA CARD MACRO	Performs macros to write files, read files, compare files to memory, search files, and other operations for PCMCIA Card Interface Units.	355
	CPS	SIGNED BINARY COMPARE	Compares two 16-bit (4-digit) signed binary values and outputs the result to the GR, EQ, and LE flags.	202
	CPSL	DOUBLE SIGNED BINARY COMPARE	Compares two 32-bit (8-digit) signed binary values and outputs the result to the GR, EQ, and LE flags.	203
	(@)DBS	SIGNED BINARY DIVIDE	Divides one 16-bit signed binary value by another and outputs the 32-bit signed binary result to R+1 and R.	255
	(@)DBSL	DOUBLE SIGNED BINARY DIVIDE	Divides one 32-bit signed binary value by another and outputs the 64-bit signed binary result to R+3 to R.	256
	DSW	DIGITAL SWITCH INPUT	Inputs 4- or 8-digit BCD data from a digital switch.	341
	(@)EMBC	SELECT EM BANK	Changes the current EM bank to the specified bank number.	319
	(@)FCS	FCS CALCULATE	Checks for errors in data transmitted by a Host Link command.	310
	FPD	FAILURE POINT DETECT	Finds errors within an instruction block.	312
	(@)HEX	ASCII-TO-HEXADECIMAL	Converts ASCII data to hexadecimal data.	219
	(@)IEMS	INDIRECT EM ADDRESSING	Changes the destination of indirect DM addressing (*DM) to DM or the specified EM bank. This instruction can be used to change the current EM bank.	318
	(@)IORD	SPECIAL I/O UNIT READ	Transfers data from the specified Special I/O Unit's memory to words in the PC.	352
	(@)IOWR	SPECIAL I/O UNIT WRITE	Transfers data from words in the PC to the specified Special I/O Unit's memory.	353
	(@)MAX	FIND MAXIMUM	Finds the maximum value in specified data area and outputs that value to another word.	257
	(@)MBS	SIGNED BINARY MULTIPLY	Multiplies the signed binary content of two words and outputs the 8-digit signed binary result to R+1 and R.	253
	(@)MBSL	DOUBLE SIGNED BINARY MULTIPLY	Multiplies two 32-bit (8-digit) signed binary values and outputs the 16-digit signed binary result to R+3 through R.	254
	(@)MIN	FIND MINIMUM	Finds the minimum value in specified data area and outputs that value to another word.	258
	MTR	MATRIX INPUT	Inputs data from an 8 input point \times 8 output point matrix and records that data in D to D+3.	350
	(@)NEG	2'S COMPLEMENT	Converts the four-digit hexadecimal content of the source word to its 2's complement and outputs the result to R.	226
	(@)NEGL	DOUBLE 2'S COMPLEMENT	Converts the eight-digit hexadecimal content of the source words to its 2's complement and outputs the result to R and R+1.	227
	(@)PID	PID CONTROL	PID control is performed according to the operand and PID parameters that are preset. (The only CQM1 model that can use PID(—) is the CPU4□.)	266
	(@)PMCR	PROTOCOL MACRO	Calls and executes the specified communications sequence (protocol) that has been registered in the Communications Board.	337

Code	Mnemonic	Name	Function	Page
	(@)RXD	RECEIVE	Receives data via a communications port.	331
	(@)SBBL	DOUBLE BINARY SUBTRACT	Subtracts an 8-digit binary value (normal or signed data) from another and outputs the result to R and R+1.	251
	(@)SCL	SCALING	Performs a scaling conversion on the calculated value.	222
	(@)SRCH	DATA SEARCH	Searches the specified range of memory for the specified data. Outputs the word address(es) of words in the range that contain the data.	316
	(@)STUP	CHANGE RS-232C SETUP	Changes the PC Setup settings for the specified port.	335
	(@)SUM	SUM CALCULATE	Computes the sum of the contents of the words in the specified range of memory.	261
	(@)TKY	TEN KEY INPUT	Inputs 8 digits of BCD data from a 10-key keypad.	348
	(@)TXD	TRANSMIT	Sends data via a communications port.	333
	(@)XDMR	EXPANSION DM READ	The contents of the designated number of words of the fixed expansion DM data are read and output to the destination word on the PC side.	317
	(@)XFR2	EM BLOCK TRANSFER	Moves content of several consecutive source words to consecutive destination words. Words in the any valid EM bank can be specified for the source or destination. This instruction can be used to change the current bank.	190
	ZCPL	DOUBLE AREA RANGE COMPARE	Compares an 8-digit value to a range defined by lower and upper limits and outputs the result to the GR, EQ, and LE flags.	201

Appendix C Error and Arithmetic Flag Operation

The following table shows the instructions that affect the N, OF, UF, ER, CY, GR, LE and EQ flags.

In general, N indicates a negative result, OF indicates that the result of a 16-bit calculation is greater than 32,767 (7FFF) or the result of a 32-bit calculation is greater than 2,147,483,647 (7FFF FFFF). UF indicates that the result of a 16-bit calculation is less than –32,768 (8000) or the result of a 32-bit calculation is less than –2,147,483,648 (8000 0000). Refer to Section 5 Instruction Set for details.

ER indicates that operand data is not within requirements. CY indicates arithmetic or data shift results. GR indicates that a compared value is larger than some standard, LT that it is smaller, and EQ, that it is the same. EQ also indicates a result of zero for arithmetic operations. Refer to Section 5 Instruction Set for details.

Vertical arrows in the table indicate the flags that are turned ON and OFF according to the result of the instruction. Although ladder diagram instructions, TIM, and CNT are executed when ER is ON, other instructions with a vertical arrow under the ER column are not executed if ER is ON. All of the other flags in the following table will also not operate when ER is ON.

Instructions not shown do not affect any of the flags in the table. Although only the non-differentiated form of each instruction is shown, differentiated instructions affect flags in exactly the same way.

All 8 flags are turned OFF when END(01) is executed, so their status cannot be monitored with a Programming Console.

Mnemonic	25503 (ER)	25504 (CY)	25505 (GR)	25506 (EQ)	25507 (LE)	25404 (OF)	25405 (UF)	25402 (N)	Page
TIM	\$								159
CNT	\$								166
END (01)	OFF	OFF	158						
SFT(10)	OFF								171
CNTR(12)	\$								169
TIMH(15)	\$								164
WSFT(16)	\$								178
CMP(20)	\$		\$	\$	\$				193
MOV(21)	\$			\$				\$	180
MVN(22)	\$			\$				\$	180
BIN(23)	\$			\$				OFF	204
BCD(24)	\$			\$					205
ASL(25)	\$	\$		\$				\$	175
ASR(26)	\$	\$		\$				OFF	175
ROL(27)	\$	\$		\$				\$	176
ROR(28)	\$	\$		\$				\$	176
COM(29)	\$			\$				\$	277
ADD(30)	\$	\$		\$					229
SUB(31)	\$	\$		\$					231
MUL(32)	\$			\$					235
DIV(33)	\$			\$					236
ANDW(34)	\$			\$				\$	278
ORW(35)	\$			\$				\$	279
XORW(36)	\$			\$				\$	280
XNRW(37)	\$			\$				\$	281
INC(38)	\$			\$					228
DEC(39)	\$			\$					228
STC(40)		ON							229

Mnemonic	25503 (ER)	25504 (CY)	25505 (GR)	25506 (EQ)	25507 (LE)	25404 (OF)	25405 (UF)	25402 (N)	Page
CLC(41)									229
MSG(46)	\$								305
ADB(50)	\$	\$		\$		\$	\$	\$	243
SBB(51)	\$	\$		\$		\$	\$	\$	245
MLB(52)	\$			\$				\$	248
DVB(53)	\$			\$				\$	248
ADDL(54)	\$	\$		\$					230
SUBL(55)	\$	\$		\$					233
MULL(56)	\$			\$					236
DIVL(57)	\$			\$					237
BINL(58)	\$			\$				OFF	205
BCDL(59)	\$			\$					206
XFER(70)	\$								182
BSET(71)	\$								181
ROOT(72)	\$			\$					241
XCHG(73)	\$								183
SLD(74)	\$								177
SRD(75)	\$								177
MLPX(76)	\$								209
DMPX(77)	\$								212
SDEC(78)	\$								215
FDIV(79)	\$				\$				238
DIST(80)	\$				\$			\$	183
COLL(81)	\$				\$			\$	185
MOVB(82)	\$								187
MOVD(83)	\$								188
SFTR(84)	\$	\$							173
TCMP(85)	\$			\$					199
ASC(86)	\$								218
SEND(90)	\$								320
SBS(91)	\$								285
SBN(92)	\$	\$	\$	\$	\$	\$	\$	\$	286
WDT(94)	\$								308
IORF(97)	\$								308
RECV(98)	\$								325
MCRO(99)	\$								287

Expansion Instructions

The default function codes are shown for the instructions that have default function codes.

Mnemonic	25503 (ER)	25504 (CY)	25505 (GR)	25506 (EQ)	25507 (LE)	25404 (OF)	25405 (UF)	25402 (N)	Page
7SEG()	\$								338
ADBL(—)	\$	\$		\$		\$	\$	\$	249
APR(69)	\$			\$				\$	263
ASFT(17)	\$								178
AVG(—)	\$								259
BCMP(68)	\$								197
BCNT(67)	\$			\$					310

Mnemonic	25503 (ER)	25504 (CY)	25505 (GR)	25506 (EQ)	25507 (LE)	25404 (OF)	25405 (UF)	25402 (N)	Page
BXF2()	\$								191
CMCR(—)	\$								355
CMPL(60)	\$		\$	\$	\$				196
COLM(64)	\$			\$					225
CPS(—)	\$		\$	\$	\$				202
CPSL(—)	\$		\$	\$	\$				203
DBS()	\$			\$				\$	255
DBSL(—)	\$			\$				\$	256
DSW()	\$								341
EMBC(—)	\$								319
FCS()	\$								310
FPD(—)	\$	\$							312
HEX(—)	\$								219
HKY(—)	\$								345
HMS(66)	\$			\$					208
IEMS(—)	\$								318
INT(89)	\$								289
IORD(—)	\$			\$					352
IOWR(—)	\$			\$					353
LINE(63)	\$			\$					224
LMSG(47)	\$								306
MAX(—)	\$			\$				\$	257
MBS(—)	\$			\$				\$	253
MBSL()	\$			\$				\$	254
MCMP(19)	\$			\$					192
MIN(—)	\$			\$				\$	258
MPRF(61)	\$								309
MTR(—)	\$								350
NEG(—)	\$			\$			\$	\$	226
NEGL(—)	\$			\$			\$	\$	227
PID(—)	\$	\$							266
PMCR(—)	\$								337
RXD(—)	\$								331
SBBL(—)	\$	\$		\$		\$	\$	\$	251
SCAN(18)	\$								303
SCL(—)	\$			\$					222
SEC(65)	\$			\$					207
SRCH(—)	\$			\$					316
STUP(—)	\$								335
SUM(—)	\$			\$				\$	261
TERM(48)	\$								307
TKY(—)	\$								348
TTIM(87)	\$								165
TXD(—)	\$								333
XDMR(—)	\$								317
XFR2(—)	*								190
XFRB(62)	\$								189
ZCP(88)	*		\$	\$	\$				200

Error and Arithmetic Flag Operation

Appendix C

Mnemonic	25503 (ER)	25504 (CY)	25505 (GR)	25506 (EQ)	25507 (LE)	25404 (OF)	25405 (UF)	25402 (N)	Page
ZCPL()	\$		\$	\$	\$				201

Appendix D Word Assignment Recording Sheets

This appendix contains sheets that can be copied by the programmer to record I/O bit allocations and terminal assignments, as well as details of work bits, data storage areas, timers, and counters.

I/O Bits

Programmer: Program:

Word:	Unit	
Bit	Field device	Notes
00		
01		
02		
03		
04		
05		
06		
07		
80		
09		
10		
11		
12		
13		
14		
15		

Word:	Unit	:
Bit	Field device	Notes
00		
01		
02		
03		
04		
05		
06		
07		
80		
09		
10		
11		
12		
13		
14		
15		

Date:

Word:	Unit:	Unit:		
Bit	Field device	Notes		
00				
01				
02				
03				
04				
05				
06				
07				
80				
09				
10				
11				
12				
13				
14				
15				

Page:

Word:	Unit:	Unit:		
Bit	Field device	Notes		
00				
01				
02				
03				
04				
05				
06				
07				
08				
09				
10				
11				
12				
13				
14				
15				

Work Bits

Programmer: Program:

Area:	Word:		
Bit	Usage	Notes	
00			
01			
02			
03			
04			
05			
06			
07			
80			
09			
10			
11			
12			
13			
14			
15			

Area:	Word:		
Bit	Usage	Notes	
00			
01			
02			
03			
04			
05			
06			
07			
80			
09			
10			
11			
12			
13			
14			
15			

Date:

Page:

Area:	Word:		
Bit	Usage	Notes	
00			
01			
02			
03			
04			
05			
06			
07			
08			
09			
10			
11			
12			
13			
14			
15			

Area:	Word	d:
Bit	Usage	Notes
00		
01		
02		
03		
04		
05		
06		
07		
08		
09		
10		
11		
12		
13		
14		
15		

Data Storage

Programmer:		Program:	Date	Date:		
Word	Contents	Notes	Word	Contents	Notes	
			 			
			1			
			<u> </u>			
			1			
			1			
			<u> </u>			
			<u> </u>			
			<u> </u>			
			<u> </u>			
			<u> </u>			
						
			1			
			1			
			1			

Timers and Counters

		Program:	ogram: Date:			Page:	
TC address	T or C	Set value	Notes	TC address	T or C	Set value	Notes
				 			
				 			
				<u> </u>			
				-			
				 			
	İ						
				 			

Appendix E Program Coding Sheet

The following page can be copied for use in coding ladder diagram programs. It is designed for flexibility, allowing the user to input all required addresses and instructions.

When coding programs, be sure to specify all function codes for instructions and data areas (or # for constant) for operands. These will be necessary when inputting programs though a Programming Console or other Peripheral Device.

Program Coding Sheet

Program: Programmer: Date: Page: Address Address Operand(s) Instruction Operand(s) Instruction Address Instruction Operand(s)

Appendix F Data Conversion Tables

Normal Data

Decimal	BCD	Hex	Binary	
00	00000000	00	00000000	
01	0000001	01	0000001	
02	00000010	02	00000010	
03	00000011	03	00000011	
04	00000100	04	00000100	
05	00000101	05	00000101	
06	00000110	06	00000110	
07	00000111	07	00000111	
08	00001000	08	00001000	
09	00001001	09	00001001	
10	00010000	0A	00001010	
11	00010001	0B	00001011	
12	00010010	0C	00001100	
13	00010011	0D	00001101	
14	00010100	0E	00001110	
15	00010101	0F	00001111	
16	00010110	10	00010000	
17	00010111	11	00010001	
18	00011000	12	00010010	
19	00011001	13	00010011	
20	00100000	14	00010100	
21	00100001	15	00010101	
22	00100010	16	00010110	
23	00100011	17	00010111	
24	00100100	18	00011000	
25	00100101	19	00011001	
26	00100110	1A	00011010	
27	00100111	1B	00011011	
28	00101000	1C	00011100	
29	00101001	1D	00011101	
30	00110000	1E	00011110	
31	00110001	1F	00011111	
32	00110010	20	00100000	

Signed Binary Data

Decimal	16-bit Hex	32-bit Hex
2147483647		7FFFFFF
2147483646		7FFFFFE
	•	
·	•	•
32768		0008000
32767	7FFF	00007FFF
32766	7FFE	00007FFE
·	•	•
5	0005	00000005
4	0004	00000004
3 2	0003 0002	00000003 00000002
1	0002	00000002
0	0000	00000000
-1	FFFF	FFFFFFF
-1 -2 -3 -4	FFFE	FFFFFFE
-3	FFFD	FFFFFFD
_4 _5	FFFC FFFB	FFFFFFFC FFFFFFFB
12	ГГГБ	ГГГГГГГ
-32767 -32768	8001 8000	FFFF8001 FFFF8000
-32769		FFFF7FFF
-2147483647		80000001
-2147483648		80000000

Appendix G Extended ASCII

Programming Console Displays

Bits	0 to 3	Bits 4 to 7													
BIN		0000	0001	0010	0011	0100	0101	0110	0111	1010	1011	1100	1101	1110	1111
	HEX	0	1	2	3	4	5	6	7	Α	В	С	D	Е	F
0000	0	NUL	DLE	Space	Ø	a	P	٠.	F		Ø	ā	P	٠.	F
0001	1	SOH	DC ₁	!	1	Ħ	Q	a	9	!	1	A	Q	ā	4
0010	2	STX	DC_2	11	2	В	R	Ь	r	H	2	В	R	b	r
0011	3	ETX	DC_3	#	3	C	5	c	≘.	#	3	C	5	c.	5.
0100	4	EOT	DC ₄	\$	4	D	T	d	t.	\$	4	D	T	d	t.
0101	5	ENQ	NAK	7.	5	E	U	0	u	%	5	Ξ	U	=	u
0110	6	ACK	SYN	&	6	F	Ų	f	V	&	6	F	V	f	Ų
0111	7	BEL	ETB	7	7	G	W	g	W	7	7	G	W	9	W
1000	8	BS	CAN	(8	Н	X	h	X	(8	Н	Х	h	×
1001	9	HT	EM)	9	I	Y	i	Ä)	9	I	Y	i	Ή
1010	Α	LF	SUB	*	:	J	Z	j	Z	*	:	J	Z	j	Z
1011	В	VT	ESC	+	;	K	Ľ	k	{	+	;	K	Ľ	k	<
1100	С	FF	FS	,	<	<u></u>	¥	1	I	7	<	<u>L</u>	#	1	ı
1101	D	CR	GS		****	M]	m	>		****	М]	m	>
1110	E	S0	RS		>	N	^	n	÷		>	N	^	n	
1111	F	S1	US	/	?	0		o	÷	/	?	0		O	÷

address The location in memory where data is stored. For data areas, an address con-

sists of a two-letter data area designation and a number that designates the word and/or bit location. For the UM area, an address designates the instruction location (UM area). In the FM area, the address designates the block location,

etc.

allocation The process by which the PC assigns certain bits or words in memory for various

functions. This includes pairing I/O bits to I/O points on Units.

AND A logic operation whereby the result is true if and only if both premises are true.

In ladder-diagram programming the premises are usually ON/OFF states of bits

or the logical combination of such states called execution conditions.

APF Acronym for all plastic fiber-optic cable.

AR area A PC data area allocated to flags, control bits, and work bits.

arithmetic shift A shift operation wherein the carry flag is included in the shift.

ASCII Short for American Standard Code for Information Interchange. ASCII is used to

code characters for output to printers and other external devices.

ASCII Unit An Intelligent I/O Unit used to program in BASIC. When connected to an NSU on

a Net Link System, commands can be sent to other nodes.

Backplane A base onto which Units are mounted to form a Rack. Backplanes provide a se-

ries of connectors for these Units along with wiring to connect them to the CPU Unit. Backplanes also provide connectors used to connect them to other Backplanes. In some Systems, different Backplanes are used for different Racks; in other Systems, Racks differ only according to the Units mounted to them.

BCD Short for binary-coded decimal.

BCD calculation An arithmetic calculation that uses numbers expressed in binary-coded deci-

mal.

binary A number system where all numbers are expressed to the base 2, i.e., any num-

ber can be written using only 1's or 2's. Each group of four binary bits is equiva-

lent to one hexadecimal digit.

binary calculation An arithmetic calculation that uses numbers expressed in binary.

binary-coded decimal A system used to represent numbers so that each group of four binary bits is

numerically equivalent to one decimal digit.

bit A binary digit; hence a unit of data in binary notation. The smallest unit of in-

formation that can be electronically stored in a PC. The status of a bit is either ON or OFF. Different bits at particular addresses are allocated to special purposes, such as holding the status input from external devices, while other bits are avail-

able for general use in programming.

bit address The location in memory where a bit of data is stored. A bit address must specify

(sometimes by default) the data area and word that is being addressed, as well

as the number of the bit.

bit designator An operand that is used to designate the bit or bits of a word to be used by an

instruction.

bit number A number that indicates the location of a bit within a word. Bit 00 is the rightmost

(least-significant) bit; bit 15 is the leftmost (most-significant) bit.

building-block PC A PC that is constructed from individual components, or "building blocks." With

building-block PCs, there is no one Unit that is independently identifiable as a

PC. The PC is rather a functional assembly of components.

bus bar The line leading down the left and sometimes right side of a ladder diagram.

Instruction execution proceeds down the bus bar, which is the starting point for

all instruction lines.

call A process by which instruction execution shifts from the main program to a sub-

routine. The subroutine may be called by an instruction or by an interrupt.

carry flag A flag that is used with arithmetic operations to hold a carry from an addition or

multiplication operation, or to indicate that the result is negative in a subtraction operation. The carry flag is also used with certain types of shift operations.

clock pulseA pulse available at a certain bit in memory for use in timing operations. Various

clock pulses are available with different pulse widths.

clock pulse bit A bit in memory that supplies a pulse that can be used to time operations. Vari-

ous clock pulse bits are available with different pulse widths, and therefore differ-

ent frequencies.

common data Data that is stored in the LR Area of a PC and which is shared by other PCs in the

same system. Each PC has a specified section of the LR Area allocated to it.

This allocation is the same in each LR Area of each PC.

Communications Board A board that is mounted to the optional slot of a C200HX/HG/HE CPU Unit. With

a Communications Board, the CPU Unit can communicate with the SYSMAC LINK Unit, SYSMAC NET Link Unit, Programmable Terminal, Temperature Controller, personal computer, bar code reader, or any other peripheral device via

RS-232C, RS-422, or RS-485.

condition An message placed in an instruction line to direct the way in which the terminal

instructions, on the right side, are to be executed. Each condition is assigned to a bit in memory that determines its status. The status of the bit assigned to each condition determines, in turn, the execution condition for each instruction up to a

terminal instruction on the right side of the ladder diagram.

constant An operand for which the actual numeric value is specified by the user, and

which is then stored in a particular address in the data memory.

control bit A bit in a memory area that is set either through the program or via a Program-

ming Device to achieve a specific purpose, e.g., a Restart bit is turned ON and

OFF to restart a Unit.

Control System All of the hardware and software components used to control other devices. A

Control System includes the PC System, the PC programs, and all I/O devices

that are used to control or obtain feedback from the controlled system.

controlled system The devices that are being controlled by a PC System.

control signal A signal sent from the PC to effect the operation of the controlled system.

counter A dedicated group of digits or words in memory used to count the number of

times a specific process has occurred, or a location in memory accessed through a TC bit and used to count the number of times the status of a bit or an

execution condition has changed from OFF to ON.

CPU An acronym for central processing unit. In a PC System, the CPU executes the

program, processes I/O signals, communicates with external devices, etc.

CPU Backplane A Backplane which is used to create a CPU Rack.

CPU Rack Part of a building-block PC, the CPU Rack contains the CPU Unit, a power sup-

ply, and other Units. With most PCs, the CPU Rack is the only Rack that provides

linkable slots.

CTS An acronym for clear-to-send, a signal used in communications between elec-

tronic devices to indicate that the receiver is ready to accept incoming data.

cycle The process used to execute a ladder-diagram program. The program is ex-

amined sequentially from start to finish and each instruction is executed in turn

based on execution conditions.

cycle time The time required for a single cycle of the ladder-diagram program.

data area An area in the PC's memory that is designed to hold a specific type of data, e.g.,

the LR area is designed to hold common data in a PC Link System. Memory

areas that hold programs are not considered data areas.

data area boundary

The highest address available within a data area. When designating an operand

that requires multiple words, it is necessary to ensure that the highest address in

the data area is not exceeded.

data sharing An aspect of PC Link Systems and of Data Links in Net Link Systems in which

common data areas or common data words are created between two or more

PCs.

debug A process by which a draft program is corrected until it operates as intended.

Debugging includes both the removal of syntax errors, as well as the fine-tuning

of timing and coordination of control operations.

decimal A number system where all numbers are expressed to the base 10. In a PC all

data is ultimately stored in binary form, four binary bits are often used to repre-

sent one decimal digit, via a system called binary-coded decimal.

decrement Decreasing a numeric value.

default A value automatically set by the PC when the user omits to set a specific value.

Many devices will assume such default conditions upon the application of power.

definer A number used as an operand for an instruction but that serves to define the

instruction itself, rather that the data on which the instruction is to operate. Defin-

ers include jump numbers, subroutine numbers, etc.

delay In tracing, a value that specifies where tracing is to begin in relationship to the

trigger. A delay can be either positive or negative, i.e., can designate an offset on

either side of the trigger.

destination The location where an instruction is to place the data on which it is operating, as

opposed to the location from which data is taken for use in the instruction. The

location from which data is taken is called the source.

differentiated instruction An instruction that is executed only once each time its execution condition goes

from OFF to ON. Non-differentiated instructions are executed each cycle as long

as the execution condition stays ON.

differentiation instruction An instruction used to ensure that the operand bit is never turned ON for more

than one cycle after the execution condition goes either from OFF to ON for a Differentiate Up instruction or from ON to OFF for a Differentiate Down instruc-

tion.

digit A unit of storage in memory that consists of four bits.

digit designator An operand that is used to designate the digit or digits of a word to be used by an

instruction.

distributed control

An automation concept in which control of each portion of an automated system

is located near the devices actually being controlled, i.e., control is decentralized and 'distributed' over the system. Distributed control is one of the fundamental

concepts of PC Systems.

DM area A data area used to hold only word data. Words in the DM area cannot be ac-

cessed bit by bit.

downloadThe process of transferring a program or data from a higher-level computer to a

lower-level computer or PC.

electrical noiseRandom variations of one or more electrical characteristics such as voltage, cur-

rent, and data, which might interfere with the normal operation of a device.

EM area Extended data memory area. Like DM, the EM memory can be accessed in word

units only and EM area data is retained when the power to the PC is turned off.

error code A numeric code generated to indicate that an error exists, and something about

the nature of the error. Some error codes are generated by the system; others

are defined in the program by the operator.

exclusive ORA logic operation whereby the result is true if one, and only one, of the premises

is true. In ladder-diagram programming the premises are usually the ON/OFF states of bits, or the logical combination of such states, called execution condi-

tions.

exclusive NOR A logic operation whereby the result is true if both of the premises are true or both

of the premises are false. In ladder-diagram programming the premises are usually the ON/OFF states of bits, or the logical combination of such states, called

execution conditions.

execution condition The ON or OFF status under which an instruction is executed. The execution

condition is determined by the logical combination of conditions on the same

instruction line and up to the instruction currently being executed.

execution timeThe time required for the CPU Unit to execute either an individual instruction or

an entire program.

Expansion I/O Backplane A Backplane which is used to create an Expansion I/O Rack.

Expansion I/O Rack Part of a building-block PC, an Expansion I/O Rack is connected to either a CPU

Rack or another Expansion I/O Rack to increase the number of slots available

for mounting Units.

extended counter A counter created in a program by using two or more count instructions in suc-

cession. Such a counter is capable of counting higher than any of the standard

counters provided by the individual instructions.

extended timer A timer created in a program by using two or more timers in succession. Such a

timer is capable of timing longer than any of the standard timers provided by the

individual instructions.

Factory Intelligent Terminal A programming device provided with advanced programming and debugging

capabilities to facilitate PC operation. The Factory Intelligent Terminal also provides various interfaces for external devices, such as floppy disk drives.

An error that stops PC operation and requires correction before operation can

continue.

fatal error

FIT Abbreviation for Factory Intelligent Terminal.

flag A dedicated bit in memory that is set by the system to indicate some type of oper-

ating status. Some flags, such as the carry flag, can also be set by the operator

or via the program.

flicker bit A bit that is programmed to turn ON and OFF at a specific frequency.

floating point decimal A decimal number expressed as a number between 0 and 1 (the mantissa) multi-

plied by a power of 10, e.g., 0.538×10^{-5} .

Floppy Disk Interface Unit A Unit used to interface a floppy disk drive to a PC so that programs and/or data

can be stored on floppy disks.

force reset The process of forcibly turning OFF a bit via a programming device. Bits are usu-

ally turned OFF as a result of program execution.

force set The process of forcibly turning ON a bit via a programming device. Bits are usu-

ally turned ON as a result of program execution.

function code A two-digit number used to input an instruction into the PC.

hardware error An error originating in the hardware structure (electronic components) of the PC,

as opposed to a software error, which originates in software (i.e., programs).

hexadecimal A number system where all numbers are expressed to the base 16. In a PC all

data is ultimately stored in binary form, however, displays and inputs on Programming Devices are often expressed in hexadecimal to simplify operation. Each group of four binary bits is numerically equivalent to one hexadecimal digit.

Host Link System A system with one or more host computers connected to one or more PCs via

Host Link Units so that the host computer can be used to transfer data to and from the PC(s). Host Link Systems enable centralized management and control

of PC Systems.

Host Link Unit An interface used to connect a PC to a host computer in a Host Link System.

host computer A computer that is used to transfer data or programs to from a PC in a Host Link

System. The host computer is used for data management and overall system

control. Host computers are generally personal or business computers.

HR area A data area used to store and manipulate data, and to preserve data when pow-

er to the PC is turned OFF.

increment Increasing a numeric value.

indirect address An address whose contents indicates another address. The contents of the se-

cond address will be used as the operand. Indirect addressing is possible in the

DM area only.

initialization error An error that occurs either in hardware or software during the PC System start-

up, i.e., during initialization.

initialize Part of the startup process whereby some memory areas are cleared, system

setup is checked, and default values are set.

input The signal coming from an external device into the PC. The term input is often

used abstractly or collectively to refer to incoming signals.

input bit A bit in the IR area that is allocated to hold the status of an input.

input device An external device that sends signals into the PC System.

input point The point at which an input enters the PC System. Input points correspond

physically to terminals or connector pins.

input signal A change in the status of a connection entering the PC. Generally an input signal

is said to exist when, for example, a connection point goes from low to high volt-

age or from a nonconductive to a conductive state.

instruction A direction given in the program that tells the PC of an action to be carried out,

and which data is to be used in carrying out the action. Instructions can be used to simply turn a bit ON or OFF, or they can perform much more complex actions,

such as converting and/or transferring large blocks of data.

instruction block A group of instructions that is logically related in a ladder-diagram program. Al-

though any logically related group of instructions could be called an instruction block, the term is generally used to refer to blocks of instructions called logic blocks that require logic block instructions to relate them to other instructions or

logic blocks.

instruction execution time The time required to execute an instruction. The execution time for any one

instruction can vary with the execution conditions for the instruction and the op-

erands used within it.

instruction line A group of conditions that lie together on the same horizontal line of a ladder dia-

gram. Instruction lines can branch apart or join together to form instruction

blocks.

interface An interface is the conceptual boundary between systems or devices and usual-

ly involves changes in the way the communicated data is represented. Interface devices such as NSBs perform operations like changing the coding, format, or

speed of the data.

interlock A programming method used to treat a number of instructions as a group so that

the entire group can be reset together when individual execution is not required. An interlocked program section is executed normally for an ON execution condi-

tion and partially reset for an OFF execution condition.

interrupt (signal)A signal that stops normal program execution and causes a subroutine to be run.

Interrupt Input Unit A Rack-mounting Unit used to input external interrupts into a PC System.

inverse condition A condition that produces an ON execution condition when the bit assigned to it

is OFF, and an OFF execution condition when the bit assigned to it is ON.

I/O capacity The number of inputs and outputs that a PC is able to handle. This number

ranges from around one hundred for smaller PCs to two thousand for the largest

ones.

I/O Control Unit A Unit mounted to the CPU Rack in certain PCs to monitor and control I/O points

on Expansion I/O Units.

I/O devices The devices to which terminals on I/O Units, Special I/O Units, or Intelligent I/O

> Units are connected. I/O devices may be either part of the Control System, if they function to help control other devices, or they may be part of the controlled sys-

tem.

I/O Interface Unit A Unit mounted to an Expansion I/O Rack in certain PCs to interface the Expan-

sion I/O Rack to the CPU Rack.

I/O Link Created in an Optical Remote I/O System to enable input/output of one or two IR

> words directly between PCs. The words are input/output between the PC controlling the Master and a PC connected to the Remote I/O System through an I/O

Link Unit or an I/O Link Rack.

I/O Link Unit A Unit used with certain PCs to create an I/O Link in an Optical Remote I/O Sys-

tem.

I/O point The place at which an input signal enters the PC System, or at which an output

> signal leaves the PC System. In physical terms, I/O points correspond to terminals or connector pins on a Unit; in terms of programming, an I/O points corre-

spond to I/O bits in the IR area.

I/O response time The time required for an output signal to be sent from the PC in response to an

input signal received from an external device.

I/O table A table created within the memory of the PC that lists the IR area words allocated

to each Unit in the PC System. The I/O table can be created by, or modified from,

a Programming Device.

I/O Unit The most basic type of Unit mounted to a backplane to create a Rack. I/O Units

> include Input Units and Output Units, each of which is available in a range of specifications. I/O Units do not include Special I/O Units, Link Units, etc.

A word in the IR area that is allocated to a Unit in the PC System.

A data area whose principal function is to hold the status of inputs coming into

the system and that of outputs that are to be set out of the system. Bits and words in the IR that are used this way are called I/O bits and I/O words. The remaining

bits in the IR area are work bits.

JIS Acronym for Japanese Industrial Standards.

I/O word

IR area

A type of programming where execution moves directly from one point in a projump

gram to another, without sequentially executing any instructions in between.

Jumps are usually conditional on an execution condition.

A definer used with a jump that defines the points from and to which a jump is to jump number

be made.

ladder diagram (program) A form of program arising out of relay-based control systems that uses circuit-

type diagrams to represent the logic flow of programming instructions. The ap-

pearance of the program is similar to a ladder, and thus the name.

ladder diagram symbol A symbol used in a ladder-diagram program.

ladder instruction An instruction that represents the 'rung' portion of a ladder-diagram program.

The other instructions in a ladder diagram fall along the right side of the diagram

and are called terminal instructions.

LAN An acronym for local area network.

leftmost (bit/word)The highest numbered bits of a group of bits, generally of an entire word, or the

highest numbered words of a group of words. These bits/words are often called

most-significant bits/words.

Link Adapter A Unit used to connect communications lines, either to branch the lines or to con-

vert between different types of cable. There are two types of Link Adapter:

Branching Link Adapters and Converting Link Adapters.

link A hardware or software connection formed between two Units. "Link" can refer

either to a part of the physical connection between two Units (e.g., optical links in Wired Remote I/O Systems) or a software connection created to data existing at

another location (Network Data Links).

linkable slotA slot on either a CPU or Expansion I/O Backplane to which a Link Unit can be

mounted. Backplanes differ in the slots to which Link Units can be mounted.

Link System A system that includes one or more of the following systems: Remote I/O Sys-

tem, PC Link System, Host Link System, or Net Link System.

Link Unit Any of the Units used to connect a PC to a Link System. These are Remote I/O

Units, I/O Link Units, PC Link Units, Host Link Units, and Net Link Units.

load The processes of copying data either from an external device or from a storage

area to an active portion of the system such as a display buffer. Also, an output

device connected to the PC is called a load.

local area networkA network consisting of nodes or positions in a loop arrangement. Each node

can be any one of a number of devices, which can transfer data to and from each

other.

logic block A group of instructions that is logically related in a ladder-diagram program and

that requires logic block instructions to relate it to other instructions or logic

blocks.

logic block instruction An instruction used to locally combine the execution condition resulting from a

logic block with a current execution condition. The current execution condition could be the result of a single condition, or of another logic block. AND Load and

OR Load are the two logic block instructions.

logic instruction Instructions used to logically combine the content of two words and output the

logical results to a specified result word. The logic instructions combine all the same-numbered bits in the two words and output the result to the bit of the same

number in the specified result word.

loop A group of instructions that can be executed more than once in succession (i.e.,

repeated) depending on an execution condition or bit status.

LR area A data area that is used in a PC Link System so that data can be transferred be-

tween two or more PCs. If a PC Link System is not used, the LR area is available

for use as work bits.

main program All of a program except for the subroutines.

masking 'Covering' an interrupt signal so that the interrupt is not effective until the mask is

removed.

Master Short for Remote I/O Master Unit.

memory area Any of the areas in the PC used to hold data or programs.

mnemonic code A form of a ladder-diagram program that consists of a sequential list of the

instructions without using a ladder diagram. Mnemonic code is required to input

a program into a PC when using a Programming Console.

MONITOR mode A mode of PC operation in which normal program execution is possible, and

which allows modification of data held in memory. Used for monitoring or debug-

ging the PC.

most-significant (bit/word) See leftmost (bit/word).

NC inputAn input that is normally closed, i.e., the input signal is considered to be present

when the circuit connected to the input opens.

nest Programming one loop within another loop, programming a call to a subroutine

within another subroutine, or programming an IF-ELSE programming section

within another IF-ELSE section.

Net Link System An optical LAN formed from PCs connected through Net Link Units. A Net Link

System also normally contains nodes interfacing computers and other peripheral devices. PCs in the Net Link System can pass data back and forth, receive commands from any interfaced computer, and share any interfaced peripheral

device.

Net Link Unit The Unit used to connect PCs to a Net Link System. The full name is "SYSMAC

Net Link Unit."

Network Service BoardA device with an interface to connect devices other than PCs to a Net Link Sys-

tem.

Network Service UnitA Unit that provides two interfaces to connect peripheral devices to a Net Link

System.

nodeOne of the positions in a LAN. Each node incorporates a device that can commu-

nicate with the devices at all of the other nodes. The device at a node is identified by the node number. One loop of a Net Link System (OMRON's LAN) can consist of up to 126 nodes. Each node is occupied by a Net Link Unit mounted to a PC or

a device providing an interface to a computer or other peripheral device.

NO input An input that is normally open, i.e., the input signal is considered to be present

when the circuit connected to the input closes.

noise interference Disturbances in signals caused by electrical noise.

nonfatal error A hardware or software error that produces a warning but does not stop the PC

from operating.

normal condition A condition that produces an ON execution condition when the bit assigned to it

is ON, and an OFF execution condition when the bit assigned to it is OFF.

NOT A logic operation which inverts the status of the operand. For example, AND

NOT indicates an AND operation with the opposite of the actual status of the op-

erand bit.

NSB An acronym for Network Service Board.

NSU An acronym for Network Service Unit.

OFF The status of an input or output when a signal is said not to be present. The OFF

state is generally represented by a low voltage or by non-conductivity, but can be

defined as the opposite of either.

OFF delay The delay between the time when a signal is switched OFF (e.g., by an input

device or PC) and the time when the signal reaches a state readable as an OFF signal (i.e., as no signal) by a receiving party (e.g., output device or PC).

ON The status of an input or output when a signal is said to be present. The ON state

is generally represented by a high voltage or by conductivity, but can be defined

as the opposite of either.

ON delay The delay between the time when an ON signal is initiated (e.g., by an input de-

vice or PC) and the time when the signal reaches a state readable as an ON sig-

nal by a receiving party (e.g., output device or PC).

one-shot bitA bit that is turned ON or OFF for a specified interval of time which is longer than

one cycle.

on-line removal Removing a Rack-mounted Unit for replacement or maintenance during PC op-

eration.

operand Bit(s) or word(s) designated as the data to be used for an instruction. An operand

can be input as a constant expressing the actual numeric value to be used or as

an address to express the location in memory of the data to be used.

operand bit A bit designated as an operand for an instruction.

operand word A word designated as an operand for an instruction.

operating error An error that occurs during actual PC operation as opposed to an initialization

error, which occurs before actual operations can begin.

Optical I/O Unit A Unit that is connected in an Optical Remote I/O System to provide 8 I/O points.

Optical I/O Units are not mounted to a Rack.

Optical Slave Rack

A Slave Rack connected through an Optical Remote I/O Slave Unit.

OR A logic operation whereby the result is true if either of two premises is true, or if

both are true. In ladder-diagram programming the premises are usually ON/OFF states of bits or the logical combination of such states called execution condi-

tions.

output The signal sent from the PC to an external device. The term output is often used

abstractly or collectively to refer to outgoing signals.

output bit A bit in the IR area that is allocated to hold the status to be sent to an output de-

vice.

output device An external device that receives signals from the PC System.

output point The point at which an output leaves the PC System. Output points correspond

physically to terminals or connector pins.

output signal A signal being sent to an external device. Generally an output signal is said to

exist when, for example, a connection point goes from low to high voltage or from

a nonconductive to a conductive state.

overseeing Part of the processing performed by the CPU Unit that includes general tasks

required to operate the PC.

overwrite Changing the content of a memory location so that the previous content is lost.

parity Adjustment of the number of ON bits in a word or other unit of data so that the

total is always an even number or always an odd number. Parity is generally used to check the accuracy of data after being transmitted by confirming that the

number of ON bits is still even or still odd.

PC An acronym for Programmable Controller.

PCB An acronym for printed circuit board.

PC configuration The arrangement and interconnections of the Units that are put together to form

a functional PC.

PCF Acronym for plastic-clad optical fiber cable.

PC Link System A system in which PCs are connected through PC Link Units to enable them to

share common data areas, i.e., each of the PCs writes to certain words in the LR area and receives the data of the words written by all other PC Link Units con-

nected in series with it.

PC Link Unit The Unit used to connect PCs in a PC Link System.

PC System With building-block PCs, all of the Racks and independent Units connected di-

rectly to them up to, but not including the I/O devices. The boundaries of a PC System are the PC and the program in its CPU Unit at the upper end; and the I/O Units, Special I/O Units, Optical I/O Units, Remote Terminals, etc., at the lower

end.

peripheral device Devices connected to a PC System to aid in system operation. Peripheral de-

vices include printers, programming devices, external storage media, etc.

port A connector on a PC or computer that serves as a connection to an external de-

vice.

present valueThe current value registered in a device at any instant during its operation. Pres-

ent value is abbreviated as PV.

printed circuit board A board onto which electrical circuits are printed for mounting into a computer or

electrical device.

Printer Interface Unit A Unit used to interface a printer so that ladder diagrams and other data can be

printed out.

programThe list of instructions that tells the PC the sequence of control actions to be car-

ried out.

Programmable Controller

A computerized device that can accept inputs from external devices and generate outputs to external devices according to a program held in memory. Programmable Controllers are used to automate control of external devices. Although single-component Programmable Controllers are available, building-block Programmable Controllers are constructed from separate components. Such building-block Programmable Controllers are formed only when enough of these separate components are assembled to form a functional assembly, i.e., no one individual Unit is called a PC.

programmed alarm

An alarm given as a result of execution of an instruction designed to generate the alarm in the program, as opposed to one generated by the system.

programmed error

An error arising as a result of the execution of an instruction designed to generate the error in the program, as opposed to one generated by the system.

programmed message

A message generated as a result of execution of an instruction designed to generate the message in the program, as opposed to one generated by the system.

Programming Console

The simplest form or programming device available for a PC. Programming Consoles are available both as hand-held models and as CPU Unit-mounting models.

Programming Device

A peripheral device used to input a program into a PC or to alter or monitor a program already held in the PC. There are dedicated programming devices, such as Programming Consoles, and there are non-dedicated devices, such as a host computer.

PROGRAM mode

A mode of operation that allows inputting and debugging of programs to be carried out, but that does not permit normal execution of the program.

PROM Writer

A peripheral device used to write programs and other data into a ROM for permanent storage and application.

prompt

A message or symbol that appears on a display to request input from the operator.

P۷

Acronym for present value.

Rack

An assembly of various Units on a Backplane that forms a functional unit in a building-block PC System. Racks include CPU Racks, Expansion I/O Racks, I/O Racks, and Slave Racks.

refresh

The process of updating output status sent to external devices so that it agrees with the status of output bits held in memory and of updating input bits in memory so that they agree with the status of inputs from external devices.

relay-based control

The forerunner of PCs. In relay-based control, groups of relays are interconnected to form control circuits. In a PC, these are replaced by programmable circuits.

Remote I/O Master Unit

The Unit in a Remote I/O System through which signals are sent to all other Remote I/O Units. The Remote I/O Master Unit is mounted either to a CPU Rack or an Expansion I/O Rack connected to the CPU Rack. Remote I/O Master Unit is generally abbreviated to Master.

Remote I/O Slave Unit

A Unit mounted to a Backplane to form a Slave Rack. Remote I/O Slave Unit is generally abbreviated to Slave.

Remote I/O System A system in which remote I/O points are controlled through a Master mounted to

a CPU Rack or an Expansion I/O Rack connected to the CPU Rack.

Remote I/O Unit Any of the Units in a Remote I/O System. Remote I/O Units include Masters,

Slaves, Optical I/O Units, I/O Link Units, and Remote Terminals.

remote I/O word An I/O word allocated to a Unit in a Remote I/O System.

reset The process of turning a bit or signal OFF or of changing the present value of a

timer or counter to its set value or to zero.

return The process by which instruction execution shifts from a subroutine back to the

main program (usually the point from which the subroutine was called).

reversible counter A counter that can be both incremented and decremented depending on the

specified conditions.

reversible shift register A shift register that can shift data in either direction depending on the specified

conditions.

right-hand instruction Another term for terminal instruction.

rightmost (bit/word)

The lowest numbered bits of a group of bits, generally of an entire word, or the

lowest numbered words of a group of words. These bits/words are often called

least-significant bits/words.

rotate register A shift register in which the data moved out from one end is placed back into the

shift register at the other end.

RUN mode The operating mode used by the PC for normal control operations.

scheduled interrupt An interrupt that is automatically generated by the system at a specific time or

program location specified by the operator. Scheduled interrupts result in the execution of specific subroutines that can be used for instructions that must be

executed repeatedly for a specified period of time.

self diagnosis A process whereby the system checks its own operation and generates a warn-

ing or error if an abnormality is discovered.

self-maintaining bit A bit that is programmed to maintain either an OFF or ON status until set or reset

by specified conditions.

servicing The process whereby the PC provides data to or receives data from external de-

vices or remote I/O Units, or otherwise handles data transactions for Link Sys-

tems.

set The process of turning a bit or signal ON.

set value The value from which a decrementing counter starts counting down or to which

an incrementing counter counts up (i.e., the maximum count), or the time from

which or for which a timer starts timing. Set value is abbreviated SV.

shift registerOne or more words in which data is shifted a specified number of units to the right

or left in bit, digit, or word units. In a rotate register, data shifted out one end is shifted back into the other end. In other shift registers, new data (either specified data, zero(s) or one(s)) is shifted into one end and the data shifted out at the oth-

er end is lost.

Slave Short for Remote I/O Slave Unit.

Slave Rack A Rack containing a Remote I/O Slave Unit and controlled through a Remote I/O

Master Unit. Slave Racks are generally located away from the CPU Rack.

slot A position on a Rack (Backplane) to which a Unit can be mounted.

software error An error that originates in a software program.

software protect A means of protecting data from being changed that uses software as opposed

to a physical switch or other hardware setting.

source The location from which data is taken for use in an instruction, as opposed to the

location to which the result of an instruction is to be written. The latter is called

the destination.

Special I/O Unit A dedicated Unit that is designed for a specific purpose. Special I/O Units in-

clude Position Control Units, High-Speed Counter Units, Analog I/O Units, etc.

SR area A data area in a PC used mainly for flags, control bits, and other information pro-

vided about PC operation. The status of only certain SR bits may be controlled

by the operator, i.e., most SR bits can only be read.

SSS Abbreviation for SYSMAC Support Software.

subroutine A group of instructions placed after the main program and executed only if called

from the main program or activated by an interrupt.

subroutine number A definer used to identify the subroutine that a subroutine call or interrupt acti-

vates.

SV Abbreviation for set value.

switching capacity The maximum voltage/current that a relay can safely switch on and off.

syntax error

An error in the way in which a program is written. Syntax errors can include

'spelling' mistakes (i.e., a function code that does not exist), mistakes in specifying operands within acceptable parameters (e.g., specifying reserved SR bits as a destination), and mistakes in actual application of instructions (e.g., a call to a

subroutine that does not exist).

SYSMAC Support Software A software package installed on a IBM PC/AT or compatible computer to func-

tion as a Programming Device.

system configuration The arrangement in which Units in a system are connected.

system error

An error generated by the system, as opposed to one resulting from execution of

an instruction designed to generate an error.

system error message An error message generated by the system, as opposed to one resulting from

execution of an instruction designed to generate a message.

TC area A data area that can be used only for timers and counters. Each bit in the TC area

serves as the access point for the SV, PV, and Completion flag for the timer or

counter defined with that bit.

TC number A definer that corresponds to a bit in the TC area and used to define the bit as

either a timer or a counter.

terminal instruction An instruction placed on the right side of a ladder diagram that uses the final

execution conditions of an instruction line.

terminator The code comprising an asterisk and a carriage return (* CR) which indicates the

end of a block of data, whether it is a single-frame or multi-frame block. Frames

within a multi-frame block are separated by delimiters.

timer A location in memory accessed through a TC bit and used to time down from the

timer's set value. Timers are turned ON and reset according to their execution

conditions.

TM area A memory area used to store the results of a trace.

transmission distance The distance that a signal can be transmitted.

TR area A data area used to store execution conditions so that they can be reloaded later

for use with other instructions.

trace An operation whereby the program is executed and the resulting data is stored in

TM memory to enable step-by-step analysis and debugging.

transfer The process of moving data from one location to another within the PC, or be-

tween the PC and external devices. When data is transferred, generally a copy of the data is sent to the destination, i.e., the content of the source of the transfer

is not changed.

trigger address An address in the program that defines the beginning point for tracing. The actu-

al beginning point can be altered from the trigger by defining either a positive or

negative delay.

UM area The memory area used to hold the active program, i.e., the program that is being

currently executed.

Unit In OMRON PC terminology, the word Unit is capitalized to indicate any product

sold for a PC System. Though most of the names of these products end with the word Unit, not all do, e.g., a Remote Terminal is referred to in a collective sense

as a Unit. Context generally makes any limitations of this word clear.

unit number A number assigned to some Link Units and Special I/O Units to facilitate identifi-

cation when assigning words or other operating parameters to it.

watchdog timer A timer within the system that ensures that the cycle time stays within specified

limits. When limits are reached, either warnings are given or PC operation is

stopped depending on the particular limit that is reached.

Wired Slave Rack A Slave Rack connected through a Wired Remote I/O Slave Unit.

word A unit of data storage in memory that consists of 16 bits. All data areas consists

of words. Some data areas can be accessed only by words; others, by either

words or bits.

word address The location in memory where a word of data is stored. A word address must

specify (sometimes by default) the data area and the number of the word that is

being addressed.

word multiplier A value between 0 and 3 that is assigned to a Master in a Remote I/O System so

that words can be allocated to non-Rack-mounting Units within the System. The

word setting made on the Unit is added to 32 times the word multiplier to arrive at the actual word to be allocated.

work bit

A bit in a work word.

work word

A word that can be used for data calculation or other manipulation in programming, i.e., a 'work space' in memory. A large portion of the IR area is always reserved for work words. Parts of other areas not required for special purposes may also be used as work words, e.g., LR words not used in a PC Link or Net Link System.

Α	definition, 25
	Output OFF, 42
address tracing. See tracing, data tracing.	Control System, definition, 3
addresses, in data area, 26	controlled system, definition, 3
advanced I/O instructions	counters
7-SEGMENT DISPLAY OUTPUT, 339	bits in TC area, 68
DIGITAL SWITCH INPUT, 342	changing SV, 408
functions, 338	conditions when reset, 166, 170 creating extended timers, 168
HEXADECIMAL KEY INPUT, 346	extended, 168
MATRIX INPUT, 351 TEN-KEY INPUT, 348	inputting SV, 106
· · · · · · · · · · · · · · · · · · ·	Power OFF, 54
Analog Timer Unit, programming examples, 130	reversible counters, 169
application examples, 385	CPU Rack, definition, 15
AR area, 48–55	CPU Unit, 12
arithmetic flags, 139	CPU Unit-mounting Device Mounted Flag, 55
arithmetic operations, flags, 44	operational flow, 362–363
ASCII, converting data, 218, 219	CPU Unit indicators, 13
	current EM bank, changing the current bank, 319
_	cycle, First Cycle Flag, 43
В	cycle monitor time, extending, 308
L-44	cycle time, 362–366
battery Low Pottern Flor 42	calculating, 366–368
Low Battery Flag, 42	controlling, 303
operation without backup battery, 21	Cycle Time Indicators, 55
BCD calculations, 228–242	displaying on Programming Console, 110
converting, 26	error flag, 43
definition, 26	extending the cycle monitor time, 308
binary	flag for SCAN(18), 55
calculations, 243	
definition, 26	D
signed binary, 28	U
unsigned binary, 27	data
unsigned binary, 27 bits	data comparison instructions, 192–203
bits controlling, 150	
bits controlling, 150 forced set/reset, 395	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228
bits controlling, 150 forced set/reset, 395 monitoring, 392–395	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228
bits controlling, 150 forced set/reset, 395	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404
bits controlling, 150 forced set/reset, 395 monitoring, 392–395	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407
bits controlling, 150 forced set/reset, 395 monitoring, 392–395	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398
bits controlling, 150 forced set/reset, 395 monitoring, 392–395	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C C200H programs, transferring to C200HS, 8	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. <i>See</i> word	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310 clock, reading and setting, 413	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 29
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. <i>See</i> word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications host link, 424	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 29 in LR area, 69
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications host link, 424 link, one-to-one, 432	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 29 in LR area, 69 in SR area, 33
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. <i>See</i> word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications host link, 424 link, one-to-one, 432 one-to-one, 433	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 69 in SR area, 33 in TC area, 68
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications host link, 424 link, one-to-one, 432 one-to-one, 433 wiring, 421	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 69 in SR area, 33 in TC area, 68 in TR area, 71
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications host link, 424 link, one-to-one, 432 one-to-one, 433 wiring, 421 Communications Board, settings, 65	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 69 in SR area, 33 in TC area, 68 in TR area, 71 data tracing, 304–319
bits controlling, 150 forced set/reset, 395 monitoring, 392–395 buzzer, 92 C200H programs, transferring to C200HS, 8 calendar/clock, dedicated bits, 53 canceling, forced set/reset, 397 channel. See word checksum, calculating frame checksum, 310 clock, reading and setting, 413 clock pulse bits, 43 communications host link, 424 link, one-to-one, 432 one-to-one, 433 wiring, 421	comparison instructions, 192–203 converting, 27, 204–227 decrementing, 228 incrementing, 228 modifying, 404 modifying binary data, 407 modifying hex/BCD, 398 moving, 180–192 data area, definition, 23 data areas, structure, 25 Data Link table, transferring, 102 data memory, fixed, 57 data retention in AR area, 49 in HR area, 68 in IR area, 69 in SR area, 33 in TC area, 68 in TR area, 71 data tracing, 304–319 flags and control bits, 55

decrementing, 228	AR and SR area error flags, 451
definers, definition, 138	arithmetic, 44
delay time, in C500 Remote I/O Systems, 380	programming example, 194, 197, 201
differentiated instructions, 140	CPU Unit-mounting Device Mounted, 55
function codes, 138	CY
digit, monitoring, 392	clearing, 229
digit numbers, 26	setting, 229
DIP switch, 20	Cycle Time Error, 43 definition, 24
displays	First Cycle, 43
converting between 4-digit hex and decimal, 401	FPD Trigger Bit, 55
converting between 8-digit hex and decimal, 402	I/O Verification Error, 43
converting between hex and ASCII, 400	Instruction Execution Error, 44
I/O Unit designations, 100	Link Units, 55
Programming Console, English/Japanese switch, 91	Low Battery, 42
DM area	Optical I/O Error, 51
allocating UM to expansion DM, 412	Step, 44
Using EM for indirect addressing, 318	flags
	arithmetic, 139
	error and arithmetic, 525
E	signed binary arithmetic, 525
-	floating-point decimal, division, 238
EM (Extended Data Memory) area, 71	forced set/reset, 395
EM area	canceling, 397–398
changing the current bank, 319	Forced Status Hold Bit, 41
clearing selected EM banks, 95	Frame Check Sequence. See frames, FCS
Using EM for indirect addressing, 318	frame checksum, calculating with FCS(—), 310
EM bank number, changing the current bank, 319	frames
ER. See flag, Instruction Execution Error	dividing, precautions, 424
error codes, programming, 302	FCS, 425
error history, dedicated bits, 52	function codes, 138
error messages, programming, 305, 306	changing expansion instruction function codes, 411
errors	reading expansion instruction function codes, 411
clearing messages, 97	
fatal, 449	
history area, 58	G–H
initialization, 447	J. 11
Instruction Execution Error Flag, 44	Group-2 High-density I/O Units, 4
message tables, 447–450	Group-2 B7A Interface Units, word allocation, 32
messages when inputting programs, 108	Group-2 High-density I/O Units, word allocation, 32
non-fatal, 447	hexadecimal, definition, 26
programming indications, 446	High-density I/O Units. See Group-2 High-density I/O Units:
programming messages, 305, 306	Units
reading and clearing messages, 446	host link
resetting, 303	communications
SR and AR area flags, 451	See also host link commands
execution condition, definition, 76	procedures, 424
execution time, instructions, 369–377	setting parameters, start and end codes, 428
expansion DM, allocating UM to, 412	host link commands
expansion DM area, allocation, 57	**, 500
Expansion I/O Rack, definition, 15	EX, 500
expansion instructions, 141, 522	FK, 490
changing function code assignments, 411	IC, 501
reading function code assignments, 411	KC, 491 KR, 488
expansion keyboard mapping, 413	KS, 487
	MF, 486
_	MI, 496
F	MM, 492
	MS, 483
FAL area, 42, 302	QQIR, 498
fatal operating errors, 449	QQMR, 497
flag	R#, 475

R\$, 476	7SEG(—), 338
R%, 478	ADB(50), 243
RC, 463	ADBL(—), 249
RD, 465	ADD(30), 229
RE, 466	ADDL(54), 230
RG, 464	AND, 78, 149
RH, 462	combining with OR, 79
RJ, 466	AND LD, 81, 150
RL, 461	combining with OR LD, 84
RP, 494	use in logic blocks, 82
RR, 460	AND NOT, 78, 149
SC, 485	ANDW(34), 278
TS, 493	APR(69), 263
W#, 479	ASC(86), 218
W\$, 480	ASFT(17), 178
W%, 482	ASL(25), 175
WC, 470	ASR(26), 175
WD, 472	AVG(—), 259
WE, 474	BCD(24), 205
*	BCDL(59), 206
WG, 471	BCMP(68), 197
WH, 469	
WJ, 473	BCNT(67), 310
WL, 468	BIN(23), 204
WP, 495	BINL(58), 205
WR, 467	BSET(71), 181
XZ, 499	BXF2(—), 191
Host Link Systems, error bits and flags, 40	CLC(41), 229
Host Link Units, PC cycle time, 367	CMCR(—), 355
HR area, 68	CMP(20), 193
,	CMPL(60), 196
	CNT, 166
1	CNTR(12), 169
	COLL(81), 185
I/O L:4	COLM(64), 225
I/O bit	COM(29), 277
definition, 29	CPS(—), 202
limits, 29	CPSL(—), 203
I/O numbers, 32	DBS(—), 255
I/O points, refreshing, 308, 309	DBSL(—), 256
I/O response time, one-to-one link communications, 385	DEC(39), 228
I/O response times, 378	DIFD(14), 121, 151–152
1	using in interlocks, 156
I/O status, maintaining, 42	using in jumps, 158
I/O table	DIFU(13), 121, 151–152
clearing, 101	using in interlocks, 156
reading, 99	using in jumps, 158
registration, 96	DIST(80), 183
verification, 97	DIV(33), 236
Verification Error flag, 43	DIVL(57), 237
I/O Units. See Units	DMPX(77), 212
I/O word	DSW(—), 341
allocation, 30	DVB(53), 248
definition, 29	EMBC(—), 319
limits, 29	END(01), 80, 144, 158
incrementing, 228	execution times, 369-377
indirect addressing, 139	FAL(06), 302
Using EM for indirect addressing, 318	FALS(07), 302
	FCS(—), 310
input bit	FDIV(79), 238
application, 29	FPD(—), 312
definition, 3	HEX(—), 219
input device, definition, 3	HKY(—), 345
input point, definition, 3	HMS(66), 208
input signal, definition, 3	IEMS(—), 318
instruction set, 519	IL(02), 117, 155–157
moducation bot, 517	120(02), 111, 133-131

H C(02) 117 155 157	GENID (00) 220	
ILC(03), 117, 155–157	SEND(90), 320	
INC(38), 228	SET, 153	
INT(89), 289	SFT(10), 171	
IORD(—), 352	SFTR(84), 173	
IORF(97), 308	SLD(74), 177	
IOWR(—), 353	SNXT(09), 293	
JME(05), 157	SRCH(—), 316, 317	
JMP(04), 157	SRD(75), 177	
JMP(04) and JME(05), 119	STC(40), 229	
KEEP(11), 154	STEP(08), 293	
in controlling bit status, 121	STUP(—), 335	
ladder instructions, 77	SUB(31), 231	
LD, 78, 149	SUBL(55), 233	
LD NOT, 78, 149	SUM(—), 261	
	TCMP(85), 199	
LINE(63), 224	TERM(48), 88, 307	
LMSG(47), 306	. 1 11 =1	
MAX(—), 257	terminology, 74	
MBS(—), 253	TIM, 159	
MBSL(—), 254	TIMH(15), 164	
MCMP(19), 192	TKY(—), 348	
MCRO(99), 287	TRSM(45), 304	
MIN(—), 258	TTIM(87), 165	
	TXD(—), 333	
MLB(52), 248	WDT(94), 308	
MLPX(76), 209	WSFT(16), 178	
MOV(21), 180	XCHG(73), 183	
MOVB(82), 187	* //	
MOVD(83), 188	XFER(70), 182	
MPRF(61), 309	XFR2(—), 190	
MSG(46), 305	XFRB(62), 189	
MTR(—), 350	XNRW(37), 281	
MUL(32), 235	XORW(36), 280	
	ZCP(88), 200	
MULL(56), 236	ZCPL(—), 201	
MVN(22), 180	instructions	
NEG(—), 226		
NEGL(—), 227	advanced I/O, 338	
NOP(00), 158	designations when inputting, 106	
NOT, 76	instruction set lists, 145	
operands, 74	IORF(97), 385	
OR, 79, 149	mnemonics list, ladder, 145	
combining with AND, 79	interlocks, 155–157	
	using self-maintaining bits, 121	
OR LD, 82, 150	interrupts, 281	
combining with AND LD, 84	control, 289	
use in logic blocks, 83		
OR NOT, 79, 149	IR area, 29–32	
ORW(35), 279		
OUT, 80, 150		
OUT NOT, 80, 150	J–L	
PID(—), 266	5 L	
PMCR(—), 337	jump numbers, 157	
	jumps, 157–158	
RECV(98), 325		
RET(93), 286	keyboard mapping, 414	
ROL(27), 176	expansion keyboard mapping, 413	
ROOT(72), 241	ladder diagram	
ROR(28), 176	branching, 115	
RSET, 153	IL(02) and ILC(03), 117	
RXD(—), 331	using TR bits, 115	
SBB(51), 245	controlling bit status	
SBBL(—), 251	using DIFU(13) and DIFD(14), 121, 151–152	
SBN(92), 286		
	using KEEP(11), 154–159	
SBS(91), 285 SCAN(18), 202	using OUT and OUT NOT, 80	
SCAN(18), 303	using SET and RSET, 153	
SCL(—), 222	converting to mnemonic code, 76–88	
SDEC(78), 215	display via SSS, 75	
SEC(65), 207	instructions	

combining, AND LD and OR LD, 84 controlling bit status using KEEP(11), 121 using OUT and OUT NOT, 150 format, 138	application, 30 controlling, via Output OFF bit, 42 controlling ON/OFF time, 151 controlling status, 120, 121 definition, 3
notation, 138	output device, definition, 3
structure, 75	output point, definition, 3
using logic blocks, 81	output signal, definition, 3
ladder diagram instructions, 149–150	output signal, definition, s
LEDs. See CPU Unit indicators	
leftmost, definition, 26	Р
Link System, flags and control bits, 40-41	F
Link Units	password, entering on Programming Console, 92
See also Units	PC
flags, 55	configuration, 15
logic block instructions, converting to mnemonic code, 81–87	definition, 3
logic blocks. See ladder diagram	flowchart, 363
logic instructions, 277–281	PC Link Systems
LR area, 69	error bits and flags, 40–41
	LR area application, 69
	PC Setup, 60
M	default, 60
	Peripheral Devices Flags, 54
mapping, expansion keyboard mapping, 413	Peripheral Devices, Connecting through SYSMAC LINK, 54
memory all clear, 93	peripheral devices, 5 Programming Console, 5, 88–91
memory areas	SYSMAC Support Software (SSS), 5
clearing, 93 definition, 23	peripheral port, communications
· · · · · · · · · · · · · · · · · · ·	receiving, 430
Memory class tess, transferring C200HS programs, 8	transmitting, 429
memory clear, 96	power supply, Power OFF Counter, 54
memory partial clear, 94	precautions, general, xiii
messages, programming, 305, 306	present value. See PV
mnemonic code, converting, 76–88	program execution, 126
models, C200HS, 503	Program Memory
modifying data, hex/binary, 398	setting address and reading content, 104-105
monitoring binary, 405	structure, 76
differentiation monitoring, 403	programming
monitoring 3 words, 404	checks for syntax, 108–110
mounting Units, location, 15	entering and editing, 105 example, using shift register, 172
	inputting, modifying and checking, 104–120
	inserting and deleting instructions, 112–114
N-O	instructions, 519
11 0	jumps, 119
nesting, subroutines, 285	precautions, 124
non-fatal operating errors, 447	preparing data in data areas, 181
normally closed condition, definition, 76	searching, 111–112 setting and reading from memory address, 104
NOT, definition, 76	simplification with differentiated instructions, 152
one-to-one link, wiring, 432	writing, 74
one-to-one link communications, I/O response timing, 385	Programming Console, 88–91
operand bit, 76	See also peripheral devices
operands, 138	programs, transferring from C200H, 8
allowable designations, 138	Protocol Macro function, 435
requirements, 138	PROTOCOL MACRO instruction, 337
operating modes, 91	PV
operation, preparations, 91–103	accessing via PC area, 69
Optical I/O Unit, Error flag, 51	CNTR(12), 170
output bit	timers and counters, 159

R	SYSMAC LINK, loop status and completion codes, 38 SYSMAC LINK System			
Racks, types, 15	Active Node Flags, 52			
Remote I/O Master Units, PC cycle time, 367	instructions, 320			
Remote I/O Systems, error bits and flags, 39	service time, 53			
response time calculations, C500 PCs, 382	Using Peripheral Devices, 54			
response times, I/O, 378–389	SYSMAC NET, loop status and completion codes, 38			
rightmost, definition, 26	SYSMAC NET Link System			
RS-232C	Data Link Table transferring, 102			
communications	instructions, 320 service time, 53			
one-to-one link, 432	SYSMAC Support Software. <i>See</i> peripheral devices			
procedures, 428	3 I SMAC Support Software. See peripheral devices			
receiving, 430				
transmitting, 429	т			
connecting Units, 432	I			
RS-232C port, wiring example, 422	TC area, 68–69			
	TC numbers, 68, 159			
	TERMINAL mode, 88			
S	Key Bits, 54			
salf maintaining hits using KEED(11) 154	time, reading and setting the clock, 413			
self-maintaining bits, using KEEP(11), 154 set value. See SV	timers			
	bits in TC area, 68			
settings communications, host link, 424	changing SV, 408			
Communications Board, 65	conditions when reset, 160, 164			
PC Setup, 60	TTIM(120), 165			
Special I/O Unit Area, 67	example using CMP(20), 194 extended timers, 161			
seven-segment displays, converting data, 215	flicker bits, 163			
shift registers, 171–179	inputting SV, 106			
controlling individual bits, 172	ON/OFF delays, 161			
signed binary arithmetic flags, 525	one-shot bits, 162			
signed binary data, 28	TR area, 71			
Special I/O Unit, programming examples, 126	TR bits, use in branching, 115			
Special I/O Unit Area, settings, 67	tracing			
Special I/O Unit Default Area, 57	See also See data tracing and address tracing.			
Special I/O Units. See Units	flags and control bits, 55			
SR area, 33–48				
SSS. See peripheral devices	11 \\/			
stack operation	U–W			
COLL(81), 185	UM Area, allocation to expansion DM, 412			
DIST(80), 183	UM area, 70			
status indicators. See CPU Unit indicators	Units			
step execution, Step flag, 44	definition, 4			
step instructions, 293–302	High-density I/O Units, definition, 4			
subroutine number, 286	I/O Units, definition, 4			
subroutines, 281–292	Link Units, definition, 4			
SV	Special I/O Units, definition, 4			
accessing via TC area, 69	unsigned binary data, 27			
changing, 408	watchdog timer, 366			
CNTR(12), 170	extending, 308			
timers and counters, 159	word bit, definition, 24			
switches, DIP. See DIP switch	work word, definition, 24			

Revision History

A manual revision code appears as a suffix to the catalog number on the front cover of the manual.

Cat. No. W303-E1-08

Revision code

The following table outlines the changes made to the manual during each revision. Page numbers refer to the previous version.

Revision code	Date	Revised content		
1	June 1996	Original production		
2	January 1998	All Pages: "LSS" replaced with "SYSMAC Support Software." Pages xiv, xvi: Cautions added. Page 7: One "4000" changed to "4096." Page 19: Added information on operation without a back-up battery. Page 27, 70: CompoBus/D added to IR/SR allocation table. Page 18: Model specifications removed from last table. Page 30: Note added on Special I/O Unit limitations. Page 31: Function of SR 25208 corrected. Pages 34, 44: Error code tables changed. Page 47: Function added for AR 0709. Page 48: Functions added for AR 2411 and AR 2412. Page 51: Table on clock accuracy added. Page 89: Power supply cycling information added to step 4 at the top of the page. Page 67: I/O comment description changed in table. Page 58: Paragraph added before table, description of DM 6602 rewritten, and "6. Peripheral Port Settings (DM 6650 through DM 6654)" removed from list of settings possible from SSS. Page 64: Description of Special I/O Unit Settings corrected. Page 86, 87: Information added on use of SHIFT key to input hexadecimal A to F. Page 123: Added "DM 6623."	Page 139, 144, 342, 359, 509: CMCR added. Page 158, 164: Precautions added on programming timers and counters. Page 237: Program corrected. Page 265: Corrected graphic (including callout). Page 267: Added graphics. Page 278 on: Subroutine numbers corrected to three digits. Page 264: Modified description of integral time, derivative time, and time unit. Page 301: Changed numeric values for WDT(94). Page 302: "I/O numbers" corrected to "unit numbers." Page 311: Added sentence before last table. Pages 313 to 316: Controller Link information add to SEND/RECV. Page 314: Added indirect designation for source/destination beginning word. Page 321, 322: Notes added. Page 346: PC card servicing added. Page 347: Special I/O refresh times corrected. Page 357: Condition for SRCH corrected. Page 357: Condition for SRCH corrected. Page 416: Table of maximum number of PTs added and information added to table. Page 429: Simplified CPU Unit troubleshooting procedure added.	
3	January 2000	Page xiv: Safety precautions rearranged and reworded. Page 20: Details of communications parameters set in pin 5 of CPU Unit DIP switch changed. Page 21: Added graphics and Always OFF Flag name. Page 34 to 37: Changed function details for bits 25412, 26400 to 26403, 26408 to 26411, 26714, 26715, 27004 to 27010, 27200 to 27210, 27303 to 27307, 27503, 27505, 27508 to 27515, 28100 to 28115. Page 45 and 46: Added error conditions for timeout error. Page 56: Added information for DM6031. Page 59: Corrected I/O bus error code. Page 61 to 65: Changed minimum servicing time for DM 6613, DM 6614, and DM 6617. Added serial communications mode for standard port settings in DM 6645 and DM 6650. Changed wording for one-to-one links. Corrected setting for serial communications mode setting in bits 12 to 15 of DM 6650. Added condition for use of host link mode with the Peripheral Port. Page 153: Information added on executing SET and RESET	instructions. Page 186: Corrected stack pointer details. Page 187: Changed operand information. Page 195: Changed operand information. Page 200: Changed address details. Page 320: Added EM area designation information for C-series PCs. Page 332 and 333: Added operand information. Page 355: Corrected bit number of SEND(90)/RECV(98) Enable Flag. Page 361: Added refresh times for other Special I/O Units. Page 428: Added graphic. Page 430: Changed graphic. Page 446: Added CPU error information. Page 447: Added CPU error information. Page 447: Added error codes. Page 468: Corrected beginning words of DM AREA WRITE-WD command. Page 500 to 503: Corrected and added new model numbers and specifications. Page 510 and 511: Corrected model numbers.	
4	June 2000	Page v: Minor change made to safety information. Page 20: Change made to function information for pin 5. Pages 160, 164, 165: Precautionary information on timers	added. Page 333: Row added to table next to ladder diagram. Note added to middle graphic and after bottom table.	
5	October 2000	Page 49: Minor change made to information on word 7 in table Page 433: Information on half duplex and full duplex communic		
6	April 2001	Page 32: Note added under table. Page 52: "Controller Link" added in three locations. Page 272: Example added.		
07	April 2002	Page 35: Port error code added. Page 200: Ladder symbol removed.		
08	February 2003	Page 20: Description of pin 3 and notes changed. Page 165: Paragraph on refreshing PVs and completion flags removed. Page 356: Illustration at the bottom of the page changed and "offset" removed from the paragraph above the illustration. Page 357: Column headings changed in top table.		

OMRON Corporation

FA Systems Division H.Q. 66 Matsumoto Mishima-city, Shizuoka 411-8511

Japan Tel: (81)55-977-9181/Fax: (81)55-977-9045

Regional Headquarters OMRON EUROPE B.V.

Wegalaan 67-69, NL-2132 JD Hoofddorp The Netherlands

Tel: (31)2356-81-300/Fax: (31)2356-81-388

OMRON ELECTRONICS LLC

1 East Commerce Drive, Schaumburg, IL 60173 U.S.A.

Tel: (1)847-843-7900/Fax: (1)847-843-8568

OMRON ASIA PACIFIC PTE. LTD.

83 Clemenceau Avenue, #11-01, UE Square, Singapore 239920

Tel: (65)6835-3011/Fax: (65)6835-2711

OMRON

Authorized Distributor: